

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

September 20, 1988

United States Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555

Serial No. 88-233
NO/RCB:jmj
Docket No. 50-338
License No. NPF-4

Gentlemen:

VIRGINIA ELECTRIC AND POWER COMPANY
NORTH ANNA POWER STATION UNIT 1
PROPOSED CHANGE TO TECHNICAL SPECIFICATIONS
CONTAINMENT INTEGRATED LEAKRATE TEST SCHEDULE

Pursuant to 10CFR50.90, the Virginia Electric and Power Company requests an amendment, in the form of a change to the Technical Specifications, to Operating License NPF-4 for North Anna Power Station Unit 1.

The proposed amendment would modify the requirement of Technical Specification 4.5.1.2a to conduct Type A test at 40 ± 10 month intervals during each 10-year service period. The last Type A test was performed on this unit on September 11, 1984, causing the next testing date to become due on or before November 11, 1988. Technical Specification 4.6.1.2a also requires the third Type A test of the service period to be conducted during the shutdown for the 10-year plant inservice inspection. The 10-year inservice inspection is currently scheduled to be conducted during the refueling outage commencing in February 1989. Virginia Electric and Power Company proposes to amend the Technical Specification to conduct the third Type A test of the first 10-year service period during the 1989 Refueling/10-year ISI Outage.

The proposed Technical Specification change is provided in Attachment 1. A Safety Evaluation is provided in Attachment 2.


This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that the change does not involve an unreviewed safety question as defined in 10CFR50.59 or a significant hazards consideration as defined in 10CFR50.92.

8810040372 880920
PDR ADDCK 05000338
P PNU

w/check #150
A017
1/1

We have evaluated this request in accordance with the criteria of 10CFR170.12.
The application fee of \$150.00 is enclosed.

Very truly yours,



W. R. Cartwright
Vice President - Nuclear

Attachments

1. Proposed Technical Specification 4.6.1.2a
2. Safety Evaluation

cc: U. S. Nuclear Regulatory Commission
101 Marietta Street, N.W.
Suite 2900
Atlanta, GA 30323

Mr. J. L. Caldwell
NRC Senior Resident Inspector
North Anna Power Station

Commissioner
Department of Health
Room 400
109 Governor Street
Richmond, Virginia 23219

COMMONWEALTH OF VIRGINIA)
)
COUNTY OF HENRICO)

The foregoing document was acknowledged before me, in and for the County and Commonwealth aforesaid, today by W. R. Cartwright who is Vice President - Nuclear, of Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 20 day of September, 19 88.
My Commission expires: February 25, 19 90.

Vicki L. Hull
Notary Public

(SEAL)