

UNIVERSITY OF CALIFORNIA, BERKELEY

BERKELEY • DAVIS • IRVINE • LOS ANGELES • RIVERSIDE • SAN DIEGO • SAN FRANCISCO



SANTA BARBARA • SANTA CRUZ

COLLEGE OF ENGINEERING  
DEPARTMENT OF NUCLEAR ENGINEERING

BERKELEY, CALIFORNIA 94720

March 24, 1986

50-224

Mr. Cecil O. Thomas, Chief  
Standardization and Special Projects Branch  
Division of Licensing  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Sir:

Please find enclosed revised pages 8 and 10 of our Berkeley Research Reactor Annual Report for 1985.

Please note that lines 4, 5, and 6 of page 8 should read as follows:

"Maximum concentration at one particular period at stack discharge was  $2.54 \times 10^{-6} \mu\text{Ci/ml}$ . This concentration is 81% of the allowable maximum concentration for this facility of  $3.12 \times 10^{-6} \mu\text{Ci/ml}$ ."

Line 10 of page 10 should read:

"... maximum swipe activities recorded was  $8.4 \times 10^{-2} \mu\text{Ci}/100 \text{ cm}^2$  from..."  
and line 19 of page 10 should read:

"... for the year was 299 mrem".

Please amend your report accordingly. We apologize for this inconvenience.

Sincerely yours,

Tek H. Lim  
Reactor Supervisor

THL/lp  
Enclosure.

8603310373 860324  
PDR ADOCK 05000224  
R PDR

A020  
111