

PDR

MAR 28 1986

Docket No. 50-409

Mr. James W. Taylor
General Manager
Dairyland Power Cooperative
2615 East Avenue South
La Crosse, Wisconsin 54601

Dear Mr. Taylor:

Subject: VENTILATION ISOLATION VALVE DEBRIS SCREENS (TAC 58019)

Re: La Crosse Boiling Water Reactor

By letter dated April 30, 1984, we informed you that installation of debris screens for the protection of ventilation isolation valves was required to be in full compliance with Branch Technical Position (BTP) CSB-6-4. We also requested you to provide us an installation schedule for the debris screens. Pursuant to our request, you responded by letter dated June 5, 1984 and committed to install debris screens in the round ventilation ducts during the March/April 1986 refueling outage. You stated that the debris screens will be added on the containment building side of the intake and exhaust ventilation isolation valves, and that loading from LOCA differential pressure will be considered in the design and attachment of the debris screens.

The staff has reviewed the debris screen installation proposal and finds it acceptable. This completes the staff's action on this item.

Seismic design consideration of the debris screen installation is pending the results of the consequence study (part of the Systematic Evaluation Program). The study will determine whether the screens must be seismically designed. Further action on this issue will be taken when we report on the consequence study.

Sincerely,

Original signed by

John A. Zwolinski, Director
BWR Project Directorate #1
Division of BWR Licensing

DISTRIBUTION

Docket File ACRS(10)
NRC PDR RBuck
Local PDR JStang
BWD#1 Reading GHolahan
OELD GLainas
RBernero LaCrosse File
EJordan
BGrimes
JPartlow
CJamerson

8604010294 860328
PDR ADOCK 05000409
P PDR

OFC	:DBL:PD#1	:DBL:PD#1	:DBL:PD#1	:DBL:PD#1	:	:	:
NAME	:RFBuck:tm	:JStang	:CJamerson	:JAZwolinski	:	:	:
DATE	:3/28/86	:3/28/86	:3/29/86	:3/28/86	:	:	:

OFFICIAL RECORD COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

March 28, 1986

Docket No. 50-409

Mr. James W. Taylor
General Manager
Dairyland Power Cooperative
2615 East Avenue South
La Crosse, Wisconsin 54601

Dear Mr. Taylor:

Subject: VENTILATION ISOLATION VALVE DEBRIS SCREENS (TAC 58019)

Re: La Crosse Boiling Water Reactor

By letter dated April 30, 1984, we informed you that installation of debris screens for the protection of ventilation isolation valves was required to be in full compliance with Branch Technical Position (BTP) CSB-6-4. We also requested you to provide us an installation schedule for the debris screens. Pursuant to our request, you responded by letter dated June 5, 1984 and committed to install debris screens in the round ventilation ducts during the March/April 1986 refueling outage. You stated that the debris screens will be added on the containment building side of the intake and exhaust ventilation isolation valves, and that loading from LOCA differential pressure will be considered in the design and attachment of the debris screens.

The staff has reviewed the debris screen installation proposal and finds it acceptable. This completes the staff's action on this item.

Seismic design consideration of the debris screen installation is pending the results of the consequence study (part of the Systematic Evaluation Program). The study will determine whether the screens must be seismically designed. Further action on this issue will be taken when we report on the consequence study.

Sincerely,

A handwritten signature in dark ink, appearing to read "John A. Zwolinski", is written over the typed name.

John A. Zwolinski, Director
BWR Project Directorate #1
Division of BWR Licensing

cc: See next page

Mr. James W. Taylor
Dairyland Power Cooperative

La Crosse Boiling Water Reactor

cc:

Fritz Schubert, Esquire
Staff Attorney
Dairyland Power Cooperative
2615 East Avenue South
La Crosse, Wisconsin 54601

Clarence Riederer, Chief Engineer
Wisconsin Public Service
Commission
Post Office Box 7854
Madison, Wisconsin 53707

Roy P. Lessy, Jr.
O. S. Heistand
Morgan, Lewis & Bockius
1800 M Street, N.W.
7th Floor North Receptionist
Washington, D.C. 20036

Mr. John Parkyn, Plant Manager
La Crosse Boiling Water Reactor
Dairyland Power Cooperative
P. O. Box 275
Genoa, Wisconsin 54632

U.S. Nuclear Regulatory Commission
Resident Inspectors Office
Rural Route #1, Box 276
Genoa, Wisconsin 54632

Town Chairman
Town of Genoa
Route 1
Genoa, Wisconsin 54632

Chairman, Public Service Commission
of Wisconsin
Hill Farms State Office Building
Madison, Wisconsin 53702

Regional Administrator, Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, Illinois 60137