

OPERATING DATA REPORT

DOCKET NO 50-341
 UNIT FERMI-2
 DATE 01-07-86
 COMPLETED BY L.P. Eregni
 TELEPHONE (313) 586-5313

OPERATING STATUS

1. REPORTING PERIOD December GROSS HOURS IN REPORTING PERIOD N/A
2. CURRENTLY AUTHORIZED POWER LEVEL (Mwt) 165 MAX DEPEND CAPACITY (MWeNet) *
 DESIGN ELECTRICAL RATING (MWe Net) 1150
3. POWER LEVEL TO WHICH RESTRICTED (IF ANY) (MWe Net) 57.5
4. REASONS FOR RESTRICTION (IF ANY) Confirmatory Action Letter dated July 16, 1985 restricts power from exceeding 5% until authorized by NRC.

	THIS MONTH	YR TO DATE	CUMULATIVE
5. NUMBER OF HOURS REACTOR WAS CRITICAL	<u>0</u>	<u>1912.5</u>	<u>1912.5</u>
6. REACTOR RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
7. HOURS GENERATOR ON LINE	<u>0</u>	<u>0</u>	<u>0</u>
8. UNIT RESERVE SHUTDOWN HOURS	<u>0</u>	<u>0</u>	<u>0</u>
9. GROSS THERMAL ENERGY GENERATED (MWH)	<u>0</u>	<u>105,861.6</u>	<u>105,861.6</u>
10. GROSS ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
11. NET ELECTRICAL ENERGY GENERATED (MWH)	<u>0</u>	<u>0</u>	<u>0</u>
12. REACTOR SERVICE FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
13. REACTOR AVAILABILITY FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
14. UNIT SERVICE FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
15. UNIT AVAILABILITY FACTOR	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
16. UNIT CAPACITY FACTOR (Using MDC)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
17. UNIT CAPACITY FACTOR (Using Design MWe)	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
18. UNIT FORCED OUTAGE RATE	<u>N/A</u>	<u>N/A</u>	<u>N/A</u>
19. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH)			
20. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP		<u>01/31/86</u>	
21. UNITS IN TEST STATUS (PRIOR TO COMMERCIAL OPERATION)	FORECAST		ACHIEVED
INITIAL CRITICALITY		<u>06/20/85</u>	<u>06/21/85</u>
INITIAL ELECTRICITY		<u>02/28/86</u>	
COMMERCIAL OPERATION		<u>05/01/86</u>	

*To be determined

8604010301 851231
 PDR ADDOCK 05000341
 R PDR

IE24
 111

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-341

UNIT FERMI-2

DATE 01-07-86

COMPLETED BY L.P. Bregni

TELEPHONE (313) 586- 5313

MONTH December

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	0
2	0
3	0
4	0
5	0
6	0
7	0
8	0
9	0
10	0
11	0
12	0
13	0
14	0
15	0
16	0

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
17	0
18	0
19	0
20	0
21	0
22	0
23	0
24	0
25	0
26	0
26	0
28	0
29	0
30	0
31	N/A

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-341
 UNIT NAME Fermi - 2
 DATE 01-07-86
 COMPLETED BY L.P. Bregni
 TELEPHONE (313) 586-5313

REPORT MONTH December

NO	DATE	TYPE F FORCED S SCHEDULED	DURATION (HOURS)	REASON (1)	METHOD OF SHUTTING DOWN THE REACTOR OR REDUC- ING POWER (2)	CORRECTIVE ACTIONS/COMMENTS
1	851201	S	744.0	H	4	Plant has been shut down since October 11, 1985 for a scheduled maintenance outage and is still in the outage at this time

(1) REASONS

- | | |
|--------------------------------|--|
| A. EQUIPMENT FAILURE (EXPLAIN) | E. OPERATOR TRAINING AND LICENSE EXAMINATION |
| B. MAINT OR TEST | F. ADMINISTRATIVE |
| C. REFUELING | G. OPERATIONAL ERROR (EXPLAIN) |
| D. REGULATORY RESTRICTION | H. OTHER (EXPLAIN) |

(2) METHOD

- | | |
|-----------------|--------------------|
| 1. MANUAL | 3. AUTOMATIC SCRAM |
| 2. MANUAL SCRAM | 4. OTHER (EXPLAIN) |

Robert S. Lenart
Plant Manager

Detroit
Edison

Fermi-2
6400 North Dixie Highway
Newport, Michigan 48166
(313) 586-5201



Nuclear
Operations

January 7, 1986
NP860011

U. S. Nuclear Regulatory Commission
Attention: Director, Office of Resource Management
Washington, D.C. 20555

Gentlemen:

Reference: Fermi 2
NRC Docket No. 50-341
NRC License No. NPF-43

Subject: Monthly Operating Status Report
for December, 1985

Enclosed for your information and use is the Fermi 2
Monthly Operating Status Report for December, 1985. This
report includes the Operating Data Report, Average Daily
Unit Power Level, and the Summary of Unit Shutdowns and
Power Reductions identified in NRC Regulatory Guide 1.16
and Fermi 2 Technical Specification 6.9.1.6.

If you have any questions, please contact us.

Sincerely,

R. S. Lenart
Plant Manager

Enclosure

cc: Mr. P. M. Byron
Mr. M. D. Lynch

USNRC, Document Control Desk
Washington, D.C. 20555

Regional Administrator
USNRC Region III
799 Roosevelt Road
Glen Ellyn, IL 60137

Mr. Dennis Hahn
Division of Radiological Health
Michigan Department of Health
3500 North Logan
P.O. Box 30033
Lansing, MI 48909

Mr. Jon Eckert
Monroe Office of Civil Preparedness
965 South Raisinville Road
Monroe, MI 48161

IE24
11