


Log # TXX-4739
File # 10110
903.8

TEXAS UTILITIES GENERATING COMPANY
SKYWAY TOWER • 400 NORTH OLIVE STREET, L.B. 81 • DALLAS, TEXAS 75201

March 25, 1986

WILLIAM G. COUNSIL
EXECUTIVE VICE PRESIDENT



Mr. Eric H. Johnson, Director
Division of Reactor Safety and Projects
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76012

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NO. 50-445
SAFETY CLASS PIPE SUPPORTS MOUNTED TO NNS EMBEDDED PLATE
SDAR: CP-86-05 - INTERIM REPORT

Dear Mr. Johnson:

On January 13, 1986, we verbally notified your Mr. T. Westerman of a deficiency involving four piping systems which have been identified as including safety class pipe supports mounted to non-safety related embedded plates. This is an interim report of a potentially reportable item under the provisions of 10CFR50.55(e). We have submitted an interim report logged TXX-4701, dated February 12, 1986. Constraints involving testing inside the Unit 1 boundary for the remaining single support have delayed completion of our final report on this matter.

We are continuing our evaluation and anticipate completion of our final report by April 25, 1986.

Very truly yours,

A handwritten signature in cursive script that reads "W. G. Council".

W. G. Council

JWA/arm

c - NRC Region IV (0 + 1 copy)

Director, Inspection & Enforcement (15 copies)
U. S. Nuclear Regulatory Commission
Washington, D.C. 20555

86-295

A DIVISION OF TEXAS UTILITIES ELECTRIC COMPANY
8604010310 860325
PDR ADOCK 05000445
S PDR

1/0
IE27