Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION P O BOX 128 SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN STATION MANAGER TELEPHONE (714) 308-6241

00

June 2, 1988

U. S. Nuclear Regulatory Commission Document Control Desk Washington, D.C. 20555

SUBJECT: Docket No. 50-362 Report of NPDES Permit Violation San Onofre Nuclear Generating Station, Unit 3

Pursuant to Section 3.2 of Appendix B, Environmental Protection Plan, Operating License No. NPF-15 for San Onofre Unit 3, enclosed is a copy of the April 1988 monthly NPDES report summary which includes a description of a violation of the San Onofre Unit 3 NPDES Permit.

If you require any additional information, please so advise.

Sincerely, HEMOR

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspection, Units 1, 2, and 3)
J. B. Martin (Regional Administrator, USNRC Region V)

Southern California Edison Company

P. O. BOX 128 SAN CLEMENTE, CALIFORNIA 92672

B KAT7 MANAGER OPERATIONS AND MAINTENANCE SUPPORT

May 2/, 1988

TE_EPHONE (714) 368 6631

Mr. Ladin Delaney, Executive Officer California Regional Water Quality Control Board San Diego Region 9771 Clairemont Mesa Boulevard, Suite B San Diego, California 92124-1331

Dear Mr. Delaney:

Subject: NPDES San On Aucle. Generating Statio , Unit 3

The SONGS monitoring report covering the month of April is submitted in accordance with the requirements of CRWQCB Order 85-13 (NPDES Permit No. CA0108181). A summary of the generating unit's status and significant analytical results is provided below.

The unit was in operation during April. All sampled water sources were found to be within permit limits. On April 24, 1988, the circulating water delta temperature exceeded the daily average allowed by one degree. This occurred due to a series of unusual conditions. A heat treatment was in progress on Unit 2 including the Unit 2 saltwater cooling discharge line, which was lined up to discharge to the Unit 3 intake. This lineup caused the delta temperature to increase. Although prompt action was taken to reduce power, limits on the late of power reduction were such that it was not possible to immediately reduce the average temperature rise to less than 20°F without shutting the unit down. To avoid this problem in the future, we have initiated operating procedure changes.

Pursuant to Order No. 85-13, Reporting Requirement 12, your letter dated June 25, 1985, authorizes the following representative(s) to sign and certify all reports required by this order: Arthur Kneisel, Environmental Engineer. Mr. Ladin Delaney

.

I certify under penalty of law that I have personally examined and am familiar with the information submitted in the attached document, and based on my inquiry of those individuals immediately responsible for obtaining the information, I believe the submitted information is true, accurate, and complete. I am aware that there are significant penalties for submitting false information, including the possibility of fine and imprisonment.

Sincerely,

Brian Katz

Enclosure

cc: Environmental Protection Agency, Region IX



Carolina Power & Light Company

Brunswick Steam Electric Plant P. O. Box 10429 Southport, NC 28461-0429

June 3, 1988

FILE: B09-13510C SERIAL: BSEP/88-0594

U.S. Nuclear Regulatory Commission Washington, DC 20555 Attn: Document Control Desk

> BRUNSWICK STEAM ELECTRIC PLANT UNITS 1 AND 2 DOCKET NOS. 50-325 AND 50-324 LICENSE NOS DPR-71 AND DPR-62 MONTHLY OPERATING REPORT

Dear Mr. Scroggins:

In accordance with Technical Specification 6.9.1.6 for the Brunswick Steam Electric Plant, Units 1 and 2, Carolina Power & Light Company herewith submits the report of operating statistics and shutdown experience for the month of May 1988.

Very truly yours,

J.A.P. Bisting for

C. R. Dietz, General Manager Brunswick Steam Electric Plant

MW/srg MSC/85-0014

Enclosures

cc:	Mr.	Μ.	R.	Beebe
	Mr.	Τ.	С.	Bell
	Dr.	J.	Ν.	Grace
	Ms.	F .	Ε.	Harrison
	Mr.	Μ.	D.	Hill
	Mr.	Ρ.	W .	Howe
	Mr.	L.	S.	Mull
	Mr.	R.	G.	Oeh1
	Mr.	W.	Η.	Ruland
	Mr.	R.	Μ.	Scrog/ ins
	Ms.	Η.	Μ.	Shaver
	Ms.	D.	J.	Vicks
	INPO			

IE24