

September 29, 1988

Docket Nos. 50-317
and 50-318

DISTRIBUTION

~~Docket File~~ ACRS(10)
NRC PDR
Local PDR
PDI-1 Rdg.
SVarga
BBroger
RCapra
CVogan
SMcNeil
LTripp, RI
DHood
OGC
EJordan
BGrimes

Mr. J. A. Tiernan
Vice President-Nuclear Energy
Baltimore Gas and Electric Company
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4
P.O. Box 1535
Lusby, MD 20657

Dear Mr. Tiernan:

SUBJECT: REQUEST FOR ADDITIONAL INFORMATION - BG&E RESPONSE TO NRC
BULLETIN 88-01, "DEFECTS IN WESTINGHOUSE CIRCUIT BREAKERS"
(TACS 65955 and 65956)

While reviewing your September 8, 1988 response to NRC Bulletin 88-01, "Defects in Westinghouse Circuit Breakers," the NRC staff noted that a schedule for and description of corrective actions, necessitated by type DS-206 and DS-416 breaker inspection failures, was not provided. Subsequent discussions with your staff indicated that most failed breakers had been repaired but that corrective actions on several breakers had been deferred.

Though submission to the NRC, of a schedule for and description of corrective actions for breaker inspection failures, was not required by NRC Bulletin 88-01, it now is requested that you provide such a schedule/description.

Please respond to this request within 70 days of its date of issuance.

This request for information affects fewer than 10 respondents; therefore, OMB clearance is not required under P.L. 96-511.

Sincerely,

~~Original signed by~~

Scott Alexander McNeil, Project Manager
Project Directorate I-1
Division of Reactor Projects, I/II

PDI-1 *CV*
LA:CVogan
09/29/88

PDI-1 *SMcNeil*
PM:SMcNeil:d1g
09/29/88

RCapra
PDI-1
PD:RCapra
09/29/88

*DFol
1/0*

8810050321 880929
PDR ADOCK 05000317
Q FDC

Mr. J. A. Tiernan
Baltimore Gas & Electric Company

Calvert Cliffs Nuclear Power Plant

cc:

Mr. John M. Gott, President
Calvert County Board of
Commissioners
Prince Frederick, Maryland 20768

D. A. Brune, Esq.
General Counsel
Baltimore Gas and Electric Company
P. O. Box 1475
Baltimore, Maryland 21203

Mr. Jay E. Silberg, Esq.
Shaw, Pitman, Potts and Trowbridge
1800 M Street, NW
Washington, DC 20036

Mr. W. J. Lippold, General Supervisor
Technical Services Engineering
Calvert Cliffs Nuclear Power Plant
MD Rts 2 & 4, P. O. Box 1535
Lusby, Maryland 20657

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
P. O. Box 437
Lusby, Maryland 20657

Department of Natural Resources
Energy Administration, Power Plant
Siting Program
ATTN: Mr. T. Mageite
Tawes State Office Building
Annapolis, Maryland 21204

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406