

Georgia Power Company
Post Office Box 282
Waynesboro, Georgia 30830
Telephone 404 554-9961
404 724-8114

Southern Company Services, Inc.
Post Office Box 2625
Birmingham, Alabama 35202
Telephone 205 870-6011



Vogtle Project

June 1, 1988

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D. C. 20555

File: X7BC35
Log: GN-1457

PLANT VOGTLE - UNIT 2
NRC DOCKET NUMBER 50-425
CONSTRUCTION PERMIT NUMBER CPPR-109
SER CONFIRMATORY ITEM 24: TESTING OF P-4 INTERLOCK

Gentlemen:

GPC letter GN-1145, dated October 31, 1986, indicated that a permanently installed voltage indicator and selector switch had been installed in Unit 1 to facilitate testing of the P-4 interlock. This resolved confirmatory item 24 for Unit 1 in SSER 4.

GPC has now installed a similar switch and voltage indicator in Unit 2. The description in FSAR paragraph 7.2.2.2.3 applies to Unit 2, as well as Unit 1. This should allow the resolution of confirmatory item 24 for Unit 2 also.

If your staff requires any additional information, please do not hesitate to contact me.

Sincerely,

J. A. Bailey
Project Licensing Manager

8806100188 880601
PDR ADOCK 05000425
E PDR

JAB/wk1

xc: NRC Regional Administrator
NRC Resident Inspector
P. D. Rice
L. T. Gucwa
R. A. Thomas
B. W. Churchill, Esquire
J. B. Hopkins (2)
G. Bockhold, Jr.
R. J. Goddard, Esquire
R. W. McManus
Vogtle Project File

Boo1
1/0