

SEP 21 1988

Docket Nos. 50-277
50-278

Philadelphia Electric Company
ATTN: Mr. C. A. McNeill
Executive Vice President-Nuclear
2301 Market Street
Philadelphia, Pennsylvania 19101

Gentlemen:

Subject: Inspection Nos. 50-277/278/88-29

This letter refers to the routine safety inspection conducted by Mr. H. J. Kaplan of this office on August 5, 1988 and August 8-12, 1988 at the Peach Bottom Power Station, Delta, Pennsylvania. Mr. Kaplan discussed the findings of the inspection with members of your staff at the conclusion of the inspection.

The inspection focused on replacement of emergency service water system piping, the erosion-corrosion monitoring program, an indication in the Unit 3 recirculation pump to pipe weld, and inspection of the shroud access cover plate welds in Units 2 and 3. Areas examined during this inspection are described in the NRC Region I Inspection Report which is enclosed with this letter. Within the areas examined, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel and observations by the inspector. No violations or deviations were identified.

Your cooperation is appreciated.

Sincerely,

Original Signed By:
Jacque P. Durr

Jacque P. Durr, Chief
Engineering Branch
Division of Reactor Safety

Enclosure:
NRC Inspection Report Nos. 50-277/88-29 and 50-278/88-29

OFFICIAL RECORD COPY

CIR PB 88-29 - 0001.0.0
09/13/88

8810060042 880921
PDR ADOCK 05000277
Q PDC

IE:01

SEP 21 1988

Philadelphia Electric Company

2

cc w/encl:

John S. Kemper, Sr., Senior Vice President-Nuclear
J. W. Gallagher, Vice President, Nuclear Services
E. C. Kistner, Chairman, Nuclear Review Board
Dickinson M. Smith, Vice President, Peach Bottom Atomic Power Station
Jack Urban, General Manager, Fuels Department, Delmarva Power & Light Co.
John F. Franz, Plant Manager, Peach Bottom Atomic Power Station
Troy B. Conner, Jr., Esquire
W. H. Hirst, Director, Joint Generation Projects Department,
Atlantic Electric
Bryan W. Gorman, Manager, External Affairs
Eugene J. Bradley, Esquire, Assistant General Counsel (Without Report)
Raymond L. Hoyis, Esquire
Thomas Magette, Power Plant Siting, Nuclear Evaluations
W. M. Alden, Director, Licensing Section
Doris Poulsen, Secretary of Harford County Council
Public Document Room (PDR)
Local Public Document Room (LPDR)
Nuclear Safety Information Center (NSIC)
NRC Resident Inspector
Commonwealth of Pennsylvania

bcc w/encl:

Region I Docket Room (with concurrences)
Management Assistant, DRMA (w/o encl)
Section Chief, DRP
PAO (2) SALP and All Inspection Reports
Robert J. Bores, DRSS
R. Martin, NRR
B. Clayton, EDO
C. Y. Cheng, NRR
C. McCracken, NRR

RI:DRS
Kaplan/pmb/rw
9/14/88

RI:DRS
Strosnider
9/14/88

RI:DRS
Durr
9/29/88

OFFICIAL RECORD COPY

CIR PB 88-29 - 0002.0.0
09/13/88