



South Carolina Electric & Gas Company
P.O. Box 764
Columbia, SC 29218
(803) 748-3513

Dan A. Nauman
Vice President
Nuclear Operations

March 25, 1986

06 MAR 2 10:01

Dr. J. Nelson Grace
Regional Administrator
U.S. Nuclear Regulatory Commission
Suite 2900
101 Marietta Street, NW
Atlanta, Georgia 30323

SUBJECT: Virgil C. Summer Nuclear Station
Docket No. 50/395
Operating License No. NPF-12
Special Report (SPR 86-001)

Dear Dr. Grace:

Attached is a Special Report for the Virgil C. Summer Nuclear Station. This report is submitted pursuant to the requirements of Section 6 of the Technical Specifications.

Should there be any questions, please call us at your convenience.

Very truly yours,

D. A. Nauman

RJB:DAN/lcd
Attachment

c: V. C. Summer	K. E. Nodland
O. W. Dixon, Jr./T. C. Nichols, Jr.	R. A. Stough
E. H. Crews, Jr.	G. O. Percival
E. C. Roberts	R. L. Prevatte
J. G. Connelly, Jr.	J. B. Knotts, Jr.
W. A. Williams, Jr.	S. D. Hogge
Group Managers	I&E Washington
O. S. Bradham	Document Management
D. R. Moore	Branch
C. A. Price	INPO Records Center
W. T. Frady	ANI Library
C. L. Ligon (NSRC)	NPCF
R. M. Campbell	File

IE22

Dr. J. Nelson Grace
SPR 86-001
Page Two
March 25, 1986

EVENT DESCRIPTION

On February 26, 1986, Fire Doors IB-118 and IB-119, located in the battery charging rooms, were opened to allow the use of a portable charging unit on two cells of station Battery "A". Because of an unresolved seismic concern, the portable charging unit cannot be placed in battery room "A". It is estimated that this condition will exist until mid April, 1986.

ACTION TAKEN

The Licensee has taken the compensatory action as required by Technical Specification 3.7.10, "Fire Rated Assemblies." The Licensee is evaluating the seismic concern for resolution.