



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION IV
611 RYAN PLAZA DRIVE, SUITE 1000
ARLINGTON, TEXAS 76011

September 27, 1988

NOTICE OF SIGNIFICANT MEETING

Name of Licensee: Public Service Company of Colorado

Name of Facility: Fort St. Vrain

Docket Number: 50-267

Date and Time of Meeting: October 3, 1988, at 1 p.m.

Location of Meeting: Region IV, 8th Floor

Purpose of Meeting: Items identified in NRC Inspection Reports 50-267/88-15
and 50-267/88-23 (see attachment)

NRC Attendees: J. Milhoan, Director, Division of Reactor Safety
A. Beach, Deputy Director, Division of Reactor Projects
T. Westerman, Chief, Reactor Project Section B
K. Heitner, Project Manager, NRR (by phone conference)
I. Barnes, Chief, Materials and Quality Program Section
R. Farrell, Senior Resident Inspector, Fort Calhoun Station
R. Mullikin, Project Engineer, Reactor Project Section B
L. Ellershaw, Inspector, Material & Quality Program Section

Licensee Attendees: R. Williams, Vice President - Operations
P. Tomlinson, Manager - QA
D. Warembourg, Manager - Nuclear Engineering
C. Fuller, Manager - Nuclear Production
G. Redmond, Project Manager - Circulator Outage
D. Goss, Nuclear Regulatory Affairs
L. Brey, Manager - Nuclear Licensing, Fuels and Resources

NOTE: Attendance by NRC personnel should be made known by 4 p.m. September 29,
1988, via telephone call to Tom Westerman, ext. 145.

Approved By:


T. F. Westerman, Chief
Project Section B

Attachment: As stated

8810060299 880927
PDR ADOCK 05000267
PNU

IE 45
1/1

ATTACHMENT

Purpose of Meeting:

1. Control of Special Processes
 - a. Welding Program
 - (1) Welding of Struts to Circulator
 - (2) Qualification of Welding Procedures
 - b. Nondestructive Examination Program
 - (1) NDE of Circulator Studs
2. Control of Receipt Inspection Activities
 - a. Installation of circulator that had a HOLD tag installed on it
3. Licensee Oversight of Vendor Activities
 - a. Failure of licensee to identify welding program inadequacies at GA
4. Corrective Action Program
 - a. Untimely correction of concerns identified during an inspection in 1986

Notice of Significant Meeting
Public Service Company of Colorado
October 3, 1988

-2-

Distribution:

DMB IE45

J. M. Taylor, DEDRO
T. E. Murley, D/NRR
F. J. Miraglia, ADT/NRR
T. T. Martin, ADT/NRR
J. Lieberman, D/OE
L. J. Chandler, Asst. GC for Enf.
K. Heitner, Project Manager, NRR
T. O. Martin, DEDRO
R. D. Martin, RIV
R. E. Hall, RIV
J. Gilliland, PAO, RIV
NRC Attendees
Licensee Attendees
Licensee Address List

IE45
11