

CALCULATION
ED-Q2268-87324
480V Reactor MOV Board ZC
w/All Attachments

881006037B 880923
PDR ADUCK 05000259
P PNU

TSD-EDC

CALCULATION COVER SHEET

TITLE THERMAL OVERLOAD HEATER CALCULATIONS -
480V FOR MOV BD 2C

PLA IT
10/2/73**PREPARING ORGANIZATION**

FRASCO

KEY NOUNS (Consult RIMS DESCRIPTORS LIST)**THERMAL OVERLOAD CALCULATION**

Each time these calculations are issued, preparers must ensure that the original (RIMS) accession number is filled in.

BRANCH/PROJECT IDENTIFIERS

ED-Q2268-87324

Rev (for RIMS' use)

(150)

RIMS-accession number

R0

880411C0068

322

'880331 109

APPLICABLE DESIGN DOCUMENT(S)

RL

B22

'88 0815 102

AS REFERENCED

R-

SAR SECTION(S) UNID SYSTEM(S)

N/A

268

R-

Revision 0

R1

R2

R3

Safety-related?

Yes No

ECN No. (or indicate Not Applicable)

DCN

E-2-P7010

H 1239 RA

Prepared

Dan J. Amato

8-1-88

Jeffrey P. McGaugh

Checked

John (BHATT) 3-17-88

8-1-88

Ronald K. Kirby

Reviewed

Jeffrey P. McGaugh

8-1-88

Shawn C. Stevens

Approved

J. C. Miller

8-1-88

Shawn C. Stevens

Date

3/22/88

8-1-88

List all pages added by this revision.

4A, 5A, 6A

7A, 8A

List all pages deleted by this revision.

4, 5, 6, 7, 8

List all pages changed by this revision.

AS NOTED

STATEMENT OF PROBLEM:
THERMAL OVERLOAD HEATERS (TOL)
AT BNP WERE NOT PREVIOUSLY
DOCUMENTED.THIS CALCULATION DETERMINES
THE DESIGN AND EVALUATES THE
INSTALLED TOL HEATERS PER
REQUIREMENTS OF ASME IEEE 87031.**Abstract**These calculations contain an unverified assumption(s)
that must be verified later. Yes No **CLASSIFICATION**ESSENTIAL
DIRECT DESIGN INPUT

R1

- Microfilm and store calculations in RIMS Service Center.
 Microfilm and return calculations to:

Calculation File Room

Microfilm and store Return F2 BPN

Title:

CULATION NO: ED-Q2268-87324
NORMAL OVERLOAD HEATER CALCULATIONS
480V REACTOR MOV BD 2C

REVISION LOG

Revision No.	DESCRIPTION OF REVISION	Date Approved
0	THIS CALCULATION VOIDS AND SUPERSEDES CALCULATION NO BFEP-E1-86062 RIMS-B22-870504 104 AND ALL REVISIONS THERETO.	
1	REVISED HEATER SIZES BASED ON CLARIFICATION OF G.E. INSTRUCTIONS.	8/11/88

PREP. : JPM
CHECKED : RKH / 88 / 88 / REV. I

ED-Q2268-87324
Page 3 of 11

TABLE OF CONTENTS

<u>Section</u>	<u>Page</u>
1.0 <u>GENERAL</u>	4A
2.0 <u>CRITERIA</u>	4A
3.0 <u>CODES AND STANDARDS</u>	7A
4.0 <u>ASSUMPTIONS</u>	7A
5.0 <u>DESIGN INPUT DATA</u>	7 A
6.0 <u>CALCULATIONS</u>	9 & 1.0 - 31.3
7.0 <u>SUMMARY OF CALCULATION RESULTS</u>	9
8.0 <u>CONCLUSIONS</u>	10
9.0 <u>REFERENCES</u>	11

RI

Rev 1 | Prepared JPM 8-1-88
| Checked RK 8-1-88

ED-02268-87324
Page 4 of 11

1.0 GENERAL

1.1 Purpose

The purpose of this calculation is to establish the requirements and guidelines to evaluate, verify, control and retain engineering calculations for thermal overload relay (TOL) selection.

1.2 Scope

The scope of this calculation is to determine the design for TOL heater sizes and settings and to evaluate the installed TOL heaters for continuous duty motors and motor operated valve motors powered from the Motor Control Centers (MCC) required for Unit 2 restart at Browns Ferry Nuclear Plant utilizing QIR-EED-87031 design criteria. (Ref. #5)

2.0 CRITERIA

The manufacturer's recommendations are used in the selection of overload heaters. The overload heater sizes and settings will be in accordance with the design criteria in QIR-EED-87031. RI

2.1 Continuous Duty Motors

Following is the process to be used in the selection of thermal overload heaters for continuous duty motors: RQ

- 2.1.1 The walkdown input data for the motor nameplate and motor control center will be recorded and used to perform the calculations. (Ref. #3)

2.1.2 Temperature Correction Factor

Manufacturer's recommendations shall be followed when non-accident ambient temperatures of the motor and motor control centers are within 18°C of each other. If the temperature difference is higher, the full load current shall be multiplied by temperature correction factor before selecting the overload heater. (Ref. #5)

The temperature correction factor is the ratio of motor ambient temperature correction factor and overload heater ambient temperature correction factor. (Ref. #5)

2.1.3 Designed thermal overload heaters are sized as follows:

- a) The service factor is determined from the walkdown input data. From Ref. #1 sh. 1, the derating factor is selected and the motor nameplate full load current is multiplied by the derating factor to determine the maximum full load current to be used in the heater table. (Ref. #1 sh. 8)
- b) The heater catalog number is selected for the starter NEMA size and maximum full load current calculated in Item 2.1.3 a. If the maximum full load current does not match the heater table, use the next larger maximum motor full load current and adjust the percent setting of the overload relay as required.
- c) The degree of protection provided by the overload heater is evaluated by multiplying the maximum motor full load current given in the heater table by 125% and dividing by the motor nameplate full load current. (Ref. #9)
- d) This value is then compared to the design criteria for acceptance. (Ref. #5)

2.1.4 The installed thermal overload heaters are evaluated as follows:

The maximum motor full load current given in the table is multiplied by 125% and by the percent setting of the overload relay. This value is the trip current of the overload heater. The trip current of the heater is then divided by the nameplate full load current of the motor to determine the percent protection. (Ref. #9) This value is then compared to the design criteria for acceptance. (Ref. #5)

2.1.5 Section 4 of the calculation sheet makes the recommendation to either leave the installed heater and adjust setting as necessary or to replace with the thermal overload heater sized in section 2 of the calculation sheet.

2.2 Motor Operated Valve Motors

The following procedures are to be used for motor operated valve motors:

2.2.1 The walkdown input data for the motor nameplate and motor control center will be recorded and used to perform the calculations. (Ref. #3)

This Sheet Added by Rev. 1

2.1.3 Thermal overload heaters for continuous duty motors are sized as follows:

- a) The service factor is determined from the walkdown input data. Multiply the motor nameplate full load current by the service factor derating factor to determine the current to be used when selecting a heater from the heater table. (Ref. #1 Sh. 8)
- b) The heater is selected from the heater table for the starter size it will be used with. The heater minimum current must be equal to or greater than the motor full load current calculated in Item 2.1.3 a above.
- c) Heater minimum current is determined from the heater tables by the method described in G.E. "Application Tips" dated March 11, 1983 No. 001.
- d) The degree of protection provided by the overload heater is evaluated by multiplying the heater minimum current by 1.25 and dividing by the motor nameplate full load current. (Ref. #9)
- e) This value is then compared to the design criteria for acceptance. (Ref. #5)

2.1.4 Acceptability of existing thermal overload heaters will be determined using the method described in 2.1.3 above and based on the following:

- a) Heaters will be selected based on an overload relay setting of 100%.
- b) Existing heaters will be reset or replaced as required.

2.2 Motor Operated Valve Motors

Following is the process to be used in the selection of thermal overload heaters for motor operated valve motors:

2.2.1 The walkdown input data for the motor nameplate and motor control center will be recorded and used to perform the calculations. (Ref. #3)

2.2.2 Designed thermal overload heaters are sized as follows:

Using the time-current curve for the overload relay (Ref. #1 Shts 5 through 7) locate the 15 second point and determine the current rating multiple for the particular zone of curve selected. Locked rotor current is divided by the current rating multiple to calculate the trip current. Divide trip current by factor of 1.25 to determine the heater selection current. (Ref. #9)

2.2.3 The heater catalog number is selected for the ~~proper~~ NEMA size and the heater selection current from heater selection table (Ref. #1, Sh. 3). If the heater selection current does not match the heater table, use the next larger maximum heater selection current. This value is the maximum full ~~load~~ current of the heater (I_m).

2.2.4 The overload heater trip current (I_t) is calculated by multiplying maximum motor full load current (I_m) by factor of 1.25 and the percent setting of the overload relay. (Ref. #9)

2.2.5 Determine the tripping time of the heater at 100% Full Load Current (FLC), 200% FLC and Locked Rotor Current/Amps (LRA) by dividing these values by the trip current for each value. The percent values obtained ~~should~~ be compared to the time vs current curves giving time in seconds. The heater tripping zones are given in Ref. #1 Shts 2, 3, & 4 and time-current curves are given in Ref. #1 Shts 5, ~~6~~ & 7. If the trip time does not fall within the acceptance criteria, then overload relay setting shall be adjusted to bring the trip time with the acceptance criteria outlined in QIR EEA 870 (Ref. #5)

2.2.6 Installed thermal overload heaters are evaluated as follows:

The heater catalog number is located in the heater selection table (Ref. #1 Sh. 3) for the proper size NEMA starter. The maximum motor full load current is located opposite the catalog number. After determining the maximum motor full load current follow steps 2.2.4 and 2.2.5 above to determine the tripping time of the overload heater for 100% FLC, 200% FLC and LRA.

2.2.7 Section 5 of the calculation sheet makes the recommendation either to leave the installed heater and adjust the setting as necessary or to replace thermal overload heater with the one sized in section 3 of the calculation sheet.

2.2.8 If the Locked Rotor Current/Amps (LRA) is to be determined from the NEC code letter, select the value from Sec. 3.6 NEC Table 430.7 (h) and multiply by the motor rated horsepower. The KVA value obtained is divided by the square root of three and the motor rated voltage to determine the motor Locked Rotor Current/Amps (LRA).

This Sheet Added by Rev. 1

2.2.2 Thermal overload heaters for motor operated valves are sized as follows:

- a) Using the time-current curve for the overload relay (Ref. #1 Shts. 5-7) locate the 15 second point and determine the current rating multiple for the particular zone of curve selected. Locked rotor current is divided by the current rating multiple to calculate the trip current. Divide trip current by factor of 1.25 to determine the heater selection current. (Ref. #9)
- b) The heater is selected for the starter size it will be used with. The heater selected should have minimum current rating equal to or less than the current calculated in 2.2.2a above.
- c) The ^{RELAY} ~~overload heater~~ trip current (I_t) is calculated by multiplying heater minimum current (I_m) by factor of 1.25. (Ref. #9)
- d) Determine the tripping time of the heater at 100% Full Load Current (FLC), 200% FLC and Locked Rotor Current by dividing these values by the tripping current. The percent values obtained shall be used to determine the maximum and minimum trip times from the heater curve operating band and recorded on the calculation worksheet. The heater tripping zones and time-current curves are given in TVA memorandum dated March 2, 1987 (RIMS B2Z 870302 013). The values obtained will then be compared to the criteria outlined in QIR-EEB-87031 to verify the acceptability of heater selected. (Ref. #5)

2.2.3 Acceptability of existing thermal overload heaters will be determined using the method described in 2.2.2 above and based on the following:

- a) Heaters will be selected based on an overload relay setting of 100%.
- b) Existing heaters will be reset or replaced as required.

2.2.4 If the Locked Rotor Current/Amps (LRA) is to be determined from the NEC code letter, select the maximum value from Sec. 3.6 NEC Table 430-7(b) and multiply by the motor rated horsepower. The KVA value obtained is divided by the square root of three and the motor rated voltage to determine the motor Locked Rotor Current.

2.2.5 For cases where the 200% FLC criteria stated in QIR-EEB-87031 is not met, acceptability of the selected heater is proven by demonstrating that full load current can be carried for at least the motor duty cycle which is greater than 2 times the valve stroke time. This meets the alternate criteria stated in the QIR.

3.0 CODES AND STANDARDS

- 3.1 National Electric Code - NFPA 70-1987, 430-32 & 430-34 for Continuous Duty Motors.
- 3.2 IEEE Transactions - Vol. PAS-100, No. 1, Jan. 1981, Pg. 43, Motor Overload Protection for Motors on Motor-Operated Valves.
- 3.3 National Electrical Manufacturers Association (NEMA) - Standards.
- 3.4 American National Standard for Electrical Power Systems and Equipment - Voltage Rating (60 Hz) ANSI C84.1-1982.
- 3.5 National Electrical Code - NFPA 70-1987, Tab 430-110 (C3).
- 3.6 National Electrical Code - NFPA 70-1987, Tab 430-7 (b).

4.0 ASSUMPTIONS

- 4.1 Assumptions will be made for the required data to perform the calculations where the walkdown input data is not available. Assumptions shall be noted in the calculation sheets based on the following documentation:
 - a) TVA's design approved drawings and EQP walkdown input data
 - b) Manufacturer's published data
 - c) By similarity among motors with same characteristics (e.g. used for alike functions, same size MOV operator, same horsepower, purchased on same contract).
 - d) Vendor drawings.
- 4.2 Locked rotor current for small motors below 1/2 HP that are not listed in the reference tables will be six (6) times full load current (NFPA 70-1987, 430-110 (C3)).
- 4.3 Continuous duty motors will be considered to be a Design B, Class B Insulation, 40°C Rise, NEC Code C, continuous duty and a Service Factor of 1 unless stated otherwise in the walkdown input data (Ref. #3).
- 4.4 The ambient temperature differential is assumed to be less than 15°C for all continuous duty motors where the average ambient temperature does not exceed 40°C.

5.0 DESIGN INPUT DATA

Ref. #1 Technical Justification - Thermal Overload Heaters (RIMS B22 870302 013).

Att. A: General Electric publications for CR124 overload relays and heaters applications, sheets 1 through 8.

3.0 CODES AND STANDARDS

This Sheet Added by Rev. L

- 3.1 National Electric Code - NFPA 70-1987, 430-32 & 430-34 for Continuous Duty Motors.
- 3.2 IEEE Transactions - Vol. PAS-100, No. 1, Jan. 1981, Pg. 43, Motor Overload Protection for Motors on Motor-Operated Valves.
- 3.3 National Electrical Manufacturers Association (NEMA) - Standards.
- 3.4 American National Standard for Electrical Power Systems and Equipment - Voltage Rating (60 Hz) ANSI C84.1 1982.
- 3.5 National Electrical Code - NFPA 70-1987, 430-110 (C3).
- 3.6 National Electrical Code - NFPA 70-1987, Tab 430-7 (b).

4.0 ASSUMPTIONS

- 4.1 Assumptions will be made for the required data to perform the calculations where the walkdown input data is not available. Assumptions shall be noted in the calculation sheets based on the following documentation:
 - a) TVA's design approved drawings and EQP walkdown input data
 - b) Manufacturer's published data
 - c) By similarity among motors with same characteristics (e.g. used for alike functions, same size MOV operator, same horsepower, purchased on same contract).
 - d) Vendor drawings.
- 4.2 Motor data may be obtained from TVA Design Guide DS-E2.4.6 if unavailable from walkdown data or through assumptions described in 4.1 above.
- 4.3 Continuous duty motors will be considered to be a Design B, Class B Insulation, 40°C Rise, NEC Code C, continuous duty and a Service Factor of 1 unless stated otherwise in the walkdown input data. (Ref. #3)
- 4.4 The ambient temperature differential is assumed to be less than 18°C for all equipment where the average ambient temperature does not exceed 40°C.

5.0 DESIGN INPUT DATA

Ref. #1 Technical Justification - Thermal Overload Heaters (RIMS 822 870302 013).

Att. A: General Electric publications for CR124 overload relays and heaters applications, sheets 1 through 8.

Sheet 1 - How to use heater tables.

Sheet 2 - Overload relay heater tripping zones for open relay-open starter or enclosed starter-sizes 00, 0, 1, 2, and 5 - Drawing #231HAL65-3.

PREPARED 8-1-88
CHECKED RK 8-1-88 REV. I

ED-02268-37324
Page 3 of 11

Sheet 1 - How to use heater tables.

Sheet 2 - Overload relay heater tripping zones for open relay-open starter or enclosed starter-sizes 00, 0, 1, 2, and 5 - Drawing #231HA165 - 3.

Sheet 3 - Overload heaters tripping zones for open and enclosed size 4 starters - Drawing #515A296 - 1.

Sheet 4 - Overload relay heaters tripping zones for size 3 starters - Drawing #K-0770791 - 1.

Sheet 5 - Time-Current characteristics curves for series 00, 0, 1, 2, and 5 starter overload heaters - Drawing #31HA165-2. Read with sheet #2 listed above.

Sheet 6 - Time-Current characteristics curves for size 3 starter overload heaters - Drawing #K-0770790-1. Read with sheet #4 listed above.

Sheet 7 - Time-Current characteristics curves for size 4 starter overload heaters - Drawing #55-172391-1. Use with sheet #3 listed above.

Sheet 8 - Overload heater selection table extracted from instruction manual GEII-2614C.

Att. B: General Electric approximate motor full load current ratings for motors from 1/4 HP to 400 HP. Sheet 1 of 1.

Ref. #2 Rotork Controls Inc. Publication AF2/01 (4/1983) - Rotork 7874305 480V Motor Data for Motor Operated Valves (55C 01057 D, K -01-02-01) P.D. D-03.

Ref. #3 Walkdown Info. Data - Motor & Motor Control Centers (QIRFOP3602, QIRFOP37005, QIRFOP87035, QIRFOP87095 & MD-1105).

Ref. #4 General Electric letter for sizing Thermal Overload Heaters (RIIS P73 870125 702).

Ref. #5 QIR Please QIR EFB 87031 (RIIS P43 870203 903).

Ref. #6 Mechanical Valve Motor Operator tabulation drawings (47A353 Series).

Ref. #7 American National Standard for Electrical Power Systems and Equipment - Voltage Ratings (60 Hz) ANSI C84.1 1982, Page 10.

Ref. #8 Environmental drawings (47A272 Series).

Ref. #9 General Electric Publication - Instructions, Installation and Maintenance of 7700 Line Motor Control Center (GEII-2614C), Contract 402/102.

Rev 1 | Prepared JPM 8-1-88
| Checked JRK 8-1-88

ED-Q2268-87324
Page 8A of 11

This Sheet Added by Rev. L

Sheet 3 - Overload heaters tripping zones for open and enclosed size 4 starters - Drawing #545A296-1.

Sheet 4 - Overload relay heaters tripping zones for size 3 starters - Drawing #K-9770791-1.

Sheet 5 - Time-Current characteristics curves for series 00, 0, 1, 2, and 5 starter overload heaters - Drawing 231HA165-2. Read with sheet #2 listed above.

Sheet 6 - Time-Current characteristics curves for size 3 starter overload heaters - Drawing #K-9770790-1. Read with sheet #4 listed above

Sheet 7 - Time-Current characteristics curves for size 4 starter overload heaters - Drawing #55-172381-1. Use with sheet #3 listed above.

Sheet 8 - Overload heater selection table extracted from instruction manual GEH-2614C.

Att. B: General Electric approximate motor full load current ratings for motors from 1/4 HP to 400 HP. Sheet 1 of 1.

Ref. #2 Rotork Controls Inc. Publication AE2/01 (4/1983) - Rotork # 7874305 480V Motor data for Motor Operated Valves (55G 01057 D, K -01-08-01) Pg. 5 D-03.

Ref. #3 Walkdown Input Data - Motor & Motor Control Centers (QIREQP86073, QIREQP87005, QIREQP87035, QIREQP87096 & WD-1184)

Ref. #4 General Electric letter for sizing Thermal Overload Heaters (RIMS B22 870126 702).

Ref. #5 QIR Release QIR EEB 87031 (RIMS 343 870203 903), Supplemented by Memorandum (Guha to ~~Reinhard~~ RIMS B22 88012 011.

Ref. #6 Mechanical Valve Motor Operator tabulation drawings (47A368 Series).

Ref. #7 American National Standard for Electrical Power Systems and Equipment - Voltage Ratings (60 Hz) ANSI C84.1 1982, Page 10.

Ref. #8 Environmental drawings (47W225 Series).

Ref. #9 General Electric Publication - Instructions, Installation and Maintenance of 7700 Line Motor Control Center GEH-2614F, Contract #824182.

Ref. #10 General Electric "Application Tips" dated 3/11/83, no. 001 GE General Purpose Control Department.

Ref. #11 TVA Electrical Design Guide DG-E2.4.6 Rev 0

R1

R1

REV.I

PREPARED JPM 8-1-88
CHECKED RK 8-1-88PP-02218-87324
Page 0 of 11

5.0 CALCULATIONS

The calculation for TOL Heaters are prepared on individual set of sheets as identified in the calculation index and contain the following:

- a. Walkdown Input Data
- b. Manufacturer Data
- c. Definitions
- d. Acceptance Limits
- e. Calculations
- f. Design of Overload Heaters
- g. Evaluation of Installed Overload Heaters
- h. Comments

7.0 SUMMARY OF CALCULATION RESULTS

480V Reactor MCC Rd 2C

- 30 _____ MCC Compartments have been evaluated in this calculation.
- 30 _____ Individual TOL Heater calculations prepared.
- 2 _____ Installed TOL Heater sizes and settings have been determined acceptable.
- +2 - 3 _____ Installed TOL Heater sizes have been determined acceptable but require resetting.
- 25 _____ Installed TOL Heater sizes have been determined unacceptable and require replacing and setting.
- ? _____ TOL Heater calculations have unverified assumptions.

R1

REV. I

PREPARED JPM 8-1-88
CHECKED RK 8-1-88

FD-224-A-97324
Page 10 of 11

3.0 CONCLUSIONS

All thermal overload (TCL) heaters required for Unit 2 restart have been designed and the installed TCL heaters have been evaluated for compliance with the CIP EPR 87931 design criteria. The evaluation of the installed TCL heaters has determined:

C.1 Acceptable - Use as is.

The following Motor Control Center (MCC) compartment breaker sizes and settings have been determined acceptable:

Conn., '90.

7A
8B

81

3.7 Acceptable - Deser.

The following Motor Control Center (MCC) compartment sizes have been determined acceptable but require resetting.

卷之三

R1

REV.1

PREPARED JPM 8-1-88
CHECKED RK 8-1-88

EP-02269-37324
Page 11 of 11

3.3 Inacceptable - Replace.

The following Motor Control Center (MCC) compartment heater sizes and settings have been determined unacceptable:

Compnt. No.

4E	1A	5C	8E
5E	1D	6B	9B
9B	3C	6C	11A
R6A	4A	6E	
R6E	4B	7B	
R8B	4C	7C	
R3F	5B	7E	
R11A			

4.0 REFERENCES

4.1 Company Procedure

E-30-TVA-PFIP - Preparation, Review and Approval of Calculations for Browns Ferry Nuclear Plant.

E-76-TVA-PFIP - Procedure for Design Verification for Nuclear Power Plants

E-77-TVA-PFIP - Procedure for Identifying, Selecting and Documenting Design Inputs for Nuclear Power Plants.

E-7-TVA-PFNP - Processing Drawings for Review and Approval.

I-5-TVA-PFNP - Site Document Control.

PJ-1-TVA-PFIP - Project Filing System.

4.2 TVA Procedure

RFEP-PI-87-29 - Procedure for Assignment of Document Numbers.

NFP 3.1 Calculations

NFP 5.1 Design Output

NFP 5.2 Review

4.3 TVA Calculation

Electrical Equipment Required to Support Unit 2 Restart

211S1 243 440206 012.

CALCULATION NO. ED-C2268-37321
 THERMAL OVERLOAD HEATSHED CALCULATION
 BOARD PEF 420V REACTOR H/W ID 20
 UNIT 2

REV. 1.0 OF 31

PEF, A

DATE

3/16/85

COMPLETED BY

JUL

DATE

3/16/85

CHECKED BY

TAB

DATE

3/17/85

CALCULATION INDEX SHEET

REV. 1

PREPARED JPM 8-1-88
 CHECKED VRK 8-1-88

Item	Comt.	Description	Page No.	Date Sheet No.	Rev. Code

1	-	Calculation Index Sheet	1	1-1	A1
2	1A	Drywell Blower 2A-5	2	2-1-1.3	A1
3	1B	Recirc 'W Set Oil Pmp 2A-3	3	3-1-3.3	A1
4	3C	CPO Return Isol Vlv	4	4-1-4.5	A1
5	2E	CPO 'tr Pressure Control Vlv	5	5-1-5.5	A1
6	2F	PR CCI Seal 'tr Collec & Transfer Pmp	6	6-1-6.3	A1
7	19	PR Fount Drain Pump Pmp 2A	7	7-1-7.3	A1
8	4C	PPC 'N. Header Sectionalizing Vlv	8	8-1-8.5	A1
9	4F	CPO 'tr Pressure Control Vlv	9	9-1-9.5	A1
10	5D	Bus Heat Exch Alt Clg & Hyd Clg 'tr Vlv	10	10-1-10.5	A1
11	5C	CCI Spare Pmp Suction Vlv	11	11-1-11.5	A1
12	7F	CPO Pmp A Suct Isol Vlv	12	12-1-12.5	A1
13	5B	Stator Liquid Clg 'tr Shutoff MCV	13	13-1-13.5	A1
14	5C	CCW Spare Pump Disch Vlv	14	14-1-14.5	A1
15	5B	Main Stm Line Drain Vlv	15	15-1-15.5	A1
16	7A	PR Floor Drain Pump Pmp 2A	16	16-1-16.3	A1
17	7B	Precooler Liquid Clg 'tr Shutoff MCV	17	17-1-17.5	A1
18	7C	PR/PU Blowdown MCV	18	18-1-18.5	A1
19	7E	PR/CCW Filter & Demin Sys Pypass MCV	19	19-1-19.5	A1
20	8P	Turb oil EHC Fluid Clg 'tr Shutoff MCV	20	20-1-20.5	A1
21	8C	PR/CCU Drain to Radwaste MCV	21	21-1-21.5	A1
22	3E	PR/CCW Restrict Orifice Bypass MCV	22	22-1-22.5	A1
23	9P	Main Stm Line Drain MCV	23	23-1-23.5	A1
24	9E	Main Stm Line to Condenser MCV	24	24-1-24.5	A1
25	11A	Drywell Blower 2B-5	25	25-1-25.3	A1
26	11C	CPO 'tr Transfer MCV	26	26-1-26.5	A1
27	76A	Recirc Header Equalizer MCV	27	27-1-27.5	A1
28	76E	Recirc Pmp 2B Suction MCV	28	28-1-28.5	A1
29	78P	Recirc Pmp 2A Suction Valve	29	29-1-29.5	A1
30	78E	Recirc Header Equalizer Valve	30	30-1-30.5	A1
31	711P	PSG Water Head Tank Pmp 2A	31	31-1-31.3	A1

CALCULATION NO. ED-Q2268-87324

SHEET 2.1 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. 0

DATE 3/16/68

BOARD REF 480V REACTOR 2 M&V BD. 2C COMPUTED BY

DYL DATE 3/16/68

UNIT # 2 DWG. NO. 45B2299-6 REV. 0 CHECKED BY

PHS DATE 3/17/68

COMP # 1A EQUIP REF. DRY WELL BLOWER 2A-5

REV. I PREPARED: JPM 8-1-88
CONTINUOUS DUTY MOTORS CHECKED: JRK 8-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR.	<u>GE</u>	MODEL	<u>CR106E0</u>	SIZE	<u>3</u>
O/L RELAY TYPE	<u>CR124</u>	HEATER SIZE	<u>CR123F45.7B</u>	SETTING	<u>100 FA</u>
					<u>110 °C</u>

MOTOR NAMEPLATE DATA:

H.P. 40 (2) VOLTS 460 (2) PLC 52 (3) PHASE 3 (2) INS. CLASS B (1) NEC CODE G (2)
 DUTY CONT (2) S.F. 1.0 (1) TEMP RISE 60 (2) DEG C. AMBIENT TEMP -- DEG C
 (1) (2) SEE SH. 3.3

AMBIENT TEMPERATURE: (REF #8)

MOTOR AMBIENT TEMP 42 DEG C
 STARTER AMBIENT TEMP ≤ 40 DEG C

EQUIP. LOCATED IN POSITION OF REACTOR BLDG. WHICH IS NOT PART OF HARSH ENVIRONMENT PER DWSAS ASN803-8 REV. 5 & 47W225-102 REV. 1

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF #1 SH. 1) 0.9 TEMP CORRECTION FACTOR (TCF) —
 HEATER TABLE: (REF #1 SH. 8)

DEFINITIONS

RELAY

I (t) -- HEATER TRIP CURRENT / MINIMUM

I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG / RELAY TRIP

1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT

D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR. (REF #1 SH 1)

I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT

X* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

PROTECTION FROM 115% TO 130%, (REF #5)
 OVERLOAD HEATERS RANGE FROM 85% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
 IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION I (n) = I ADJUSTED = _____ AMPS

0051T

CALCULATION NO. ED-Q2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR MOV 50 2C COMPUTED BY

UNIT # 2 DWG. NO. 45B2299-6 REV. 0 CHECKED BY

COMP # 1A EQUIP REF. DRYWELL BLOWER ZA-S

SHEET 2.2 OF 31

REV. 0 DATE 9/16/88

DRAFT DATE 3/16/88

ZB DATE 3/17/88

REV. I PREPARED: JPM 8-1-88
CHECKED: RK 8-1-88

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HP. HEATER SIZE (REF #5)

$$I(n) \times D.F. = \text{USE D.F. PER REF #1 SH 1}$$

$$\underline{52} \quad I(n) \times \underline{0.9} \quad D.F. = \underline{46.3} \quad \text{AMPS}$$

$$\begin{array}{c} \text{CATALOG HEATER SIZE } \underline{\text{CR123 F56-7B}} \\ \text{I}(n) = \underline{47.0} \end{array}$$

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

$$\frac{\underline{47.0}}{\underline{47.0 + 50.2}} \quad I(n) \times 1.25 \times 100 \% / \underline{52} \quad I(n) = \underline{113 \%}$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED. NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\begin{array}{c} \% = [\% \text{ PROTECTION} \times I(n)] / [I(n) \times 1.25] \\ \underline{100 \%} = [\underline{113 \%} \times \underline{52}] / \underline{47.0 \times 1.25}, \underline{100 \%} = \underline{113 \%} \end{array}$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED. NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 4. REPLACE HEATER -
 NO - PROCEED WITH FOLLOWING
PROCEED TO SECTION 54

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \underline{1.25} = \text{TRIP AMPS}$$

$$I(t) = \underline{46.3} \quad I(n) \times 1.25 \times \underline{1.00} \quad \underline{1.25} = \underline{52.5} \quad \text{AMPS}$$

CALCULATION NO. ED-Q2268-87324

SHEET 2.3 OF 3.1

THERMAL OVERLOAD HEATER CALCULATION

REV 6

DATE 9/16/55

BOARD REF 430V REACTOR MOV BD 2C COMPUTED BY

DJA

DATE 3/16/55

UNIT # 2 Dwg. No. 45B2299-6 Rev. 0 CHECKED BY

MAB

DATE 3/17/55

COMP # 1A EQUIP REF. DRYWELL BLOWER 2A-5

REV 1

PREPARED: JPM 3-1-88

CHECKED: JEM 3-1-88

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

$\% \text{ PROTECTION} = I(t) / I(a) \times 100$

$$\frac{53.63I(t)}{52} \times 100 = 103\%$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$115\% = (\% \text{ PROTECTION} \times I(a)) / [I(a) \times 1.25]$$

$$115\% = \frac{\% \text{ PROT.} \times 52}{52 \times 1.25}, \frac{1}{5} \text{ PROT.} = 119\%$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 F48,7B ^{5/16-88 F61.4B} F65.88

OVERLOAD HEATER SETTING +15% 100%

5. COMMENTS: RESET THE INSTALLED TOL HEATERS TO 115%

(1) ASSUMPTION PER SECT. 4.3

(2) INFORMATION BASED ON WALKDOWN DATA

WD-1105

(3) ASSUMPTION PER NEC ARTICLE 430,
TABLE 430-150

REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE

CALCULATION NO. ED-Q2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR M&V BD-2.C COMPUTED BY

UNIT # 2 DWG. NO. 4582299-L REL. 0 CHECKED BY

COMP # 10 EQUIP-RPT. RECIRCULATION MS SET ON PUMP 1A-3

RELAY | OPERATOR: KEN R. J. - 88
CONTINUOUS DUTY MOTORS | CHECKED: KEN R. J. - 88

SHEET 3 OF 3

REF. 5

DATE 3/16/88

DATE 3/16/88

DATE 3/17/88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR109FD SIZE 4
O/L RELAY TYPE CR124 HEATER SIZE CR123F77.2B SETTING 115 %

MOTOR NAMEPLATE DATA:

H.P. 60 VOLTS 460 PLC 76.5 PHASE 3 INS. CLASS 3 NEC CODE G.
DUTY CONT S.F. 1.0 TEMP RISE 40 ① DEG C. AMBIENT TEMP 40 DEC C.

AMBIENT TEMPERATURE: (REF #8)

152.5 SH. 3.3

MOTOR AMBIENT TEMP 40 DEG C
STARTER AMBIENT TEMP 40 DEG C

EQUIP. LOCATED IN POSITION OF
REACTOR BUG WHICH IS NOT
PART OF HAZARD ENVIRONMENT PER
DWGS 47W220-2 REV. E 47W225-119
REV. 1

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF# 1-SH.1) 0.9 TEMP CORRECTION FACTOR (TCF) -
HEATER TABLE: (REF #1 - SH.3)

DEFINITIONS

- RELAY
I (t) -- HEATER TRIP CURRENT MIN:MAX
I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR (REF# 1-SH.1)
I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT
% -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

PROTECTION FROM 115 % TO 130 %. (REF 45)
OVERLOAD HEATERS RANGE FROM 83% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION I (n) = I ADJUSTED = _____ 100%

0051T

CALCULATION NO. E D - Q 2268-87324

SHEET 3 . 2 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV O

DATE 3/16/88

BOARD REF 430V REACTOR M2V P7.2C COMPUTED BY

DIA

DATE 3/16/88

UNIT # 2 DWG. NO. 45B2229-4 REL.C CHECKED BY

1403

DATE 3/17/88

COMP # 10 EQUIP REF. RECIRCULATION MG SET OIL PUMP 2A-3

REV. I

PREPARED: JPN 5-1-88

CHECKED: VRK 8-1-88

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HEATER SIZE (REF #5)

$$I(n) \times D.F. = \text{ (USE D.F. PER REF #1 SH 1)}$$

$$76.5 \quad I(n) \times 0.9 \quad D.F. = \underline{68.85} \quad \text{AMPS}$$

F91.4B

CATALOG HEATER SIZE CR123 F84.9B

$$I(m) = \underline{73.1}$$

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

$$73.1 \quad I(m) \times 1.25 \times 100 \% / \underline{76.5} \quad I(n) = \underline{119 \%}$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED. NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\% * = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$$

$$\% * =$$

$$\% * =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED. NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 4.

REPLACE HEATER

CR123 F77.8B

 NO - PROCEED WITH FOLLOWING
PROCEED TO SECTION 4

T(%) = 67.8

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \frac{\%}{100} = \text{TRIP AMPS}$$

$$I(t) = \underline{67.8} \quad I(m) \times 1.25 \times \frac{119}{100} \% = \underline{97.46} \quad \text{AMPS}$$

CALCULATION NO. ED-Q226E-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR M&V SD. 2C COMPUTED BY

UNIT # 2

DWG. NO. 45B2299-L P=1.0 CHECKED BY

COMP # 1D

EQUIP REF. CECIRCULATION MG SET OIL PUMP 2A-3

SHEET 3.3 OF 31

REV 0

DATE 3/16/88

DW

DATE 3/16/88

MH

DATE 3/17/88

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

$$\% \text{ PROTECTION} = I(t) / I(n) \times 100$$

97.46 I(t) / I(n) × 100 = 127%

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$I^* = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$$

$$I^* =$$

$$I^* =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE F91.4B
CR123 F77.2A

OVERLOAD HEATER SETTING -115% 100%

5. COMMENTS: THE INSTALLED HEATERS & SETTINGS ARE
ACCEPTABLE

① ASSUMPTION REFER TO SECT. 4.3

REPLACE INSTALLED TOL HEATERS AS
SHOWN ABOVE

CALCULATION NO. 5 - Q2268-87324
 THERMAL OVERLOAD CATER CALCULATION
 BOARD REF 480V FACTOR MOV BD 2C COMPUTED BY DIA SHEET 4.1 31
 UNIT # 2 DWG. NO. 45B2299-L REV. O CHECKED BY THB DATE 3/17/88
 COMP # 3 C EQUIP REF. CRD RETURN ISOLATION VALVE FCV- 85-30
 MOTOR OPERATED VALVE MOTORS
 WALKDOWN INPUT DATA: (REF # 3) REV. 1 PREPARED: JPM 3-1-88
 CHECKED: RK 3-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR109 CO. SIZE 1.
 O/L RELAY TYPE CR124 HEATER SIZE CR123C1-96A SETTING 150^{1/2} PA
 85% QC

MOTOR NAMEPLATE DATA: ①

STARTING TORQUE 10 ③ ft# RPM 1700 DUTY 15 min.S.F. -
 H.P. 1.0 ② VOLTS 460 FLC 2.3 LRA 11.9 ③ PHASE 3 INS. CLASS -
 NEC CODE LETTER - TEMP RISE 75 deg C.

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-SH. 8
 TIME VS. CURRENT CURVE: REF # 1-SH. 5

- ① SEE SH. 4.3
- ② SEE SH. 4.3
- ③ SEE SH. 4.3

DEFINITIONS

RELAY
 I (t) -- HEATER TRIP CURRENT MINIMUM MAXIMUM JPM 7/2/88
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG & RELAY TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 %* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

THERMAL OVERLOAD CIRCUIT CALCULATION

REV. 2

BOARD REF 430V

27161-2

ACTOR NO 50 3C

27161-4

UNIT 1-2

12 27161-8

COMP 1-3C

27161-9

EQUIP REF. CRD RETURN ISOLATION VALVE FCV- 25-50

CALCULATIONS:

REV. 1

PR-DATED: 1/24/88 8-1-88
CHANGED: 1/24/88 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I_{(adjusted)} = \frac{V_{(nameplate)}}{V_{(operating)}} \times I_{(nameplate)}$$

$$I_{(adjusted)} =$$

FOR THIS CALCULATION $I_{(n)} = I_{(adjusted)}$ = _____ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = \frac{HP \times KVA/HP \times 1000}{(1.73 \times 460)}$$

$$LRA = \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF! SH.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 11.9 / 6.25 = 1.90$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = $1.90 / 1.25 = 1.52$ AMPS

CATALOG HEATER SIZE CR125 <1.84A C1.84A ZONE 3
 $I(m)$ +.56 1.48

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{\%}{100} = \frac{+1.48}{1.48} \times 1.25 \times \frac{100\%}{1.85}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(2.3 \text{ I}(n) / \frac{1.85}{1.85} I(t)) \times 100 = \frac{1.85}{1.24} \approx \frac{1.85}{24.2} \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times 2.3 \text{ I}(n) / \frac{1.85}{1.85} I(t)) \times 100 = \frac{2.3}{1.24} \approx \frac{2.3}{24.2} \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(11.9 \text{ MTR LRA} / \frac{1.85}{1.85} I(t)) \times 100 = \frac{11.9}{6.43} \approx \frac{11.9}{64.3} \text{ SECS}$

CALCULATION NO. ED-Q2268-37324

SHEET 4 .3 OF 5

THERMAL OVERLOAD

TER CALCULATION

REV. O

BOARD REF 480V

1 TOE MOV BD 3C

COMPUTED BY DLU

7-21-88

UNIT # 2

Dwg. NO. 45B2299-6 REI.0

CHECKED BY

7-21-88

COMP # 3C

EQUIP REF. CRD RETURN ISOLATION VALVE FCV- 55-16

7-21-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

REV. I PREPARED: 1PM 8-1-88
CHECKED: 1PM 8-1-88 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \% = 1.76 \times 1.25 \times 95\% \\ I(t) = 1.85 \text{ AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP DIVIDER)

$$\left(\frac{2.3}{2.3} \right) I(n) / 1.85 I(t) \times 100 = \frac{24}{24} \times \frac{100}{100} \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE: (TRIP DIVIDER)

$$(2 \times \frac{2.3}{2.3}) I(n) / 1.85 I(t) \times 100 = \frac{249}{249} \times \frac{100}{100} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE: (TRIP DIVIDER)

$$\left(\frac{11.7}{11.7} \right) MTR LRA / 1.85 I(t) \times 100 = \frac{643}{643} \times \frac{100}{100} \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

- COMMENTS
- (1) BASED ON WALKDOWN DATA OF EQUIPMENT CONNECTED TO 480V REACTOR MOV BD 3C COMPUT. 3C. ASSUMPTION LKE FUNCTIONS.
 - (2) ASSUMPTION PER ONELINE Dwg. Dwg N# 45N751-5 2521
 - (3) ASSUMPTION PER Dwg VPF 2547-36-3 (SIMILAR CIRCUIT LOAD CURRENT & HP, GE TAG = 12-56 FCV-69-16)

CALCULATION NO. ED-G2268-87524

SHEET - .4 OF 5

THERMAL OVERLOAD

ITER CALCULATION

REV. C

E 3/16/88

BOARD REF 480V

CT#2 1A/1V 30 SEC

COMPUTED BY DIL

E 3/16/88

UNIT # 2

DWG. NO. 4582279.6 RE1.0

CHECKED BY JAS

DATE 3/17/88

COMP # 3C

EQUIP REF. CRD RETURN ISOLATION VALUE

22.95.50

REV. I PREPARED: JAS 3-1-88

4.

EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHECKED: JAS 3-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5./ REPLACE HEATER - PROCEED TO SECTION 5
NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 1.75 \quad I(n) \times 1.25 \times 1.00 =$$

$$I(t) = 2.19 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) \quad I(n) / 2.19 \quad I(t)) \times 100 = \underline{105} \quad \text{(TRIP TIME)}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) \quad I(n) / 2.19 \quad I(t)) \times 100 = \underline{210} \quad \text{2.92 - 1.5 SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times 11.9) \quad \text{MTR LRA} / 2.19 \quad I(t)) \times 100 = \underline{543} \quad \text{13.2 - 2.2 SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = 1.75 \times 1.25 \times 85\%$$

$$I(t) = 1.36 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) \quad I(n) / 1.36 \quad I(t)) \times 100 = \underline{124} \quad \text{(TRIP TIME)}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) \quad I(n) / 1.36 \quad I(t)) \times 100 = \underline{247} \quad \text{2.2 - 1.2 SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times 11.9) \quad \text{MTR LRA} / 1.36 \quad I(t)) \times 100 = \underline{540} \quad \text{10.11 - 2.2 SECS}$$

0050P

THERMAL OVERLOAD

TER CALCULATION

REV. 0

BOARD REF 460V

ACT 012 MOV RD. 2C

COMPUTED BY

Dyle

3/16/88

UNIT # 2

LNU. NO. 45B2259-6

REV. 0 CHECKED BY

THE

DATE 3/17/88

COMP # 3C

EQUIP REF.CRD RETRN ISOLATN

VALVE FNO. 35-50

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REV. I

PREPARED: JPM 3-1-88

CHECKED: RV 3-1-88

YES THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 61.95A

C 1.84A

OVERLOAD HEATER SETTING 85% 100%

COMMENTS: RESET THE INSTALLED TOL HEATER TO 85%
REPLACE HEATERS AS SHOWN ABOVE

CALCULATION NO. Q2268-87324

THERMAL OVERLOAD CATER CALCULATION

BOARD REV 4 30V REACTOR LOAD 50 ZG COMPUTED BY DYL DATE 3/16/88
 UNIT # 2 DWG. NO. 45B2299-6 REV. 0 CHECKED BY TAK DATE 3/17/88
 COMP # 3E EQUIP REF. C1CD WATER PRESSURE CONTROL VALVE PCV-85-23
 MOTOR OPERATED VALVE MOTORS PREPARED: JPM 8-1-88
 REV. I CHECKED: RKE 8-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE - MODEL CR109CO SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 CO. 36A SETTING 100% OFA
 95% OFC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 2 ft# RPM 850 DUTY 15 min.S.P. -
 H.P. - VOLTS 460 FLC .45 LRA 1.45 PHASE 3 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-54.8
 TIME VS. CURRENT CURVE: REF# 1-54.5

(1) SEE SH. 5.3

DEFINITIONS

- I (t) -- HEATER TRIP CURRENT RELAY MINIMUM MAXIMUM JPM 7/2/88
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- % -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. 5A-Q 2268-87324

THERMAL OVERLOAD

HEATER CALCULATION

SHEET 5.2 OF 31

REV. O

TE 3/16/55

BOARD REF 4300 FACTOR AUX. 5-2C COMPUTED BY D.J.L. DATE 3/17/55
 UNIT # 2 DWG. NO. 45B2299-6 REV. 5 CHECKED BY T.H.R. EQUIP REF. CRD WATER PRESSURE CONTROL VALVE PCV-BS-23
 COMP # 300 REV. I DRAFTED: J.P.A. B-1-88
 CHECKED: R.K. B-1-88

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
 IF YES:

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES:

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
 RECORD VALUE 5.1

TRIP CURRENT = (LRA) / (MULTIPLE OF CURRENT RATING)

$$\text{TRIP CURRENT} = 1.48 / 5.1 = .29$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
 HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = .29 / 1.25 = .23 AMPS

CATALOG HEATER SIZE CR123 CO.36A * ZONE A

$$I(m) \underline{0.34} \underline{0.29}$$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \underline{2.34} \times 1.25 \times \underline{100\%}$$

$$I(t) = \underline{0.39} \text{ AMPS } \underline{0.29}$$

$$\underline{0.36}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(\underline{.45} I(n) / \underline{0.39} I(t)) \times 100 = \underline{115} : \underline{125} \text{ OVER } \underline{900} \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \underline{.45} I(n) / \underline{0.39} I(t)) \times 100 = \underline{230} : \underline{250} \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\underline{1.48} \text{ MTR LRA} / \underline{0.39} I(t)) \times 100 = \underline{378} : \underline{411} \text{ } \underline{13.5 - 16} \text{ SECS}$$

3PM 8.1.88

22

* NOTE: THIS IS THE SMALLEST HEATER SIZE AVAILABLE
 AND IS THEREFORE ACCEPTABLE PER DIRECTIVE 87031

0050P

CALCULATION NO. Q2268-87324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 450V FACTOR MOTOR BD. 2C COMPUTED BY DYL DATE 3/16/85
 UNIT # 2 DWG. NO. 45B2293-6 REV. 0 CHECKED BY JIF DATE 3/17/85
 COMP # 3E EQUIP REF. CRD WATER PRESSURE CONTROL VALVE PCV-B5-23
 REV. 1 PREPARED: JPM 8-1-88 CHECKED: JRK 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(a) \times 1.25 \times \frac{\%}{\%} = 2.31 \times 1.25 \times \frac{75\%}{2.23 \text{ AMPS}}$$

100% MOTOR FLG TO HEATER CURRENT BASE: (TRIP TIME)
 $(\frac{1.45}{2.23} I(a) / 2.23 I(t)) \times 100 = 136 \approx 0.1327 \text{ SECS}$

200% MOTOR FLG TO HEATER CURRENT BASE
 $(\frac{2.45}{2.23} I(a) / 2.23 I(t)) \times 100 = 273 \approx 3.250 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\frac{1.45}{1.45} MTR LRA / 2.23 I(t)) \times 100 = 149 \approx 11.5 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREPB67031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER VENDOR DATA PROVIDED
IN EBASCO LETTER TO LIMIT TORQUE
DATED MARCH 18, 1985

* ACCEPTABLE PER QIREPB67031 (R= .5)
RIMS = B45 870203 203

CALCULATION NO. 57-02268-27324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 450A FACTOR NO. 1.25

UNIT # 2 DWG. NO. 45B2299-6 REV. 0

COMP # 35 EQUIP REF. CED WATER PRESSURE CONTROL VALVE

SHEET 5.4 OF 71

REV. 0

E 3/16/78

FS 3/16/78

DATE 3/16/78

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5. NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \frac{z}{z} = \text{TRIP AMPS}$$

$$I(t) = I(m) \times 1.25 \times \frac{z}{z}$$

$$I(t) = \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
$$(\frac{I(n)}{I(t)} \times 100) = \frac{\text{SECS}}{\text{SECS}}$$
200% MOTOR FLC TO HEATER CURRENT BASE:
$$(2 \times \frac{I(n)}{I(t)} \times 100) = \frac{\text{SECS}}{\text{SECS}}$$
LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
$$(\frac{\text{MTR LRA}}{I(t)} \times 100) = \frac{\text{SECS}}{\text{SECS}}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 5 NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(m) \times 1.25 \times \frac{z}{z} = \text{TRIP AMPS}$$

$$I(t) = I(m) \times 1.25 \times \frac{z}{z} = \text{AMPS} \times 1.25 \times \frac{z}{z}$$

$$I(t) = \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
$$(\frac{I(n)}{I(t)} \times 100) = \frac{\text{SECS}}{\text{SECS}}$$
200% MOTOR FLC TO HEATER CURRENT BASE:
$$(2 \times \frac{I(n)}{I(t)} \times 100) = \frac{\text{SECS}}{\text{SECS}}$$
LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
$$(\frac{\text{MTR LRA}}{I(t)} \times 100) = \frac{\text{SECS}}{\text{SECS}}$$

0050P

CALCULATION NO. 57-32268-37324
THERMAL OVERLOAD

WATER CALCULATION

BOARD REF 480V

FACTOR MOV BD. 2 C

COMPUTED BY DAK

SHEET 5.5 OF 31

REV. 0

FE 3/16/85

UNIT # 2

DWG. NO. 45B2299-L REV. 0

CHECKED BY

TE 3/16/85

COMP # 3E

EQUIP REF. CRD WATER PRESSURE CONTROL VALVE PCV-B5-23

REV. 1

PREPARED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

THE DATE 3/17/85

CHECKED: JRK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 CO. 36A

OVERLOAD HEATER SETTING 35% 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS

To ~~35%~~ 100%.

CALCULATION NO. ED-Q 2268-87324

SHEET 6.1 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. O

DATE 3/16/88

BOARD REF 130V RECTOR M6V SD 2C COMPUTED BY DJA

DATE 3/16/88

UNIT # 2 DWG. NO. 45B2299-6 RE-CHECKED BY JWB

DATE 3/17/88

COMP # 4A EQUIP REF. RBCCW SEAL WTR COLLECTION & TRANSFER PUMPS

REV. I PREPARED: JPM 8-1-88

CONTINUOUS DUTY MOTORS CHECKED: RK 8-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR 106CO SIZE 1
O/L RELAY TYPE CR124 HEATER SIZE CR123 C1.31A SETTING 100%

MOTOR NAMEPLATE DATA:

H.P. 1/2 VOLTS 460 FLC 1.1 PHASE 3 INS. CLASS B NEC CODE K
DUTY CONT S.F. 1.25 TEMP RISE - DEG C. AMBIENT TEMP 40 DEC C

AMBIENT TEMPERATURE: (REF #8)

MOTOR AMBIENT TEMP ≤ 40 DEG C
STARTER AMBIENT TEMP ≤ 40 DEG C

EQUIP. LOCATED IN PORTION OF REACTOR BLDG. WHICH IS NOT PART OF HARSH ENVIRONMENT PER DWGS 47W464-19 Rev. I & 47W225-110 Rev. I

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF# 1-SH.1) 1 TEMP CORRECTION FACTOR (TCF) -
HEATER TABLE: (REF #1 -SH.5)

DEFINITIONS

- I (t) -- RELAY TRIP CURRENT MINIMUM MAXIMUM JPM 7/1/88
I (n) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR. (REF #1 SH 1)
I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT
%* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

PROTECTION FROM 125% TO 140% (REF #5)
OVERLOAD HEATERS RANGE FROM 85% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES / NO
IF YES;

$$I_{(adjusted)} = \frac{V_{(nameplate)}}{V_{(operating)}} \times I_{(nameplate)}$$

$$I_{(adjusted)} =$$

FOR THIS CALCULATION I (n) = I ADJUSTED = _____ AMPS

CALCULATION NO. ED-G2265-87B74

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V RECTOR MOV BD. 2C COMPUTED BY DYL DATE 3/16/85
 UNIT # 2 DWG. NO. 45B2299-L RE-CHECKED BY THB DATE 3/17/85
 COMP # 2A EQUIP REF. R3CCW SEAL WTB COLLECTION TRANS = 100%

SHEET 5.2 OF 31

REV- 0 DATE 3/16/85
 REV- 1 DATE 3/17/85

REV. 1 PREPARED: JPM 8-1-85
 CHECKED: ORK 8-1-85

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HEATER SIZE (REF #5)

 $I(n) \times D.F. =$ (USE D.F. PER REF #1 SH 1)

$$\underline{1.1} \quad I(n) \times \underline{1} \quad D.F. = \underline{1.1} \quad \text{AMPS}$$

CATALOG HEATER SIZE C.R.123 E1.31A
 $I(m) = \underline{+1.8} \quad 1.19$

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

$$\frac{\underline{+1.8}}{1.19} \quad I(m) \times 1.25 \times 100 \% / \underline{1.1} \quad I(n) = \frac{1.8}{1.35} \%$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\% = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$$

$\% =$

$\% =$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 4.

REPLACE HEATER. PROCEED TO SECTION 4.

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \% = \text{TRIP AMPS}$$

$$I(t) = \underline{I(m)} \times 1.25 \times \underline{\%} = \underline{\text{AMPS}}$$

CALCULATION NO. ED-02268-87324

SHEET 6.3 OF 31

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF C30V REACTOR MOU SD 2C COMPUTED BY DVL
 UNIT # 2 DWG. NO. 45B2299-6 REV. 0 CHECKED BY TBS
 COMP # 4A EQUIP REF. R3CCW SEAL WTR COLLECTION TRANSFER PUMP

REV 0	DATE 3/16/85
DVL	DATE 3/16/85
TBS	DATE 3/17/85
REV. 1	PREPARED: JPM 8-1-88
	HECKED: VRK 8-1-88

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

$$\% \text{ PROTECTION} = I(t) / I(n) \times 100$$

$$\underline{\underline{I(t)}} / \underline{\underline{I(n)}} \times 100 = \underline{\underline{\quad}}$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

 YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE.

 NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\%^* = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$$

$$\%^* =$$

$$\%^* =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

 NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C1.48A
CR123A

OVERLOAD HEATER SETTING 100%

5. COMMENTS: THE INSTALLED TOL HEATERS & SETTINGS ARE
ACCEPTABLE.

REPLACE THE INSTALLED TOL HEATERS
AS SHOWN ABOVE.

CALCULATION NO. ED-Q7268-37324

SHEET 7.1 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. 0

DATE 3/16/68

BOARD REF 480V REACTOR 440V BD. 20 COMPUTED BY DYL DATE 3/16/68

UNIT 1 DWG. NO. 47W225-1 RETO CHECKED BY TKE DATE 3/17/68

COMP 143 EQUIP REF. REACTOR BLDG. EQUIP. DEAUX SUMP PUMP 2A

REV. 1 APPROVED: JPA F-1-BE

CONTINUOUS DUTY MOTORS CHECKED: VR 2-17-68

WALKDOWN INPUT DATA: (REF # 3)MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR109CO SIZE K-
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C10.4B SETTING 5%

MOTOR NAMEPLATE DATA:

H.P. 7.5 VOLTS 440 FLC 10.6 PHASE 3 INS. CLASS B NEC CODE G
 DUTY S-N-T S.P. 1.0 TEMP RISE 55 DEG C. AMBIENT TEMP - DEG C

AMBIENT TEMPERATURE: (REF #8)

MOTOR AMBIENT TEMP ≤ 40 DEG C EQUIP. LOCATED IN PORTION OF REACTOR
 STARTER AMBIENT TEMP ≤ 40 DEG C BLDG. WHICH IS NOT PART OF REACTOR
 ENVIRONMENT PER DWGS. 47W225-103 REV. A

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF# 1-54.1) 0.9 TEMP CORRECTION FACTOR (TCF) -
 HEATER TABLE: (REF #1-54.2)

DEFINITIONS

- RELAY
 I (t) -- HEATER TRIP CURRENT MINIMUM
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR. (REF #1-54.1)
 I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT
 % -- PER CENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (%)

ACCEPTANCE LIMITS:

PROTECTION FROM 115% TO 130% (REF #5)
 OVERLOAD HEATERS RANGE FROM 85% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
 IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) = \frac{440 \times 10.6}{460} = 10.13$$

FOR THIS CALCULATION I (n) = I ADJUSTED = 10.13 AMPS

CALCULATION NO. E.D.-Q2265-87324
THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 430V REACTOR MAX BDEG COMPUTED BY
UNIT # 2 DWG. NO. 4CB2299-6 REV. C CHECKED BY
COMP # 43 EQUIP REF. REACT. 2-1-26 = 33-2 DRAIN 5000-1-1-1A

SHEET 7 . 2 OF 2

REV C DATE 5/16/88
DYL DATE 5/16/88
TMB DATE 5/16/88
REV. I PREPARED JPM 5-1-88
CHECKED ORR 5-1-88

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HEATER SIZE (REF #5)

$I(n) \times D.F. =$ (USE D.F. PER REF #1 SH 1)

10.13 $I(n) \times$ 0.9 $D.F. =$ 9.12 AMPS

CATALOG HEATER SIZE C12.58
CR125 SH 2B
I(m) = 8.88 / 10.0

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

8.88 $I(m) \times 1.25 \times 100$ % / 10.13 $I(n) =$ 125 %
10.0

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

% = [% PROTECTION $\times I(n)] / [I(m) \times 1.25]$

% =

% =

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE. FIELD TO RESET SETTING. PROCEED TO SECTION 4.

NO - PROCEED WITH FOLLOWING
PROCEED TO SECTION 4

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$I(t) = I(m) \times 1.25 \times I^2 =$ TRIP AMPS

$I(t) = 9.12 \times 1.25 \times 1.5 =$ 13.0 AMPS

C
CALCULATION NO. ED-Q2265-37324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 422V REACTOR 1A9V SD. 2G COMPUTED BY DIA DATE 3/16/58
UNIT # 2 DWG. NO. 45B2252-6 S#13 CHECKED BY JAS DATE 3/17/58
COMP # 45 EQUIP REF. REACTOR 1A9 EQUIP 126.0 1.25 2A

SHEET 7.3 OF 21

REV O

DATE 3/16/58

REV I

DATE 3/16/58

REV II

DATE 3/17/58

REV III

DATE 3/17/58

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

$$\% \text{ PROTECTION} = I(t) / I(a) \times 100$$

$$\underline{12.0} \quad I(t) / \underline{10.12} \quad I(a) \times 100 = \underline{128} \quad \%$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

 YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$I^* = [\% \text{ PROTECTION} \times I(a)] / [I(a) \times 1.25]$$

$$I^* =$$

$$I^* =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C12.5BOVERLOAD HEATER SETTING HS% 100%

5. COMMENTS: INSTALLED TOL HEATERS SETTINGS ARE AMENDABLE

① ASSUMPTION, REFERRED TO SECT. 4.3REPLACE INSTALLED TOL HEATERS AS SHOWN ABOVE,

CALCULATION NO. 57-Q2269-37814

THERMAL OVERLOAD STARTER CALCULATION

BOARD REP 460V FACTOR NOV 13D 26

SHEET 3.1 OF 21

REV. 0

E 3/16/88

UNIT # 2 DWG. NO. 45B2292-1 REV. C

COMPUTED BY DIA

DATE 3/16/88

COMP # 4C EQUIP. REF. EECW N-FADEC SECTIONALIZING VALVE FEV. 67-21

MOTOR OPERATED VALVE MOTORS

WALKDOWN INPUT DATA: (REF # 3)

REV. I PREPARED: JMA 2-1-88
CHECKED: JRE 2-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR10960 SIZE 1
O/L RELAY TYPE CR124 HEATER SIZE CR123 CO. 71A SETTING 75%

MOTOR NAMEPLATE DATA:

STARTING TORQUE 5 ① ft# RPM 1725 DUTY 15 min. S.P.
H.P. 3/33 ① VOLTS 460 FLC .95 LRA 5.1 ① PHASE 3 INS. CLASS 5
NEC CODE LETTER - TEMP RISE 75 deg C.

MANUFACTURER'S DATA:

① See SH. 3.3

HEATER TABLE: REF # 1-SH.3

TIME VS. CURRENT CURVE: REF # 1-SH.5

DEFINITIONS

RELAY

I (t) -- HEATER TRIP CURRENT, MINIMUM

I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP

1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT

I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT

% -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER CENT (P.C.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2263-87324

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 480V

ACTS: MAY 62 SEC

COMPUTED BY DIA

SHEET 3 .2 OF 31

REV. O

E 3/14/88

UNIT # 2

DWG. NO. 4582555-1 REV. C

CHECKED BY JHS DATE 3/17/88

COMP # 4C

EQUIP REF. 25LN N-114R SECTIONALIZING VALVE FCV-67-21

REV. I

E 3/14/88

CALCULATIONS:PREPARED: JPM 5-1-88
CHECKED: JRK 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES / NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES / NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\underline{\quad} \text{HP} \times \underline{\quad} \text{kVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-545) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 5.1 / 6.25 = .82$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = .82 / 1.25 = .66 AMPS
CATALOG HEATER SIZE C C123 C0.75A

$$I(m) = \frac{.66}{0.75} = 0.63$$

'B' ZONE

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100}{100\%} = \frac{.66}{0.63} \times 1.25 \times \frac{100\%}{100\%}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(.95) I(n) / \frac{.66}{0.75} I(t) \times 100 = \frac{44.2}{120} \approx \frac{1}{3} \text{ OVER } 100\% \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times .95) I(n) / \frac{.66}{0.75} I(t) \times 100 = \frac{88.4}{241} \approx \frac{1}{3} \text{ OVER } 100\% \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(5.1 \text{ MTR LRA} / \frac{.66}{0.75} I(t)) \times 100 = \frac{59.2}{646} \approx \frac{1}{3} \text{ OVER } 100\% \text{ SECS}$

CALCULATION NO. 17-02268-27524

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 4301

ACTS 1A21 F-2 26

SHEET 8.3 OF 21

REV. 0

3/16/88

3/16/88

UNIT # 2

DWG. NO. 4522295.0 REV. 0

COMPUTED BY DJA

3/16/88

COMP # 45

EQUIP REF. SECW 1. HEADERS SECTIONALIZING VALUE E-1-57-21

CHECKED BY

DATE 3/17/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

REV. I

PREPARED: JIM 8-1-88

CHECKED: RK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(a) \times 1.25 \times \frac{75}{100} = 1.25 \times 95\%$$

$I(t) = .98$ AMPS

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$\frac{.95}{.95} I(a) / \frac{.92}{.92} I(t) \times 100 = 1.0 \times 1.0 = 1.0 \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE

$$\frac{.95}{.95} I(a) / \frac{.92}{.92} I(t) \times 100 = 2.2 \times 2.2 = 4.8 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\frac{.95}{.95} I(a) / \frac{.92}{.92} I(t) \times 100 = 6.22 \times 6.22 = 38.6 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIRUEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER PHILADELPHIA GEAR CO. DWG. NO.

15-477-3292-3 E 47A368-67-2 REV. D

THERMAL OVERLOAD HEATER CALCULATION

REV. 5

RE 5/14/88

BOARD REF. ECD-32263-878-4

COMPUTED BY DYL

RE 3/14/88

UNIT 2 DWG. NO. 445B2032-6 REV. C

CHECKED BY JMS

DATE 3/17/88

COMP # 4 EQUIP REF. EECW 4. LEADER SECTIONALIZING VALVE FCV-67-21

REV. I PREPARED JPM 8-1-88

CHECKED JRK 8-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5

 NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times 1 = \text{TRIP AMPS}$$

< 2423 > 2.71A

$$I(n) = 1.0 \quad I(n) \times 1.25 \times 9.0 =$$

< 2423 > 12

$$I(n) = 1.74 \quad \text{AMPS}$$

< 2423 > 3.00A

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{.95}{.95} \right) I(n) / \left(\frac{.76}{.76} \right) I(t) \times 100 = \frac{1.25}{1.25} = \text{SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{2 \times .95}{2 \times .95} \right) I(n) / \left(\frac{.76}{.76} \right) I(t) \times 100 = \frac{2.50}{2.50} = \frac{61.32}{61.32} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\left(\frac{5.1}{5.1} \right) \text{MTR-LRA} / \left(\frac{.76}{.76} \right) I(t) \times 100 = \frac{1.71}{1.71} = \frac{9.2}{9.2} = \text{SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5. NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times 1 = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times 1.2 = \frac{1.2}{1.2} \times 1.25 = \frac{1.5}{1.5} = 105\%$$

$$I(n) = 1.74 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{.95}{.95} \right) I(n) / \left(\frac{.81}{.81} \right) I(t) \times 100 = \frac{1.25}{1.25} = \text{SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{2 \times .95}{2 \times .95} \right) I(n) / \left(\frac{.81}{.81} \right) I(t) \times 100 = \frac{2.25}{2.25} = \frac{72.94}{72.94} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\left(\frac{5.1}{5.1} \right) \text{MTR-LRA} / \left(\frac{.81}{.81} \right) I(t) \times 100 = \frac{1.20}{1.20} = \frac{10.2}{10.2} = \text{SECS}$$

CALCULATION NO. ED-G2263-37324

SHEET 3 OF 3

THERMAL OVERLOAD

TER CALCULATION

REV. O

5/16/88

BOARD REF 480V

ACTOR MOV 50 CC COMPUTED BY DJL
UNIT # 2 LNO. CER2500-3 RE10 CHECKED BY THE DATE 3/17/88
COMP # 4C EQUIP REF. EECW N. HEADERS SECTIONALIZING VALVE. SCV-37.2

5/16/88

REV. I PREPARED: JPM 3-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

CHECKED: ORK 3-1-88

 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C0.78A
CR12360-71AOVERLOAD HEATER SETTING 105% 100%COMMENTS: RESET THE INSTALLED TOL HEATERS TO 105%
REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE.

CALCULATION NO. Q2268-87324 SHEET 9 .1 / 31
 THERMAL OVERLOAD HEATER CALCULATION REV. O DATE 8/16/88
 BOARD REF 480V REACTOR MOV BD 2C COMPUTED BY DJA DATE 8/16/88
 UNIT # 2 DWG. NO. 4582299-1, REL. 0 CHECKED BY TMC DATE 8/17/88
 COMP # 4E EQUIP REF. CRD WATER PRESSURE CONTROL VALVE PCV-85-27
 MOTOR OPERATED VALVE MOTORS
 WALKDOWN INPUT DATA: (REF # 3) REV. I PREPARED: JPM 8.1-88
 MOTOR CONTROL CENTER DATA:
 STARTER MFGR. GE MODEL CR109CO SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR125CO.60A SETTING 110 OA
102 OC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 2 ft# RPM 850 DUTY 15 min.S.F. -
 H.P. - VOLTS 460 FLC .45 LRA 1.48 PHASE 3 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.

(1) SEE SH. 9.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-54.3
TIME VS. CURRENT CURVE: REF # 1-54.5

DEFINITIONS

- RELAY
 I (t) -- HEATER TRIP CURRENT, MINIMUM
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 I* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. 22268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR MAX B.D. 20 COMPUTED BY DIA DATE 3/10/68
UNIT # 2 DWG. NO. 45B2259-10 REV. 0 CHECKED BY TMA DATE 3/17/68
COMP # 43 EQUIP REF. C.R.D. WATER PRESSURE CONTROL VALVE PCV-A5-27

SHEET 9 OF 31

REV. 0

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I_{\text{adjusted}} = \frac{V_{\text{nameplate}}}{V_{\text{operating}}} \times I_{\text{nameplate}}$$

$$I_{\text{adjusted}} =$$

FOR THIS CALCULATION $I_{\text{(n)}} = I_{\text{ADJUSTED}} =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-545) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 5.1

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 1.48 / 5.1 = 0.29$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 0.29 / 1.25 = 0.23 AMPSCATALOG HEATER SIZE CR123 CO.36A ZONE A
 $I_{\text{(n)}} = \frac{0.36}{0.23} = 0.29$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(n) \times 1.25 \times \frac{\%}{100} = \frac{0.36}{0.23} \times 1.25 \times \frac{100\%}{0.29}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (0.45 \text{ I}(n) / \frac{0.23}{0.36} \text{ I}(t)) \times 100 = \frac{1.15}{1.25} \approx 0.92 \text{ SECs}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2 \times 0.45 \text{ I}(n) / \frac{0.23}{0.36} \text{ I}(t)) \times 100 = \frac{2.31}{2.50} \approx 0.92 \text{ SECs}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(1.48 \text{ MTR LRA} / \frac{0.23}{0.36} \text{ I}(t)) \times 100 = \frac{4.11}{4.11} \approx 13.5 \text{ SECs}$$

NOTE: THIS IS THE SMALLEST HEATER SIZE AVAILABLE
AND IS THEREFORE ACCEPTABLE PER C.R.C. 87031

0050P

R1

CALCULATION NO. 7-Q2268-87324

THERMAL OVERLOAD

HEATER CALCULATION

SHEET 9.3

31

REV. 0

RE 2416145

BOARD REF 430 REACTOR MOV. BD 2C COMPUTED BY DFL DATE 3/16/88
 UNIT # 2 DWG. NO. 4SB2299-6 REV. 0 CHECKED BY TIR DATE 3/17/88
 COMP # 4E EQUIP. REF. CRD. WATER PRESSURE CONTROL VALVE PCV-55-27

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? REV. I PREPARED: JPM 8-1-88
 CHECKED: RX 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(a) \times 1.25 \times 7\% = 0.31 \times 1.25 \times 35\%$$

$$I(t) = 0.33 \text{ AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(2 \times 0.45) / 0.33 I(t) \times 100 = 136 : 3+32.300 \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE
 $(2 \times 0.45) / 0.33 I(t) \times 100 = 273 : 52.50 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(1.48 \text{ MTR LRA} / 0.33 I(t)) \times 100 = 448 : 11.5 \text{ 1/2 SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS (1) ASSUMPTION PER VENDOR DATA PROVIDED
IN EPASCO LETTER TO LIMITORQUE

DATED MARCH 18, 1988

*ACCEPTABLE PER QIREEB-87031 (REF. 5)
RIMS = 343 870293 903

CALCULATION NO. D-Q 2268-87324

THERMAL OVERLOAD WATER CALCULATION

BOARD REF 480A REACTOR MOV BD 2C COMPUTED BY DVL

UNIT # 2 DWG. NO. 45B2299-6 REV. O CHECKED BY TEC DATE 3/17/88

COMP # 4E EQUIP REF. CRD WATER PRESSURE CONTROL VALUE PCV-BS-27

SHEET 9.4 OF 31

REV. O

ATE 3/16/88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.✓ NO - REPLACE HEATER - PROCEED TO SECTION 5

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{I}{I} = \text{TRIP AMPS}$$

GR 2300.50A

$$I(t) = 0.52 \times I(n) \times 1.25 \times \frac{102}{I} =$$

I(t) = 0.52

$$I(t) = 0.52 \text{ AMPS}$$

ZONE A

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(0.45 \times I(n) / 0.52 \times I(t)) \times 100 = 60 \text{ : over } 900 \text{ SECS}$$
200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 0.45 \times I(n) / 0.52 \times I(t)) \times 100 = 136 \text{ : over } 900 \text{ SECS}$$
LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(1.48 \times \text{MTR LRA} / 0.52 \times I(t)) \times 100 = 324 \text{ : } 54.70 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 5✓ NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{I}{I} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{I}{I} = 0.52 \times 1.25 \times \frac{35\%}{I}$$

$$I(t) = 0.55 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(0.45 \times I(n) / 0.55 \times I(t)) \times 100 = 32 \text{ : over } 900 \text{ SECS}$$
200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 0.45 \times I(n) / 0.55 \times I(t)) \times 100 = 164 \text{ : over } 100 \text{ SECS}$$
LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(1.48 \times \text{MTR LRA} / 0.55 \times I(t)) \times 100 = 267 \text{ : } 53.50 \text{ SECS}$$

CALCULATION NO. ED-Q2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480A FACTOR MCV BD 2C COMPUTED BY D.W. DATE 3/16/55

UNIT # 1 DWG. NO. 45B2299-6 REV. O CHECKED BY TGS DATE 3/17/PP

COMP # 4E EQUIP REF. CRD WATER PRESSURE CONTROL VALVE PCV-85-27

REV. I PREPARED: JPM 8-1-88

CHECKED: RK 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 C 0.36A

OVERLOAD HEATER SETTING 85% 100%

COMMENTS: REPLACE THE INSTALLED TOL HEATERS
WITH THOSE SHOWN ABOVE.

CALCULATION NO. ED-Q2268-37324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 480 FACTOR M&V 25 1- COMPUTED BY DJU DATE 3/16/88
 UNIT # 2 DWG. NO. 46B2299-6 REV. 0 CHECKED BY JHJ DATE 3/17/88
 COMP # 53 EQUIP REF. BJS HT. EACH. ALT. CLK & HYDR. CLG. WTR. SPLITTER M34 FCY-24-25
 MOTOR OPERATED VALVE MOTORS

SHEET 1 OF 1 / 31
 REV. 0 RE 3/16/88
 DATE 3/16/88

WALKDOWN INPUT DATA: (REF # 3)

REV. I PREPARED: JPM 8-1-88
CHECKED: RK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR10960 SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C0.39A SETTING 100% OA
 98% OC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 2 ft# RPM 1725 DUTY 15 min.S.F. -
 H.P. 1/3 VOLTS 440 FLC 7 LRA 2.6 1 PHASE 3 INS. CLASS B ①
 NEC CODE LETTER — TEMP RISE 75 deg C.

① SEE SH.10.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1 - SH.8

TIME VS. CURRENT CURVE: REF # 1 - SH.5

DEFINITIONS

- I (t) -- HEATER TRIP CURRENT / MINIMUM
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- ** PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2264-27324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V

FACTOR M₂/I F5 2C COMPUTED BY D.J.L. DATE 3/11/88
UNIT # 2 DWG. NO. 45B2299-6 REV. O CHECKED BY TES DATE 3/11/88
COMP # 5B EQUIP REF. BUS 4T. EYCH. ALT.CLR. E HYDR. CLS. WTR. SLO. TJA MUL FCL-24-25

SHEET 10.2 OF 11

REV. O

E 3/11/88

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) = \frac{440 \times .7}{460} = .67$$

FOR THIS CALCULATION I (n) = I ADJUSTED = .67 AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\text{HP} \times \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-54-5) LOCATE THE 13 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = \frac{2.6}{6.25} = \frac{.54}{.42}$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT/1.25 = .43 / 1.25 = .34 AMPS

CATALOG HEATER SIZE CR12360-46A CO.39A
I(m) .43 0.39 0.32 ZONE S

RELAY

3PM 7/11/88

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$\therefore I(t) = I(m) \times 1.25 \times \% = \frac{.43}{.42} \times 1.25 \times \frac{100\%}{100\%}$$

$$I(t) = \frac{.54}{.42} \text{ AMPS}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:

$$(.67 \text{ I(n)} / \frac{.54}{.42} \text{ I(t)}) \times 100 = \frac{12.4\%}{13.7\%} \text{ OVER } 920 \text{ SECs}$$

200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times .67 \text{ I(n)} / \frac{.54}{.42} \text{ I(t)}) \times 100 = \frac{34.8\%}{27.3\%} \text{ 41 - } \frac{1}{2} \text{ SECs}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2.6 \text{ MTR LRA} / \frac{.54}{.42} \text{ I(t)}) \times 100 = \frac{48.4\%}{53\%} \text{ 10 - } \frac{1}{2} \text{ SECs}$$

CALCULATION NO. ED-22265-37524
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 480 FACTOR MOV BD 2C COMPUTED BY DIA DATE 3/14/88
 UNIT # 2 DWG. NO. 45B2229-6 REV. O CHECKED BY TMB DATE 3/17/88
 COMP # 5B EQUIP REF. 3VSHT. EXCH. ALT CLR. & HYD. CLG. WTR. SHUT OFF 140V REV. 24-25
 REV. I PREPARED: JPM -88
 ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? CHECKED: RK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{**}{**} = .43 \times 1.25 \times 95\%$$

$$I(t) = .51 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE. (TRIP TIME)

$$(2 \times .57 - I(n)) / .51 \quad I(t) \times 100 = 121 \approx \text{OVER } 900 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE

$$(2 \times .57 - I(n)) / .51 \quad I(t) \times 100 = 262 \approx 37.55 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times .6 - MTR LRA) / .51 \quad I(t) \times 100 = 510 \approx 9.2 - 15 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS (1) ASSUMPTIONS PER CRANE TELEDYNE DWG. N2

T-12942-3 ISSUED UNDER CONTRACT # 70C55-92272-1

47A368-24-2 REV. O. THE FULL LOAD CURRENT SHOWN

ON THE VENDOR DWG. IS LESS THAN THAT GIVEN IN THE WALKDOWN DATA; THEREFORE, USE OF THE LOCKED ROTOR CURRENT FROM THE VENDOR DRAWING IN THIS CALCULATION WILL BE CONSERVATIVE.

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

ATE 3/16/88

BOARD REF 480

FACTOR M_{AV} BD 2C

COMPUTED BY

ATE 3/16/88

UNIT # 2

DWG. NO. 45B2299-6 REV. O

CHECKED BY

DATE 3/17/88

COMP # 58

EQUIP REF. 3.5 HT. EXCH. A-T CLR. & HYDR. CLG. WTR. S-A THERM. FGR. FGR. 24-25

REV. I

PREDARED: JPM 8.1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHECKED: RKB 8-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.~~REPLACE HEATER PROCEED TO SECTION 5 3/17/88~~ NO PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{I}{I(n)} = \text{TRIP AMPS}$$

ER123-60-39A

$$I(t) = .34 \quad I(n) \times 1.25 \times \frac{I}{I(n)} = \text{TRIP AMPS}$$

I_n = .34

$$I(t) = .43 \quad \text{AMPS}$$

B-zone

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{.67}{.67} \right) I(n) / \frac{.43}{.43} I(t) \times 100 = \frac{150}{150} \text{ % OVER 140 SEGS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{2 \times .67}{.67} \right) I(n) / \frac{.43}{.43} I(t) \times 100 = \frac{312}{312} \text{ % } 30.55 \text{ SEGS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\left(\frac{2.6}{2.6} \right) \text{ MTR LRA} / \frac{.43}{.43} I(t) \times 100 = \frac{605}{605} \text{ % } 11.10 \text{ SEGS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5. NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{I}{I(n)} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{I}{I(n)} = .34 \times 1.25 \times .75\% = .2625$$

$$I(t) = .40 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{.67}{.67} \right) I(n) / \frac{.40}{.40} I(t) \times 100 = \frac{160}{160} \text{ % } \text{OVER 140 SEGS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{2 \times .67}{.67} \right) I(n) / \frac{.40}{.40} I(t) \times 100 = \frac{335}{335} \text{ % } 32.47 \text{ SEGS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\left(\frac{2.6}{2.6} \right) \text{ MTR LRA} / \frac{.40}{.40} I(t) \times 100 = \frac{650}{650} \text{ % } 9.6 - 14.2 \text{ SEGS}$$

THERMAL OVERLOAD HEATER CALCULATION

REV. O

E 311W4

BOARD REF 480 FACTOR MAX FSD 2C COMPUTED BY TIA

IE 311W4

UNIT # 2 WNG. NO. 45B2259-6 REV. O CHECKED BY TIA

DATE 3/16/88

COMP # 53 EQUIP REF. BUS UT EACH ALT CLR. HYDR. GIG WTR. SHUTOFF MAX FCU-24-25

REV. 1 PREPARED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

CHECKED: ORK 8-1-88

DO NOT

DELETE
JPM 7/19/88 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE ^{JPM} 60.48A 7/19/88 CR123 60+32A C0.39AOVERLOAD HEATER SETTING 95% 100%COMMENTS: RESET THE INSTALLED TOL HEATERS TO 95%REPLACE THE INSTALLED TOL HEATERS ^{JPM} 7/19/88
AS SHOWN ABOVE ^{JPM} 7/19/88RESET THE INSTALLED TOL HEATERS TO 100%

CALCULATION NO. E-022268-37324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 430X FACTOR MOV ED. 2C COMPUTED BY DIAL DATE 3/11/88
 UNIT # 2 DWG. NO. 42512299-6 REV. D CHECKED BY THB - DATE 3/11/88
 COMP # 5C EQUIP REP. CLOSED COOLING WATER SPARE PUMP SECTION VALUE
 MOTOR OPERATED VALVE MOTORS
 PREPARED: JMW 3-1-88
 WALKDOWN INPUT DATA: (REF # 3) CHECKED: RK 3-1-88
 SCY-70587

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR10940 SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C1.09A SETTING 100%

MOTOR NAMEPLATE DATA:

STARTING TORQUE 120 ① ft# RPM 29 DUTY 15 min. S.P.
 H.P. 0.6 ① VOLTS 460 FLC 2.1 ① LRA 7.8 ① PHASE 3 INS. CLASSIS —
 NEC CODE LETTER — TEMP RISE — deg C.

① SEE SH. II. 3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1. SH. 8
 TIME .VS. CURRENT CURVE: REF# 1. SH. 5

DEFINITIONS

RELAY
 I (t) -- HEATER TRIP CURRENT MINIMUM
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 %* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR. NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q 2265-37324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 490 FACTOR AND FD SC COMPUTED BY DHL 3-21-1988
 UNIT # 2 DWG. NO. 45B2299-6 REV. 0 CHECKED BY TMB DATE 3-17-1988
 COMP # 5C EQUIP REF. CLOSED COOLING WATER SPARE PUMP GATE VALVE

SHEET 11.2 OF 1

REV. 0

CALCULATIONS:

REV. I PREPARED: JWA 3-7-88
CHECKED: EK 3-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} =$ AMPSE

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\begin{aligned} LRA &= (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460) \\ LRA &= \underline{\quad} \text{AMPS} \end{aligned}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1.54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

TRIP CURRENT = (LRA) / (MULTIPLE OF CURRENT RATING)

$$\text{TRIP CURRENT} = 7.8 / 6.25 = 1.25$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 1.25 / 1.25 = 1.0 AMPS

CATALOG HEATER SIZE C2123 C1.16A ZONE 6

$$I(m) \quad \frac{+24}{+24} \quad 0.95$$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$\begin{aligned} I(t) &= I(m) \times 1.25 \times \frac{100}{100} = \frac{+24}{+24} \times 1.25 \times \frac{100\%}{100\%} \\ I(t) &= \frac{+24}{1.19} \text{ AMPS} \end{aligned}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(\underline{2.1} \text{ I}(n) / \frac{+24}{1.19} \text{ I}(t)) \times 100 = \frac{+63}{176} \approx \frac{220+40}{176} \text{ SECS}$

(TRIP TIME)

OVER 9'00

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \underline{2.1} \text{ I}(n) / \frac{+24}{1.19} \text{ I}(t)) \times 100 = \frac{323}{353} \approx \frac{25+5}{353} \text{ SECS}$

29.42

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\underline{7.8} \text{ MTR LRA} / \frac{+24}{1.19} \text{ I}(t)) \times 100 = \frac{602}{655} \approx \frac{4+1}{655} \text{ SECS}$$

9.5 - 14.0

CALCULATION NO. ED-Q2269-97324
THERMAL OVERLOAD HEATER CALCULATION
BOARD REF 430

FACTOR NOV BD 2C COMPUTED BY DJL DATE 3/16/88
UNIT # 2 DWG. NO. 45B2299-6 REV. 0 CHECKED BY JAS DATE 3/17/88
COMP # 5C EQUIP REF. CLOSED COOLING WATER 2 SPARE PUMP SUCTION VALVE

SHEET 11.3 - 31

REV. O

TE 3/16/88

DATE 3/16/88

DATE 3/17/88

REV. I
ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

FCV-70-67

PREPARED: JPM 8-1-88
CHECKED: JPK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN
PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING
TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{78}{100} = 1.04 \times 1.25 \times \underline{95\%}$$
$$I(t) = \underline{1.24} \text{ AMPS}$$

100% MOTOR PLUG TO HEATER CURRENT BASE: (TRIP TIME)
 $(2 \times 1.24) / 1.24 I(t) \times 100 = 169 \text{ } \frac{\text{SECS}}{\text{OVER 14 SECS}}$

200% MOTOR PLUG TO HEATER CURRENT BASE
 $(2 \times 2.1) / 1.24 I(t) \times 100 = 339 \text{ } \frac{\text{SECS}}{32.45 \text{ SECS}}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(7.8 \text{ MTR LRA}) / 1.24 I(t) \times 100 = 529 \text{ } \frac{\text{SECS}}{10.3-15 \text{ SECS}}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE
OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY
SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREB07031 FOR INSTRUCTIONS CONCERNING
ACCEPTANCE CRITERIA.

COMMENTS (1) ASSUMPTION PER REF. #2 - ROTORK CONTROLS INC

BASED ON SPEED OF 29 RPM

CALCULATION NO. ED-Q2268-87324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 480V ACTOR PAU BD 2C COMPUTED BY DIL DATE 3/16/88
 UNIT # 2 DWG. NO. 45R2299-6 FEU.O CHECKED BY MMJ3 DATE 3/17/88
 COMP # 5C EQUIP REF. CLOSED COOLING WATER SPARE PUMP SECTION VALUE

SHEET 11.4 OF 31

REV. O

FE 3/16/88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

REV. I

FCV-70-07

PREPARED: JPM 8-1-
CHECKED: RK 8-1-

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 1.23 \times 1.25 \times \frac{1}{2} = 0.775$$

$$I(t) = 0.94 \text{ AMPS}$$

$$I(t) = 0.94$$

$$I(t) = 0.94$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ MTR LRA}) / 1.13 \text{ I}(t) \times 100 = 178 \text{ SECS}$$

(TRIP TIME)

178 : 125 = 1.40 SECS

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ MTR LRA}) / 1.13 \text{ I}(t) \times 100 = 356 \text{ SECS}$$

356 : 29.42 = 12.0 SECS

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times 7.8 \text{ MTR LRA}) / 1.13 \text{ I}(t) \times 100 = 661 \text{ SECS}$$

661 : 9.4 = 71.3 SECS

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.

NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 1.23 \times 1.25 \times \frac{1}{2} = 0.94 \times 1.25 = 1.1875$$

$$I(t) = 1.23 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ MTR LRA}) / 1.23 \text{ I}(t) \times 100 = 171 \text{ SECS}$$

(TRIP TIME)

171 : over 140 SECS

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ MTR LRA}) / 1.23 \text{ I}(t) \times 100 = 341 \text{ SECS}$$

341 : 32 = 10.6 SECS

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times 7.8 \text{ MTR LRA}) / 1.23 \text{ I}(t) \times 100 = 621 \text{ SECS}$$

621 : 10 = 62.1 SECS

CALCULATION NO. ED-G 2268-87524

THRMAL OVERLOAD WATER CALCULATION

BOARD REF 480 FACTOR MAX BD 2C COMPUTED BY DIA TE 3/14/88
UNIT # 2 WNG. NO. 15B2299-6 REV. 0 CHECKED BY TBS DATE 3/13/88
COMP # 5C EQUIP REF. CLOSED COOLING WATER SPARE PUMP EJECTION VALVE

SHEET 11.5 OF 31

REV. 0

TE 3/14/88

TE 3/14/88

DATE 3/13/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE? REV. 1 | PREPARED: 9PM 7-8-88
CHECKED: VRK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 9.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C 1.18A
CR123 ± 0.9A

OVERLOAD HEATER SETTING +05% 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 105%
REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE,

CALCULATION NO. ED-Q2263-37324

THERMAL OVERLOAD STARTER CALCULATION

BOARD REF 430A FACTOR NOV FED 2G - COMPUTED BY A1 DATE 2/11/85
UNIT # 2 DWG. NO. 45B2299.6 REV. O CHECKED BY FMS DATE 2/7/88
COMP # 5E EQUIP REF. CRD-PMA-2-A SECTION ISOLATED ALM FED-35-65

SHEET 10.1 OF 11

REV. O

E 911047

MOTOR OPERATED VALVE MOTORS

REV. I

RECD BY: FM 3-1-88

WALKDOWN INPUT DATA: (REF # 3)

FILED: FM 3-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR 3920 SIZE
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C1 312 SETTING 85% OA
 150% OC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 5 ft# RPM 1725 DUTY 15 min. S.Z. -
 H.P. 330 VOLTS 460 FLC .95 LRA 5.10 PHASE 2 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.

(1) SEE 214-193

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-SH. 8

TIME VS. CURRENT CURVE: REF # 1-SH. 5

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT /MINIMUM
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG / ZELAY TRIP
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- Z* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q226A-3724
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 420 SEACT. 4115V SD 2C COMPUTED BY D.L. REV. O DATE 7/14/48
 UNIT # 2 DWG. NO. 4532299.6, REV. O CHECKED BY MAB DATE 7/14/58
 COMP # 5E EQUIP REF. C.R.D. Hump A SUCTION ISOLATION VALVE F.C.V. 25-65

SHEET 12.2 OF 31
 REV. O

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
 IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate}) \times I(\text{nameplate})}{V(\text{operating})}$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(a) = I \text{ ADJUSTED} =$ _____ AMPS.

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\begin{aligned} \text{LRA} &= (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460) \\ \text{LRA} &= \underline{\quad} \text{AMPS} \end{aligned}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF. I-SH.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
 RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 5.1 / 6.25 = .82$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
 HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = .62 / 1.25 = .50 AMPS

CATALOG HEATER SIZE CR123 50.78A 3' ZONE

$$I(a) = \frac{.62}{0.79} = 0.63$$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$\begin{aligned} I(t) &= I(m) \times 1.25 \times \% = \frac{.62}{0.79} \times 1.25 \times 100\% \\ I(t) &= \frac{.62}{0.79} \text{ AMPS} = 0.63 \end{aligned}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (\frac{.95}{0.79} I(a) / \frac{.25}{0.79} I(t)) \times 100 = \frac{110}{120} = \frac{11}{12} \text{ SECS}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2 \times \frac{.95}{0.79} I(a) / \frac{.25}{0.79} I(t)) \times 100 = \frac{420}{241} = \frac{82.4}{66.5} \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } (\frac{5.1}{0.79} \text{ MTR LRA} / \frac{.25}{0.79} I(t)) \times 100 = \frac{593}{646} = \frac{11.3}{9.8} = 1.15 \text{ SECS}$$

THERMAL OVERLOAD HEATER CALCULATION

REV. O

ATE 3/16/88

BOARD REF 48 REACTOR M&V BD 2C COMPUTED BY D.J.L ATE 3/16/88
UNIT # 2 DWG. NO. 45P2299.6 REV. O CHECKED BY JAS DATE 3/17/88
COMP # 5E EQUIP REF. CRD PUMP A SUCTION ISOLATION VALVE FCV-67-21ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?REV. I PREPARED: JAM 8-1-88
CHECKED: JRK 8-1-88 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) * 1.25 * \frac{75}{100} = .69 * 1.25 * \frac{95\%}{100}$$

$$I(t) = .82 \text{ AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(2 \times .75 I(n) / .82 I(t)) * 100 = 116 \approx 12 \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE

$$(2 \times .75 I(n) / .82 I(t)) * 100 = 332 \approx 74.96 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(5.1 \text{ MIR IRAI} / .82 I(t)) * 100 = 622 \approx 10.5 - 15.3 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE? YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIACOMMENTS (1) ASSUMPTION BASED ON COMPARISON OF ELEC.CHARACTERISTICS OF FCV-67-21 COMPT. 4C, AND
DWG. 15-477-3292-3.

CALCULATION NO. ED-C42263-37324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 430 FACTOR 4 MCV P.D. 2C COMPUTED BY DYL DATE 3/16/88
UNIT # 2 Dwg. No. 45B2299-1 REV. O CHECKED BY TBS DATE 3/16/88
COMP # 5E EQUIP REF. CRD PUMP A SUCTION ISOLATION VALVE FCY-35-65

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REV. 1 PREPARED: JPM 8-1-88
CHECKED: WRK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 <0.78A

OVERLOAD HEATER SETTING 95% 100%

COMMENTS: REPLACE THE INSTALLED TOL HEATERS WITH
THOSE SHOWN ABOVE.

CALCULATION NO. ED-G-2202-37324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 430 FACTOR MOV 50-20 COMPUTED BY DJA DATE 3/16/85
 UNIT 1-2 DWG. NO. 45P2299-6 REV. O CHECKED BY TMS DATE 3/17/85
 COMP # 63 EQUIP. REF. STATER 50HP COOLING WATER SHUT-OFF MCY FCB-24-41
 MOTOR OPERATED VALVE MOTORS
 REV. I PREPARED: JPM 8-1-88
 WALKDOWN INPUT DATA: (REF # 3) CHECKED: RK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR10920 SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 CO. 29A SETTING 115%

MOTOR NAMEPLATE DATA:

STARTING TORQUE 2 ft# RPM 1725 DUTY 15 min.S.F.
 H.P. 133 VOLTS 440 FLC 7 LRA 2.6 PHASE 3 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.
 (1) SEE SH. 13-3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-SH. B
 TIME VS. CURRENT CURVE: REF # 1-514.5

DEFINITIONS

RELAY
 I (t) -- HEATER TRIP CURRENT / MINIMUM
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 % -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEE87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2268-37324 SHEET 15.2 OF 1
 THERMAL OVERLOAD WATER CALCULATION REV. O E 3-11-88
 BOARD REF 480 FACTOR MOV ED. 2C COMPUTED BY DHL E 3-11-88
 UNIT 2 DWG. NO. 45B2299-L REL. 0 CHECKED BY THS DATE 3-11-88
 COMP 63 EQUIP REF. STATOR & LIQUID COOLING WATER SHUT-OFF 3-11-88-61

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
 IF YES;

$$I \text{ (adjusted)} = \frac{V \text{ (nameplate)}}{V \text{ (operating)}} \times I \text{ (nameplate)}$$

$$I \text{ (adjusted)} = \frac{440 \times .7}{460} = .67$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} = .67$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
 RECORD VALUE 5.4 6.25

TRIP CURRENT = (LRA) / (MULTIPLE OF CURRENT RATING)

$$\text{TRIP CURRENT} = \frac{2.6}{5.4} = \frac{.54}{6.25} = .42$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
 HEATER SELECTION CURRENT = TRIP CURRENT/1.25 = .42/1.25 : 3.36Amps

CATALOG HEATER SIZE C 2 1 2 3 6 0 - 1 8 A C 0.39 A 1.5' Zone 3
 $I(m) = \frac{.42}{.43} = \frac{0.39}{0.32} = \frac{1.5'}{1.5'}$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100}{100} = \frac{.42}{0.40} \times 1.25 \times \frac{100\%}{0.32}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (\underline{.67} \text{ I(n) / } \frac{.54}{0.40} \text{ I(t))} \times 100 = \frac{.67}{0.40} \times \frac{100\%}{0.32} \text{ OVER } 0.0 \text{ SECS}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2 \times \underline{.67} \text{ I(n) / } \frac{.54}{0.40} \text{ I(t))} \times 100 = \frac{1.34}{0.40} \times \frac{100\%}{0.32} \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } 335 \text{ A } \frac{1.34}{0.40} \times \frac{100\%}{0.32} \text{ SECS}$$

$$(\underline{2.6} \text{ MTR LRA / } \frac{.54}{0.40} \text{ I(t))} \times 100 = \frac{6.5}{0.40} \times \frac{100\%}{0.32} \text{ SECS}$$

CALCULATION NO. ED-Q22GD-B7324

THERMAL OVERLOAD

BOARD REF 480

UNIT # 2

COMP # 6B

HEATER CALCULATION

FACTOR NO. V B D Z C COMPUTED BY DIA

DWG. NO. 45B2299.6 REV. O CHECKED BY TAB

EQUIP REF. 5140K LIQUID COOLING WATER SHUT-OFF VALVE FCV-24-41

SHEET 13.1 OF 1

REV. O

DATE 2/14/88

REV. DATE 2/14/88

CHECKED DATE 2/14/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

PREPARED: GOW R-1-88
CHECKED: EFK E-1-88 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times 78 = .43 \times 1.25 \times 95\% \\ I(t) = .51 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(1.67 I(n) / .51 I(t)) \times 100 = 121 : \text{TRIP TIME}$$

200% MOTOR PLC TO HEATER CURRENT BASE

$$(2 \times 1.67 I(n) / .51 I(t)) \times 100 = 202 : \text{TRIP TIME}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2.0 MTR IRA / .51 I(t)) \times 100 = 510 : \text{TRIP TIME}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREPB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER CRANE TELE DYNE INC. NO.

T-12942-3 ISSUED UNDER CONTRACT # 70055-92272-1

47A368-24-2 REV. O. THE FULL LOAD CURRENT SHOWN

ON THE VENDOR DWG IS LESS THAN THAT GIVEN IN THE WALKDOWN DATA; THEREFORE, USE OF THE LOCKED ROTOR CURRENT FROM THE VENDOR DRAWING IN THIS CALCULATION WILL BE CONSERVATIVE.

0050P

CALCULATION NO. ED-G2268-87324

SHEET 13.4 OF 21

THERMAL OVERLOAD

TER CALCULATION

REV. O

E 3/16/88

BOARD REF 480V

ACTR NOV BD 2C

COMPUTED BY DIA

E 3/16/88

UNIT # 2

DWG. NO. 45B2299-6 REV. O

CHECKED BY TUES

DATE 3/17/88

COMP # 68

EQUIP REF. STATIC LIQUID COOLING WATER SL/TUFF M4V EG4-24-41

REV. I PREPARED: JPM 3-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHECKED: RK 3-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

~~REPLACE HEATER PROCEED TO SECTION 5~~ 3PM 7/17/88

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

GR-123-0097A

$$I(t) = .34 I(n) \times 1.25 \times \frac{1}{2} = .34$$

I(n) = .34

$$I(t) = .19 \text{ AMPS}$$

B-0097

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / (.49 I(t)) \times 100 = 137 \approx 200-900 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / (.49 I(t)) \times 100 = 273 \approx 50-67 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times .67) MTR LRA / (.49 I(t)) \times 100 = 531 \approx 14-21 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.

NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = .34 \times 1.25 \times \frac{1}{2} = .35$$

$$I(t) = .40 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / (.40 I(t)) \times 100 = 168 \approx 200-140 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / (.40 I(t)) \times 100 = 335 \approx 30-47 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times .67) MTR LRA / (.40 I(t)) \times 100 = 660 \approx 9.6-14.8 \text{ SECS}$$

0050P

CALCULATION NO. ED-52263-B7E24

THERMAL OVERLOAD

BOARD REF 450W

UNIT # 2

COMP # 6B

WATER CALCULATION

FACTOR 1.15V 3D 2C

DWG. NO. 4532299.6

REV. 0

CHECKED BY

EQU'P REF. STATOR LIQUID COOLING WATER SUITABILITY

DATE 3/16/88

REVIEW DATE 3/17/88

PREPARED: JPM 8-1-88

CHICKEN: WRK 8-1-88

DATE 3/17/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND

IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL

BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD

HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE

CO.48A

CR12260.39A CO.39

OVERLOAD HEATER SETTING

95% 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 95%

REPLACE THE INSTALLED TOL HEATERS AS

DO NOT

DISPOSE

3 PM 7/13/88

SHOWN ABOVE

3 PM

7/13/88

RESET THE INSTALLED TOL HEATERS TO 100%

0050P

CALCULATION NO. ED-Q2263-87524

SHEET 14.1

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 480V

FACTORS

NAME PLATE

2C

COMPUTED BY DIA

DATE 3/16/88

UNIT 1-2

DWG. NO 45B2299-6

REV. O

CHECKED BY THIS

DATE 3/17/88

COMP # GC

EQUIP REF. CLOSERD CLG WTR SPARE PUMP DISCH VLV. FCV-70-68

MOTOR OPERATED VALVE MOTORS

REV. I

PREPARED: JPM 3-1-88

WALKDOWN INPUT DATA: (REF # 3)

CHECKED: WRK 3-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR109 CO SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C1.05A SETTING 100%¹

MOTOR NAMEPLATE DATA:

STARTING TORQUE 120(1) ft-lb RPM 29 DUTY 15 min.S.P.
 H.P. 0.6(1) VOLTS 460 FLC 7.1(1) LRA 7.9(1) PHASE 3 INS. CLASS
 NEC CODE LETTER - TEMP RISE - deg C.

(1) SEE SH. 14.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-SH. 8
 TIME .VS. CURRENT CURVE: REF# 1-SH. 5

DEFINITIONSRELAY

- I (t) -- HEATER TRIP CURRENT MINIMUM
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY TRIP
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- ¹* PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
 MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
 REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. EN-Q2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V

UNIT 1

COMP 6

ACTOR MOU. SD 2C

DWG. NO. 45B2299-6 REV. O

EQUIP REF. CLOSED CLG. WTR. SPARE PUMP DISCH. VLV. FCV-70-68

SHEET 14.2

REV. O

RE 3/16/88

DATE 3/16/88

TJB DATE 3/17/88

FCV-70-68

CALCULATIONS:REV. I PREPARED: JPM 8-1-88
CHECKED: RK 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1.54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

TRIP CURRENT = (LRA) / (MULTIPLE OF CURRENT RATING)

$$\text{TRIP CURRENT} = 7.3 / 6.25 = 1.25$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 1.25 / 1.25 = 1.0 AMPS
CATALOG HEATER SIZE CR123 C1.15A

$$I(m) = \underline{\quad} + \underline{\quad} = 0.95$$

B' ZONE

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{\%}{100} = \frac{+0.4}{1.19} \times 1.25 \times 100\%$$

$$I(t) = \underline{\quad} \text{AMPS} \quad \underline{\quad} \text{0.95}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(\underline{2.1} \text{ I}(n) / \underline{1.19} \text{ I}(t)) \times 100 = \frac{+6.2}{1.76} \% = \frac{+6.2}{1.76} \text{ SECS}$
~~OVER 140~~ SECS

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \underline{2.1} \text{ I}(n) / \underline{1.19} \text{ I}(t)) \times 100 = \frac{+12.4}{3.53} \% = \frac{+12.4}{3.53} \text{ SECS}$
~~25-60~~ SECS

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\underline{7.3} \text{ MTR LRA} / \underline{1.19} \text{ I}(t)) \times 100 = \frac{+6.2}{6.55} \% = \frac{+6.2}{6.55} \text{ SECS}$$

~~9.5-14.0~~ SECS

0050P

CALCULATION NO. F-GL268-87324

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 480V

ACTOR NO. 111 FSD 2C

COMPUTED BY D.L. DATE 3/16/88

UNIT # 2

DWG. NO. J5B2299.6 REV. O CHECKED BY TBS DATE 3/17/88

COMP # GC

EQUIP REF. CLOSED CLG.WTR. SPARE PUMP DISCH. VLV. FCV. 70-68

REV. I PREPARED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? CHECKED: JRK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(a) \times 1.25 \times \frac{7}{8} = 1.24 \times 1.25 \times 95\%$$

$$100\% \text{ MOTOR FLG TO HEATER CURRENT BASE: } (2 \times 1.24) \times 100 = 248 : 228.45 \text{ SEGS}$$

$$200\% \text{ MOTOR FLG TO HEATER CURRENT BASE: } (2 \times 2.1 \times 1.24) \times 100 = 529 : 228.45 \text{ SEGS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2.1 \times 1.24) \times 100 = 529 : 128.15 \text{ SEGS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER REF # 2 ROTORK CONTROLS INC

BASED ON SPEED OF 29 RPM

CALCULATION NO. 30-Q2268-37324
 THERMAL OVERLOAD
 BOARD REF 430
 UNIT # 2
 COMP # GC

EATER CALCULATION
 FACTOR MAX BD. 2C COMPUTED BY DIA
 DWG. NO. 45B2299-6 REV. 0 CHECKED BY FIA DATE 3/16/88
 EQUIP REF. CLOSED CLG WTR SPACE PUMP DISCH. V.V REV. 7-2-63

SHEET 14.4 / 21

REV. 0

TE 3/16/88

ATE 3/16/88

FIA DATE 3/17/88

REV. I PREPARED: 1PM 8-1-88

CHECKED: FAK 8-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER
 IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = .94 \quad I(n) \times 1.25 \times \frac{1}{2} = .44$$

$$I(t) = 1.18 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(2 \times 2.1) \quad I(n) / 1.18 \quad I(t) \times 100 = 173 : 135 + 1.0 \quad \text{SECS}$

200% MOTOR PLC TO HEATER CURRENT BASE:
 $(2 \times 2.1) \quad I(n) / 1.18 \quad I(t) \times 100 = 356 : 29 - 45 \quad \text{SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(7.8) \quad \text{MTR-LRA} / 1.18 \quad I(t) \times 100 = 6(0) : 9.4 - 13.3 \quad \text{SECS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.

NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = .94 \times 1.25 \times 105\%$$

$$I(t) = 1.23 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(2 \times 2.1) \quad I(n) / 1.23 \quad I(t) \times 100 = 171 : 162 + 1.2 \quad \text{SECS}$

200% MOTOR PLC TO HEATER CURRENT BASE:
 $(2 \times 2.1) \quad I(n) / 1.23 \quad I(t) \times 100 = 341 : 36 - 45 \quad \text{SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(7.8) \quad \text{MTR-LRA} / 1.23 \quad I(t) \times 100 = 6(3) : 10 - 14 \quad \text{SECS}$

CALCULATION NO. ED-52268-37324

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 480V

ACT/R MAY 82

SHEET 14.5 OF 71

REV. O

3/16/88

UNIT # 2

DWG. NO. 45B2299-10

COMPUTED BY DJA

3/16/88

COMP # GC

EQUIP REF. CLNGD CLG WTR SPARE PUMP DSGN Y14 FCL-75-68

REV. 1 PREPARED: JPM 3-1-88

CHECKED: RK 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

51169 NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

C 1.18A

OVERLOAD HEATER SIZE CR123 E1.05A

OVERLOAD HEATER SETTING 105% 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 105%

REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE

CALCULATION NO. ED-G2268-37324

THERMAL OVERLOAD

HEATER CALCULATION

BOARD REF 480V

ACTOR MAIN SD 20

SHEET 15.1

REV. O

3:

DATE 3/16/88

UNIT # 2

DWG. NO. 4582299-G REV. O

COMPUTED BY D.L.C.

DATE 3/16/88

COMP # GE

EQUIP REF. MAIN STEAM LINE DEAN VALVE

CHECKED BY MJS

DATE 3/17/88

MOTOR OPERATED VALVE MOTORS

WALKDOWN INPUT DATA: (REF # 3)

REV. I

PREPARED: JPM 8-1-88

CHECKED: RK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR109CO SIZE 1
 O/L RELAY TYPE CR123 HEATER SIZE CR123 C1.36A SETTING 90 OA
93 °C

MOTOR NAMEPLATE DATA:

STARTING TORQUE 7.5 ft# RPM 1700 DUTY 15 min.S.P. —
 H.P. 0.5 ① VOLTS 460 FLC 2.3 LRA 10.9 ① PHASE 3 INS. CLASS —
 NEC CODE LETTER — TEMP RISE 75 deg C.

MANUFACTURER'S DATA:HEATER TABLE: REF # 1- SH. 8TIME .VS. CURRENT CURVE: REF# 1- SH. 5

① SEE SH. 15.3

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT MINIMUM
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- % PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
 MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
 REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-GP22292-37324

THERMAL OVERLOAD

BOARD REF 4300

UNIT # 2

COMP # GE

HEATER CALCULATION

FACTORY M&V BD. 2C

DWG. NO. 4GP32292-6 REV. O

EQUIP REF. MAIN STEAM LINE DRAIN VALVE

SHEET 15.2 / 31

REV. O

DATE 3/16/88

COMPUTED BY DJW

DATE 3/16/88

CHECKED BY T4B

DATE 3/17/88

CALCULATIONS:

REV. I

PREPARED: JPM 8-1-88

CHECKED: VRK 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-S4.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 10.9 / 6.25 = 1.74$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 1.74 / 1.25 = 1.40 AMPSCATALOG HEATER SIZE CR123 C1.63A 'B' ZONE 2
 $I(m) = \frac{1.47}{1.64} \quad \frac{1.31}{1.31}$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{1.47}{1.64} = \frac{1.47}{1.64} \times 1.25 \times \frac{100\%}{1.31}$$

$$I(t) = \frac{1.84}{1.64} \text{ AMPS}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2.3 \text{ I}(n) / \frac{1.84}{1.64} \text{ I}(t)) \times 100 = \underline{\quad} \% \text{ OVER } 900 \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times 2.3 \text{ I}(n) / \frac{1.84}{1.64} \text{ I}(t)) \times 100 = \frac{250}{280} : \frac{42-82}{47-65} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\frac{10.9}{1.64} \text{ MTR LRA} / \frac{1.84}{1.64} \text{ I}(t)) \times 100 = \frac{1592}{665} : \frac{11-5-17}{9-2-13-5} \text{ SECS}$$

0050P

CALCULATION NO. ED-52268-37584

THERMAL OVERLOAD

MASTER CALCULATION

BOARD REF 480

FACTOR MAX 50 %

COMPUTED BY DYL

SHEET 15.3

REV. O

E

2/16/88

UNIT # 2

DWG. NO. 45B2299-6 REV. O

CHECKED BY JHG

FEB

2/17/88

COMP # 2E

EQUIP REP. MAIN STEAM LINE DRAIN VALVE

DATE 3/17/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

REV. I

PREPARED:

JUN

2-7-88

CHECKED:

FEB

2-1-88

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{75}{100} = 1.47 \times 1.25 \times 95\%$$

$$I(t) = 1.75 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\frac{2.3}{2.3} I(n) / 1.75 I(t) \times 100 = 131 \text{ % } \text{ (TRIP TIME)}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\frac{2 \times 2.3}{2.3} I(n) / 1.75 I(t) \times 100 = 263 \text{ % } \text{ (TRIP TIME)}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\frac{10.7}{10.7} MTR IRA / 1.75 I(t) \times 100 = 623 \text{ % } \text{ (TRIP TIME)}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREED87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER PHILADELPHIA GEAR L27 DWG

ENTITLED "LIMIT TORQUE MASTER CERTIFICATION II"

STATION 1, 2 & 3 REV. E & DWG 47A365-1-2

REV. 3

THERMAL OVERLOAD HEATER CALCULATION

REV. O

DATE 3/16/88

BOARD REF 43

REACTOR MOV 60 2C

COMPUTED BY DWA

DATE 3/16/88

UNIT # 2

DWG. NO. 45B2299-L REV. 0

CHECKED BY TBS

DATE 3/17/88

COMP # GE

EQUIP REF. MAIN STEAM LINE DRAIN VALVE FCV-1-55

REV. DATED: JPM 3-1-88

4.

EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHECKED: JRK 3-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5. REPLACE HEATER - PROCEED TO SECTION 5 NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{I}{I} = \text{TRIP AMPS}$$

CR+23 C1.5+A

$$I(t) = 1.56 I(n) \times 1.25 \times \frac{98}{I} =$$

I = 1.56

$$I(t) = 1.91 \text{ AMPS}$$

B-E0007

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) I(n) / 1.91 I(t) \times 100 = 120 \text{ : OVER } 200 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) I(n) / 1.91 I(t) \times 100 = 241 \text{ : } 66.35 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(10.9 \text{ MTR LRA}) / 1.91 I(t) \times 100 = 571 \text{ : } 10.2 - 18 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 5. NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{I}{I} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{I}{I} = 1.56 \times 1.25 \times \frac{90\%}{I}$$

$$I(t) = 1.72 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) I(n) / 1.72 I(t) \times 100 = 131 \text{ : OVER } 200 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3) I(n) / 1.72 I(t) \times 100 = 261 \text{ : } 55.74 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(10.9 \text{ MTR LRA}) / 1.72 I(t) \times 100 = 619 \text{ : } 10.5 - 15.2 \text{ SECS}$$

CALCULATION NO. ED-62265-87824

SHEET 15.5 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. O

ATE 3/10/88

BOARD REF 480

FACTOR 2 MAX RD 2C

COMPUTED BY DIA

ATE 3/10/88

UNIT # 2

W.G. NO. 2EF2299.6 REJ.0

CHECKED BY TMM

DATE 3/17/88

COMP # 6E

EQUIP REF. MAIN STEAM LINE DRAIN VALVE

FCV-1-58

REV. I

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

PREPARED: JPM 8-1-88

DATE 3/17/88

CHECKED: RK 8-1-88

SMR-88
1-3-88 YES THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C 1.63A
CR123 C1.84AOVERLOAD HEATER SETTING -90% 100%COMMENTS: RESET THE INSTALLED TOL HEATERS TO 90%
REPLACE THE INSTALLED TOL HEATERS
AS SHOWN ABOVE.

CALCULATION NO. ED-G2268-87324

SHEET 16.1 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. O

D

DATE 3/16/88

BOARD REF 480V REACTOR M&V BD 2C COMPUTED BY

D&L

DATE 3/16/88

UNIT # 2 DWG. NO. 4532299-6 REV.O CHECKED BY

D&L

DATE 3/17/88

COMP # 7A EQUIP REF. REACTOR BLDG. FLOOR DRAIN SUMP PUMP PA

REV. I PREPARED: JPM 8-1-88

CONTINUOUS DUTY MOTORS CHECKED: RK 8-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR106 CO SIZE 1
O/L RELAY TYPE CR124 HEATER SIZE CR123 C/2.5B SETTING 100%

MOTOR NAMEPLATE DATA:

H.P. 7.5 VOLTS 440 FLC 10.6 PHASE 3 INS. CLASS B (1) NEC CODE G.
DUTY CONT S.F. 1.0 TEMP RISE 55 DEG C. AMBIENT TEMP — DEC C

AMBIENT TEMPERATURE: (REF #8)

① SEE SH. 16.3

MOTOR AMBIENT TEMP \leq 40 DEG C
STARTER AMBIENT TEMP \leq 40 DEG C

EQUIP LOCATED IN PORTION OF
REACTOR BLDG. WHICH IS NOT
PART OF HARSH ENVIRONMENT PER
DWGS. 47W200-7 REV. A & 47W225-103
REV. I

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF # 1-SH.1) 0.9 TEMP CORRECTION FACTOR (TCP) —
HEATER TABLE: (REF #1 - SH.8)

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT ~~MINIMUM~~
I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG ~~RELAY TRIP~~
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR. (REF #1 SH 1)
I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT
~~%~~ -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

PROTECTION FROM 115% TO 130% (REF #5)
OVERLOAD HEATERS RANGE FROM 85% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES ____ NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) = \frac{440 \times 10.6}{460} = 10.13$$

FOR THIS CALCULATION I (n) = I ADJUSTED = 10.13 AMPS

CALCULATION NO. ED-Q7268-87324

SHEET 16.2 OF 11

THERMAL OVERLOAD HEATER CALCULATION

REV O

DATE 2/14/75

BOARD REF 480V REACTOR MOV 3D 2C COMPUTED BY DUL DATE 2/14/75

UNIT # 2 DWG. NO. 4582C99-L REV. O CHECKED BY THERS DATE 2/14/75

COMP # 7A EQUIP REF. REACTOR BLDG FLOOR DRAIN SUM 2 7A

REV. I PREPARED: 1PM 2-14-75

CHECKED: WRK E-14-75

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HEATER SIZE (REF #5)

$$I(n)_{\text{N.P.}} = \text{ (USE D.F. PER REF #1 SH 1)}$$

$$\underline{10.13} \quad I(n)_{\text{x}} \underline{0.9} \quad \text{D.F.} = \underline{9.12} \quad \text{AMPS}$$

C12.5B

CATALOG HEATER SIZE CR123 6H-3B

$$I(m) = \underline{9.99}$$

10.0

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

$$\frac{\underline{9.99}}{10.0} \quad I(m) \times 1.25 \times 100 \quad \% / \underline{10.13} \quad \% = \underline{92.3} \quad \%$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SIZED.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\% = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$$

$$\% =$$

$$\% =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SIZED.

NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE. FIELD TO RESET SETTING. PROCEED TO SECTION 4.

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \% = \text{TRIP AMPS}$$

$$I(t) = \underline{0.9} \quad I(n) \times 1.25 \times \underline{100} \quad \% = \underline{13.62} \quad \text{AMPS}$$

CALCULATION NO. ED-Q2268-97324

SHEET 16.3 OF 21

THERMAL OVERLOAD HEATER CALCULATION

REV O

DATE 3/16/68

BOARD REF 430V REACTOR MOV SD 26 COMPUTED BY

DW

DATE 3/16/68

UNIT # 2

DWG. NO. LER2299-2 RE/0 CHECKED BY

TAB

DATE 3/16/68

COMP # 7A

EQUIP REF. REACTOR ELDG FLGS DRAIN SUMP PUMP 2A

REV. I

PREPARED: JMA 3-1-68

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

CHECKED: ORS 3-1-68

% PROTECTION = $I(t) / I(n) \times 100$

$$\frac{+3.12 I(t)}{+0.12 I(n)} \times 100 = 135\%$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$I^* = [\% \text{ PROTECTION} \times I(n)] / [I(n) \times 1.25]$$

$$90\% = \% \text{ PROT} \times 10.12 / 10.9 \times 1.25, \% \text{ PROT} = 121\%$$

$$I^* =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123C12.5B

OVERLOAD HEATER SETTING 90% 100%

5. COMMENTS: RESET THE INSTALLED TOL HEATERS TO 90%

① ASSUMPTION, REFER TO SECT. 4.5

THE INSTALLED TOL HEATERS & SETTINGS ARE ACCEPTABLE.

CALCULATION NO. ED-22163-87324

SHEET 17.1 OF 31

THERMAL OVERLOAD

TER CALCULATION

REV. O

3/14/88

BOARD REF 430

ACTOR, MUL 30 CC

COMPUTED BY DYA

3/14/88

UNIT # 2

DWG. NO. 4532299-6 REV. 0

CHECKED BY THIS DATE 3/14/88

COMP # 78

EQUIP REF. PRESCALER, LIQUID COOLING WATER SHUT-OFF VALVE ECR-24-57

MOTOR OPERATED VALVE MOTORS

REV. I

PREPARED: G.M. 3-1-88

CHECKED: D.P.C. 3-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR.	GE	MODEL	CR1096P	SIZE	1
O/L RELAY TYPE	CR124	HEATER SIZE	CR123 CO. 39A	SETTING	95%

MOTOR NAMEPLATE DATA:

STARTING TORQUE	2	ft#	RPM	1725	DUTY	15	min.S.P.	-			
H.P.	1.33	VOLTS	440	FLC	.7	LRA	2.6	PHASE	3	INS. CLASS	S ①
NEC CODE LETTER	-	TEMP RISE	-	75	deg C.						

① SEE 4-17-2

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1 - SH. S

TIME .VS. CURRENT CURVE: REF # 1 - SH. S

DEFINITIONSRELAYI (t) -- HEATER TRIP CURRENT ~~MINIMUM~~

I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY TRIP

1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT

I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT

% -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (%)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.* 200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 1 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREEB87031 FOR INSTRUCTIONS.

THERMAL OVERLOAD HEATER CALCULATION

REV. O

E 5/16/88

BOARD REF 450 ACT-Z 115V 30 20 COMPUTED BY DYL E 5/16/88
UNIT # 2 WG. NO. 45B2299.6 REV. G CHECKED BY T/45 DATE 3/17/88
COMP # 75 EQUIP REF. PCT COOLER LIQUID COOLING WATER SHUT OFF MAY 24 1988

REV. I

E 5/16/88

CALCULATIONS:PREPARED: JAM 5-1-88
CHECKED: ORR 5-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I \text{ (adjusted)} = \frac{V \text{ (nameplate)}}{V \text{ (operating)}} \times I \text{ (nameplate)}$$

$$I \text{ (adjusted)} = \frac{440 \times .7}{460} = .67$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} = .67$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 5+ 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 2.6 / 5+ 6.25 = \frac{2.6}{6.25} = 0.42$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER HEATER SELECTION CURRENT = TRIP CURRENT/1.25 = 2.6 / 1.25 = 2.08 AMPSCATALOG HEATER SIZE C 2 1 2 3 6 0 - 4 2 0 C 0 . 3 9 A W 2 0 4 2
 $I(m) = \frac{43}{0.44} \frac{0.39}{0.40} \frac{0.32}{0.32} = 0.42$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100}{100} = \frac{43}{0.44} \times 1.25 \times \frac{100\%}{100\%}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } \frac{43}{0.44} \text{ I(t)} \times 100 = \frac{100}{100} \text{ (TRIP TIME)}$$

$$(43 / 0.44) \times 100 = \frac{100}{100} \text{ SEC3}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } \frac{43}{0.44} \times 200 = \frac{200}{100} \text{ SEC3}$$

$$(43 / 0.44) \times 200 = \frac{200}{100} \text{ SEC3}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } \frac{43}{0.44} \text{ I(t)} \times 100 = \frac{43}{0.44} \times 335 = \frac{335}{0.44} = 756.8$$

$$(43 / 0.44) \times 335 = \frac{335}{0.44} \text{ SEC3}$$

$$(43 / 0.44) \times 335 = \frac{335}{0.44} \text{ SEC3}$$

CALCULATION NO. ED-Q2268-37324

THERMAL OVERLOAD CIRCUIT CALCULATION

BOARD REF 430V

ACT 312 MAY 30 26

UNIT # 2

COMP # 7B

COMPUTED BY DIV

LNG. NO. 1532299.6 REV. O

CHECKED BY TTS

EQUIP REF. PC & COOLER LIQUID COOLING WATER SIDE

SHEET 17.3 OF 31

REV. O

9/16/77

3/17/77

DATE 3/17/77

REV. 1

PREPARED: JDM 8-1-88

CHECKED: JRK 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) * 1.25 * \frac{7}{5} = .43 * 1.25 * \frac{93}{5},$$

$$I(t) = ,51 \text{ AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(\frac{.67}{.51} I(n) / \frac{.51}{.51} I(t)) * 100 = \frac{.67}{.51} * \frac{100}{.51} = 132 \frac{9}{100} \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(\frac{2 \times .67}{.51} I(n) / \frac{.51}{.51} I(t)) * 100 = \frac{2 \times .67}{.51} * \frac{100}{.51} = 262 \frac{9}{100} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE: (TRIP TIME)

$$(\frac{8.6}{.51} MTR LRA / \frac{.51}{.51} I(t)) * 100 = \frac{8.6}{.51} * \frac{100}{.51} = 172 \frac{9}{100} \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ASSUMPTION PER CRANE TELEDYNE DWG. N°

T-12942-3 ISSUED UNDER CONTRACT # 70C55-92272-1

47A36B-24-2 REV. O. THE FULL LOAD CURRENT SHOWN

ON THE VENDOR DWG IS LESS THAN THAT GIVEN IN THE WALKDOWN DATA; THEREFORE, USE OF THE LOCKED ROTOR CURRENT FROM THE VENDOR DRAWING IN THIS CALCULATION WILL BE CONSERVATIVE

THERMAL OVERLOAD THER CALCULATION

REV. 2

3/11/88

BOARD REF 430W ACTOR M4V SD. 2G

COMPUTED BY DIA

3/11/88

UNIT # 2 DUG. NO. 45B2299-6 REV. 0

CHECKED BY JMB

DATE 3/7/88

COMP # 7B EQUIP REF. PRECOOLER LIQUID COOLING WATER SHUTOFF VALVE FCV-24-57

REV. I PERTINENT: JPM 3-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHARTED: VRK 3-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.REPLACE HEATER PROCEED TO SECTION 5
3/11/88 NO PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$62+83 = 69.89A$$

$$I(t) = .34 I(n) \times 1.25 \times \frac{1}{2} = \frac{1}{2} *$$

$$\frac{1}{2} \times .34 = .17A$$

$$I(t) = .43 \text{ AMPS}$$

$$\frac{1}{2} \times .43 = .215A$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / .43 I(t) \times 100 = \frac{1.34}{.43} = 3.10 : 12.10 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / .43 I(t) \times 100 = \frac{1.34}{.43} = 3.10 : 23.55 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times .67) MTR LRA / .43 I(t) \times 100 = \frac{1.34}{.43} = 3.10 : 11.10 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5. NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = .34 \times 1.25 = \frac{1}{2} *$$

$$I(t) = .40 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / .40 I(t) \times 100 = \frac{1.34}{.40} = 3.35 : \text{OVER } 140 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times .67) I(n) / .40 I(t) \times 100 = \frac{1.34}{.40} = 3.35 : 32.47 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(2 \times .67) MTR LRA / .40 I(t) \times 100 = \frac{1.34}{.40} = 3.35 : 9.314.2 \text{ SECS}$$

CALCULATION NO. ED-22763-27524

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 482V

CT-12 MOV BD 30

COMPUTED BY DLA

SHEET 17.5 OF 21

REV. 0

3/16/88

UNIT # 2

NO. 45B2299.6 REV. 0

CHECKED BY TAC

3/16/88

COMP # 73

EQUIP REF. PCT COOLER LIG. D Cooling WATER SU, T, FF M2V FCL-24-57

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REBUI PREPARED: JPM 8-1-88
CHECKED: JRK 8-1-88

YES THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. ^{DO NOT} ~~DELET~~ ^{SPM} 7/13/88

NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR-23 60-39A C0.39A

OVERLOAD HEATER SETTING 95% 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 95%

REPLACE THE INSTALLED TOL HEATERS ^{SPM} ~~7/13/88~~
AS SHOWN ABOVE ^{SPM} ~~7/13/88~~

RESET THE INSTALLED TOL HEATERS TO 100%

CALCULATION NO. ED-Q2268-37324

SHEET 13.1 OF 31

THERMAL OVERLOAD CENTER CALCULATION

REV. O

BOARD REF 450V

ACTUAL M&V FD 26

COMPUTED BY DIA

E 3/16/88

UNIT # 2

DWG. NO. 4582299.6 RE/2

CHECKED BY TMS

E 3/16/88

COMP # 75

EQUIP REF. NWCU BLOWDOWN M&V = 24V - 39- 16

DATE 3/17/88

MOTOR OPERATED VALVE MOTORS

WALKDOWN INPUT DATA: (REF # 3)

REV. I

TRIPPOINT: JPM 8-1-88

CHECKED: RK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR.	GE	MODEL	CR123C0	SIZE	1
O/L RELAY TYPE	CR124	HEATER SIZE	CR123 C1.63A	SETTING	100%

MOTOR NAMEPLATE DATA:

STARTING TORQUE	10.	ft#	RPM	1700	DUTY	15	min.S.F.	-			
H.P.	1/2	VOLTS	460	FLC	2.1	LRA	11.9	PHASE	3	INS. CLASS	B
NEC CODE LETTER	-	TEMP RISE	-	75	deg C.						

(1) SEE 14.18.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-514.8

TIME .VS. CURRENT CURVE: REF# 1-514.5

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- ** -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

* 200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

THERMAL OVERLOAD HEATER CALCULATION

REV. C

RE 3/14/88

BOARD REF 480 FACTOR MOV 5D 2C

COMPUTED BY DYL

RE 3/14/88

UNIT # 2 UWG. NO. 45B2299-L REJ. O

CHECKED BY JMB

DATE 3/7/88

COMP # 7C EQUIP REF. RWC J P-SW-0001N MOV FCY-69-4

CALCULATIONS:

REV. I

PREPARED: 1PM 2-1-88
CHECKED: JRK 2-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES:

$$I_{(adjusted)} = \frac{V_{(nameplate)}}{V_{(operating)}} \times I_{(nameplate)}$$

$$I_{(adjusted)} =$$

FOR THIS CALCULATION $I_{(n)} = I_{(adjusted)}$ = _____ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES:

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\text{HP}} \times \underline{\text{KVA/HP}} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\hspace{2cm}} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF. 1-SH-5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

TRIP CURRENT = (LRA) / (MULTIPLE OF CURRENT RATING)

$$\text{TRIP CURRENT} = 11.9 / 6.25 = 1.90$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 1.90 / 1.25 = 1.52 AMPSCATALOG HEATER SIZE CR123 C1.94A

$$I_{(m)} = \frac{1.52}{1.48} = 1.04$$

3' ZONE

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I_{(m)} \times 1.25 \times \frac{100\%}{1.48} = \frac{1.52}{1.48} \times 1.25 \times \frac{100\%}{1.48}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2.1 \text{ I}(n) / \frac{1.95}{1.85} \text{ I}(t)) \times 100 = \frac{108}{114} : \text{ over } 900 \text{ SECES}$$

200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ I}(n) / \frac{1.95}{1.85} \text{ I}(t)) \times 100 = \frac{216}{227} : \frac{86-114}{78-102} \text{ SECES}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(11.9 \text{ MTR LRA} / \frac{1.95}{1.85} \text{ I}(t)) \times 100 = \frac{643}{643} : \frac{107-114}{9.8-14.5} \text{ SECES}$$

CALCULATION NO. ED-Q2265-47524
THERMAL OVERLOAD METER CALCULATION
BOARD REF 4801 FACTOR MAY BD 2C COMPUTED BY DWU
UNIT # 2 UNG. NO. 4522299-6 REV. 0 CHECKED BY TMM DATE 3/7/88
COMP # 7G EQUIP REP. DWU FLOWDOWN MAY FCV 69-16

SHEET 1 OF 3
REV. 0

E 3/16/88
E 3/16/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? REV. I PREPARED: JPM 8-1-88
CHECKED: JRK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \% = 1.56 \times 1.25 \times 95\%.$$

$$I(t) = 1.85 \text{ AMPS}$$

100% MOTOR FLG TO HEATER CURRENT BASE: (TRIP TIME)

$$(2 \times 1.85) / 1.95 I(t) \times 100 = 11.7 \text{ SECS}$$

200% MOTOR FLG TO HEATER CURRENT BASE

$$(2 \times 1.85) / 1.95 I(t) \times 100 = 22.7 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE

$$(11.9 \text{ MTR LRA} / 1.95 I(t)) \times 100 = 54.3 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIRBEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER DWU'S UPF 2547-36-3 E 47A268-69-2 REV. 2

THERMAL OVERLOAD HEATER CALCULATION

REV. O

3/16/88

BOARD REF 430

FACTOR MAY 30 86

COMPUTED BY DVA

3/16/88

UNIT # 2

M.G. NO. 45B2299-6 REV. 0

CHECKED BY

DATE 3/16/88

COMP # 76

EQUIP REF. RWCW BLOWDOWN M-1 REV- 12-16

CALCULATION NO. ED-G0068-87324

SHEET 15.5 OF 31

THERMAL OVERLOAD

TER CALCULATION

REV. O

E 3/16/88

BOARD REF 480W

ACTOR M1V 5D 2C COMPUTED BY DYC

3/16/88

UNIT # 2

NO. 4582299-6 REV. 0 CHECKED BY

JARDINE 3/17/88

COMP # 7C

EQUIP REF. RWCU BLOW DOWN M1V FCV-69-16

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REV. I

PREPARED: JPM 8-1-88

CHECKED: URK 8-1-88

 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:OVERLOAD HEATER SIZE C 1.84 AOVERLOAD HEATER SETTING 100 %COMMENTS: THE INSTALLED TOL HEATERS SETTINGS ARE
ACCEPTABLEREPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE.

CALCULATION NO. ED-C4226P-37826

SHEET 19.1 OF 21

THERMAL OVERLOAD

TER CALCULATION

REV. O

3/16/88

BOARD REF 482V

FACTORY MAY 1982

COMPUTED BY DYL 5-21-88

UNIT # - 2

LWG. NO. 16B2299.6 REV. O

CHECKED BY

THIS DATE 3-16-88

COMP # 75

EQUIP REF. RWCU FILTER F05MIN SYS BY-PASS MAX FLOW 60-3

MOTOR OPERATED VALVE MOTORS

REV. I

PREPARED: 1PM 3-1-88

WALKDOWN INPUT DATA: (REF # 3)

CHECKED: 1PM 3-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR10960 SEE 1
 O/L RELAY TYPE CR24 HEATER SIZE CR123C1.63A SETTING 85% OA
 100% OC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 7.5 ft# RPM 1720 DUTY 15 min.S.P.
 H.P. 5 VOLTS 460 FLC 2.1 LRA 11.9 PHASE 3 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-54-8
 TIME VS. CURRENT CURVE: REF # 1-54-5

(1) SEE 34.19.3

DEFINITIONS

- RELAY
 I (t) -- HEATER TRIP CURRENT MINIMUM
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 % -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER INCH (I.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
 MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
 REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. EL-GCCGB-37824

SHEET 19.2 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 420 A-T-2 MAY ED 2C COMPUTED BY 52A

E 3/16/88

UNIT # - ? Lwg. NO. 45B2299-6 REV. O CHECKED BY 7743 DATE 3/17/88

E 3/16/88

COMP # - ? EQUIP REF. RWGCU FILTER & DEMIN SYS. BY PASS MAY 2CV-B-5

E 3/16/88

CALCULATIONS:REV. I PREPARED: JPM 8-1-88
CHECKED: JPK 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I_{(adjusted)} = \frac{V_{(nameplate)}}{V_{(operating)}} \times I_{(nameplate)}$$

$$I_{(adjusted)} =$$

FOR THIS CALCULATION $I_{(n)} = I_{(adjusted)}$ = _____ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\text{HP} \times \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-44.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 11.9 / 6.25 = 1.90$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 1.90 / 1.25 = 1.52 AMPS

CATALOG HEATER SIZE C2123 C1.24A 'B' ZONE
 $I_{(n)} = \frac{1.52}{1.48}$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(n) \times 1.25 \times \frac{\%}{100} = \frac{1.52}{1.48} \times 1.25 \times \frac{100\%}{1.85}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2.1 \text{ I}(n) / \frac{1.90}{1.85} \text{ I}(t)) \times 100 = \frac{4.8}{1.4} \text{ SECS}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2 \times 2.1 \text{ I}(n) / \frac{1.90}{1.85} \text{ I}(t)) \times 100 = \frac{9.6}{2.27} \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } (11.9 \text{ MTR LRA} / \frac{1.90}{1.85} \text{ I}(t)) \times 100 = \frac{64.3}{9.8} \text{ SECS}$$

CALCULATION NO. SU-Q2268-47574

SHEET 19.3 OF 21

THERMAL OVERLOAD

REV. O

3/14/88

BOARD REF 480V

TER CALCULATION

3/14/88

UNIT # - 2

ACTOR MOV ED SG COMPUTED BY DYN

3/14/88

COMP # 75

DWG. NO. 4582299.6 REV.O CHECKED BY 774B DATE 3/14/88

EQUIP REF. N.Y.C. FILTEC EDEMIN SYS BY PASS MOD FEB-87-8

-- ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? REW: PREPARED: QM H-1-B8
CHECKED: VRC 1-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times 2\% = 1.85 \times 1.25 \times 95\%$$

$$I(t) = 1.85 \text{ AMPS}$$

$$100\% \text{ MOTOR FLG TO HEATER CURRENT BASE: } (TRIP TIME)$$

$$(2 \times \frac{I(n)}{1.85} I(t)) \times 100 = 1.4 \text{ SECS}$$

$$200\% \text{ MOTOR FLG TO HEATER CURRENT BASE: } (2 \times \frac{I(n)}{1.85} I(t)) \times 100 = 2.7 \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } (11.9 \text{ MTR LRA} / 1.85 I(t)) \times 100 = 4.3 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREBB87031 FOR INSTRUCTIONS CONCERNING "ACCEPTANCE CRITERIA".

COMMENTS ① ASSUMPTION Per Dwg's UPF# 2547-34-3

47A368-69-2 REV.2

THERMAL OVERLOAD HEATER CALCULATION

REV. O

3-25-88

BOARD REF 480V

FACTOR 3.175 SD 2C COMPUTED BY DRA

3-25-88

UNIT # 2

WNG. NO. 4582259-4 REV. 0 CHECKED BY J. M. H.

3-25-88

COMP # 75

EQUIP REF. RWCU FILTER & DEMIN SYS BY FASCO MFG. CO. 6-9-88

REV. 1 PREPARED: J. M. H. 3-1-88

4.

EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHECKED: J. M. H. 3-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$I(t) = I(m) \times 1.25 \times Z^* = \text{TRIP AMPS}$

ER-129-61024

$I(t) = 1.47 I(n) \times 1.25 \times Z^*$

Z=2.127

$I(t) = 1.47 \text{ AMPS}$

B=2.005

100% MOTOR PLC TO HEATER CURRENT BASE:

(TRIP TIME)

$(2 \times 1.47 I(n) / 1.47 I(t)) \times 100 = 114 : 222 = 0.606$

200% MOTOR PLC TO HEATER CURRENT BASE:

$(2 \times 1.47 I(n) / 1.47 I(t)) \times 100 = 230 : 76 = 14.2 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$(1.9 \text{ MTR LRA} / 1.47 I(t)) \times 100 = 47 : 9.8 = 4.8 \text{ SECS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$I(t) = I(m) \times 1.25 \times Z^* = \text{TRIP AMPS}$

$I(t) = I(m) \times 1.25 \times Z^* = \text{TRIP AMPS}$

$I(t) = \text{TRIP AMPS}$

100% MOTOR PLC TO HEATER CURRENT BASE:

(TRIP TIME)

$(I(n) / I(t)) \times 100 = \text{TRIP TIME} : \text{SECS}$

200% MOTOR PLC TO HEATER CURRENT BASE:

$(2 \times I(n) / I(t)) \times 100 = \text{TRIP TIME} : \text{SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$(MTR LRA / I(t)) \times 100 = \text{TRIP TIME} : \text{SECS}$

CALCULATION NO. ED-92263-57324

THERMAL OVERLOAD CTER CALCULATION

BOARD REF 430V

ACT 25 MAY 80 SD 26 COMPUTED BY DKL

UNIT # 2 DWG. NO. 25B2299-6 REV. 0 CHECKED BY TBS DATE 3/17/85

COMP # 75 EQUIP REF. 241CU FILTER & DEMIN SYST. BY PASS RATE 257.59 A

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

SHEET 19.5 OF 51

REV. 0

3/16/85

2/16/85

3/17/85

REVI REPIRED: 9AM 2-1-85
CHECKED: DKL 2-1-85

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE G1.84A
CR123 G1.84A

OVERLOAD HEATER SETTING 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 100%

REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE

THERMAL OVERLOAD

TER CALCULATION

REV. O

2/16/88

BOARD REF 483V

FACTOR 1.05V 0.0 25

COMPUTED BY DYL

2/16/88

UNIT 1 - 2

DWG. NO. 45B2299-4-REL-O

CHECKED BY TMB

DATE 2-17-88/PJ

COMP 1 - 2

EQUIP. REF. 7-2K-16-21-24-FLD-CLG-WTR SHUTTER, 120V 5A-0.5

MOTOR OPERATED VALVE MOTORS

REV. I

PREPARED: JIM 2-1-88

WALKDOWN INPUT DATA: (REF # 3)

CHECKED: JIM 2-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR10960 SIZE 1
 O/L RELAY TYPE CR224 HEATER SIZE CR123 CO.39A SETTING 100%

MOTOR NAMEPLATE DATA:

STARTING TORQUE	2	ft#	RPM	1725	DUTY	15	MIN. S.S.	-
H.P.	.133	① VOLTS	440	FLC	.7	LRA	2.6 ①	PHASE 3 IHS. CLASS B ①
NEC CODE LETTER	-	TEMP RISE	-	-	75	deg C.	-	-

(1) SEE 54-30-2

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-541.8

TIME .VS. CURRENT CURVE: REF# 1-541.5

DEFINITIONSRELAY

- I (t) -- HEATER TRIP CURRENT
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG ^{MINIMUM} TRIP
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- % -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PERCENT (P.V.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 3 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-G2263-97324

SHEET 20.2 OF 21

THERMAL OVERLOAD CALCULATION

REV. O

BOARD REF 482V

ACTOR NOV 27, 26

COMPUTED BY D.L.

5/16/87

UNIT # 2

DWG. NO. 1582299.6 REV. 0

CHECKED BY

5/16/87

COMP # 25

EQUIP REF. TURBINE SILENTIC FLUID GLWTR. SHUT-OFF MAX 200-124-25

REV. 1 PREPARED: J.R. 3-1-89

CHECKED: J.R. 3-1-89

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) = \frac{440 \times .7}{460} = .67$$

FOR THIS CALCULATION I (n) = I ADJUSTED = .67 AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\text{HP} \times \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 5.4 6.25

TRIP CURRENT = (LRA) / (MULTIPLE OF CURRENT RATING)

$$\text{TRIP CURRENT} = \frac{2.6}{5.4} = \frac{.54}{6.25} = 0.42$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER.
HEATER SELF-SISSION CURRENT = TRIP CURRENT / 1.25 = .42 / 1.25 = .34 AMPSCATALOG HEATER SIZE CR123 60.48A CO.39A
I(m) .48 .34 0.32 0.32 0.32 0.32

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100}{100} = \frac{.48}{0.48} \times 1.25 \times \frac{100\%}{100\%}$$

$$I(t) = \frac{.54}{0.48} \text{ AMPS} = \frac{.54}{0.48} \text{ 3/16" 7/16" 1/2"}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE: (.67) (TRIP TIME)
I(n) / .54 I(t) x 100 = .67 / .54 : over 900 SECS200% MOTOR FLC TO HEATER CURRENT BASE: (2x .67) (TRIP TIME)
I(n) / .54 I(t) x 100 = 1.34 / .54 : 41.60 SECSLOCKED ROTOR AMPS TO HEATER CURRENT BASE: (2.6 MTR LRA / .54 (TRIP TIME)
I(t) x 100 = 5.2 / .54 : 33.50 SECS(2.6 MTR LRA / .54 I(t) x 100 = 5.2 / .54 : 46 SECS

CALCULATION NO. ED-02269-37854

SHEET 20.3 OF 51

THERMAL OVERLOAD PER CALCULATION

REV. O

3/14/87

BOARD REF 480V ALATOR MAY 5D 2G COMPUTED BY DYL 3/14/87
 UNIT # 2 DWG. NO. 4582299-6 REV.O CHECKED BY TMB DATE 3/14/87
 COMP # EB EQUIP REF. TURBINE G-1A-6-24000 C.G.WTR. SHT.FE MAY 561-24-05

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? REVI: PREPARED: JPM 8 1-88
CHECKED: VRK 8 1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) + 1.25 \times \frac{I}{n} = .48 + 1.25 \times \frac{95\%}{51}$$

$$I(t) = .51 \text{ AMPS}$$

400% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(\frac{.57}{.51} - 1) \times 100 = 1.61 \times 1.45 = 2.35 \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE
 $(\frac{.67}{.51} - 1) \times 100 = 2.62 \times 2.7 = 7.05 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE
 $(\frac{2.6}{1.61} - 1) \times 100 = 1.6 \times 2.8 = 4.5 \text{ SECS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QREBB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION PER CRANE TELEDYNE DWG. NO.

T-12942-3 ISSUED UNDER CONTRACT # 70055-92272-1

47A369-24-2 REV.O. THE FULL LOAD CURRENT SHOWN ON THE VENDOR DWG IS LESS THAN THAT GIVEN IN THE WALKDOWN DATA; THEREFORE, USE OF THE LOCKED ROTOR CURRENT FROM THE VENDOR DRAWING IN THIS CALCULATION WILL BE CONSERVATIVE.

CALCULATION NO. ED-32968-37504

THERMAL OVERLOAD CIRCUIT CALCULATION

BOARD REF 480V ACTOR NO. 50 50 26 COMPUTED BY SJA DATE 3/16/88
UNIT # 2 DWG. NO. 4CB2299-6 REV. O CHECKED BY DATE 3/16/88
COMP # 513 EQUIP REF. TURBINA OIL FENG FLUID CO. WTR. SHUTTER AND FCY-24-65

SHEET 20.4 OF 31

REV. O

3/16/88

3/16/88

DATE 3/16/88

REV. I PREPARED: 8 PM 3-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER
IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3? YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE,
FIELD TO RESET SETTING. PROCEED TO SECTION 5. NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$I(t) = I(a) \times 1.25 \times 1.25 = \text{TRIP AMPS}$

CR-23-40-5DA

$I(t) = .34 I(a) \times 1.25 \times 1.25 = .34$

I(a) = .34

$I(t) = .43 \text{ AMPS}$

.34 = .43

100% MOTOR PLC TO HEATER CURRENT BASE:

$(\frac{.67}{.67} I(a) / .43 I(t)) \times 100 = 150 \times 0.72 = 108 \text{ SECS}$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$(\frac{.67}{.67} I(a) / .43 I(t)) \times 100 = 310 \times 0.72 = 223.55 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$(\frac{2.6}{2.6} \text{ MTR LRA} / .43 I(t)) \times 100 = 600 \times 0.72 = 432 \text{ SECS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5. NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$I(t) = I(a) \times 1.25 \times 1.25 = \text{TRIP AMPS}$

$I(t) = I(a) \times 1.25 \times 1.25 = .34 \times 1.25 = 95\%$

$I(t) = .40 \text{ AMPS}$

100% MOTOR PLC TO HEATER CURRENT BASE:

$(\frac{.67}{.67} I(a) / .40 I(t)) \times 100 = 150 \times 0.72 = 108 \text{ SECS}$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$(\frac{.67}{.67} I(a) / .40 I(t)) \times 100 = 310 \times 0.72 = 223.55 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$(\frac{2.6}{2.6} \text{ MTR LRA} / .40 I(t)) \times 100 = 600 \times 0.72 = 432 \text{ SECS}$

CALCULATION NO. ED-G 2268-87324

THERMAL OVERLOAD THERM CALCULATION

BOARD REF 480 ACTOR NOV BD 2C COMPUTED BY D.L.A.

UNIT 1-2 NO. 4582299.6 REV.0 CHECKED BY J.M.C. 2/16/88

COMP 813 EQUIP REF. TURBINE OIL BENG FLUID COOLING SYSTEM REV. 24-65

SHEET 2 OF 5

REV. 0

2/16/88

2/16/88

2/16/88

2/16/88

2/16/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

✓ YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. J.M.C. 2/16/88

✓ NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR 123 60-48A C0.39A

OVERLOAD HEATER SETTING 95% 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 100%

REPLACE THE INSTALLED TOL HEATERS IS SHOWN ABOVE J.M.C. 2/16/88

SHOWN ABOVE J.M.C. 2/16/88

THE INSTALLED TOL HEATERS AND SETTING ARE
ACCEPTABLE.

CALCULATION NO. ED-Q2263-37324

SHEET 21.1 OF 31

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

3-3/16/88

BOARD REF 480V

ACTOR MOY BD 2C COMPUTED BY DJU

2-3/16/88

UNIT # 2 DWG. NO. 45B2299-6 REV.O.

CHECKED BY TDR

DATE 3/17/88 P.P.

COMP # 8C EQUIP. REF. RWCY.DRAIN TO RADWASTE

N-4V REV. G 9-17-

MOTOR OPERATED VALVE MOTORS.

WALKDOWN INPUT DATA: (REF # 3)

REV.I

PREPARED: JPM 8-1-88

CHECKED: RRK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR109CO SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C1.94A SETTING 100% OA
95% OC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 10 ft# RPM 1700 DUTY 15 min.S.F.
 H.P. .66 VOLTS 460 FLC 2.1 LRA 11.9 PHASE 3 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.

(1) SEE SH.21.3

MANUFACTURER'S DATA:HEATER TABLE: REF # 1 - SH.8TIME .VS. CURRENT CURVE: REF# 1 - SH.5DEFINITIONS

- RELAY
 I (t) -- HEATER TRIP CURRENT
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY TRIP
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 %* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREEB87031 FOR INSTRUCTIONS.

THERMAL OVERLOAD HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 1804

ACTOR NOV 3D 2C

COMPUTED BY DJL

3/16/88

UNIT # 2

L.G. NO.45B2299-L REV. O

CHECKED BY MAB

3/17/88

COMP # 8C

EQUIP REF. RWCU DRAIN TO SADWASTE

MOV FCY-69-17

3/17/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? YES PREPARED: JPM 3-1-88
CHECKED: VRK 3-1-88 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) * 1.25 * \% = \underline{1.56} * 1.25 * \underline{0\%}$$

$$I(t) = \underline{1.85} \text{ AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(2 \times \underline{2.1} I(n) / \underline{1.85} I(t)) * 100 = \underline{11.4} : \underline{500} \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE

$$(2 \times \underline{2.1} I(n) / \underline{1.85} I(t)) * 100 = \underline{22.7} : \underline{700} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(11.7 \text{ MTR LRA} / \underline{1.85} I(t)) * 100 = \underline{64.9} : \underline{10} - 14.4 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREPB07031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS (1) ASSUMPTION PER DWGS U.P.F. # 2547-36-3 & 47A368-69-2 REV. 2

CALCULATION NO. ED-Q2268-87324
 THERMAL OVERLOAD WATER CALCULATION
 BOARD REF 480V ACTOR NOV BD 2C COMPUTED BY DIL DATE 3/16/88
 UNIT # 2 G. NO. 45B2299-6 REV.0 CHECKED BY PAB 3/17/88
 COMP # 8C EQUIP REF. RWCU DRAIN TO RADWASTE NOV FCV-69-17

SHEET 21.4 OF 31
 REV. O

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER
 IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times z^* = \text{TRIP AMPS}$$

$$I(t) = \underline{\quad} I(m) \times 1.25 \times \underline{\quad} z^*$$

$$I(t) = \underline{\quad} \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(\underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(\underline{\quad} \text{MTR LRA} / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{SECS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 5

NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(m) \times 1.25 \times z^* = \text{TRIP AMPS}$$

$$I(t) = I(m) \times 1.25 \times z^* = \underline{\quad} \times 1.25 \times \underline{\quad}$$

$$I(t) = \underline{\quad} \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(\underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(\underline{\quad} \text{MTR LRA} / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{SECS}$

CALCULATION NO. ED-32268-87324

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 480V

ACTOR MOV BD 2C

COMPUTED BY DYA

SHEET 21.5 OF 31

REV. O

DTE 3/16/88

UNIT # 2

NO. 45B2299-6 REV. O

CHECKED BY TBR

3/16/88

COMP # 9C

EQUIP REF. RWCU DRAIN TO RADWASTE

MOV FCV-69-17

REV 1

PREPARED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

CHECKED : JRK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 C1.84A

OVERLOAD HEATER SETTING 95% - 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 95%

100%

CALCULATION NO. ED-92269-87324

SHEET 2E.1 OF 21

THERMAL OVERLOAD CALCULATION

REV. C

E 31/01/88

BOARD REF 480V ACTUAL VAC 50-60 Hz

COMPUTED BY DSW

E 31/01/88

UNIT # 2 DWG. NO. 45B2299.6 REV. O

CHECKED BY THIS

DATE 3/17/88

COMP # RE

EQUIP. REF. R116U RESTRICTING ORIFICE BY PASS MOT. FCV-LB-12

MOTOR OPERATED VALVE MOTORS

REV. I

RECORDED: JPM 8-1-88

WALKDOWN INPUT DATA: (REF # 3)

CHECKED: JRK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CC109CO SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 CL.63A SETTING 100% OA
 105% OC

MOTOR NAMEPLATE DATA:

STARTING TORQUE 7.5 ft# RPM 1700 DUTY 15 min.S.F. -
 H.P. .5 VOLTS 260 FLC 2.1 LRA 11.9 PHASE 2 INS. CLASS B
 NEC CODE LETTER - TEMP RISE 75 deg C.

(See sh. 22.3)

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1 - SH. 8

TIME VS. CURRENT CURVE: REF # 1 - SH. 5

DEFINITIONS

RELAY

I (t) -- HEATER TRIP CURRENT

I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY TRIP

1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT

I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT

** PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2268-87314

THERMAL OVERLOAD

BOARD REF 480V

UNIT 6 2

COMP 8 E

HEATER CALCULATION

ACTOR M6V BD 2C

DWG. NO. 45B2295-6 REV. O

EQUIP REF. RWCU RESTRICTING ORIFICE BY PAGES 1A5Y-FCU. 69-14

SHEET 11.2 OF 31

REV. O

TE 3/16/88

COMPUTED BY DJL

TE 3/16/88

CHECKED BY JHG

DATE 3/17/88

CALCULATIONS:REV. I DRAFTED: JPM 8-1-88
CHANGED: JRK 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate}) \times I(\text{nameplate})}{V(\text{operating})}$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 11.9 / 6.25 = 1.90$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 1.90 / 1.25 = 1.52 AMPS
CATALOG HEATER SIZE C2123 C1.84A

$$I(m) \quad \begin{array}{c} +56 \\ -56 \end{array} \quad 1.48 \quad \text{B' ZONE}$$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{\%}{100} = \frac{+56}{1.48} \times 1.25 \times \frac{100\%}{1.85}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2.1 \text{ I}(n) / \frac{1.90}{1.85} \text{ I}(t)) \times 100 = \frac{408}{114} \% \quad \text{(TRIP TIME)} \quad \frac{2.1}{1.85} \text{ SECS}$$

200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ I}(n) / \frac{1.90}{1.85} \text{ I}(t)) \times 100 = \frac{815}{227} \% \quad \frac{2.1 \times 2}{1.85} \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(11.9 \text{ MTR LRA} / \frac{1.90}{1.85} \text{ I}(t)) \times 100 = \frac{643}{643} \% \quad \frac{11.9}{1.85} \text{ SECS}$$

0050P

CALCULATION NO. ED-Q2268-87324

SHEET 22.3 OF 31

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 430V

ACTOR MCV F.C. 12

COMPUTED BY D.W.

E 3/16/88

UNIT # 2

UWG. NO. 45B2299-6 REV. O

CHECKED BY P.M.

DATE 3/17/88

COMP # P.E.

EQUIP REP. RWCU RESTRICTING CRIFICE BY. PASS MCV - PCV-69-14

REV. I

PREPARED: 9PM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

CHECKED: VRK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO ACHIEVE THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{1.56}{1.85} = 1.56 \times 1.25 \times 95\%$$

$$I(t) = 1.85 \text{ AMPS}$$

100% MOTOR PIC TO HEATER CURRENT BASE: (TRIP TIME)

$$(2 \times 2.1 \text{ I}(n) / 1.85 \text{ I}(t)) \times 100 = 11.4 \approx 2.9 \text{ SECS}$$

200% MOTOR PIC TO HEATER CURRENT BASE:

$$(2 \times 2.1 \text{ I}(n) / 1.85 \text{ I}(t)) \times 100 = 22.7 \approx 7.3 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(11.9 \text{ MTR LRA} / 1.85 \text{ I}(t)) \times 100 = 64.3 \approx 9.9 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREED07031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS (1) ASSUMPTION PER DWGS VPFS 2517.36.3 &

47A368-69.2 REV. 2

THERMAL OVERLOAD CIRCUIT CALCULATION

REV. O

E 3/16/88

BOARD REF 430V CT 12 MVA 30 30

COMPUTED BY DKL

E 3/16/88

UNIT # 2 DWG. NO. E-22299-6 REV. O

CHECKED BY JLB

DATE 3/17/88

COMP # 8E EQUIP REF. RWCU RESTRICTING ORIFICE BY-PASS MANU- PCV. 65.14

REV. I PERIOD: JPM 8-1-88

CHECKED: VRK 8-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \frac{z}{z^*} = \text{TRIP AMPS}$$

ER183 C1.63A

$$I(t) = 1.47 \quad I(m) \times 1.25 \times \frac{100}{z^*}$$

I(m) = 1.47

$$I(t) = 1.24 \quad \text{AMPS}$$

B1.63A

100% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times 1.1) \quad I(n) / 1.04 \quad I(t) \times 100 = 114 \quad \text{(TRIP TIME)}$$

SECS

200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times 2.1) \quad I(n) / 1.04 \quad I(t) \times 100 = 223 \quad \text{SECS}$$

76 100 SECS

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(11.9 \quad \text{MTR LRA}) / 1.04 \quad I(t) \times 100 = 6.47 \quad \text{SECS}$$

9.8 + 4.4 SECS

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(m) \times 1.25 \times \frac{z}{z^*} = \text{TRIP AMPS}$$

$$I(t) = I(m) \times 1.25 \times \frac{z}{z^*} = \text{TRIP AMPS}$$

$$I(t) = \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE:

$$(\quad I(n) / \quad I(t) \times 100 = \quad \text{(TRIP TIME)}$$

SECS

200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times \quad I(n) / \quad I(t) \times 100 = \quad \text{SECS}$$

SECS

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\quad \text{MTR LRA} / \quad I(t) \times 100 = \quad \text{SECS}$$

SECS

CALCULATION NO. ED-G22G3-57324

SHEET 22 OF 31

THERMAL OVERLOAD

TER CALCULATION

REV. O

BOARD REF 480V

.TOL MOV BD 2C

COMPUTED BY DXL

2-1-88 15:55

UNIT # 2

DRUG. NO. 45B2299-G REV. O

CHECKED BY

2-1-88 15:55

COMP # 8E

EQUIP REF. 2WCU RESTRICTING ORIFICE BY-PASS 15:55 P.C.U-10.3-14

REWI PREPARED: JFM 2-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

CHIEF : JFM 2-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

✓
7-3-88

NO THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

C 1.84A

OVERLOAD HEATER SIZE CR123 E1.63A

OVERLOAD HEATER SETTING 100%

COMMENTS: RESET THE INSTALLED TOL HEATERS TO 100%
REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE

CALCULATION NO. ED-Q2268-87324

SHEET 28.1 OF 34

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 480V

ACTOR MOV. BD 26

COMPUTED BY DIAU

E 3/16/88

UNIT # 1

DWG. NO. 45B2299-6 REV. O

CHECKED BY TMB

DATE 3/17/88

COMP # 9B

EQUIP REF. MAIN STEAM LINE DRAIN MOV FCV-1-57

MOTOR OPERATED VALVE MOTORS

REV. I

WALKDOWN INPUT DATA: (REF # 3)

PREPARED: JPM 3-1-88
CHECKED: JPK 3-1-88MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR105C SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C1.84A SETTING 00%

MOTOR NAMEPLATE DATA:

STARTING TORQUE 7.5 ft# RPM 1700 DUTY 15 min. S.F. —
 H.P. 0.5 (1) VOLTS 460 FLC 2.3 LRA 10.9 (1) PHASE 3 INS. CLASS —
 NEC CODE LETTER — TEMP RISE 75 deg C.

(1) SEE SH. 23.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-54.8

TIME VS. CURRENT CURVE: REF # 1-54.5

DEFINITIONS

RELAY

I (t) -- HEATER TRIP CURRENT MINIMUM

I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP

1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM FULL LOAD CURRENT

I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT

** PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
 MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
 REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q226B-57324

THERMAL OVERLOAD

BOARD REF 4504

UNIT # 2

COMP # 98

HEATER CALCULATION

ACTOR MOV BD. 2C

DWG. NO. 45B2299-6 REV. O

EQUIP REF. MAIN STEAM LINE DRAIN MOV FCV-1-57

SHEET 25.2 OF 31

REV. O

DATE 3/16/88

COMPUTED BY DYL

DATE 3/16/88

CHECKED BY TAP DATE 3/17/88

CALCULATIONS:

REV. I

PREPARED: JDM 8-1-88

CHECKED: RK 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I \text{ (adjusted)} = \frac{V \text{ (nameplate)}}{V \text{ (operating)}} \times I \text{ (nameplate)}$$

$$I \text{ (adjusted)} =$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\begin{aligned} LRA &= (\text{HP} \times \text{KVA/HP} \times 1000) / (1.73 \times 460) \\ LRA &= \text{AMPS} \end{aligned}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF. -545) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 10.9 / 6.25 = 1.74$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT/1.25 = 1.74 / 1.25 = 1.40 AMPS

CATALOG HEATER SIZE CR123 C1.63A
 $I(m)$ + .47 1.31 'B' ZONE

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \% = + .47 \times 1.25 \times 100\% \\ I(t) = + .54 \text{ AMPS} / 1.31$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE:} \\ (\underline{2.3} \text{ } I(n) / \underline{+ .34} \text{ } I(t)) \times 100 = \frac{\underline{+ .25}}{\underline{1.64}} \% \text{ OVER } 900 \text{ SECS}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE:} \\ (2 \times \underline{2.3} \text{ } I(n) / \underline{+ .34} \text{ } I(t)) \times 100 = \frac{\underline{+ .50}}{\underline{1.64}} \% \text{ } 52-32 \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE:} \\ (\underline{10.9} \text{ MTR LRA} / \underline{+ .34} \text{ } I(t)) \times 100 = \frac{\underline{+ .26}}{\underline{1.64}} \% \text{ } 11.5-17 \text{ SECS}$$

0050P

CALCULATION NO. ED-Q22263-B7324

SHEET 23.3 OF 31

THERMAL OVERLOAD

TER CALCULATION

REV. O

E 3/16/88

BOARD REF 480V

ACTOR MOV BD 2C

COMPUTED BY DYL

3 3/16/88

UNIT # 2

Dwg. No. 45B2299-6 REV. O

1/13

DATE 3/17/88

COMP # 9B

EQUIP PEP. MAIN STEAM LINE DRAIN MOV FCV-1-57

REV. 1

RELEASED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

CHECKED: ORK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times z = 1.47 \times 1.25 \times 95\%$$

$$I(t) = 1.75 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(2.3 \times I(n) / 1.75 \times I(t)) \times 100 = 131 \times 0.02900 \text{ SECS}$

200% MOTOR PLC TO HEATER CURRENT BASE
 $(2 \times 2.3 \times I(n) / 1.75 \times I(t)) \times 100 = 263 \times 0.02900 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(10.9 \times I(n) / 1.75 \times I(t)) \times 100 = 683 \times 0.02900 \text{ SECS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS (1) ASSUMPTION PER PHILADELPHIA GEAR CORP Dwg.
ENTITLED "LIMIT TORQUE MASTER CERTIFICATION I"
STATION 1,2&3 REV. E 8 Dwg. 47A363-1-2
REV. 3

CALCULATION NO. ED-G2268-87324

SHEET 13.4 OF 51

THERMAL OVERLOAD HEATER CALCULATION

REV C

E 3/16/55

BOARD REF 480V

LTOR M&V F.G. 2C

COMPUTED BY D.W.H.

F 2/16/55

UNIT # 2

DWG. NO. ACB2299.6 Rev. 0

CHECKED BY

DATE 3/17/55

COMP # 9B

EQUIP REF. MAIN STEAM LINE PUMP M&V FCV-1-57

REV 1 EDITION 2-1-55

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5. REPLACE HEATER - PROCEED TO SECTION 5 NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

CROSS CHECK

$$I(t) = 1.56 \quad I(m) \times 1.25 \times 100 \times \frac{1}{2}$$

EMERGENCY

$$I(t) = 1.95 \quad \text{AMPS}$$

BUDGET

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2.3 \times 1.95) / 1.95 \times 100 = \frac{1.95}{1.95} \times 100 = 100 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3 \times 1.95) / 1.95 \times 100 = \frac{2.3}{1.95} \times 100 = 120 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(10.9 \times 1.95) / 1.95 \times 100 = \frac{10.9}{1.95} \times 100 = 10.9 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5. NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(m) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 1.56 \times 1.25 \times \frac{1}{2} = 1.95$$

$$I(t) = 1.76 \quad \text{AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(2.3 \times 1.76) / 1.76 \times 100 = \frac{1.76}{1.76} \times 100 = 100 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 2.3 \times 1.76) / 1.76 \times 100 = \frac{2.3}{1.76} \times 100 = 120 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(10.9 \times 1.76) / 1.76 \times 100 = \frac{10.9}{1.76} \times 100 = 10.9 \text{ SECS}$$

CALCULATION NO. ED-G2268-07324

SHEET 23.5 OF 31

THERMAL OVERLOAD CTER CALCULATION

REV. O

BOARD REF 480V CTOR M&V BD 20 COMPUTED BY DUL

2-106/68

UNIT # 2 DWG. NO. 45B2269.6 RE1.0 CHECKED BY 745 DATE 3/1/88

2114/88

COMP # 9B EQUIP REF. MAIN STEAM LINE DRAIN NO. 20-1-57

DATE 3/1/88

REV.1

ENTERED!

3-1-88

CHECKED!

3-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?TIR
2-10-88 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C1.63A
CR123 E1.344OVERLOAD HEATER SETTING 90% 100%COMMENTS: RESET THE INSTALLED TOL HEATERS TO 100%
REPLACE THE INSTALLED TOL HEATERS AS
SHOWN ABOVE

CALCULATION NO. FP Q226B-87324

SHEET 24.1 OF 21

THERMAL OVERLOAD ER CALCULATION

REV. O

3/16/85

BOARD REF 480V RELAY TOR MOV P.D. 2C COMPUTED BY J.W.L DATE 3/16/85
 UNIT # 2 DWG. NO. 45B2299 REV. O CHECKED BY T.R.K DATE 3/17/85
 COMP # 9 E EQUIP REF. MAIN STEAM LINE DRAIN TO CONDENSER MOV -
 MOTOR OPERATED VALVE MOTORS FCV-1-59

WALKDOWN INPUT DATA: (REF # 3)

REV. I TRIPPED: JPM 8-1-88
CHECKED: JRK 8-1-88MOTOR CONTROL CENTER DATA:

STARTER MFG. GE MODEL CR10960 SIZE 1
 O/L RELAY TYPE CR124 HEATER SIZE CR123 C1.18A. SETTING 100%

MOTOR NAMEPLATE DATA: (1)

STARTING TORQUE 5 ft# RPM 1800 DUTY - min.S.P. -
 H.P. 33 VOLTS 440 FLC 0.9 LRA 2.87 PHASE - INS. CLASS -
 NEC CODE LETTER - TEMP RISE - deg C.

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-SH.8

TIME .VS. CURRENT CURVE: REF # 1 SH.5

(1) SEE SH. 24.3

DEFINITIONS

- ^{RELAY}
 I (t) -- HEATER TRIP CURRENT ^{MINIMUM}
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG ^{# RELAY TRIP}
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 % -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
 MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
 REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-G 2268-87324

SHEET 24.2 OF 31

THERMAL OVERLOAD CIRCUIT CALCULATION

REV. O

3/16/88

BOARD REF 480V

3/16/88

UNIT # 2

LTCR NOV 30, 26

COMPUTED BY DIA

3/16/88

COMP # 9E

DWG. NO. 45B22299-6 REV. O

CHECKED BY T.M.

DATE 3/17/88

EQUIP REF. MAIN STEAM LINE DRAIN TO CONDENSER MOV-

CALCULATIONS:

REV. 1 (RECALC'D): JPM 3-1-88

CHECKED: R.K. 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) = \frac{440 \times 0.9}{460} = 0.86$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} = 0.86$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF I-SH-5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 4.87 / 6.25 = 0.78$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = $0.78 / 1.25 = 0.62$ AMPS

CATALOG HEATER SIZE CR 123 60-71A $\frac{7.78}{0.78} = 0.78A$ CO. 71A ZONE 'B'

$$I(m) = \frac{0.62}{0.78} = 0.78A$$

$$I(m) = \frac{0.62}{0.78} = 0.78A$$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100\%}{7.78} = \frac{0.62}{0.78} \times 1.25 \times \frac{100\%}{0.78}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR PLC TO HEATER CURRENT BASE: } (0.86, I(n) / 0.78, I(t)) \times 100 = \frac{100}{0.78} \% \text{ OVER } 900 \text{ SECS}$$

$$200\% \text{ MOTOR PLC TO HEATER CURRENT BASE: } (2 \times 0.86, I(n) / 0.78, I(t)) \times 100 = \frac{200}{0.78} \% \text{ } 82-105 \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } (4.87 \text{ MTR LRA} / 0.78, I(t)) \times 100 = \frac{487}{0.78} \% \text{ } 67-88 \text{ SECS}$$

$$(4.87 \text{ MTR LRA} / 0.78, I(t)) \times 100 = \frac{487}{0.78} \% \text{ } 104-158 \text{ SECS}$$

CALCULATION NO. ED-G2268-87324

THERMAL OVERLOAD

"ER" CALCULATION

BOARD REF 430V

ACTOR MOV 5D 2C

COMPUTED BY DIA - 3/16/58

UNIT 1-2

DWG. NO. 45B2299-L REV. O

SHEET 24.3 OF 31

REV. O

3/16/58

COMP 1-9E

EQUIP REF. MAIN STEAM LINE DRAIN TO CONDENSER MOV-

DATE 3/17/58

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

FCV-1-59

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{I}{I(n)} = \frac{I(n)}{\text{AMPS}} \times 1.25 \times \frac{I}{I(n)}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(\frac{I(n)}{I(t)}) \times 100 = \frac{I(n)}{I(t)} \times 100 = \frac{I(n)}{\text{SECS}}$

200% MOTOR FLC TO HEATER CURRENT BASE
 $(2 \times \frac{I(n)}{I(t)}) \times 100 = \frac{2 \times I(n)}{I(t)} \times 100 = \frac{2 \times I(n)}{\text{SECS}}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(\frac{MTR LRA}{I(t)}) \times 100 = \frac{MTR LRA}{I(t)} \times 100 = \frac{MTR LRA}{\text{SECS}}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS _____

① ASSUMPTION PER P.H.L. GEAR CORP. DWG ENTITLED
 LIMIT TORQUE MASTER CERTIFICATION I, STATION #1, #2, #3
 REV. E (CONTRACT # 68-91062) & 47A368-1-2 REV. 3,
 BASED ON SERIAL NUMBER & ORDER NUMBER GIVEN
 IN THE WALKDOWN DATA.

CALCULATION NO. ED-GZZ68-87324

SHEET 24.4 OF 31

THERMAL OVERLOAD

TER CALCULATION

REV. O

3/16/58

BOARD REF 480V

ACTOR MOV BD 2C COMPUTED BY DYL

3/16/58

UNIT # 2

DWG. NO. LSB2299-6 REV. O CHECKED BY TAKS

DATE 3/17/58

COMP # 9E

EQUIP REF. MAIN STEAM LINE DRAIN TO CONDENSER MOV-

REV. I PREMKT: JAM 8-1-87 CV-1-59

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER
IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5

NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{4} = \text{TRIP AMPS}$$

GR123 C1-18A

$$I(t) = 1.04 I(n) \times 1.25 \times 100\% \frac{1}{4}$$

I(n) = 1.04

$$I(t) = 1.3 \text{ AMPS}$$

ZONE B

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(0.86 I(n) / 1.3 I(t)) \times 100 = 66 \frac{1}{4} 27.2 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 0.86 I(n) / 1.3 I(t)) \times 100 = 132 \frac{1}{4} 27.2 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(1.87 MTR LRA / 1.3 I(t)) \times 100 = 375 \frac{1}{4} 26-33 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.

NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{1}{4} = \text{TRIP AMPS}$$

$$I(t) = I(n) \times 1.25 \times \frac{1}{4} = 1.04 \times 1.25 \times 85\%$$

$$I(t) = 1.11 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(0.86 I(n) / 1.11 I(t)) \times 100 = 7 \frac{1}{4} 27.2 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times 0.86 I(n) / 1.11 I(t)) \times 100 = 155 \frac{1}{4} 27.2 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(1.87 MTR LRA / 1.11 I(t)) \times 100 = 137 \frac{1}{4} 27.2 \text{ SECS}$$

CALCULATION NO. ED-Q2263-87324

SHEET 24.5 OF 31

THERMAL OVERLOAD

ER CALCULATION

REV. O

4/16/88

BOARD REF 480V

ACTOR MSV 5D 2C COMPUTED BY

DIA

4/16/88

UNIT # 2

DWG. NO. 45B2295-6 REV. O CHECKED BY

JHG DATE 4/16/88

4/16/88

COMP # 9E

EQUIP REF. MAIN STEAM LINE DRAIN TO CONDENSER NOV-

FCV - L-59

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REV. I

PREPARED: JHM 4-1-88

CHECKED: RCG 4-8-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 EO.71A CO.71A

OVERLOAD HEATER SETTING 100%

COMMENTS: REPLACE THE INSTALLED TO L HEATERS
WITH THOSE SHOWN ABOVE.

CALCULATION NO. ED-G2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR MOV BD 2C COMPUTED BY

UNIT # 2 DWG. NO. 45B2299-6 REVOCHECKED BY

COMP # 11A EQUIP REF. DRYWELL BLOWERS 2B-5

SHEET 25.1 OF 31

REV. 0

DATE 3/16/88

DIA

DATE 3/16/88

JMB

DATE 3/17/88

REW CONTINUOUS DUTY MOTORS

PREPARED: 9AM 3-1-88
CHECKED: PM 3-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR106EO (4) SIZE 3
O/L RELAY TYPE CR124 HEATER SIZE CR123 F4F, 7B SETTING 100%

MOTOR NAMEPLATE DATA:

H.P. 40 (2) VOLTS 460 (2) FLC 52 (3) PHASE 3 (2) INS. CLASS B (1) NEC CODE G (2)
DUTY (CONT) S.F. 1.0 (1) TEMP RISE 60 (2) DEG C. AMBIENT TEMP - DEG C
0 (2) - SEE SH. 25.3

AMBIENT TEMPERATURE: (REF #8)

MOTOR AMBIENT TEMP 42 DEG C
STARTER AMBIENT TEMP 40 DEG C

EQUIP. LOCATED IN PORTION OF
REACTOR BLDG. WHICH IS NOT
PART OF HARSH ENVIRONMENT.
PER DWG. 45N803-B REJS &
47W22S-102 REV. I

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF #1 - SH. 1) 0.9 TEMP CORRECTION FACTOR (TCF -)
HEATER TABLE: (REF #1 SH. 3)

DEFINITIONS

- RELAY
I (t) -- HEATER TRIP CURRENT ^{MINIMUM}
I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG ^{RELAY TRIP}
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR. (REF #1 SH. 1)
I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT
% -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER MIL (P.M.)

ACCEPTANCE LIMITS:

PROTECTION FROM 115% TO 130% (REF #5)
OVERLOAD HEATERS RANGE FROM 85% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION I (n) = I ADJUSTED = _____ AMPS

CALCULATION NO. ED-Q2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR MOV 50 ZC COMPUTED BY

UNIT # 2 DWG. NO 45B2299-L REV.0 CHECKED BY

COMP # 11A EQUIP REF. DRYWELL FLOWER 2B-S

REV.1 | PREPARED: 8PM 8-1-88
CHECKED: ORR 8-1-88

SHEET 25.2 OF 31

REV 0 DATE 3/16/88

DJA DATE 3/16/88

749 DATE 3/17/88

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HEATER SIZE (REF #5)

$I(n) \times D.F. =$ (USE D.F. PER REF #1 SH 1)

$$52 \quad I(n) \times 0.9 \quad D.F. = \quad 46.8 \quad \text{AMPS}$$

F 65.8 B

CATALOG HEATER SIZE CR123 F56.7B

$$I(m) = 47.0$$

50.2

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

$$\frac{47.0}{50.2} I(m) \times 1.25 \times 100 \% / \frac{52}{47.0} I(n) = \frac{112}{121} \%$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\% * = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$$

$$105 \% * = \frac{\% \text{ PROT} \times 52}{47.0 \times 1.25}, \% \text{ PROT} = 119\%$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 4.

REPLACE HEATER

NO - PROCEED WITH FOLLOWING

PROCEED TO SECTION 4

CR123 F44.7B

I(m) = 42.9

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \% * \text{ TRIP AMPS}$$

$$I(t) = 42.9 \times 1.25 \times 100 \% * = 53.63 \text{ AMPS}$$

CALCULATION NO. ED-Q2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 450V REACTOR M&V PD 26 COMPUTED BY

UNIT # 2 DWG. NO 45B2299.6 REV.0 CHECKED BY

COMP # 11A EQUIP REF. DRY WELL BLOWER 2B-S

SHEET 25.3 OF 31

REV 0

DATE 3/16/88

D/V/U

DATE 3/16/88

T/H/E/R

DATE 3/17/88

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

$$\% \text{ PROTECTION} = I(t) / I(n) \times 100$$

~~$$53.63 I(t) / 52 I(n) \times 100 = 103\%$$~~

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

 YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$\%^* = [\% \text{ PROTECTION} \times I(n)] / [I(n) \times 1.25]$$

~~$$+15\%^* = \frac{103\% \times 52}{42.9 \times 1.25}, 103\% \text{ PROT.} = 119\%$$~~

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE. NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 F65.88OVERLOAD HEATER SETTING +15% / 100%

5. COMMENTS: RESET THE INSTALLED TOL HEATERS TO

+15%, REPLACE THE INSTALLED TOL HEATERS AS SHOWN ABOVE(1) ASSUMPTION PER SECT. 4.3(2) ASSUMPTION BASED ON COMPARISON TO SIMILAR EQUIP. CONNECTED TO COMPT. 1A(3) ASSUMPTION PER NEC ARTICLE 430 TABLE 430.150(4) MCC WALKDOWN DATA INDICATES AN INVALID MODEL NR. ASSUMPTION - MODEL NR. IS SAME AS COMPT. 1A WHICH HAS SIMILAR EQUIP. CONNECTED TO IT.

CALCULATION NO. ED.G2268-57324

SHEET 26.2 OF 31

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

RE 3/16/88

BOARD REF 480

ACTUR NOV BD 2C

COMPUTED BY DYL

TE 3/16/88

UNIT # 2

DWG. NO. 45B2299-6 RELO

CHECKED BY TWS

DATE 3/17/88

COMP # 11C

EQUIP REF. CED WATER TRANSFER M-14-5-EC-1-35-2B

REV. 1 DRAFTED: JDM 8-1-88

CHECKED: JRK 8-1-88

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES / NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES / NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-SH-5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 5.1 / 6.25 = .82$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = .82 / 1.25 = .66 AMPS

CATALOG HEATER SIZE CR123 C0.78A 'B' ZONE

$$I(m) = \frac{0.63}{0.67} = 0.63$$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \underline{\quad} = \frac{0.63}{0.67} \times 1.25 \times \underline{100\%}$$

$$I(t) = \frac{0.79}{0.79} \text{ AMPS}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR PLC TO HEATER CURRENT BASE: } (0.95 \text{ I}(n) / \frac{0.66}{0.79} \text{ I}(t)) \times 100 = \frac{112}{120} \% \text{ over } 50\text{-SECS}$$

$$200\% \text{ MOTCR PLC TO HEATER CURRENT BASE: } (2 \times 0.95 \text{ I}(n) / \frac{0.66}{0.79} \text{ I}(t)) \times 100 = \frac{222}{241} \% \text{ over } 10\text{-SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } (5.1 \text{ MTR LRA} / \frac{0.66}{0.79} \text{ I}(t)) \times 100 = \frac{592}{646} \% \text{ over } 14.5\text{-SECS}$$

0050P

CALCULATION NO. EN-G2268-B7324

THERMAL OVERLOAD CALCULATION

BOARD REF 430V

FACTOR MOV 50 20

SHEET 24.3 OF 72

REV C

E 3/16/88

UNIT # 2

DWG. NO. 45B2292-6 EELC

COMPUTED BY EELC

E 3/16/88

COMP # 11C

EQUIP REP. WATER TRANSFER

CHECKED BY EELC

DATE 3/17/88

REV. 1 APPROVED BY EELC

FCU-25-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? (CHECKED) : RE 3-1-88

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO MEET THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(a) \times 1.25 \times \frac{2}{3} = 0.69 \times 1.25 \times \frac{95}{100}$$

$$I(t) = .82 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$(\frac{.75}{.95} I(a) / \frac{.92}{.82} I(t)) \times 100 = \frac{100}{1.17} = 85.4 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times \frac{.75}{.95} I(a) / \frac{.92}{.82} I(t)) \times 100 = \frac{200}{1.17} = 172.1 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\frac{5.1}{.92} MTR I.RA / \frac{.92}{.82} I(t)) \times 100 = \frac{510}{1.17} = 438.5 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTER'S WITHIN THE OVERLOAD HEATER RANGE?

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREEB07031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS

(1) ASSUMPTION BASED ON COMPARISON OF

ELEC. CHARACTERISTICS OF FCU-17-21 COMP. 4C,

AND DWG. 15-477-3292-3

CALCULATION NO. E.D.-2268-87324

SHEET 10.4 OF 31

THERMAL OVERLOAD

WATER CALCULATION

REV. O

E 3/16/88

BOARD REF 480U

FACTOR MOVE RD 2 C COMPUTED BY DYA

E 3/16/88

UNIT # 2

DWG. NO. 45B2295.6 REV.O

CHECKED BY

DATE 3/17/88

COMP # 11C

EQUIP REF. WATER TRANSFER MOV-2 FCV-B5-SB

REV.I PREPARED: JPM 8-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

CHECKED: VRK 8-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE, PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5. NO - PROCEED WITH FOLLOWING

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(m) \times 1.25 \times \frac{z}{z^*} = \text{TRIP AMPS}$$

$$I(t) = \underline{\quad} I(m) \times 1.25 \times \underline{\quad} \frac{z}{z^*}$$

$$I(t) = \underline{\quad} \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(\underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{ SECS}$$
200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times \underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{ SECS}$$
LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\underline{\quad} \text{MTR LRA} / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 5 NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS

$$I(t) = I(m) \times 1.25 \times \frac{z}{z^*} = \text{TRIP AMPS}$$

$$I(t) = I(m) \times 1.25 \times \frac{z}{z^*} = \underline{\quad} \times 1.25 \times \underline{\quad}$$

$$I(t) = \underline{\quad} \text{AMPS}$$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(\underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{ SECS}$$
200% MOTOR FLC TO HEATER CURRENT BASE:

$$(2 \times \underline{\quad} I(n) / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{ SECS}$$
LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\underline{\quad} \text{MTR LRA} / \underline{\quad} I(t)) \times 100 = \underline{\quad} : \underline{\quad} \text{ SECS}$$

CALCULATION NO. ED-G2268-87324

SHEET 10.5 OF 51

THERMAL OVERLOAD THER CALCULATION

REV. C

E 3/16/88

BOARD REF 480V FACTOR M&V 30% COMPUTED BY DYL

2 3/16/88

UNIT # 2 DWG. NO. 45B2299-6 REV.0 CHECKED BY JTG DATE 3/17/88

COMP # IIC EQUIP REF. WATER TRANSFER M&V-2-FCV-55-BB

REV. 1 DRAFTED: JPM 8-1-88

REVIEWED: JRK 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 C0.78 A

OVERLOAD HEATER SETTING 95% 100%

COMMENTS: THE INSTALLED TOL HEATERS SETTINGS ARE
ACCEPTABLE.

RESET THE INSTALLED TOL HEATERS TO
100%

CALCULATION NO. ED-QIREB-87031

SHEET 27.1 OF 31

THERMAL OVERLOAD CITER CALCULATION

REV. 0

E 3/16/58

BOARD REF 4930A

E 3/16/58

CTC - MAN. S. 22

COMPUTED BY DIV

E 3/16/58

UNIT # - 2

DWG. NO. 455CCFRJ-ZE

CHECKED BY FAB

E 3/17/88

COMP # RGA

EQUIP. REF. REC. RE-LAUNCH EQUALIZER MOV. FCV. 69-53.

MOTOR OPERATED VALVE MOTORS

REV. 1 | HODDREN: JDM 8-1-88

WALKDOWN INPUT DATA: (REF 6.3)

REV. 1 | CHECKED: VRK 8-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR13060 SIZE 1
O/L RELAY TYPE CR124 HEATER-SIZE CR123 C18.03 SETTING 100%

MOTOR NAMEPLATE DATA:

STARTING TORQUE 60 ft-lb RPM 3500 DUTY 15 min.S.F. -
H.P. 6 VOLTS 460 FLC 11.2 LRA 2.5 PHASE 3 (1) INS. CLASS H
NEC CODE LETTER - TEMP RISE 115 deg C.

(1) SEE E 27.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-54.8

TIME VS. CURRENT CURVE: REF# 1-54.5

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT MINIMUM
I (a) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
%* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2268-87324

SHEET #7.2 OF 5/1

THERMAL OVERLOAD

REV. O

E. F. BURGESS

BOARD REF 480V

HEATER CALCULATION

3-31-88/88

UNIT # 2

ACTGR MOU BD 2C

COMPUTED BY DYL

DATE 3/31/88

COMP # RGA

DWG NO. 45B2299-6 REV. O CHECKED BY TMS

DATE 3/31/88

EQUIP REF. RECIRC. HEADED EQUALIZER NOV 7-21-62-33

REV. I PREPARED: JPM 3-4-88

CHECKED: ER 5-4-88

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\text{HP} \times \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CL. VE (REF 1.5W 5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 91.6 / 6.25 = 14.7$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 14.7 / 1.25 = 11.8 AMPS
CATALOG HEATER SIZE CR123 C13.7 B

$$I(m) = \frac{+2.0}{13.8} \text{ AMPS}$$

ZONE
15

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100\%}{13.8} = \frac{+2.0}{13.8} \times 1.25 \times \frac{100\%}{13.8}$$

- C. DETERMINE TRIP TIMES FOR:

$$100\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (\frac{11.2}{13.8} I(n) / \frac{+5.0}{13.8} I(t)) \times 100 = \frac{75}{81} : \text{ OVER } 300 \text{ SECS}$$

$$200\% \text{ MOTOR FLC TO HEATER CURRENT BASE: } (2 \times \frac{11.2}{13.8} I(n) / \frac{+5.0}{13.8} I(t)) \times 100 = \frac{149}{162} : \text{ OVER } 400 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\frac{91.6}{13.8} \text{ MTR LRV} / \frac{+5.0}{13.8} I(t)) \times 100 = \frac{644}{664} : \frac{10.7}{9.4} : \frac{15}{13.5} \text{ SECS}$$

0050P

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 480V

CT 50A MOA SD 22

COMPUTED BY DWA

3/16/88

UNIT # 2

Dwg. No. 45B2299-6 REV. O

CHECKED BY DWA

DATE 3/12/88

COMP # R6A

EQUIP REF. 250IRC HEADER EQUALIZER MOA FCV-68-83

REV.I PREPARED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

CHECKED: RPK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(n) * 1.25 * \frac{t}{T} = \frac{12.0}{14.25} * 1.25 * \frac{95\%}{}$$

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)
 $\left(\frac{11.2}{14.25} I(n) / \frac{14.25}{14.25} I(t) \right) * 100 = \frac{7.9}{15.7} \text{ SECS}$

200% MOTOR PLC TO HEATER CURRENT BASE
 $\left(2 \times \frac{11.2}{14.25} I(n) / \frac{14.25}{14.25} I(t) \right) * 100 = \frac{15.7}{15.7} \text{ OVER 140 SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $\left(\frac{91.5}{14.25} MTR LRA / \frac{14.25}{14.25} I(t) \right) * 100 = \frac{11.7}{11.7} \text{ 0.0 14.5 SEGS}$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIREB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION BASED ON DATA FOR 60 FT^F, 3600

RPM MOTOR ON Dwg. VPF-24K6-20-3

CALCULATION NO. ED-02268-37324
 THERMAL OVERLOAD HEATER CALCULATION
 BOARD REF 480V ACTOR MOV BD 2G COMPUTED BY D.Y.U.
 UNIT # 2 W.G. NO. 4582299-L REV. 0 CHECKED BY PAB DATE 3/17/88
 COMP # 26A EQUIP REF. RECIRC. HEADER EQUALIZER MOV FCV:68-33

SHEET 27.4 OF 31

REV. O

TE 3/16/88

TE 3/16/88

DATE 3/17/88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER
 IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

- YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?
 YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.
 NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER - PROCEED TO SECTION 5
 NO - PROCEED WITH FOLLOWING

GR125C14.03
I(m) = 15.8

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT
 $I(t) = I(m) \times 1.25 \times \frac{1}{2} =$ TRIP AMPS
 $I(e) = 15.8 \times 1.25 \times 100 =$ **
 $I(t) = 19.75$ AMPS

100% MOTOR PLC TO HEATER CURRENT BASE:
 $\frac{11.2}{11.2} I(n) / 19.75 I(t) \times 100 =$ 57 : over 900 SEGS
 (TRIP TIME)
 200% MOTOR PLC TO HEATER CURRENT BASE:
 $(2 \times 11.2) I(n) / 19.75 I(t) \times 100 =$ 113 : over 900 SEGS
 LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $\frac{91.6}{MTR LRA} / 19.75 I(t) \times 100 =$ 464 : 17.5 - 90 SEGS

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

- YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.
 NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$I(t) = I(m) \times 1.25 \times \frac{1}{2} =$ TRIP AMPS
 $I(e) = I(m) \times 1.25 \times \frac{1}{2} = 15.8 \times 1.25 \times 85\%$
 $I(t) = 13.79$ AMPS

100% MOTOR PLC TO HEATER CURRENT BASE:
 $\frac{11.2}{11.2} I(n) / 13.79 I(t) \times 100 =$ 57 : over 900 SEGS
 (TRIP TIME)
 200% MOTOR PLC TO HEATER CURRENT BASE:
 $(2 \times 11.2) I(n) / 13.79 I(t) \times 100 =$ 123 : over 900 SEGS
 LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $\frac{91.6}{MTR LRA} / 13.79 I(t) \times 100 =$ 546 : 13.5 - 19.5 SEGS

CALCULATION NO. ED-32263-37324

SHEET 57.5 OF 51

THERMAL OVERLOAD HEATER CALCULATION

REV. 0

DATE 3/16/88

BOARD REF 48C

FACTOR MOV 30 2C

COMPUTED BY D&G

TE 3/16/88

UNIT # 2

AG. NO. 45B2299-G

REV. 0 CHECKED BY

TE 3/17/88

COMP # RGA

EQUIP REF. RECIRC HEADER EQUALIZER MOV FCV 62-33

REV. 1 DATE: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

CHECKED: RK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123C13.7B

OVERLOAD HEATER SETTING 75% 100%

COMMENTS: REPLACE THE INSTALLED TOL HEATERS WITH
THOSE SHOWN ABOVE

CALCULATION NO. ED-02263-37344

SHEET 28.1 OF 31

THERMAL OVERLOAD CIRCUIT CALCULATION

REV. O

E 3/16/88

BOARD REF 4304

FACTOR MOV BD 2G COMPUTED BY DIAL

E 3/16/88

UNIT # 2

DWG. NO. 45B2299-6 REV. O CHECKED BY JMB

DATE 3/17/88

COMP # 263

EQUIP REF. RECIRC PUMP 29 SUCTION MOV FCV G8-77

MOTOR OPERATED VALVE MOTORS

WALKDOWN INPUT DATA: (REF # 3)

REV. I

PREPARED: JPM 8-1-88
CHECKED: JRK 8-1-88MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR124 SIZE 1.
 O/L RELAY TYPE CR124 HEATER SIZE CR123 118.03 SETTING 25%
 100%.

MOTOR NAMEPLATE DATA:

STARTING TORQUE 60 ft-lb RPM 3500 DUTY 15 min.S.P. -
 H.P. 3 VOLTS 460 FLC 11.2 LRA 91.6(2) PHASE 3 INS. CLASS H.
 NEC CODE LETTER — TEMP RISE 115 deg C.

MANUFACTURER'S DATA:

HEATER TABLE: REF # -1- 54.3

(1) SEE SH. 28.3

TIME VS. CURRENT CURVE: REF# 1-54.3

(2) SEE SH. 28.3

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT ~~MINIMUM~~
- I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG ~~RELAY TRIP~~
- 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
- I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
- ~~I*~~ PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15 SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION, REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2268-87524

SHEET 25.2 OF 1

THERMAL OVERLOAD

TER CALCULATION

REV. O

BOARD REF 480V

KTR NOV 50 22

COMPUTED BY DYL

3/16/88

UNIT 1 2

W.G. NO. 45B2299-6 REV. O

CHECKED BY TMB

3/16/88

COMP & RGE

EQUIP REF. EECIRC. PUMP 2B SECTION

MOV FCB 28-77

3/16/88

CALCULATIONS:

REV. I

REFRED: JUN 3-1-88

3/16/88

CHECKED: JPK 3-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate}) \times I(\text{nameplate})}{V(\text{operating})}$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$LRA = (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$LRA = \underline{\quad} \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 91.6 / 6.25 = 14.7$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 14.7 / 1.25 = 11.8 AMPS

CATALOG HEATER SIZE CR123 C13.7B ZONE B
 $I(m) = \frac{+8.0}{13.8} \text{ 11.0}$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{\%}{100} = \frac{+8.0}{13.8} \times 1.25 \times \frac{100\%}{13.8}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
 $(\frac{11.2}{13.8} I(n) / \frac{+5.0}{13.8} I(t)) \times 100 = \frac{75}{81} \% \text{ OVER } 900 \text{ SECs}$

200% MOTOR FLC TO HEATER CURRENT BASE: 12c
 $(2 \times \frac{11.2}{13.8} I(n) / \frac{+5.0}{13.8} I(t)) \times 100 = \frac{149}{162} \% \text{ OVER } 4 \text{ SECs}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(\frac{91.6}{13.8} \text{ MTR LRA} / \frac{+5.0}{13.8} I(t)) \times 100 = \frac{211}{664} \% \text{ } 0.7 - 15.8 \text{ SECs}$
 $9.4 - 13.5$

CALCULATION NO. ED-22263-57324

SHEET 23.3 OF 81

THERMAL OVERLOAD HEATER CALCULATION

REV. C

E 3/16/88

BOARD REF 430X

E 3/16/88

UNIT # 2

FACTOR MOV ED 2C COMPUTED BY DGA

E 3/16/88

COMP # RGE

DWG. NO. 45B2299-6 REV. 0 CHECKED BY TBS DATE 3/17/88 P

EQUIP REF. RECIRC. PUMP 2B SUCTION MOV FCV-68-77

REV. I 13:14KED 1 PM 3-19-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? (CHECKED) WORK 8-1-88

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{\%}{\%} = \frac{2.0}{14.25} \times 1.25 \times \frac{95\%}{}$$

$$100\% \text{ MOTOR FLG TO HEATER CURRENT BASE: } (11.2 \text{ I}(n) / 14.25 \text{ I}(t)) \times 100 = \frac{11.2}{14.25} \times 100 = \frac{73.6}{14.25} = 5.2 \text{ SECS}$$

$$200\% \text{ MOTOR FLG TO HEATER CURRENT BASE } (2 \times 11.2 \text{ I}(n) / 14.25 \text{ I}(t)) \times 100 = \frac{22.4}{14.25} \times 100 = \frac{157}{14.25} = 10.9 \text{ SECS}$$

$$\text{LOCKED ROTOR AMPS TO HEATER CURRENT BASE: } (91.6 \text{ MTR LRA} / 14.25 \text{ I}(t)) \times 100 = \frac{91.6}{14.25} \times 100 = \frac{637}{14.25} = 44.5 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO QIRBED07031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION BASED ON COMPARISON OF ELEC. CHARACTERISTICS TO FCV-68-33 (COMP'T. RGA)

② ASSUMPTION BASED ON DATA FOR 60 FT., 3600

RPM MOTOR ON DWG VPF-2486-20-3

THERMAL OVERLOAD HEATER CALCULATION

REV. O

ATE 3/16/55

BOARD REF 480 FACTOR MOV BD 2C COMPUTED BY DUL
UNIT # 2 WG. NO. 45B2292-6 REV.O CHECKED BY DUL ATE 3/17/88
COMP # RGE EQUIP REF. RECIRC PUMP 2B SUCTION MOV FCV-GA-77

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER
IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

RELI TRIPRED: JPM 8-1-88
CHECKED: URK 8-1-88

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.

NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATER. PROCEED TO SECTION 5

NO - PROCEED WITH FOLLOWING

2103-613.03
I_(n) = 15.8

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 15.8 \times 1.25 \times \frac{1}{2} = 19.75$$

$$I(t) = 19.75 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\frac{11.2}{19.75} \times 100 = 57 \text{ \% } \text{ (TRIP TIME)} \text{ 0.52E-900 SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\frac{22}{19.75} \times 100 = 113 \text{ \% } \text{ (TRIP TIME)} \text{ 0.52E-900 SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\frac{21.6}{19.75} \times 100 = 114 \text{ \% } \text{ (TRIP TIME)} \text{ 17.5-26 SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.

NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$$I(t) = I(n) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 15.8 \times 1.25 \times \frac{1}{2} = 15.8 \times 1.25 \times 50\%$$

$$I(t) = 15.79 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\frac{11.2}{15.79} \times 100 = 71 \text{ \% } \text{ (TRIP TIME)} \text{ 0.52E-900 SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$\frac{22}{15.79} \times 100 = 133 \text{ \% } \text{ (TRIP TIME)} \text{ 0.52E-900 SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\frac{21.6}{15.79} \times 100 = 136 \text{ \% } \text{ (TRIP TIME)} \text{ 15.5-19.5 SECS}$$

THERMAL OVERLOAD HEATER CALCULATION

REV. 0

DATE 3/16/88

BOARD REF 482 FACTOR MOV P.D. 2C COMPUTED BY DHL
 UNIT 1 2 G. NO. 45B2299-1 REV. 0 CHECKED BY TIG
 COMP & RGE EQUIP REF. RECIRC. PUMP 2B SUCTION MOV FCV -65 -77

E 3/16/88
E 3/17/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
 IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REUI [] PREPARED: JAM 8-1-88
 CHECKED: RK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
 BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123C13.7B

OVERLOAD HEATER SETTING 95% 100%

COMMENTS: REPLACE THE INSTALLED TL HEATERS WITH
THOSE SHOWN ABOVE.

CALCULATION NO. ED-Q1003-37804

SHEET 29.1 OF 31

THERMAL OVERLOAD

HEATER CALCULATION

REV. D

E 3/16/83

BOARD REF 453

FACTOR MAN 50 SEC COMPUTED BY DLK E 3/16/83

UNIT # 2 DWG. NO. 45B2299-6 REV. 0

CHECKED BY RJS DATE 3/17/83

COMP # RSB EQUIP REF. RECIRC. PUMP 2A SUCTION VALVE = 24V 621

MOTOR OPERATED VALVE MOTORS

REV. I TRIP RELAY: 6MA 2-1-88

WALKDOWN INPUT DATA: (REF # 3)

CHECKED: URK 3-1-88

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL C123 C13.7B(3) SIZE 1
O/L RELAY TYPE CR124 HEATER SIZE CR123 C13.7B(3) SETTING 100% (3)

MOTOR NAMEPLATE DATA:

STARTING TORQUE 60 ① ft# RPM 3500 DUTY 15 min. S.P. —
H.P. 8 VOLTS 460 FLC 11.2 LRA 91.6@PHASE 3 INS. CLASS —
NEC CODE LETTER — TEMP RISE 115 deg C.

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-SH.8
TIME VS. CURRENT CURVE: REF# 1-SH.5

① SEE SH.29.3

② SEE SH.29.3

③ SEE SH.29.3

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT MINIMUM
I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG RELAY TRIP
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
%* -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER MIL (2.0%)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.

200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 3 MINUTES

MOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.

NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREEB87031 FOR INSTRUCTIONS.

CALCULATION NO. ED-Q2163-57324

SHEET 29.2 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV. O

E 3/16/88

BOARD REF 4303 FACTOR MOV 130 2.6 COMPUTED BY DLA

E 3/16/88

UNIT # 2 DWG. NO. 4222290.6 REV. O CHECKED BY JMB DATE 3/17/88

COMP # 533 EQUIP REF. EEC1CC LUMP 2A SECTION VALUE REV. 68-1

CALCULATIONS: REV. I ISSUED: JPM 8-1-88
CHECKED: RKE 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate}) \times I(\text{nameplate})}{V(\text{operating})}$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION $I(n) = I(\text{adjusted}) =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\begin{aligned} LRA &= (\underline{\quad} \text{HP} \times \underline{\quad} \text{KVA/HP} \times 1000) / (1.73 \times 460) \\ LRA &= \underline{\quad} \text{AMPS} \end{aligned}$$

3. SELECTION MOTOR OVERLOAD HEATER

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF 1-54.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (LRA) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 91.6 / 6.25 = 14.7$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 14.7 / 1.25 = 11.8 AMPS
CATALOG HEATER SIZE CR123 C 13.7 B

$$I(n) = \frac{+2.0}{+2.0} \text{ 11.0} \quad \text{ZONE } 3$$

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$\begin{aligned} I(t) &= I(n) \times 1.25 \times \frac{\%}{100\%} = \frac{+2.0}{+2.0} \times 1.25 \times \frac{100\%}{13.8} \\ I(t) &= \frac{+15.0}{+13.8} \text{ AMPS} \end{aligned}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(\frac{11.2}{13.8} I(n) / \frac{+5.0}{+5.0} I(t)) \times 100 = \frac{75}{81} \% \text{ over } 900 \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \frac{11.2}{13.8} I(n) / \frac{+5.0}{+5.0} I(t)) \times 100 = \frac{149}{162} \% \text{ over } 120 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:
 $(\frac{91.6}{13.8} \text{ MTR LRA} / \frac{+5.0}{+5.0} I(t)) \times 100 = \frac{644}{664} \% \text{ over } 9.4 - 13.5 \text{ SECS}$

CALCULATION NO. ED-G2268-37324

THERMAL OVERLOAD

TER CALCULATION

BOARD REF 4500

FACTR NOV 130 2C COMPUTED BY DUL

UNIT # 2

DWG. NO. 45B2299-6 REV. O CHECKED BY JAS DATE 3/17/87

COMP # 253

EQUIP REF. EECIRC PUMP 2A SUCTION VALVE FCV-68-1

SHEET 29.3 OF 31

REV. O

E 3/16/88

E 3/16/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS? REV. I DEPARED: JPM 8-1-88
CHIEFED: VRK 8-1-88 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{\%}{100} = 12.0 \times 1.25 \times 95\%$$

$$I(t) = 14.25 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE + (TRIP TIME)

$$\left(\frac{11.2}{14.25} I(n) / 14.25 I(t) \right) \times 100 = 78.6 \approx 0.782900 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE (2 * 11.2 I(n) / 14.25 I(t)) * 100 = 157 \approx 0.782400 \text{ SECS}

LOCKED ROTOR AMPS TO HEATER CURRENT BASE + (91.6 MTR LRA / 14.25 I(t)) * 100 = 643 \approx 9.9 - 14.5 \text{ SECS}

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4. NO REFER TO QIREEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.COMMENTS ① ASSUMPTION BASED ON COMPARISON OF ELEC CHARACTERISTICS TO FCV-68-33 COMPT. RGA② ASSUMPTION BASED ON DATA FOR 60 FT², 3600 RPM MOTOR ON DWG VPF-2486-20-3③ DESIGNED TOL HEATER SIZE USED DUE TO LACK OF MCC WALKDOWN DATA.

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

TE 3/16/58

BOARD REF 490

REACTOR NOV 50 2C COMPUTED BY DLU

REV. 0

TE 3/16/58

UNIT # 2

DWG. NO. 45B2299-6 REV. 0 CHECKED BY TMB

DATE 3/17/58

COMP # RSB

EQUIP REF. RECIRC PUMP 7A SUCTION VALVE = CV-68-1

REV. 0

TE 3/16/58

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

JFM 7/12/58

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3? YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5. NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.

REPLACE HEATERS

 NO - PROCEED WITH FOLLOWING (3) SEE SH. 29.3
 PROCEED TO SECTION 5

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$I(t) = I(m) \times 1.25 \times Z^* = \text{TRIP AMPS}$

$I(t) = I(m) \times 1.25 \times Z^*$

$I(t) = \text{AMPS}$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
($I(n)$ / $I(t)$) $\times 100 =$ % SECS200% MOTOR FLC TO HEATER CURRENT BASE:
($2 \times$ $I(n)$ / $I(t)$) $\times 100 =$ % SECSLOCKED ROTOR AMPS TO HEATER CURRENT BASE:
(MTR LRA / $I(t)$) $\times 100 =$ % SECS

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

 YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 5 NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS

$I(t) = I(m) \times 1.25 \times Z^* = \text{TRIP AMPS}$

$I(t) = I(m) \times 1.25 \times Z^* = \text{ } \times 1.25 \times \text{ }$

$I(t) = \text{AMPS}$

100% MOTOR FLC TO HEATER CURRENT BASE: (TRIP TIME)
($I(n)$ / $I(t)$) $\times 100 =$ % SECS200% MOTOR FLC TO HEATER CURRENT BASE:
($2 \times$ $I(n)$ / $I(t)$) $\times 100 =$ % SECSLOCKED ROTOR AMPS TO HEATER CURRENT BASE:
(MTR LRA / $I(t)$) $\times 100 =$ % SECS

CALCULATION NO. ED-G 226 S-37324

SHEET - 7.5 OF 51

THERMAL OVERLOAD HEATER CALCULATION

REV. 0

DATE 3/16/88

BOARD REF 480W

FACTOR - ~~MAOV~~ BD 2C

COMPUTED BY DLA

E 3/16/88

UNIT # 2

AG. NO. 45B2299-6 REV. 0 CHECKED BY TJS

IE 3/17/88

COMP # RBB

EQUIP REF. RECIRC. PUMP 2A SUCTION VALVE FCV-68-1

REV. I PREDICTED: JPM 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

[CHECKED] : JRK 8-1-88

SPR
8/1/88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C2123 C13.73

OVERLOAD HEATER SETTING 75% 100%

COMMENTS: REPLACE THE INSTALLED TOL HEATERS & SETTINGS
WITH THE DESIGNED HEATERS & SETTING
SHOWN ABOVE.

0050P

CALCULATION NO. ED-G2268-87324

SHEET 30.1 OF 31

THERMAL OVERLOAD CALCULATION

REV. 0

E 3/16/88

BOARD REF 480V ACTOR MOV BD 2C COMPUTED BY DYA
UNIT # 2 DWG. NO. 4E32299-6 REV. 0 CHECKED BY TWS DATE 3/17/88
COMP # R3E EQUIP REF. CEC/SC. HEADER EQUALIZER VALVE FCV-68-35
MOTOR OPERATED VALVE MOTORS

E 3/16/88

WALKDOWN INPUT DATA: (REF # 3)REV. 1 PREPARED: JPM 8-1-88
CHECKED: RK 8-1-88MOTOR CONTROL CENTER DATA:STARTER MFGR. GE MODEL CR105C0 SIZE 1
O/L RELAY TYPE CR124 HEATER SIZE CR123.C1B.0B SETTING 100%MOTOR NAMEPLATE DATA:STARTING TORQUE 60 ft# RPM 3500 DUTY 15 min.S.P. -
H.P. 8 VOLTS 460 FLC 11.2 LRA 91.6 ① PHASE 3 ② INS. CLASS H.
NEC CODE LETTER - TEMP RISE 115 deg C.

① SEE SH.30.3

MANUFACTURER'S DATA:

HEATER TABLE: REF # 1-54.5

TIME VS. CURRENT CURVE: REF# 1-54.5

DEFINITIONS

RELAY

- I (t) -- HEATER TRIP CURRENT ~~MINIMUM~~
 I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY
 1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
 I (n) -- MOTOR NAMEPLATE FULL LOAD CURRENT
 %* PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

ACCEPTANCE LIMITS:

OVERLOAD HEATER SETTING RANGE FROM 85% to 115%

OVERLOAD HEATERS SHALL BE SELECTED TO TRIP AS FOLLOWS:

MOTOR NAMEPLATE FULL-LOAD CURRENT TIMES SERVICE FACTOR: NOT LESS THAN THE
MOTOR DUTY RATING (15 MINUTE TYPICAL) EXCEPT AS NOTED BELOW.200% OF MOTOR NAMEPLATE FULL-LOAD CURRENT: \geq 2 MINUTES AND \leq 8 MINUTESMOTOR NAMEPLATE LOCKED ROTOR CURRENT: \geq 10 SECONDS AND \leq 15 SECONDS WITH 15
SECONDS BEING PREFERABLE.NOTE: IF THE ABOVE SELECTION CRITERIA CANNOT BE SATISFIED FOR A UNIQUE APPLICATION,
REFER TO QIREFB87031 FOR INSTRUCTIONS.

CALCULATION NO. E7-R2265-87324

SHEET 50.2 OF 51

THERMAL OVERLOAD

HEATER CALCULATION

REV. O

TE 3/16/88

BOARD REF 460

FACTOR MOI BD 2C

COMPUTED BY DIA

REV. O

TE 3/16/88

UNIT # 2

DWG. NO. 45B2299-6 REV. O

CHECKED BY THIS

DATE 3/17/88

COMP / RSE

EQUIP REF. RECIRC. HEADER EQUALIZER VALVE FCV-68-35

REV. I

DRAFTED: JPM 8-1-88

CALCULATIONS:

CHECKED: RKE 8-1-88

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I \text{ (adjusted)} = \frac{V \text{ (nameplate)}}{V \text{ (operating)}} \times I \text{ (nameplate)}$$

$$I \text{ (adjusted)} =$$

FOR THIS CALCULATION $I(n) = I \text{ ADJUSTED} =$ AMPS

2. LOCKED ROTOR CURRENT CALCULATION REQUIRED YES NO

IF YES;

CALCULATION FOR LRA USING CODE LETTER:

$$\text{LRA} = (\text{HP} \times \text{KVA/HP} \times 1000) / (1.73 \times 460)$$

$$\text{LRA} = \text{AMPS}$$

3. SELECTION MOTOR OVERLOAD HEATER.

- A. USING THE OVERLOAD RELAY TIME-CURRENT CURVE (REF. 5W.5) LOCATE THE 15 SECOND POINT AND DETERMINE THE CURRENT RATING MULTIPLE.
RECORD VALUE 6.25

$$\text{TRIP CURRENT} = (\text{LRA}) / (\text{MULTIPLE OF CURRENT RATING})$$

$$\text{TRIP CURRENT} = 91.6 / 6.25 = 14.7$$

USING THE ABOVE TRIP CURRENT AS THE MAXIMUM CURRENT, SELECT OVERLOAD HEATER
HEATER SELECTION CURRENT = TRIP CURRENT / 1.25 = 14.7 / 1.25 = 11.8 AMPS
CATALOG HEATER SIZE CR123 C13.7B

$$I(m) = \frac{12.0}{11.0}$$

RELAY

- B. DETERMINE HEATER TRIP CURRENT WITH PERCENT SETTING AT 100%

$$I(t) = I(m) \times 1.25 \times \frac{100}{100} = \frac{12.0}{11.0} \times 1.25 \times \frac{100}{100}$$

$$I(t) = \frac{12.0}{11.0} \text{ AMPS}$$

- C. DETERMINE TRIP TIMES FOR:

100% MOTOR FLC TO HEATER CURRENT BASE:
 $(\frac{11.2}{13.8} I(n) / \frac{12.0}{11.0} I(t)) \times 100 = \frac{75}{81} \approx \text{OVER } 900 \text{ SECS}$

200% MOTOR FLC TO HEATER CURRENT BASE:
 $(2 \times \frac{11.2}{13.8} I(n) / \frac{12.0}{11.0} I(t)) \times 100 = \frac{149}{162} \approx \text{OVER } 120 \text{ SECS}$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(\frac{91.6}{13.8} \text{ MTR LRA} / \frac{12.0}{11.0} I(t)) \times 100 = \frac{441}{664} \approx \frac{2.7-15.9}{9.4-13.5} \text{ SECS}$$

CALCULATION NO. ED-G2268-87324

THERMAL OVERLOAD

HEATER CALCULATION

BOARD REF 430A

FACTOR MOV BD 26

COMPUTED BY D.J.L.

SHEET 10.3 OF 31

REV. O

FE 3/16/88

UNIT # 2

DWG. NO. 45B2299-L REV. O CHECKED BY T.H.S. DATE 3/17/88

COMP # 233

EQUIP REF. FEC1/2C. HEADER EQUALIZER VALVE FCV-63-35

REV. I

INITIALED: JIM 8-1-88
CHECKED: ORK 8-1-88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIME WITH THE ACCEPTANCE LIMITS.

$$I(t) = I(n) \times 1.25 \times \frac{t}{T} = 12.0 \times 1.25 \times \frac{95\%}{100}$$

$$I(t) = 14.25 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE: (TRIP TIME)

$$(11.2 \text{ I}(n) / 14.25 \text{ I}(t)) \times 100 = 73.6 \text{ : over } 500 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE

$$(2 \times 11.2 \text{ I}(n) / 14.25 \text{ I}(t)) \times 100 = 157 \text{ : over } 140 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$(91.6 \text{ NTR I}(n) / 14.25 \text{ I}(t)) \times 100 = 648 \text{ : } 9.8 - 14.5 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED PROCEED TO SECTION 4.

NO REFER TO CIRBEB87031 FOR INSTRUCTIONS CONCERNING ACCEPTANCE CRITERIA.

COMMENTS ① ASSUMPTION BASED ON DATA FOR 60 FT², 3600

RPM MOTOR ON DWG VPF-2486-20-2

THERMAL OVERLOAD HEATER CALCULATION

REV. O

TE 3/16/88

BOARD REF 4800

FACTOR AND BD RC COMPUTED BY DYN

E 3/16/88

UNIT # 2

DWG. NO. 45B2299-L REV. O CHECKED BY 748 DATE 3/17/88

PJP

COMP # P8.E

EQUIP REF. RECIRC HEADER EQUALIZER VALVE FCV-68-35

REV. I CHECKED: JPM 8-1-88

4. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

REV. I CHECKED: JPM 8-1-88

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 3?

YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 3?YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 5.NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 5.REPLACE HEATER - PROCEED TO SECTION 5NO - PROCEED WITH FOLLOWINGI_(t) = 15.8I_(a) = 15.8

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$$I(t) = I(a) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = 15.8 \times 1.25 \times \frac{1}{2} =$$

$$I(t) = 19.75 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{11.2}{19.75} \right) I(t) / 19.75 I(t) \times 100 = \frac{57}{19.75} = \frac{57}{19.75} \times 900 \text{ SECS}$$

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times \frac{11.2}{19.75}) I(t) / 19.75 I(t) \times 100 = \frac{113}{19.75} = \frac{113}{19.75} \times 900 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\left(\frac{91.6}{19.75} \right) MTR LRA / 19.75 I(t) \times 100 = \frac{464}{19.75} = \frac{464}{19.75} \times 900 \text{ SECS}$$

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS?

YES - THE OVERLOAD HEATER SIZE AND TRIP SETTING HAVE BEEN PROPERLY SELECTED. PROCEED TO SECTION 5.NO - DETERMINE IF PERCENT SETTING CAN BE ADJUSTED TO BRING THE TRIP TIMES WITHIN THE ACCEPTANCE LIMITS.

$$I(t) = I(a) \times 1.25 \times \frac{1}{2} = \text{TRIP AMPS}$$

$$I(t) = I(a) \times 1.25 \times \frac{1}{2} = 15.8 \times 1.25 \times \frac{1}{2} = 35\%$$

$$I(t) = 15.8 \text{ AMPS}$$

100% MOTOR PLC TO HEATER CURRENT BASE:

$$\left(\frac{11.2}{15.8} \right) I(t) / 15.8 I(t) \times 100 = \frac{67}{15.8} = \frac{67}{15.8} \times 900 \text{ SECS}$$

(TRIP TIME)

200% MOTOR PLC TO HEATER CURRENT BASE:

$$(2 \times \frac{11.2}{15.8}) I(t) / 15.8 I(t) \times 100 = \frac{133}{15.8} = \frac{133}{15.8} \times 900 \text{ SECS}$$

LOCKED ROTOR AMPS TO HEATER CURRENT BASE:

$$\left(\frac{91.6}{15.8} \right) MTR LRA / 15.8 I(t) \times 100 = \frac{544}{15.8} = \frac{544}{15.8} \times 900 \text{ SECS}$$

CALCULATION NO. EID-G2263-87524

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 430A

REATOR NO. 110V BD 2C

COMPUTED BY DYL

UNIT # 2

AC. NO. 45B2299-L REV. 0 CHECKED BY JAS DATE 3/1/88

COMP ESE EQUIP REF. EEC/EC. HEATER EQUALIZER VALUE FCV-58-35

SHEET 30.3 OF 31

REV. O

TE 3/1/88

E 3/1/88

ARE ALL TRIP TIMES WITHIN THE ACCEPTANCE LIMITS AND
IS PERCENT SETTING WITHIN THE OVERLOAD HEATER RANGE?

REV. I
RECORDED: JPM 8-1-88

CHECKED: JPK 8-1-88

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.

~~NO~~ THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL
BE REPLACED WITH THE ONE SELECTED IN SECTION 3.

5. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD
HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE CR123 C13.7B

OVERLOAD HEATER SETTING 95% 100%

COMMENTS: REPLACE THE INSTALLED TOL HEATERS WITH
THOSE SHOWN ABOVE

CALCULATION NO. ED-G2268-87324

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR MOU BD 2C COMPUTED BY DYL DATE 3/16/65
UNIT # 2 DWG. NO. 45B2295-6 RELO CHECKED BY TJB DATE 3/17/65
COMP # R11A EQUIP REF. PSC WATER HEAD TANK PUMPS 2A

REV. 0 HETARER: JFM 8-1-88
CONTINUOUS DUTY MOTORS CHECKED: RK 8-1-88

WALKDOWN INPUT DATA: (REF # 3)

MOTOR CONTROL CENTER DATA:

STARTER MFGR. GE MODEL CR106C0 SIZE 1 ①
O/L RELAY TYPE 23124 HEATER SIZE CR123 C 7.78A ② SETTING 100 1/2(2)

MOTOR NAMEPLATE DATA:

H.P. 5 VOLTS 460. FLC 6.9 PHASE 3 INS. CLASS B NEC CODE J
DUTY 100% S.F. 1.15 TEMP RISE - DEG C. AMBIENT TEMP 65 DEC C

① SEE SH. 31.3

② SEE SH. 31.3

AMBIENT TEMPERATURE: (REF #8)

MOTOR AMBIENT TEMP \leq 40 DEG C
STARTER AMBIENT TEMP \leq 40 DEG C

EQUIP. LOCATED IN PORTION OF REACTOR
BLDG. WHICH IS NOT PART OF HARSH
ENVIRONMENT PER DWGS 45N2750-21
REV. 5 #47W225-103 Rev.1

MANUFACTURER'S DATA:

O/L FACTOR (D.F.) (REF# 1 SH 1) 1 TEMP CORRECTION FACTOR (TCF) —
HEATER TABLE: (REF #1 SH. 8)

DEFINITIONS

RELAY

I (t) -- HEATER TRIP CURRENT MINIMUM
I (m) -- MAXIMUM FULL LOAD CURRENT CORRESPONDING TO THE HEATER CATALOG # RELAY
1.25 -- GENERAL ELECTRIC'S MULTIPLYING FACTOR FOR ESTABLISHING MAXIMUM TRIP CURRENT
D.F. -- MOTOR DERATING FACTOR BASED ON MOTOR SERVICE FACTOR. (REF #1 SH 1)
I(n) -- MOTOR NAMEPLATE FULL LOAD CURRENT OR ADJUSTED MOTOR FULL LOAD CURRENT
% -- PERCENT SETTING OF THE OVERLOAD HEATER, EXPRESSED IN PER UNIT (P.U.)

DO
NOT
DELETE

ACCEPTANCE LIMITS:

PROTECTION FROM 125% TO 140% (REF #5)
OVERLOAD HEATERS RANGE FROM 85% to 115%

CALCULATIONS:

1. MOTOR FULL LOAD CURRENT ADJUSTMENT REQUIRED YES NO
IF YES;

$$I(\text{adjusted}) = \frac{V(\text{nameplate})}{V(\text{operating})} \times I(\text{nameplate})$$

$$I(\text{adjusted}) =$$

FOR THIS CALCULATION I (n) = I ADJUSTED = _____ AMPS

0051T

CALCULATION NO. ED-G226B-37524

THERMAL OVERLOAD HEATER CALCULATION

BOARD REF 480V REACTOR NOV 152 UC COMPUTED BY

UNIT # 2 DWG. NO. 45B2295-L REV. O CHECKED BY

COMP # R1A EQUIP REF. PSC-WATER HEAD TANK PUMP 24

SHEET 31.2 OF 31

REV O DATE 3/16/88

DJA DATE 3/16/88

THB DATE 3/17/88

REV. (1) PREPARED: JPM 8-1-88

CHECKED: RK 8-1-88

2. MOTOR OVERLOAD HEATER SELECTION

(A) CALCULATION OF HEATER SIZE (REF #5)

$I(n) \times D.F. =$ (USE D.F. PER REF #1 SH 1)

6.9 $I(n) \times$ 1 $D.F. =$ 6.9 AMPS

CATALOG HEATER SIZE CR123 7.7A

$I(m) =$ 7.7
6.93

(B) CALCULATION FOR OVERLOAD HEATER SETTING:

CALCULATE % PROTECTION USING HEATER SETTING OF 100%

6.92 $I(n) \times 1.25 \times 100$ $\% =$ 6.9 $I(n) =$ 125 %
6.93

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

✓ YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

 NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$\% = [\% \text{ PROTECTION} \times I(n)] / [I(m) \times 1.25]$

$\% =$

$\% =$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

 YES - THE OVERLOAD HEATER SIZE AND SETTING HAVE BEEN PROPERLY SELECTED.

 NO - THE OVERLOAD HEATER HAS BEEN IMPROPERLY SIZED.

3. EVALUATION OF INSTALLED MOTOR OVERLOAD HEATER

IS THE HEATER SIZE THE SAME AS CALCULATED IN SECTION 2B?

 YES - IS THE HEATER SETTING THE SAME AS CALCULATED IN SECTION 2B?

 YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE. PROCEED TO SECTION 4.

 NO - THE INSTALLED OVERLOAD HEATER SIZE IS ACCEPTABLE, FIELD TO RESET SETTING. PROCEED TO SECTION 4.

REPLACE HEATER

✓ NO - PROCEED WITH FOLLOWING (2) SEE SH-31.3
PROCEED TO SECTION 4

EVALUATION OF INSTALLED OVERLOAD HEATER TRIP CURRENT

$I(t) = I(m) \times 1.25 \times \% =$ TRIP AMPS

$I(t) =$ $I(m) \times 1.25 \times$ $\% =$ AMPS

CALCULATION NO. ED-G2243-37324

SHEET 31.3 OF 31

THERMAL OVERLOAD HEATER CALCULATION

REV O

DATE

3/16/88

BOARD REF 480V REACTOR M215D 2C COMPUTED BY

DYL

DATE

3/16/88

UNIT 2

DWG. NO. 45B2209-6 Rev C CHECKED BY

MWB

DATE

3/17/88

COMP R11A

EQUIP REF. DEC WATER LEAD TANK PUMP 2A

REV I

RECD:

DATE

3-1-88

EVALUATION OF INSTALLED OVERLOAD HEATER PROTECTION.

CHECKED:

RK

3-1-88

$$\% \text{ PROTECTION} = I(t) / I(n) \times 100$$

$$\frac{I(t)}{I(n)} \times 100 =$$

DOES THE % PROTECTION FALL WITHIN THE ACCEPTANCE LIMITS?

YES - THE INSTALLED OVERLOAD HEATER SIZE AND SETTING ARE ACCEPTABLE.NO - DETERMINE HEATER SETTING TO MEET THE % PROTECTION ACCEPTANCE CRITERIA BY USING THE CLOSEST ACCEPTANCE LIMIT VALUE.

$$z^* = [\% \text{ PROTECTION} \times I(n)] / [I(n) \times 1.25]$$

$$z^* =$$

$$z^* =$$

IS % SETTING WITHIN THE OVERLOAD HEATER RANGE?

YES - THE INSTALLED OVERLOAD HEATER SHALL BE RESET TO THIS VALUE.NO - THE INSTALLED OVERLOAD HEATER WAS INCORRECTLY SIZED AND SHALL BE REPLACED WITH THE ONE SELECTED IN SECTION 2B.

4. THIS CALCULATION HAS VERIFIED THAT THE SIZE AND SETTING OF THE OVERLOAD HEATER HAVE BEEN CORRECTLY DETERMINED TO BE:

OVERLOAD HEATER SIZE C8.67A
CR123 E7.76A

OVERLOAD HEATER SETTING 100%

5. COMMENTS: REPLACE INSTALLED TOL HEATERS WITH THE DESIGNED

TOL HEATERS & SETTINGS SHOWN ABOVE

① ASSUMPTION PER REF #1 SH.S

② DESIGNED HEATER SIZE & SETTING USED

DUE TO LACK OF MCC WALKDOWN DATA.

TV-72164A
TSD-E034

EBASCO SERVICES INC
CONTROL OF CALCULATION AND CHECK LIST
(CCCL) Sheet 1 of 2

ED-Q22168-87324

NO	TASK	TASK PERFORMED	LEAD ENGINEER CR DESIGNEE
1	Assign Calculation Preparer	Name: DAN J AMATO DJA 3/16/88	AL LANE 3/16/88
2	Advise preparer to follow technical direction provided by discipline branch (guides, standards, instructions, procedures etc) during pre-preparation of calculation.	YES DJA 3/16/88	YES AL 3/16/88
3	Enter calculation identifier/title into calculation log.	YES DJA 3/16/88	YES 3/16/88
4	Assign calculation verifier.		
5	Is Interface review required? Yes or No DJA 3/16/88 THB 3/17/88	Name: TRILECTHAN H. GHATT a) If "NO" Explain no input from other disciplines required, No impact to other disciplines. b) If "YES", with whom?	
6	Does the calculation contain unverified assumptions?	Yes No DJA 3/16/88 If "YES" THB 3/17/88	
7	Was computer program used in performing calculation?	Yes No DJA 3/16/88 If "YES" answer questions below:	
7.1	If "YES" is code verified, documented and controlled in accordance with Ebasco Procedure A-30.	Controlled User's Manual No. N/A	
7.2	Was the calculation verified independent of unverified code.	If "YES" Evidence: N/A	
7.3	Is software version, computer input and computer output documented?	If "NO" Resolve: N/A Evidence: N/A	

TV-72164A
TSD-E034

EBASCO SERVICES INC
CONTROL OF CALCULATION AND CHECK LIST
(CCCL) Page 2 of 2

ED-Q2268-87324

ITEM NO	ITEM	YES OR NO PREPARER	YES OR NO VERIFIER
8	Is the problem stated clearly and completely?	YES DJL 3/16/88	YES TMB 3/17/88
9	Is design input clearly identified and complete?	YES DJL 3/16/88	YES TMB 3/17/88
10	Are references correctly listed?	YES DJL 3/16/88	YES TMB 3/17/88
11	Are formula and equation, defined and referenced with the exception of AISC or Blodgett?	YES DJL 3/16/88	YES TMB 3/17/88
12	Is conclusion statement added, clear and correct?	YES DJL 3/16/88	YES TMB 3/17/88
13	Is the drawing revision number identified in the calculation?	YES DJL 3/16/88	YES TMB 3/17/88
14	Are all comments by the checker incorporated or otherwise reconciled?	YES DJL 3/16/88	YES TMB 3/17/88
15	Are all attachments identified and labeled?	YES DJL 3/16/88	YES TMB 3/17/88
16	Are superceded original calculations marked superceded, or made part of historical copy?	N/A DJL 3/16/88	N/A TMB 3/17/88
17	Are all calculation sheets initialed and dated by preparer and verifier?	YES DJL 3/16/88	YES TMB 3/17/88
18	Are all calculation sheets and attachments arranged properly?	YES DJL 3/16/88	YES TMB 3/17/88
19	Is the calculation log properly filled out?	YES DJL 3/16/88	YES TMB 3/17/88
20	Is the cover sheet properly filled out?	YES DJL 3/16/88	YES TMB 3/17/88
21	Is construction and operation experiences considered?	N/A DJL 3/16/88	N/A TMB 3/17/88
22	Are appropriate calculation methods used?	YES DJL 3/16/88	YES TMB 3/17/88
23	Is output verified to be reasonable compared to inputs?	YES DJL 3/16/88	YES TMB 3/17/88
24	Is adequate system performance, safety margins, etc considered?	YES DJL 3/16/88	YES TMB 3/17/88
25	Are unverified assumptions that require subsequent verification, identified?	YES DJL 3/16/88	YES TMB 3/17/88

DRAWINGS

480V REACTOR MOV Board 2A
DCA- H1239-003, -004, -005, -006
480 V REACTOR MOV BOARD 2C
DCA- H1239-011, -012, -013
480V SHUTDOWN AUX POWER
45N 779-2, -3, -6, -7, -14, -15, 16, -17

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRICAL

DRAWING CHANGE AUTHORIZATION

ECN — DCN H1239
 REVISION — REVISION 2
 SH #: 21 OF 68

R000	COMP NO	MANUFACTURER R000	STARTER		O/L HEATER ELEMENT		
			MODEL NO.	SIZE	NUMBER	O/O SETTING	A8
▲	1A	GE	CR10950(F)	1	CR123C9.55A	100	100
▲	1A	GE	CR10950(S)	1	CR123C3.26A	100	100
▲	1D	GE	CR109CO	1	CR123C18.0B	100	100
▲	1D	GE	CR106CO	1	CR123C18.0B	100	100
▲	1D	GE	CR106CO	1	CR123C18.0B	100	100
▲	2B	GE	CR109EO	3	CR123F31.4B	100	100
▲	4A	GE	CR106CO	1	CR123C7.78A	100	100
▲	4B	GE	CR109CO	1	CR123C11.8A	100	100
▲	4C	GE	CR109CO	1	CR123C2.68A	100	100
▲	4E	GE	CR106CO	1	CR123C5.92A	100	100
▲	5C	GE	CR109CO	1	CR123C2.68A	100	100
▲	5E	GE	CR106CO	1	CR123C5.92A	100	100
▲	6A	GE	CR106CO	1	CR123C8.67A	100	100
▲	6C	GE	CR109CO	1	CR123C3.26A	100	100

480V REACTOR MOV BD 2A

R000

NOTES

3. ▲ - DENOTES MCC COMP. NO. DESIGN VERIFIED FOR UNIT 2 RESTART.

Q

000	REVISED: REPLACED HEATER ELEMENTS & ADJUSTED SETTING AS NOTED. ADDED : NOTE S. SUPERSEDES DCA-B-2-P7010-002 - REV 000	Handled P. Banks	John P. T. <i>[Signature]</i>
REV.	DRAFTED BY	CHECKED BY	
THIS CHANGE IS <input checked="" type="checkbox"/> SAFETY RELATED <input type="checkbox"/> NOT RELATED TO NUCLEAR SAFETY			
BASE DRAWING		REV.	DCA NUMBER
2 - 4582239-2		000	DCA-H1239-003 200

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRIC

DRAWING CHANGE AUTHORIZATION

ECN DCN H1239
 REVISION REVISION 4
 SH #: 22 OF 68

COMP NO	MANUFACTURER	STARTER		O/L HEATER ELEMENT		
		MODEL NO.	SIZE	NUMBER	O/O SETTING	
					A8	B8
6E GE	CR109CO	1	CR123C1.63A	100	100	100
7B GE	CR109CO	1	CR123C8.67A	100	100	100
7C GE	CR109CO	1	CR123C3.26A	100	100	100
7E GE	CR109CO	1	CR123C1.63A	100	100	100
8C GE	CR109CO	1	CR123C8.67A	100	100	100
9B2 GE	CR109CO	1	CR123C1.18A	100	100	100
9D GE	CR109CO	1	CR123C1.18A	100	100	100
9E GE	CR109CO	1	CR123C1.18A	100	100	100
10A GE	CR109FO	4	CR123F91.4B	100	100	100
10A GE	R000 CR109CO	1	CR123C3.01A	100	100	100
11A GE	CR109CO	1	CR123C8.67A	100	100	100
11B GE	CR109CO	1	CR123C1.63A	100	100	100
11C GE	CR109CO	1	CR123C5.92A	100	100	100
12B GE	CR109CO	1	CR123C1.63A	100	100	100

480V REACTOR MOV BD 2A

Q

000	REVISED: REPLACED HEATER ELEMENTS & ADJUSTED SETTING AS NOTED SUPERCEDES DCA-E-2-P7010-002 & 013 REV 000	<i>Marked P. Punched</i>	<i>John P. Timmeyman</i>
REV.		DRAFTED BY	CHECKED BY

THIS CHANGE IS SAFETY RELATED NOT RELATED TO NUCLEAR SAFETY

BASE DRAWING	REV.	DCA NUMBER	REV.
2 - 45B2299-2	000	DCA-H1239-004	000

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRICAL

DRAWING CHANGE AUTHORIZATION

ECN DCN H1239
REVISION REVISION A
SH #: 23 OF 68

480V REACTOR MOY BD'2A

000	REVISED : REPLACED ELEMENTS & ADJUSTED SETTING AS NOTED SUPERSEDES DCA- M-2-P7010-013 REV 000	Hannah P. Powell John P. Thompson	
REV.	DRAFTED BY	CHECKED BY	
THIS CHANGE IS <input checked="" type="checkbox"/> SAFETY RELATED <input type="checkbox"/> NOT RELATED TO NUCLEAR SAFETY			
BASE DRAWING	REV	DCA NUMBER	REV.
2-4532299-2	000	DCA-41239-005	000

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRICAL

CHANGE AUTHORIZATION

ECN - DSN 41239
REVISION - REVISION A
SH #: 24 OF 0c

480V REACTOR MOV BD 2A

NOTES

- = DENOTES MCC COMP. NO. DESIGN VERIFIED FOR UNIT 2 RESTART.

2000

REvised, Replaced Heater
Elements & Adjusted Setting
as noted added: Note 2.
Supercedes PCA-E-2-P7010-
0003-Rev 000

Trivikram P.P. [S]

John P. Tammemäesten

23

DRAFTED
BY

CHECKED
BY

THIS CHANGE IS SAFETY RELATED NOT RELATED TO NUCLEAR SAFETY

BASE DRAWING

20

DCA NUMBER

70

2 - 45 B2299-3

000

DCA-H-239-006

10

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRICAL

DRAWING CHANGE AUTHORIZATION

ECN - DCN H1239
 REVISION - REVISION A
 SH # : 29 OF 68

R000	COMP NO	MANUFACTURER	STARTER		O/L HEATER ELEMENT		O/O SETTING
			MODEL NO.	SIZE	NUMBER	AG	
▲	IA	GE	CR106EO	3	CR123F65.8B100	100	
▲	ID	GE	CR109FO	4	CR123F91.4B100	100	
▲	3C	GE	CR109CO	1	CR123C1.84A100	100	
▲	3E	GE	CR109CO	1	CR123C0.36A100	100	
▲	4A	GE	CR106CO	1	CR123C1.48A100	100	
▲	4B	GE	CR109CO	1	CR123C12.5B100	100	
▲	4C	GE	CR109CO	1	CR123C0.78A100	100	
▲	4E	GE	CR109CO	1	CR123C0.36A100	100	
▲	5B	GE	CR109CO	1	CR123C0.39A100	100	
▲	5C	GE	CR109CO	1	CR123C1.18A100	100	
▲	5E	GE	CR109CO	1	CR123C0.78A100	100	
▲	6B	GE	CR109CO	1	CR123C0.39A100	100	
▲	6C	GE	CR109CO	1	CR123C1.18A100	100	
▲	6E	GE	CR109CO	1	CR123C1.63A100	100	

480V REACTOR MOV BD 2C

R000

R000

NOTES

3. ▲ - DENOTES MCC COMP. NO. DESIGN VERIFIED FOR UNIT 2 RESTART.

Q

000	REVISED: REPLACED HEATER ELEMENTS & ADJUSTED SETTING AS NOTED, ADDED; NOTE 3 SUPERCEDES DCA-E-2-P7010-006, REV 000	Harold P. Paschall	John P. Tomaszewski
REV.	.	DRAFTED BY	CHECKED BY
THIS CHANGE IS <input checked="" type="checkbox"/> SAFETY RELATED <input type="checkbox"/> NOT RELATED TO NUCLEAR SAFETY			
BASE DRAWING		REV.	DCA NUMBER
2 - 45B2299 - 6		000	DCA-H1239-011
			000

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRICAL

DRAWING CHANGE AUTHORIZATION

ECN - DCN H-1239
 REVISION - REVISION A
 SH #: 30 OF 68

COMP NO	MANUFACTURER	STARTER		O/L HEATER ELEMENT		
		MODEL NO.	SIZE	NUMBER	O/O SETTING	
					AG	BG
7A GE	CR106CO	1	CR123C12.53	100	100	
7B GE	CR109CO	1	CR123C0.39A	100	100	
7C GE	CR109CO	1	CR123C1.84A	100	100	
7E GE	CR109CO	1	CR123C1.84A	100	100	
8B GE	CR109CO	1	CR123C0.39A	100	100	
8C GE	CR109CO	1	CR123C1.84A	100	100	
8E GE	CR109CO	1	CR123C1.84A	100	100	
9B GE	CR109CO	1	CR123C1.63A	100	100	
9E GE	CR109CO	1	CR123C0.71A	100	100	
11A GE	CR106CO	3	CR123FG5.8B	100	100	
11C GE	CR109CO	1	CR123C0.78A	100	100	
R6A GE	CR109CO	1	CR123C13.7B	100	100	R000
R6E GE	CR109CO	1	CR123C13.7B	100	100	
R8B GE	CR109CO	1	CR123C13.7B	100	100	

480V REACTOR MOV BD 2C

Q

000	REVISED: REPLACED HEATER ELEMENTS & ADJUSTED SETTING AS NOTED. SUPERCEDES DCA-E-2-P7010-006&015 REV 000	Hanshad P. Patel	John P. Tomaszewski
REV.		DRAFTED BY	CHECKED BY

THIS CHANGE IS SAFETY RELATED NOT RELATED TO NUCLEAR SAFETY

BASE DRAWING	REV.	DCA NUMBER	REV.
2-45B2299-6	000	DCA-H1239-012	000

BROWNS FERRY NUCLEAR PLANT

DISCIPLINE: ELECTRICAL

DRAWING CHANGE AUTHORIZATION

ECN DCN H1239
REVISION REVISION A
SH #: 31 OF 68

480V REACTOR MOV BD 2C

Q

000	REVISED: REPLACED HEATER ELEMENTS & ADJUSTED SETTING AS NOTED. SUPERCEDES DCA-E-2-P7010-015 REV 000	<i>Hanshad P. Patel</i>	
REV.		DRAFTED BY	
		CHECKED BY	
THIS CHANGE IS <input checked="" type="checkbox"/> SAFETY RELATED <input type="checkbox"/> NOT RELATED TO NUCLEAR SAFETY			
BASE DRAWING	REV.	DCA NUMBER	REV.
2-45B2299-6	000	DCA-H1239-013	000

**OVERSIZE
DOCUMENT
PAGE PULLED**

SEE APERTURE CARDS

NUMBER OF OVERSIZE PAGES FILMED ON APERTURE CARDS

**APERTURE CARD/HARD COPY AVAILABLE FROM RECORD SERVICES BRANCH
FTS 492 - 8989**