

TABLE 3.3.2-3

ISOLATION SYSTEM INSTRUMENTATION RESPONSE TIME

<u>TRIP FUNCTION</u>	<u>RESPONSE TIME (Seconds)#</u>
<u>A. AUTOMATIC INITIATION</u>	
<u>1. PRIMARY CONTAINMENT ISOLATION</u>	
a. Reactor Vessel Water Level	
1) Low, Level 3	NA
2) Low Low, Level 2	$< 1.0^*/< 13^{(a)**}$
b. Drywell Pressure - High	$< 13^{(a)}$
c. Main Steam Line	
1) Radiation - High ^(b)	$< 1.0^*/< 13^{(a)**}$
2) Pressure - Low	$< 2.0^*/< 13^{(a)**}$
3) Flow - High	$< 0.5^*/< 13^{(a)**}$
d. Main Steam Line Tunnel Temperature - High	NA
e. Condenser Vacuum - Low	NA
f. Main Steam Line Tunnel Δ Temperature - High	NA
<u>2. SECONDARY CONTAINMENT ISOLATION</u>	
a. Reactor Building Vent Exhaust Plenum Radiation - High ^(b)	$< 13^{(a)}$
b. Drywell Pressure - High	$< 13^{(a)}$
c. Reactor Vessel Water Level - Low, Level 2	$< 13^{(a)}$
d. Fuel Pool Vent Exhaust Radiation - High ^(b)	$< 13^{(a)}$
<u>3. REACTOR WATER CLEANUP SYSTEM ISOLATION</u>	
a. Δ Flow - High	$< 13^{(a)##}$
b. Heat Exchanger Area Temperature - High	NA
c. Heat Exchanger Area Ventilation Δ T-High	NA
d. SLCS Initiation	NA
e. Reactor Vessel Water Level - Low Low, Level 2	$< 13^{(a)}$
<u>4. REACTOR CORE ISOLATION COOLING SYSTEM ISOLATION</u>	
a. RCIC Steam Line Flow - High	$< 13^{(a)###}$
b. RCIC Steam Supply Pressure - Low	$< 13^{(a)}$
c. RCIC Turbine Exhaust Diaphragm Pressure - High	NA
d. RCIC Equipment Room Temperature - High	NA
e. RCIC Steam Line Tunnel Temperature - High	NA
f. RCIC Steam Line Tunnel Δ Temperature - High	NA
g. Drywell Pressure - High	NA
h. RCIC Equipment Room Δ Temperature - High	NA
<u>5. RHR SYSTEM STEAM CONDENSING MODE ISOLATION</u>	
a. RHR Equipment Area Δ Temperature - High	NA
b. RHR Area Cooler Temperature - High	NA
c. RHR Heat Exchanger Steam Supply Flow High	NA

8604160335 860410
PDR ADDCK 05000373
P PDR

April 10, 1986

DISTRIBUTION:

~~Docket No.~~ 50-373
NRC PDR
Local PDR
PRC System
NSIC
BWD-3 r/f
ABournia (4)
EHylton (2)
EAdensam
Attorney, OELD
CMiles
RDiggs
JPartlow
BGrimes
EJordan
LHarmon
TBarnhart (4)