



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-361

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 143
License No. NPF-10

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee) dated March 6, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9811020017 981026
PDR ADDCK 05000361
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-10 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 143, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and is to be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James W. Clifford, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: October 26, 1998

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 143 TO FACILITY OPERATING LICENSE NO. NPF-10

DOCKET NO. 50-361

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by Amendment number and contains marginal lines indicating the areas of change.

REMOVE

INSERT

3.4-34

3.4-34

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> 1. Only required to be performed when the SDCS Relief Valve isolation valve pair is inoperable. 2. The power-lock open requirement is satisfied either with the AC breakers open for valve pair 2HV9337 and 2HV9339 or the regulating transformer output breakers open for valve pair 2HV9377 and 2HV9378, whichever valve pair is OPERABLE. <p style="text-align: center;">-----</p> <p>SR 3.4.12.1.4 Verify the OPERABLE SDCS Relief Valve isolation valve pair (valve pair 2HV9337 and 2HV9339, or valve pair 2HV9377 and 2HV9378) is in the power-lock open condition.</p>	<p>12 hours</p>
<p>SR 3.4.12.1.5 Verify that SDCS Relief Valve isolation valves 2HV9337, 2HV9339, 2HV9377, and 2HV9378 are open when the SDCS Relief Valve is used for overpressure protection.</p>	<p>72 hours</p>
<p>SR 3.4.12.1.6 Verify SDCS Relief Valve Setpoint.</p>	<p>In accordance with the Inservice Testing Program</p>



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN CALIFORNIA EDISON COMPANY

SAN DIEGO GAS AND ELECTRIC COMPANY

THE CITY OF RIVERSIDE, CALIFORNIA

THE CITY OF ANAHEIM, CALIFORNIA

DOCKET NO. 50-362

SAN ONOFRE NUCLEAR GENERATING STATION, UNIT NO. 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 134
License No. NPF-15

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern California Edison Company, et al. (SCE or the licensee) dated March 6, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C(2) of Facility Operating License No. NPF-15 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendix A and the Environmental Protection Plan contained in Appendix B, as revised through Amendment No. 134, are hereby incorporated in the license. Southern California Edison Company shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This license amendment is effective as of the date of its issuance and is to be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



James W. Clifford, Senior Project Manager
Project Directorate IV-2
Division of Reactor Projects III/IV
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: October 26, 1998

ATTACHMENT TO LICENSE AMENDMENT

AMENDMENT NO. 134 TO FACILITY OPERATING LICENSE NO. NPF-15

DOCKET NO. 50-362

Revise Appendix A Technical Specifications by removing the page identified below and inserting the enclosed page. The revised page is identified by Amendment number and contains marginal lines indicating the areas of change.

REMOVE

INSERT

3.4 34

3.4-34

SURVEILLANCE REQUIREMENTS (continued)

SURVEILLANCE	FREQUENCY
<p style="text-align: center;">-----NOTES-----</p> <ol style="list-style-type: none"> 1. Only required to be performed when the SDCS Relief Valve isolation valve pair is inoperable. 2. The power-lock open requirement is satisfied either with the AC breakers open for valve pair 3HV9337 and 3HV9339 or the regulating transformer output breakers open for valve pair 3HV9377 and 3HV9378, whichever valve pair is OPERABLE. <p style="text-align: center;">-----</p> <p>SR 3.4.12.1.4 Verify the OPERABLE SDCS Relief Valve isolation valve pair (valve pair 3HV9337 and 3HV9339, or valve pair 3HV9377 and 3HV9378) is in the power-lock open condition.</p>	<p>12 hours</p>
<p>SR 3.4.12.1.5 Verify that SDCS Relief Valve isolation valves 3HV9337, 3HV9339, 3HV9377, and 3HV9378 are open when the SDCS Relief Valve is used for overpressure protection.</p>	<p>72 hours</p>
<p>SR 3.4.12.1.6 Verify SDCS Relief Valve Setpoint.</p>	<p>In accordance with the Inservice Testing Program</p>