Fermi 2 6400 North Dixie Hwy., Newport, Michigan 48166 Tel: 313.586.5201 Fax: 313.586.4172

## **Detroit Edison**



October 26, 1998 NRC-98-0159

U. S. Nuclear Regulatory CommissionAttention: Document Control DeskWashington D C 20555

References: 1)

1) Fermi 2

NRC License No. NPF-43 NRC Docket No. 50-341

- 2) NRC Generic Letter 96-01, dated January 10, 1996
- 3) DECo Letter to NRC, "Detroit Edison Response to NRC Generic Letter 96-01", dated April 18, 1996, NRC-96-0045

Subject: Completion of NRC Generic Letter 96-01 Actions

Generic Letter 96-01 (Reference 2) requested that addressees perform comparisons of specified plant logic and schematic drawings against plant surveillance test procedures to ensure that all portions of the specified logic circuitry are adequately covered in the surveillance procedures. The Generic Letter also requested that surveillance procedures be modified as necessary for complete testing to comply with the Technical Specifications. Detroit Edison's initial response (Reference 3) to this Generic Letter indicated that the requested actions had been completed in the course of correcting self-identified testing deficiencies.

Generic Letter 96-01 acknowledged that licensees may have performed the requested reviews. For these licensees, the Generic Letter suggested that any modifications made to these logic circuits should be reviewed. Detroit Edison described its plans for additional reviews and actions intended to ensure that the affected logic circuits remain adequately covered by surveillance test procedures. These additional reviews and actions have been performed, thereby completing all necessary actions for Generic Letter 96-01.

9811020207 981026 PDR ADDCK 05000341 P PDR 16

Axo 7

USNRC NRC-98-0159 Page 2

Should you have any questions regarding this response, please contact Mr. Norman K. Peterson at (734) 586-4258.

Sincerely,

B. L. Burgess cc:

A. J. Kugler

NRC Resident Office

Regional Administrator, Region III

I, DOUGLAS R. GIPSON, do hereby affirm that the foregoing statements are based on facts and circumstances which are true and accurate to the best of my knowledge and belief.

DOUGLAS R. GIPSON Senior Vice President

On this day of <u>Ctaller</u> 1998 before me personally appeared Douglas R. Gipson, being first duly sworn and says that he executed the foregoing as his free act and deed.

Notary Public

ROSALIE A. ARMETTA NOTARY PUBLIC - MONROE COUNTY, MI MY COMMISSION EXPIRES 10/11/99

Reselie arnette