



Log # TXX-88487
File # 10110
910.3
Ref. # 10CFR50.55(e)

June 1, 1988

William G. Council
Executive Vice President

U. S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION
DOCKET NOS. 50-445 AND 50-446
AMBIENT TEMPERATURE EFFECTS ON MSIV ACTUATORS
SDAR: CP-87-19 (SUPPLEMENTAL REPORT)

Gentlemen:

On January 18, 1988, we notified you via our final report TXX-88104 of a deficiency involving the ambient temperature effects on Main Steam Isolation Valve (MSIV) actuators. This is a supplemental report to status the corrective actions implemented to date.

The Unit 2 MSIV actuators were sent to Rockwell International for repairs and have now been returned to CPSES and installed in Unit 1, in accordance with TXX-88104. However Unit 2 corrective action as stated in TXX-88104 has been revised in that the Unit 1 actuators will be reworked on site rather than in the vendor's shop prior to installation on the Unit 2 MSIVs. The anticipated completion date for the Unit 2 activities (January 1, 1989) has not changed.

Very truly yours,

W. G. Council

W. G. Council

By: *D. R. Woodlan*
D. R. Woodlan
Docket Licensing Manager

MCP/amb

c-Mr. R. D. Martin, Region IV
Resident Inspectors, CPSES (3)

IER7
1/0