

APPENDIX A
NOTICE OF VIOLATION

Gulf States Utilities
River Bend Station

Docket: 50-458
Operating License: NPF-47

During an NRC inspection conducted on April 11-15, 1988, violations of NRC requirements were identified. The violations involved the failure to follow procedures for daily and weekly reviews of radiation work permits and failure to maintain procedures. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1988), the violations are listed below:

- A. Technical Specification 6.8.1 requires written procedures to be established, implemented, and maintained covering activities referenced in Appendix A of Regulatory Guide 1.33-1978. Procedure RSP-0200, "Radiation Work Permits," requires, in Section 6.6, that radiation protection personnel will review and update radiological survey data daily and radiation protection foreman/designee will review active radiation work permits weekly.

Contrary to the above, on April 14, 1988, the NRC inspector determined that during the period September 1, 1987, through January 1, 1988, that radiation protection personnel did not review and update radiological survey data daily and radiation protection foreman/designee did not review active radiation work permits weekly.

This is a Severity Level V violation. (Supplement I)(458/8810-01)

- B. Technical Specification 6.8.1 requires that written procedures be maintained covering activities referenced in Appendix A of Regulatory Guide 1.33-1978. Procedure RSP-0200, "Radiation Work Permits," requires that personnel initiate a radiation work permit (Attachment 1) and radiation work permit addendum (Attachment 3).

Contrary to the above, on April 14, 1988, the NRC inspector determined the licensee had revised the radiation work permit and radiation work permit addendum in November 1987 without revising Attachments 1 and 3 to Procedure RSP-0200.

This is a Severity Level V violation. (Supplement I)(458/8810-02)

Pursuant to the provisions of 10 CFR 2.201, Gulf States Utilities is hereby required to submit to this office, within 30 days of the date of the letter transmitting this Notice, a written statement or explanation in reply, including for each violation: (1) the reason for the violations if admitted, (2) the corrective steps which have been taken and the results achieved,

(3) the corrective steps which will be taken to avoid further violations, and
(4) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending the response time.

Dated at Arlington, Texas,
this 10th day of June 1988.