



GPU Nuclear Corporation  
 Post Office Box 480  
 Route 441 South  
 Middletown, Pennsylvania 17057-0191  
 717 944-7621  
 TELEX 84-2386  
 Writer's Direct Dial Number:

June 6, 1988  
 C311-88-2071

US Nuclear Regulatory Commission  
 Attn: Document Control Desk  
 Washington, DC 20555

Dear Sir:

Three Mile Island Nuclear Station, Unit 1 (TMI-1)  
 Operating License No. DPR-50  
 Docket No. 50-289  
 Response to NRC Bulletin 88-03

GPU has reviewed NRC Bulletin 88-03 for applicability to TMI-1. There are no GE latching-type HFA relays installed in Class 1E applications at TMI-1.

There are GE HFA relays installed in the on-site 230KV substation control building in non-Class 1E applications. The relays in these applications are outside the scope of this bulletin and will be inspected per the GE Service Advice Letters as deemed appropriate.

Sincerely,

H. D. Haskill  
 Vice President & Director, TMI-1

HDH/SMO/spb:1177A

cc: R. Hernan  
 R. Conte  
 W. Russell

Sworn and subscribed to  
 before me this 6<sup>th</sup> day of  
June, 1988.

Notary Public

SHARON P. BROWN, NOTARY PUBLIC  
 MIDDLETOWN TOWNSHIP, DAUPHIN COUNTY  
 MY COMMISSION EXPIRES JUNE 22, 1990  
 Member, Pennsylvania Association of Notaries

TEll  
 1/0

GPU Nuclear Corporation is a subsidiary of the General Public Utilities Corporation

8806140294 880606  
 PDR ADOCK 05000289  
 Q JCD