

ATTACHMENT

PROPOSED CHANGE TO APPENDIX A  
TECHNICAL SPECIFICATION TO OPERATING LICENSES  
NPF-11 AND NPF-18

REVISED PAGES:

NPF-11  
3/4 1-10

NPF-18  
3/4 1-10

8604170125 860404  
PDR ADOCK 05000373  
P PDR

REACTIVITY CONTROL SYSTEM

SURVEILLANCE REQUIREMENTS

---

4.1.3.5 Each control rod scram accumulator shall be determined OPERABLE:

- a. At least once per 7 days by verifying that the indicated pressure is greater than or equal to 940 psig unless the control rod is inserted and disarmed or scrambled.
- b. At least once per 18 months by:
  1. Performance of a:
    - a) CHANNEL FUNCTIONAL TEST of the leak detectors, and
    - b) CHANNEL CALIBRATION of the pressure detectors, with the alarm setpoint 940 ~~+ 30~~ psig on decreasing pressure.

↑  
⊇

REACTIVITY CONTROL SYSTEM

SURVEILLANCE REQUIREMENTS

4.1.3.5 Each control rod scram accumulator shall be determined OPERABLE:

- a. At least once per 7 days by verifying that the indicated pressure is greater than or equal to 940 psig unless the control rod is inserted and disarmed or scrambled.
- b. At least once per 18 months by:
  - 1. Performance of a:
    - a) CHANNEL FUNCTIONAL TEST of the leak detectors, and
    - b) CHANNEL CALIBRATION of the pressure detectors, with the alarm setpoint 940 ~~10~~ psig on decreasing pressure.

