

***** NRC OPERATING STATUS REPORT COMPLETED BY REACTOR ENGINEERING *****

1. DOCKET.....50-423 OPERATING STATUS
2. REPORTING PERIOD...MAY 1988 OUTAGE + ONLINE HOURS... 0.0 + 744.0 = 744.0
3. UTILITY CONTACT.....A. I. ELMS 203-444-9388
4. LICENSED THERMAL POWER..... 3411
5. NAMEPLATE RATING (GROSS MWE)..... 1,253 MW
6. DESIGN ELECTRICAL RATING (NET MWE)..... 1,133.6
7. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE)..... 1,197.0
9. MAXIMUM DEPENDABLE CAPACITY (NET MWE)..... 1,141.9
9. IF CHANGES OCCUR ABOVE SINCE LAST REPORT, REASONS ARE.....
N/A
10. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE).....N/A
11. REASON FOR RESTRICTION, IF ANY....N/A

MILLSTONE #
UNIT 3 #

	MONTH	YEAR TO DATE	CUMULATIVE TO DATE
	=====	=====	=====
12. HOURS IN REPORTING PERIOD	744.0	3,647.0	18,479.0
13. NUMBER OF HOURS THE REACTOR WAS CRITICAL	744.0	2,508.0	14,271.5
14. REACTOR RESERVE SHUTDOWN HOURS	0.0	20.2	246.2
15. HOURS GENERATOR ONLINE	744.0	2,316.9	13,907.4
16. UNIT RESERVE SHUTDOWN HOUR	0.0	0.0	0.0
17. GROSS THERMAL ENERGY GENERATED (MWH)	2,524,662.0	7,585,566.0	45,864,998.4
18. GROSS ELECTRICAL ENERGY GENERATED (MWH)	886,435.5	2,648,001.0	15,857,274.0
19. NET ELECTRICAL ENERGY GENERATED (MWH)	850,352.2	2,508,992.7	15,112,625.6
20. UNIT SERVICE FACTOR	100.0	63.5	75.3
21. UNIT AVAILABILITY FACTOR	100.0	63.5	75.3
22. UNIT CAPACITY FACTOR (USING MDC NET)	100.1	60.2	71.5
23. UNIT CAPACITY FACTOR (USING DER NET)	99.1	59.6	70.9
24. UNIT FORCED OUTAGE RATE	0.0	14.0	9.4
25. UNIT FORCED OUTAGE HOURS	0.0	375.7	1,450.2

SHUTDOWNS SCHEDULED OVER NEXT SIX MONTHS (TYPE, DATE, AND DURATION OF EACH).....
N/A

IF CURRENTLY SHUTDOWN, ESTIMATED STARTUP DATE.....N/A

IE24/1

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-423
 UNIT Millstone Unit 3
 DATE 06-07-1988
 COMPILED BY A. L. SIMS 203-444-5388

MONTH MAY

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	1.148	16	1.157
2	1.149	17	1.154
3	1.150	18	1.160
4	1.152	19	1.148
5	1.156	20	1.149
6	1.148	21	1.150
7	1.149	22	1.146
8	1.152	23	1.147
9	1.150	24	1.149
10	1.150	25	1.145
11	1.058	26	1.125
12	1.145	27	1.145
13	1.154	28	1.143
14	1.097	29	1.148
15	1.151	30	1.143
		31	1.143

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-423
 UNIT Millstone Unit No. 3
 DATE June 7, 1988
 COMPLETED BY A. Elns
 TELEPHONE (203) 444-5388

REPORT MONTH MAY 1988

Page 1 of 1

No.	Date	Type (1)	Duration (Hours)	Reason (2)	Method of Shutting Down Reactor (3)	Licensee Event Report #	System Code	Component Code	Cause and Corrective Action to Prevent Recurrence
None									

1
 F: Forced
 S: Scheduled

2
 Reason:
 A - Equipment Failure (Explain)
 B - Maintenance or Test
 C - Refueling
 D - Regulatory Restriction
 E - Operator Training & License Examination
 F - Administrative
 G - Operational Error (Explain)
 H - Other (Explain)

3
 Method:
 1 - Manual
 2 - Manual Scram
 3 - Automatic Scram
 4 - Continued from previous month
 5 - Power Reduction 5 (Duration = 0)
 9 - Other (Explain)

4
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensed Event Report (LER) File (NUREG-0161)

 Exhibit I - Same Source

NORTHEAST UTILITIES



THE CONNECTICUT LIGHT AND POWER COMPANY
WESTERN MASSACHUSETTS ELECTRIC COMPANY
HOLYOKE WATER POWER COMPANY
NORTHEAST UTILITIES SERVICE COMPANY
NORTHEAST NUCLEAR ENERGY COMPANY

General Offices • Selden Street, Berlin, Connecticut

P.O. BOX 270
HARTFORD, CONNECTICUT 06141-0270
(203) 665-5000

June 9, 1988

MP-11930

Re: 10CFR50.71(a)

U. S. Nuclear Regulatory Commission
Document Control Desk
Washington, D. C. 20555

Reference: Facility Operating License No. NPF-49
Docket No. 50-423

Dear Sir:

In accordance with reporting requirements of Technical Specifications Section 6.9.1.5, the Millstone Nuclear Power Station - Unit 3 Monthly Operating Report 88-6 covering operations for the month of May is hereby forwarded.

Yours truly,

NORTHEAST NUCLEAR ENERGY COMPANY

A handwritten signature in cursive script that reads "Stephen E. Scace".
Stephen E. Scace

Station Superintendent

Millstone Nuclear Power Station

SES/AE: jlm

Attachment

cc: W. T. Russell, Region I Administrator,
W. J. Raymond, Senior Resident Inspector

IE24

11