

NUREG/CR-5096
SAND88-7016

Evaluation of Seals for Mechanical Penetrations of Containment Buildings

Prepared by D. A. Brinson, G. H. Graves

ERC International

Sandia National Laboratories

Prepared for
U.S. Nuclear Regulatory
Commission

8810110264 880831
PDR NUREG
CR-5096 R PDR

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability of responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe private, owned rights.

NOTICE

Availability of Reference Materials Cited in NRC Publications

Most documents cited in NRC publications will be available from one of the following sources:

1. The NRC Public Document Room, 1717 H Street, N.W.
Washington, DC 20555
2. The Superintendent of Documents, U.S. Government Printing Office, Post Office Box 37082
Washington, DC 20013-7082
3. The National Technical Information Service, Springfield, VA 22161

Although the listing that follows represents the majority of documents cited in NRC publications, it is not intended to be exhaustive.

Referenced documents available for inspection and copying for a fee from the NRC Public Document Room include NRC correspondence and internal NRC memoranda; NRC Office of Inspection and Enforcement bulletins, circulars, information notices, inspection and investigation notices; Licensee Event Reports, vendor reports and correspondence, Commission papers, and applicant and licensee documents and correspondence.

The following documents in the NUREG series are available for purchase from the GPO Sales Program: formal NRC staff and contractor reports, NRC-sponsored conference proceedings, and NRC booklets and brochures. Also available are Regulatory Guides, NRC regulations in the *Code of Federal Regulations*, and *Nuclear Regulatory Commission Issuances*.

Documents available from the National Technical Information Service include NUREG series reports and technical reports prepared by other federal agencies and reports prepared by the Atomic Energy Commission, forerunner agency to the Nuclear Regulatory Commission.

Documents available from public and special technical libraries include all open literature items, such as books, journal and periodical articles, and transactions. *Federal Register* notices, federal and state legislation, and congressional reports can usually be obtained from these libraries.

Documents such as theses, dissertations, foreign reports and translations, and non-NRC conference proceedings are available for purchase from the organization sponsoring the publication cited.

Single copies of NRC draft reports are available free, to the extent of supply, upon written request to the Division of Information Support Services, Distribution Section, U.S. Nuclear Regulatory Commission, Washington, DC 20555.

Copies of industry codes and standards used in a substantive manner in the NRC regulatory process are maintained at the NRC Library, 7920 Norfolk Avenue, Bethesda, Maryland, and are available there for reference use by the public. Codes and standards are usually copyrighted and may be purchased from the originating organization or, if they are American National Standards, from the American National Standards Institute, 1430 Broadway, New York, NY 10018.

Evaluation of Seals for Mechanical Penetrations of Containment Buildings

Manuscript Completed: June 1988
Date Published: August 1988

Prepared by
D. A. Brinson, G. H. Graves

ERC International
1717 Louisiana NE, Suite 202
Albuquerque, NM 87110

Under Contract to:
Sandia National Laboratories
Albuquerque, NM 87185

Prepared for
Division of Engineering
Office of Nuclear Regulatory Research
U.S. Nuclear Regulatory Commission
Washington, DC 20555
NRC FIN A1375

ABSTRACT

This report describes tests of elastomeric seals that are used in the mechanical penetrations of nuclear power plant containments. These tests assessed the effects of thermal aging, radiation and thermal aging, sealing surface separation, and squeeze on the performance of several gasket designs: O-ring, gum drop, double dog ear, and tongue and groove. Both ethylene propylene rubber and silicone rubber gaskets were tested. The environment for testing enveloped a hypothetical severe accident: 143 psig and up to 700^oF. The performance of the seals is quantified in terms of the leakage onset point on the time-temperature curve.

CONTENTS

	<u>Page</u>
Abstract	iii/iv
List of Figures	vii
List of Tables	viii
Acknowledgments	ix
Executive Summary	1
1. Introduction	3
1.1 Loss of Penetration Integrity	3
1.2 Failure of Seals in Penetrations	3
1.3 Application Caveats	4
1.4 Previous Work	4
2. Description of Tests	7
2.1 Leak Rates	7
2.2 Temperature Profile	7
2.3 Aging	7
2.4 Flange Separation	7
3. Test Procedures	16
3.1 Equipment	16
3.2 Testing Sequence	16
4. Leak Rate Data Evaluation	21
4.1 Failure Characteristics of the Elastomers	21
4.2 Apparatus Design Deficiencies	21
5. Results	23
5.1 Leakage Onset Point	23
5.2 Posttest Photographs	23
5.3 Typical Temperature Distribution	23
5.4 Observations	24
6. Summary	28
References	29
Bibliography	30

CONTENTS (Cont.)

	<u>Page</u>
Appendix A	A-1
For each test, the temperature vs. time profile is given, along with posttest photographs of the gaskets.	
Appendix B	B-1
Drawings of Test Fixtures	
Appendix C	C-1
Temperature Distribution of the 1/4-inch O-Ring Test Fixture for Test E-4	

LIST OF FIGURES

<u>Figure</u>		<u>Page</u>
1	Reactor Accident Conditions for PWRs	8
2	Reactor Accident Conditions for BWR Mk I	9
3	Reactor Accident Conditions for BWR Mk III	10
4	Test Temperature Profile (Typical)	11
5	Cross Section of Gum Drop Gasket	14
6	Cross Section of Double Dog Ear Gasket	14
7	Double Tongue and Groove Seal Design	15
8	Environmental Chamber	18
9	Cross Sectional View of Gasket Test Fixture	19
10	Simplified Piping Schematic	20
11	Leakage Onset Temperatures for Silicone Rubber O-Rings	25
12	Leakage Onset Temperatures for EP Rubber O-Rings	26

LIST OF TABLES

<u>Table</u>		<u>Page</u>
1	Test Matrix	12
2	Gaskets Tested	13
3	Performance of Aged Gaskets Compared to Performance of Unaged Gaskets	27
4	Performance of 17% Squeeze Compared to Performance of 9% Squeeze	27

ACKNOWLEDGEMENTS

These tests were planned and supervised by C. V. Subramanian and L. N. Koenig, staff members of the Containment Integrity Division of Sandia National Laboratories. Pat Drozda and Bob Padilla of the Adverse Environment Safety Assessment Division, assisted by several other technicians, performed the tests. The authors wish to thank them for submitting the data and explaining the test procedures to us.

We wish to thank Brad Parks of the Containment Integrity Division of Sandia National Laboratories, for his suggestions and careful editing.

We wish to thank Herman Graves III, the NRC project manager, for his suggestions.

We wish to thank Nancy Hedlund, Nancy Heatherly, Ski VanderLaan, and Susan Stuart of ERC International for their work in typing and in preparation of graphs.

EXECUTIVE SUMMARY

These tests were conducted at Sandia National Laboratories as part of the Integrity of Containment Penetrations Under Severe Accident Loads Program, which is sponsored by the U.S. Nuclear Regulatory Commission and managed by Sandia National Laboratories. The tests were designed to measure leak rates from seals that are typically used in the mechanical penetrations of nuclear power plant containments. Gasket cross sections were actual size, but gasket circumferences were much smaller than actual size in order to reduce the cost of testing.

A total of 22 tests were performed. Eighteen tested 1/4-inch O-rings. One test each was run on the following designs: 1/2 inch O-ring, gum drop, double dog ear, and tongue and groove. Gaskets tested were of two elastomers: silicone (SI) rubber and ethylene propylene (EP) rubber. Some gaskets were tested in the unaged condition; others were given one of the following aging histories:

1. 300°F for 168 hours
2. 300°F for 168 hours and 200 Mrad at 1 Mrad/hour

Gaskets were aged in a fixture that provided the same squeeze as the leak test fixture.

Steam was the environment for 20 of the tests; hot air for 2 of the tests. Leakage was measured in each test; however, several experimental deficiencies made it impossible to have confidence in the leak rate data.

The results reported are the leakage onset points as indicated on the temperature vs. time plots, and the posttest photographs, which indicate the extent of the gaskets' degradation at the end of the test.

Some of the observations derived from the test results are as follows:

1. The thermal and radiation aging that was specified in these tests had a negligible deleterious effect on leakage onset temperature.
2. Metal-to-metal contact at the sealing surfaces virtually prevented significant leakage.

3. Leakage onset temperature did not appear to be significantly affected by increasing squeeze* from 9% to 17%. This may suggest that the seals prevent leakage as long as positive compression exists.
4. Leakage onset temperatures ranged from 626°F to 669°F for the five steam tests of EP rubber 1/4-inch O-rings with a gap between the sealing surfaces.
5. Leakage onset temperatures ranged from 486°F to 592°F for the eight steam tests of SI rubber 1/4-inch O-rings with a gap between the sealing surfaces.
6. Posttest visual inspection indicated that all gaskets experienced severe degradation, including those that were tested without a gap between the sealing surfaces.

* Squeeze = $\frac{U-C}{U} \times 100$

where: U = uncompressed seal dimension
C = compressed seal dimension
(both dimensions measured normal to the sealing surface)

1. INTRODUCTION

Since the accident at Three Mile Island, a major effort in safety studies has been directed toward understanding the risks and consequences of severe accidents. Knowledge concerning the leakage behavior of nuclear plant containments is important input to accident mitigation strategies, risk studies, and emergency preparedness planning. Five NRC programs are concerned with containment integrity and leakage behavior under severe accident conditions: the Containment Safety Margins Program, the Valve Isolation Program, the Integrity of Containment Penetrations Under Severe Accident Conditions Program, the Electrical Penetrations Assemblies Program, and the Containment Integrity Under Extreme Loads Program.

1.1 Loss of Penetration Integrity

Calculations made under the Severe Accident Sequence Analysis Program indicate that pressures and temperatures significantly above the design basis levels are likely to occur during a severe accident. Loss of penetration integrity could occur as a result of (a) excessive pressure differentials across the penetrations, (b) degradation of seal materials resulting from exposure to high temperatures, (c) distortion of sealing surfaces as a result of containment deformation, and (d) enlargement of pre-existing leakage paths or creation of new leakage paths as a result of stress-induced cracks in liners, hatches, and flanges.* The probability of these failure modes is unknown, and the magnitude of any particular failure is difficult to predict.[1]

1.2 Failure of Seals in Penetrations

Containments subjected to severe accidents (static pressure conditions) have the potential to leak as a result of seal failure in a penetration rather than by failure of the containment shell. Some of the reasons for this are as follows:

1. Elastomers used in seals are generally not qualified for the severe accident environment.
2. Deformation at the penetration/containment interface is detrimental to seal integrity; this is especially significant when an equipment hatch sleeve deforms relative to the hatch cover and tensioning ring.

* The inflatable seals that are used in some penetrations (e.g., personnel airlocks) are not discussed in this report.

3. The sealing surfaces of pressure unseating hatches will begin to separate when the bolt preload is nullified by the internal pressure.

Note: Clauss [2] discusses the leakage potential of pressure unseating hatches. He gives a formula for the separation between the sealing surfaces and a formula for the pressure at which leaking begins in terms of the applicable stiffnesses, thermal strains, and bolt preloads. Clauss tabulates some of these numbers for existing containments. For one type of equipment hatch in BWR Mk IIIs, he calculates that separation would begin at 2X design pressure, and that at 3X design pressure the separation would be approximately 0.003 inch.

1.3 Application Caveats

The following caveats should be considered before applying the test results given in this report to full-sized penetrations:

1. The test fixture, with its reduced circumference, has relatively rigid surfaces; the gap between the flanges is nearly uniform around the perimeter. The full-sized penetration, on the other hand, might exhibit a varying gap around the perimeter.
2. In the event of a severe accident, sealing surfaces might move relative to each other. In these tests, such movement was not modeled; the test fixture's sealing surfaces were fixed.
3. Radiolytic damage to elastomers may depend not only on the absorbed dose, but also on the length of time that the elastomer is subject to radiation and hence on the dose rate. The damage caused by low dose rate exposure for a long time may be more severe than the damage resulting from high dose rate (but identical total dose) exposure over a short time. Thermal damage exhibits a similar phenomenon. These effects were not considered in the tests.

1.4 Previous Work

This section briefly mentions some of the previous work in elastomeric seal testing.

Argonne National Laboratory (ANL) produced a study [3] of existing penetrations that were believed to have a high probability of leaking when subjected to temperatures and pressures exceeding design values. They concentrated on large, operating type penetrations such as personnel airlocks, equipment hatches, and bellows seals. The ANL study is an extensive collection of text and drawings for the penetrations in 48 nuclear plants.

Welch and Kurzeka [4] investigated the effects of temperature, gland* surface finish, and squeeze** on leakage behavior. They also investigated the effects of temperature on the permeability and the compression set of elastomeric gaskets. They concluded that compression set is virtually independent of the amount of squeeze.

Welch and Kurzeka chose a compression set of 90% to represent end of useful life. Employing this number, they created some Arrhenius plots to show maximum allowable operating temperature for a given life.

Chivers and Hunt [5] offer a concise explanation of the issues in elastomeric seal performance. They include plots of compression set versus time and expected life versus temperature; end of life is defined to be when compression set reaches 100%.

Blakeston, Tomblin, and Ward [6] plotted percentage loss of standoff*** versus time and compression set versus time for selected temperatures and elastomers. They also studied the effects of oxygen on polymer degradation.

Wensel [7] reports that the change in sealing force is the best indicator of seal performance, and that it correlates well with compression set, which is easier to measure. He suggests compression set equal to 75% as a conservative estimate for the end of a gasket's useful life.

Wensel and Cotnam [8] subjected elastomeric gaskets to 350°F and 450°F water for up to one year. They concluded that compression set is an effective indicator for the extent of degradation, and that changes in hardness and weight are not effective indicators of degradation. All of the leakage in their experiments occurred at compression sets exceeding 75%.

*gland -- the cavity into which an O-ring is installed. Includes the groove and the mating surface of the second part that together confine the O-ring.

**Squeeze = $\frac{U-C}{U} \times 100$

where: U = uncompressed seal dimension
C = compressed seal dimension
(both dimensions measured normal to the sealing surface)

***standoff -- the amount by which the gasket projects from the groove.

There seems to be a strong consensus that compression set is an effective indicator of degradation in an elastomeric gasket and that the end of a gasket's useful life occurs at a compression set ranging from 75% to 100%.

Thomas Bridges [9], at Idaho National Engineering Laboratory, tested elastomeric gaskets (under contract to Sandia National Laboratories) at 160 psig and temperatures up to 700°F, unaged and thermally aged. Flange rotation was simulated by machining one flange at an angle (up to 12°) relative to the mating flange. The pressurized fluid was dry nitrogen. Some of his conclusions:

1. Flange rotation had little effect on failure temperature.
2. Thermal aging had little effect on failure temperature.*
3. Seepage leak rate** increased as flange rotation increased.
4. Seepage leak rate increased as squeeze decreased.
5. Seepage leak rate was not affected by thermal aging.
6. Leak rates after gasket failure increased as flange separation increased.
7. Failure temperatures increased as squeeze increased.

* Thermal aging probably does affect leak rates in pressure-unseating hatches, however, because it changes compression set retention.

** Seepage leak rates are those leak rates occurring prior to failure of the gasket.

2. DESCRIPTION OF TESTS

Tests were performed on five seal designs: double 1/4-inch O-ring, double 1/2-inch O-ring, double tongue and groove, double gumdrop, and double dog ear. A study by Argonne National Laboratory [3] determined that these seal designs are among the most commonly used in nuclear containment penetrations.

The test matrix is given in Table 1. The gaskets tested were of silicon (SI) rubber and ethylene propylene (EP) rubber.* The compound numbers are given in Table 2.

2.1 Leak Rates

A total of 20 tests were performed in a steam environment; 2 were performed in a hot air environment. The leak rate for the steam tests was measured by condensing the steam and then weighing the water collected during a given time. Leak rates associated with dry air tests were measured with flowmeters.

2.2 Temperature Profile

The temperatures and pressures chosen for testing enveloped the predicted severe accident conditions for the following types of nuclear containments: PWR, BWR Mk I, and BWR Mk III. The predicted worst-case temperature and pressure profiles are shown in Figures 1 through 3. The typical test temperature profile is shown in Figure 4. (This temperature profile was chosen so that failures would probably occur during regular working hours.) The temperature was first held at 360°F then increased up to 500°F, 600°F, and 700°F on successive days. The pressure was maintained at 143 psig throughout the tests.

2.3 Aging



Aging of the elastomers was in three categories: no aging, thermal aging only, and radiation followed by thermal aging. All aging was performed with the gaskets installed in the test fixture. Thermal aging was at 300°F for 168 hours. Radiation aging consisted of a 200 Mrad dose of gamma radiation applied at 1 Mrad/hour.

2.4 Flange Separation

Sealing surface separation was simulated by placing shims between the flanges of the test fixture. Tests were run with gaps of 0.006, 0.012, 0.024, and 0.048 inches as well as with metal-to-metal contact.



Note: Flange separation was fixed (constant) during the tests.

*One test was attempted with gaskets of fluorocarbon rubber; this elastomer deteriorated the fixture so severely that the test was aborted.





Reactor Accident Conditions for PWRs
(Containment Atmosphere)

Figure 1




Reactor Accident Conditions for BWR Mark I
(Drywell Atmosphere)

Figure 2



Reactor Accident Conditions for BWR Mark III
(Wetwell Atmosphere)

Figure 3



Test Temperature Profile (Typical)

Figure 4

TABLE 1

Test Matrix

TEST NO.	SEAL DESIGN	ELASTOMER	AGING	ATMOSPHERE	GAP (in)	SQUEEZE (%)	FIXTURE ^f	LEAKAGE ON SEAL TEMP. (°F)
E1	0.275" DOR	EP	None	Steam	.000	26	A	692 ^a
E2	0.275" DOR	EP	None	Steam	.024	17	A	626
E3	0.275" DOR	EP	None	Steam	.048	9	B	669 ^a
E4	0.275" DOR	EP	R & T	Steam	.000	26	B	DNL
E5	0.275" DOR	EP	None	Hot Air	.024	17	B	651
E6	0.275" DOR	EP	R & T	Steam	.024	17	B	657
E7	0.275" DOR	EP	R & T	Steam	.048	9	B	637
E8	0.275" DOR	S1	R & T	Steam	.024	17	B	524 ^b
E9	0.275" DOR	S1	R & T	Steam	.048	9	B	508 ^b
E10	0.275" DOR	EP	T	Steam	.024	17	B	648
E11	0.275" DOR	S1	T	Steam	.024	17	B	497
E12	0.275" DOR	S1	R & T	Steam	.024	17	B	592
E13	0.275" DOR	S1	None	Steam	.012	22	B	506
E14	0.275" DOR	S1	None	Steam	.006	24	B	486
S1	0.275" DOR	S1	None	Steam	.000	26	A	DNL
S2	0.275" DOR	S1	None	Steam	.024	17	B	493
S3	0.275" DOR	S1	None	Steam	.048	9	B	493
S4	0.275" DOR	S1	None	Hot Air	.024	17	B	681
DGD	DGD ^c	EP	None	Steam	.012	22	DGD	g
DDE	DDE ^d	EP	None	Steam	.012	26	DDE	617
DTG	DTG ^e	EP	None	Steam	.012	N/A	DTG	609
DOR	0.500" DOR	EP	None	Steam	.012	23	O-ring	590

DOR = Double O-ring
 DGD = Double Gum Drop
 DDE = Double Dog Ear (one gasket)
 DTG = Double Tongue and Groove
 None = No Aging

R & T = Radiation and Thermal Aging
 T = Thermal Aging Only
 EP = Ethylene Propylene Rubber
 S1 = Silicone Rubber
 DNL = Did Not Leak During Test

a The thermocouple used to determine the fixture temperature is not in the typical location as shown in Figure 9 on page 19. Instead, the temperature was measured by a thermocouple attached to the outside of the test fixture. Therefore, the reported temperature may vary slightly from that of the interior cavity of the fixture.

b See Note 2, page 23.

c See Figure 5.

d See Figure 6.

e See Figure 7.

f Two fixtures were used to test 1/4-inch O-rings; they are designated "A" and "B" (see Appendix B).


g See Appendix A, p. A-46.

TABLE 2
Gaskets Tested

GASKET TYPE	CROSS-SECTION	PERIMETER *	ELASTOMER	COMPOUND NUMBER	DUROMETER	MANUFACTURER
O-ring	0.275" dia	3-11**	EP	E603-70	70	Parker Hannifin
O-ring	0.275" dia	3-11**	SI	S604-70	70	Parker Hannifin
O-ring	0.5" dia	23-25	EP	E603-60	60	Presray
Gum Drop	Fig. 5	18-20	EP	E603-60	60	Presray
Double Dog Ear	Fig. 6	13-15	EP	E603-60	60	Presray
Tongue & Groove	Fig. 7	28-30	EP	E603-60	60	Presray


* This column gives page numbers in Appendix B.

** The largest diameter groove on the "B" Fixture was not used.




Cross Section of Gum Drop Gasket

Figure 5



Cross Section of Double Dog Ear Gasket

Figure 6



NOTE: UNINSTALLED GASKET
DIMENSIONS ARE 0.75 X 0.50

Double Tongue-and-Groove Seal Design

Figure 7

3. TEST PROCEDURE

3.1 Equipment

The steam system used for these tests has two boilers (3 hp and 6 hp), a 16-cubic-foot accumulator with 8-cubic-feet of water, and a 20-kW superheater. The system can deliver superheated steam at up to 750°F and 200 psig.

The environmental chamber is shown in Figure 8. The test environment fills the chamber and surrounds the test fixture.

Schematics of a typical test apparatus are given in Figures 9 and 10.

Test fixture drawings are in Appendix B. Test fixtures were fabricated for each gasket design. Two different 1/4-inch O-ring fixtures were used in the tests (see Table 1).

3.2 Testing Sequence*

The typical procedure for testing a gasket is as follows:


- 1) Measure compression set, hardness, and diameter of virgin gaskets.
- 2) Irradiate gaskets (in test fixture) to 200 Mrad at 1 Mrad/hour.
- 3) Measure diameter and hardness of gasket.
- 4) Thermally age gaskets (in test fixture) for 168 hours at 300°F.
- 5) Measure diameter and hardness of gaskets.
- 6) Install gaskets in test fixture.
- 7) Install shims to achieve desired gap setting.
Note: Squeeze was constant throughout the test.
- 8) Torque assembly bolts to 100 lb-in.
- 9) Place fixture in environmental chamber.
- 10) Apply steam at 143 psig and 360°F; hold overnight.
Note: Pressure was held constant throughout the tests.
- 11) Next day increase temperature to 500°F and hold for 2 hours.
- 12) Return to 360° for evening.
- 13) Next day increase temperature to 600°F and hold for 2 hours.
- 14) Return to 360° for evening.

*For a gasket that was only thermally aged, steps 2 and 3 were deleted. For a gasket that was to have no aging, steps 2,3,4 and 5 were deleted.


- 15) Next day increase temperature to 700°F and hold for 2 hours.

Note: A typical temperature profile is shown in Figure 4.

- 16) Return fixture to room temperature.
- 17) Disassemble.
- 18) Photograph gaskets and sealing surfaces.




Enviromental Chamber
Figure 8



Cross Sectional View of a Typical Test Fixture with Simplified Piping Schematic

Figure 9



Piping Schematic
Figure 10

4. LEAK RATE DATA EVALUATION

One of the original goals of this test program was to measure leakage rates for several different seal and gasket materials and cross-sectional shapes. However, for the reasons described below, only the onset of leakage was determined. It was impossible to accurately measure the leak rate past a single set of gaskets during these tests. The difficulty arose because of breakup of the seal material, which then caused clogging of the leakage detection lines. Another problem was in the design of the test fixture, which was meant to measure leakage past several different seals during a single test.

4.1 Failure Characteristics of the Elastomers

During some of the tests, the gaskets melted, allowing molten elastomer to move and clog the leakage collection ports.* Clogging occurred to such an extent during several tests that the ports were completely obstructed and leaking stopped. In other tests, the data suggests that ports were obstructed and then reopened; these tests exhibited leak rate variations that are otherwise inexplicable. The leak rates would decrease and then increase again as the material plugged the ports and then later blew through the system. Clearly, such leak rates do not represent an accurate picture of gasket performance.

4.2 Apparatus Design Deficiencies

The apparatus was designed so that three sets of two seals each could be tested simultaneously, thus tripling the amount of data generated by each test. A schematic of the test apparatus and associated leakage detection piping is shown in Figure 9. Valves V_S , V_L , V_M were all open at the beginning of the test and remained open until leakage was first detected. At this point the valves were all closed and then reopened one at a time until the location of the leak was determined. As can be seen in Figure 9, when valves V_S , V_L , V_M were closed and gaskets T_1/T_2 or T_5/T_6 began to leak, the apparatus gaskets (A_1 or A_2) may have been subjected to the full test pressure. Because the apparatus gaskets were made of the same material as the gaskets under test, they would be expected to leak under approximately the same pressure and temperature conditions. Leakage past the apparatus gaskets would have appeared to result from failure of T_3/T_4 . The degraded condition of the apparatus gaskets after the tests indicates

*For example, see the photographs in Appendix A for tests E1 and E8.

that such spurious leakage probably did occur. (See posttest photos, Appendix A). Obviously, leakage past the apparatus gaskets could cause serious errors in the measured leak rates, which were originally thought to be solely a result of test gasket failure.

The pressure and temperature conditions at the point of leakage onset for the first set of gaskets to begin leaking were not affected by this problem. Thus, the measured pressure and temperature at onset of leakage for these seals are considered correct.

5. RESULTS

5.1 Leakage Onset Point

The leakage onset point is indicated on the temperature profiles shown in Appendix A.* A summary of the leakage onset temperatures for all the tests is provided in Table 1. For 1/4-inch O-rings, these data are displayed in Figures 11 and 12.

For purposes of these tests, leakage onset point was defined to be when the leakage rate reached 1.0 ml/min of condensate.

- Note: 1. The time required for the steam to pass through the leakage piping and be condensed in the heat exchanger caused some imprecision in the leakage onset temperatures; therefore, the data should be considered approximate.
2. For tests E8 and E9, one of the three sets of gaskets that had been radiation and thermally aged failed to provide a seal when the leak test was begun. This one set was replaced by a set of unaged gaskets. During the tests, the unaged gaskets were the first to fail. After the first failure occurred, leakage onset point for the remaining gaskets was undetectable (see Section 4.2), so these data are not available for E8 and E9. Since the radiation and thermally aged gaskets were still providing an effective seal when the unaged gaskets failed, they performed at least as well as the unaged gaskets. Therefore, the temperatures reported for E8 (524°F) and E9 (508°F) are lower bounds of the leakage onset point for the radiation and thermally aged gaskets.

5.2 Posttest Photographs

Posttest photographs of the gaskets are displayed in Appendix A.

5.3 Typical Temperature Distribution

A typical temperature distribution on the 1/4-inch O-ring test fixture is shown in Appendix C.

*The typical location of the thermocouple used to determine fixture temperature is shown in Figure 9.

5.4 Observations

Note: Keep in mind that relatively few data points are reported from these tests. The observations are significant as indicative of trends only, not as proof of gasket performance under particular conditions.


1. Table 3 gives the leakage onset temperatures in each aging category for the tests with gaps of 0.024 and 0.048 inch. The data indicate that the aging specified in these tests had no deleterious effect on the leakage onset temperatures.
2. The highest leakage onset temperatures for steam environment tests occurred with no gap between the sealing surfaces (see Figures 11 and 12). Visual inspection indicates, however, that degradation of gaskets from these tests was similar to that for gaskets tested with a gap. (See posttest photos of tests E1, E4, and S1 to note gasket degradation for the tests with no gap.) It appears likely that the metal-to-metal contact delayed leakage; gasket condition apparently had little effect on the seal's performance when metal-to-metal contact was present.
3. Leakage onset temperature does not appear to be significantly affected by the amount of squeeze. Refer to Table 4. Note that of the four comparisons in the table, one shows no change in performance, and one shows deteriorated performance as squeeze increases from 9% to 17%.
4. Posttest visual inspection indicated that all gaskets experienced severe degradation, including those that were tested without a gap between the sealing surfaces.

+ STEAM TESTS

● AIR TESTS

▲ STEAM TESTS
NO LEAKAGE

(.XXX) = gap in inches




LEAKAGE ONSET TEMPERATURES
1/4 - inch SI rubber O-rings

* Test E-14, which is in this category, is not included on this plot due to a test system failure.

** See note 2 in section 5.1.

Figure 11

+ STEAM TESTS ● AIR TESTS ▲ STEAM TESTS
 (.XXX) = gap in inches NO LEAKAGE



LEAKAGE ONSET TEMPERATURES
 1/4 - inch EP rubber O-rings

Figure 12

TABLE 3

Performance of Aged Gaskets Compared to
Performance of Unaged Gaskets
(1/4-inch O-rings, steam environment)

ELASTOMER	GAP (in)	SQUEEZE (%)	LEAKAGE ONSET TEMP. (°F)		
			UNAGED	THERMAL	RAD. & THERMAL
EP	.024	17	626	648	657
EP	.048	9	669	-	637
SI	.024	17	493	497	524*/592
SI	.048	9	493	-	508*

* See note 2, page 23

TABLE 4

Performance of 17% Squeeze Compared to Performance of 9% Squeeze
(1/4-inch O-rings, steam environment)

ELASTOMER	AGING	LEAKAGE ONSET TEMP. (°F)		PERFORMANCE OF 17% COMPARED TO 9%
		AT 9% ^{**} SQUEEZE	AT 17% ^{***} SQUEEZE	
EP	None	669	626	Worse
EP	Rad & Thermal	637	657	Better
SI	None	493	493	Same
SI	Rad & Thermal	508*	524*/592	Better

* See note 2, page 23

** Gap = 0.048 inch

*** Gap = 0.024 inch

6. SUMMARY

The observations resulting from this test program may be summarized as follows:

1. The thermal and radiation aging that was specified in these tests (300°F for 168 h and 200 Mrad at 1 Mrad/h) had a negligible deleterious effect on leakage onset temperature.
2. Metal-to-metal contact at the sealing surfaces virtually prevented significant leakage.
3. Leakage onset temperature did not appear to be significantly affected by increasing squeeze from 9% to 17%.
4. Leakage onset temperatures ranged from 626°F to 669°F for steam tests of EP rubber 1/4-inch O-rings with a gap between the sealing surfaces.
5. Leakage onset temperatures ranged from 486°F to 592°F for steam tests of SI rubber 1/4-inch O-rings with a gap between the sealing surfaces.
6. Posttest visual inspection indicated that all gaskets experienced severe degradation, including those that were tested without a gap between the sealing surfaces.

REFERENCES

1. C. V. Subramanian, "Test Plan for Evaluating Leakage Behavior of Seals and Gaskets under Severe Accident Conditions," Sandia National Laboratories, Albuquerque, NM, August 1984.
2. D. B. Clauss, "Failure Mechanisms of LWR Steel Containment Buildings Subject to Severe Accident Loadings," Proceedings of the Third Workshop on Containment Integrity, NUREG/CP-0076, SAND86-0618, Sandia National Laboratories, Albuquerque, NM, August 1986, pp. 498-504.
3. M. H. Shackelford, et al., Characteristics of Nuclear Reactor Containment Penetrations, NUREG/CR-1855, SAND84-7180, Sandia National Laboratories, Albuquerque, NM, 1985.
4. F. H. Welch and W. J. Kurzeka, "Testing and Evaluation of Elastomeric Seals for Sodium-Cooled Fast Reactor Systems," presented at meeting of Nuclear Engineering Division of ASME, 1975.
5. T. C. Chivers and R. P. Hunt, "Problems, Properties, and Performance of Static Seals," CEGB Research, January 1978, pp. 26-35.
6. M. L. Blakeston, et al., "The Testing of Elastomers for Channel Seal Plugs in a Steam Generating Heavy Water Nuclear Reactor," 8th International Conference on Fluid Sealing, 1978.
7. R. G. Wensel, Resistance of O-Ring Seal Compounds to Heat and Ionizing Radiation in Air and in Water, Atomic Energy of Canada Limited, AECL-5697, 1977.
8. R. G. Wensel and B. M. Cotnam, Evaluation of O-Rings of Various Elastomer Compounds for Service in Hot Water, Atomic Energy of Canada Limited, AECL-6214, 1978.
9. T. L. Bridges, Containment Penetration Elastomer Seal Leak Rate Tests, NUREG/CR-4944, SAND87-7118, Sandia National Laboratories, Albuquerque, NM, July 1987.

BIBLIOGRAPHY

Barnes, B. L., "Containment Penetration Elastomer Seal Test," Proceedings of the Second Workshop on Containment Integrity, NUREG/CP-0056, SAND84-1514, Sandia National Laboratories, Albuquerque, NM, August 1984.

Beynel, P., et al., Compilation of Radiation Damage Test Data, European Organization for Nuclear Research, CERN 82-10, November 4, 1982.

Blakeston, M. L., et al., "The Testing of Elastomers for Channel Seal Plugs in a Steam Generating Heavy Water Nuclear Reactor," 8th International Conference on Fluid Sealing, 1978.

Bonzon, L. L., et al., Status Report on Equipment Qualification Issues, NUREG/CR-4301, SAND85-1309, Sandia National Laboratories, Albuquerque, NM, November 1986.

Bridges, T. L., Containment Penetration Elastomer Seal Leak Rate Tests, NUREG/CR-4944, SAND87-7118, Sandia National Laboratories, Albuquerque, NM, July 1987.

Chivers, T. C. and R. P. Hunt, "Problems, Properties, and Performance of Static Seals," CEGB Research, January 1978.

Clauss, D. B., Comparison of Analytical Predictions and Experimental Results for a 1:8-Scale Steel Containment Model Pressurized to Failure, NUREG/CR-4209, SAND85-0679, Sandia National Laboratories, Albuquerque, NM, July 1985.

-----, "Failure Mechanisms of LWK Steel Containment Buildings Subject to Severe Accident Loadings," Proceedings of the Third Workshop on Containment Integrity, NUREG/CP-0076, SAND86-0618, Sandia National Laboratories, Albuquerque, NM, August 1986.

Horschel, D. S., Experimental Results of High Pressure Testing a 1:6 Scale Nuclear Power Plant Containment, NUREG/CR-5121, SAND88-0906, Sandia National Laboratories, Albuquerque, NM, 1988.

Koenig, L. N., Experimental Results for a 1:8-Scale Steel Model Nuclear Power Plant Containment Pressurized to Failure, NUREG/CR-4216, SAND85-0790, Sandia National Laboratories, Albuquerque, NM, December 1986.

-----, "Leakage Potential Through Mechanical Penetrations in a Severe Accident Environment," Proceedings of the Third Workshop on Containment Integrity, NUREG/CP-0076, SAND86-0618, Sandia National Laboratories, Albuquerque, NM, August 1986.

BIBLIOGRAPHY (cont)

Raut, H. D., et al., "Gasket Leakage Behavior Trends," Welding Research Council Bulletin, Bulletin 271, October 1981.

Shackelford, M. H., et al., Characteristics of Nuclear Reactor Containment Penetrations, NUREG/CR-3855, SAND84-7180, Sandia National Laboratories, 1985.

Subramanian, C. V., "Test Plan for Evaluating Leakage Behavior of Seals and Gaskets Under Severe Accident Conditions," Sandia National Laboratories, August 1984.

Welch, F. H., and W. J. Kurzeka, "Testing and Evaluation of Elastomeric Seals for Sodium-Cooled Fast Reactor Systems," presented at meeting of Nuclear Engineering Division of ASME, 1975.

Wensel, R. G., Resistance of O-Ring Seal Compounds to Heat and Ionizing Radiation in Air and in Water, Atomic Energy of Canada Limited, AECL-5697, 1977.

Wensel, R. G., and B. M. Cotnam, Evaluation of O-Rings of Various Elastomer Compounds for Service in Hot Water, Atomic Energy of Canada Limited, AECL-6214, 1978.


APPENDIX A

TEST TEMPERATURE PROFILES AND TEST PHOTOGRAPHS

APPENDIX A TABLE OF CONTENTS

<u>Test</u>	<u>Page</u>
E1	A-2
E2	A-4
E3	A-7
E4	A-9
E5	A-11
E6	A-13
E7	A-15
E8	A-17
E9	A-20
E10	A-22
E11	A-24
E12	A-27
E13	A-29
E14	A-31
S1	A-34
S2	A-36
S3	A-38
S4	A-40
Double Dog Ear Test	A-42
Double Gum Drop Test	A-46
Double O-Ring Test (1/2 inch)	A-49
Double Tongue and Groove Test	A-52

TEST E1
temperature profile



TEST NO. E1

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.000
Leakage Orset Temp (°F):	692

*The thermocouple used to determine the fixture temperature is not in the typical location as shown in Figure 9 on page 18. Instead, the fixture temperature is based on the output of a thermocouple attached to the outside of the test fixture. Therefore, the reported temperature may vary slightly from that of the interior cavity of the fixture.



Figure A-E1.1
Test E-1
Posttest photo of leakage collection beaker
Note: Gasket material in leakage




Figure A-E1.2
Test E-1
Posttest photo of plate 3
Note: Gasket degradation


TEST E2

temperature profile

----- Chamber
Temperature

----- Fixture
Temperature

▼ Initial
Leakage



TEST NO. E2


Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	626



Figure A-E2.1
Test E-2
Posttest photo of plate 1
Note: Gasket degradation



Figure A-E2.2
Test E-2
Posttest photo of plate 3
Note: Gasket degradation



TEST NO. E3

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.048
Leakage Onset Temp (°F):	669

*The thermocouple used to determine the fixture temperature is not in the typical location as shown in Figure 9 on page 19. Instead, the fixture temperature is based on the output of a thermocouple attached to the outside of the test fixture. Therefore, the reported temperature may vary slightly from that of the interior cavity of the fixture.




Figure A-E3.1
Test E-3
Posttest photo of plate 4
Note: Gasket degradation





Figure A-E3.2
Test E-3
Posttest photo of plate 3
Note: Gasket blow-out



TEST NO. E4

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	Radiation and Thermal
Atmosphere:	Steam
GAP (in):	0.000
Leakage Onset Temp (°F):	Did Not Leak




Figure A-E4.1
Test E-4
Posttest photo of plate 2
Note: Gasket degradation


TEST E5

temperature profile

----- Chamber
Temperature

———— Fixture
Temperature

▼ Initial
Leakage



TEST NO. E5

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	None
Atmosphere:	Dry Air
GAP (in):	0.024
Leakage Onset Temp (°F):	651





Figure A-E5.1
Test E-5
Posttest photo of plate 3

TEST E6
temperature profile

----- Chamber
Temperature

———— Fixture
Temperature

▼ Initial
Leakage




TEST NO. E6

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	Radiation and Thermal
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	657



Figure A-E6.1
Test E-6
Posttest photo of plate 4
Note: Gasket degradation



TEST NO. E7

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	Radiation and Thermal
Atmosphere:	Steam
GAP (in):	0.048
Leakage Onset Temp (°F):	637




Figure A-E7.1
Test E-7
Posttest photo of plate 2
Note: Gasket material missing or blown-out





Figure A-E7.2
Test E-7
Posttest photo of plate 3
Note: Gasket degradation



TEST NO. E8

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	524 (See note 2, page 23)



Figure A-E8.1
Test E-8
Posttest photo of plate 3
Note: Gasket break-up




Figure A-E8.2
Test E-8
Posttest photo of plate 3
Note: Powdered gasket material





Figure A-E8.3
Test E-8
Posttest photo of plate 2
Note: Gasket blow-out

TEST E9
temperature profile



TEST NO. E9

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	Radiation and Thermal
Atmosphere:	Steam
GAP (in):	0.048
Leakage Onset Temp (°F):	508 (See note 2, page 23)




Figure A-E9.1
Test E-9
Posttest photo of plate 4
Note: Gasket flow and blow-out




Figure A-E9.2
Test E-9
Posttest photo of plate 2 on plate 1
Note: Powdered gasket material


TEST E10

temperature profile

----- Chamber Temperature

———— Fixture Temperature

▼ Initial Leakage



TEST NO. E10

Seal:	1/4" Double O-Ring
Elastomer:	EP Rubber
Compound:	Parker E603-70
Aging:	Thermal Only
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	648




Figure A-E10.1
Test E-10
Posttest photo of plate 1
Note: Leakage channel clogging





Figure A-E10.2
Test E-10
Posttest photo of plate 2
Note: Gasket material flow

TEST E11
temperature profile



TEST NO. E11

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	Thermal Only
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	497




Figure A-E11.1
Test E-11
Posttest photo of plate 3
Note: Use of an EP rubber apparatus gasket




Figure A-E11.2
Test E-11
Posttest photo of plate 2
Note: Use of an EP rubber apparatus gasket




Figure A-E11.3
Test E-11
Posttest photo of plate 3
Note: Gasket deyradation


TEST E12

temperature profile

---- Chamber Temperature

— Fixture Temperature

▼ Initial Leakage




TEST NO. E12

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	Radiation and Thermal
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	592



Figure A-F12.1
Test E-12
Posttest photo of plate 1
Note: Gasket degradation

TEST E13
temperature profile



TEST NO. E13

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.012
Leakage Onset Temp (°F):	506




Figure A-E13.1
Test E-13
Posttest photo of plate 2
Note: Use of EP rubber apparatus gasket



Figure A-E13.2
Test E-13
Posttest photo of plate 2
Note: SI rubber gasket degradation


TEST E14

temperature profile

----- Chamber Temperature

----- Fixture Temperature

▼ Initial Leakage



TEST NO. E14

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.006
Leakage Onset Temp (°F):	486



Figure A-E14.1
Test E-14
Posttest photo of plate 4
Note: Gasket degradation



Figure A-E14.2
Test E-14
Posttest photo of plate 2 on plate 1
Note: Gasket degradation





Figure A-E14.3
Test E-14
Posttest photo of plate 2
Note: Use of EP rubber apparatus gasket

TEST S1

temperature profile

----- Chamber
Temperature

———— Fixture
Temperature



TEST NO. S1

Seal:	1/4" Double O-ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Steam
Gap (in):	0.000
Leakage Onset Temperature:	Did Not Leak




Figure A-S1.1
Test S-1
Posttest photo of plate 1
Note: Gasket degradation




Figure A-S1.2
Test S-1
Posttest photo of plate 1
Note: Gasket degradation

TEST S2
temperature profile

--- Chamber
Temperature

— Fixture
Temperature

▼ Initial
Leakage



TEST NO. S2

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.024
Leakage Onset Temp (°F):	493




Figure A-S2.1
Test S-2
Posttest photo of plate 2
Note: Gasket blow-out

TEST S3
 temperature profile
 - - - - Chamber
 Temperature

— Fixture
 Temperature

▼ Initial
 Leakage



TEST NO. S3

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Steam
GAP (in):	0.048
Leakage Onset Temp (°F):	493



Figure A-S3.1
Test S-3
Posttest photo of plate 4
Note: Gasket flow





Figure A-S3.2
Test S-3
Posttest photo of plate 3
Note: Gasket blow-out

TEST S4
temperature profile



TEST NO. S4

Seal:	1/4" Double O-Ring
Elastomer:	SI Rubber
Compound:	Parker S604-70
Aging:	None
Atmosphere:	Dry Air
GAP (in):	0.024
Leakage Onset Temp (°F):	681



Figure A-S4.1
Test S-4
Posttest photo of plate 3
Note: Gasket degradation



Figure A-S4.2
Test S-4
Posttest photo of plate 2
Note: Gasket degradation


TEST DDE1

Temperature profile

--- Chamber Temperature

— Fixture Temperature

▼ Initial Leakage



TEST NO. DDE

Seal:	Double Dog Ear
Elastomer:	EP Rubber
Compound:	Presray E603-60
Aging:	None
Atmosphere:	Steam
GAP (in):	0.012
Leakage Onset Temp (°F):	617




Figure A-DDE1.1
Test DDE 1
Posttest photo of plate 2
Note: Gasket degradation




Figure A-DDE1.2
Test DDE 1
Posttest photo of plate 3
Note: Gasket blow-out




Figure A-DDE1.3
Test DDE 1
Posttest photo of plate 4 leakage port
Note: Leakage port clogging





Figure A-DDE1.4
Test DDE 1
Posttest photo of assembled test fixture
Note: Extruded gasket material

TEST DGD1
temperature profile

----- Chamber
Temperature

———— Fixture
Temperature

▼ Initial
Leakage



TEST NO. DGD

Seal:	Double Gum Drop
Elastomer:	EP Rubber
Compound:	Presray E603-60
Aging:	None
Atmosphere:	Steam
GAP (in):	0.012
Leakage Onset Temp (°F):	Onset occurred overnight between points indicated




Figure A-DGD1.1
Test DGD 1
Posttest photo of plate 3
Note: Gasket degradation




Figure A-DGD1.2
Test DGD 1
Posttest photo of assembled test fixture
Note: Extruded gasket material


TEST DOR1

temperature profile

----- Chamber Temperature

———— Fixture Temperature

▼ Initial Leakage



TEST NO. DOR

Seal:	1/2" Double O-Ring
Elastomer:	EP Rubber
Compound:	Presray E603-60
Aging:	None
Atmosphere:	Steam
GAP (in):	0.012
Leakage Onset Temp (°F):	590




Figure A-DOR1.1
Test DOR 1
Posttest photo of assembled test fixture
Note: Extruded gasket material




Figure A-DOR1.2
Test DOR 1
Posttest photo of plate 3
Note: Powdered gasket material




Figure A-DOR1.3
Test DOR 1
Posttest photo of plate 1
Note: Gasket degradation




Figure A-DOR1.4
Test DOR 1
Posttest photo of plate 2
Note: Leakage channel clogging


TEST DTG1

temperature profile

----- Chamber
Temperature

———— Fixture
Temperature

▼ Initial
Leakage



TEST NO. DTG

Seal:	Double Tongue and Groove
Elastomer:	FP Rubber
Compound:	Presray E603-60
Aging:	None
Atmos, here:	Steam
GAP (in):	0.012
Leakage Onset Temp (°F):	609



Figure A-DTG1.1
Test DTG 1
Posttest photo of plate 3
Note: Gasket degradation




Figure A-DTG1.2
Test DTG 1
Posttest photo of plate 3
Note: Leakage channel clogging




Figure A-DTG1.3
Test DTG 1
Posttest photo of plate 3
Note: Gasket degradation




Figure A-DTG1.4
Test DTG 1
Posttest photo of plate 3
Note: Gasket degradation


APPENDIX B

TEXT FIXTURE DRAWINGS

APPENDIX B

TEST FIXTURE DRAWINGS

<u>Page Description</u>	<u>Page</u>
1/4" O-Ring Test Fixture A	B-2
1/4" O-Ring Test Fixture B	B-7
Double Dog Ears Test Fixture	B-12
Double Gum Drop Test Fixture	B-17
Double O-Ring Test Fixture	B-22
Double Tongue & Groove Test Fixture	B-27










PLATE NO.	101
REV.	101
DATE	10/10/50
BY	J. H. B.
CHECKED	J. H. B.
APPROVED	J. H. B.
DESIGNED	J. H. B.
DRAWN	J. H. B.
SCALE	AS SHOWN









NO.	REVISION
1	AS SHOWN
2	AS SHOWN
3	AS SHOWN
4	AS SHOWN
5	AS SHOWN
6	AS SHOWN
7	AS SHOWN
8	AS SHOWN
9	AS SHOWN
10	AS SHOWN

NOTE: 1. DIMENSIONS ARE GIVEN IN FEET AND INCHES UNLESS OTHERWISE SPECIFIED.
 2. MATERIAL: STEEL.

PLATE #1
1057A * 1057B
1057C
1057D
1057E
1057F
1057G
1057H
1057I
1057J
1057K
1057L
1057M
1057N
1057O
1057P
1057Q
1057R
1057S
1057T
1057U
1057V
1057W
1057X
1057Y
1057Z






PLATE # 3	105 1/4 B
UNCLASSIFIED	UNCLASSIFIED
DATE	BY
REVISION	DESCRIPTION




NO.	REVISION	DATE	BY	CHKD.
1	ISSUED FOR CONSTRUCTION			
2	REVISION			
3	REVISION			
4	REVISION			
5	REVISION			
6	REVISION			
7	REVISION			
8	REVISION			
9	REVISION			
10	REVISION			


PROJECT NO.	100-100000
DATE	10/1/50
DESIGNED BY	W. H. HARRIS
CHECKED BY	W. H. HARRIS
SCALE	AS SHOWN
PROJECT TITLE	STADIUM SEATING
PLATE NO.	1
DATE	10/1/50
BY	W. H. HARRIS
CHKD.	W. H. HARRIS





NO.	REVISION	DATE	BY	CHKD.
1	ISSUED FOR CONSTRUCTION	10/15/54	J. H. [unclear]	[unclear]
2	REVISION TO [unclear]	11/15/54	[unclear]	[unclear]
3	REVISION TO [unclear]	12/15/54	[unclear]	[unclear]
4	REVISION TO [unclear]	1/15/55	[unclear]	[unclear]
5	REVISION TO [unclear]	2/15/55	[unclear]	[unclear]
6	REVISION TO [unclear]	3/15/55	[unclear]	[unclear]
7	REVISION TO [unclear]	4/15/55	[unclear]	[unclear]
8	REVISION TO [unclear]	5/15/55	[unclear]	[unclear]
9	REVISION TO [unclear]	6/15/55	[unclear]	[unclear]
10	REVISION TO [unclear]	7/15/55	[unclear]	[unclear]


DOUBLE DECK SLAB	
PAGE # 4	
DESIGNED BY	[unclear]
CHECKED BY	[unclear]
DATE	10/15/54
SCALE	AS SHOWN














NO.	REVISION	DATE	BY	CHKD.
1	ISSUED FOR PERMITS			
2	ISSUED FOR PERMITS			
3	ISSUED FOR PERMITS			
4	ISSUED FOR PERMITS			
5	ISSUED FOR PERMITS			
6	ISSUED FOR PERMITS			
7	ISSUED FOR PERMITS			
8	ISSUED FOR PERMITS			
9	ISSUED FOR PERMITS			
10	ISSUED FOR PERMITS			


NOTES:
 1. GENERAL REQUIREMENTS ARE SHOWN AND REFERRED TO BY DIMENSIONS.
 2. MATERIALS AND JOINTS TO BE SHOWN BY DIMENSIONS.
 3. ALL DIMENSIONS ARE TO FACE UNLESS OTHERWISE NOTED.
 4. SEE PLAN FOR ALL DIMENSIONS.

DOUBLE DECK DROP	
PLAN # 4	
DATE	11/20/57
SCALE	AS SHOWN
DESIGNED BY	W. J. HARRIS
CHECKED BY	W. J. HARRIS
APPROVED BY	










NOTES:
 1. GENERAL REQUIREMENTS ARE SET FORTH FOR SECTION
 2. MATERIALS AND DIMENSIONS SHOWN.
 3. ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED.

NOTE:
 1. ALL DIMENSIONS ARE IN INCHES UNLESS OTHERWISE SPECIFIED.
 2. ALL DIMENSIONS ARE TO BE TAKEN FROM THE CENTER OF THE FUEL ELEMENT.
 3. ALL DIMENSIONS ARE TO BE TAKEN FROM THE CENTER OF THE FUEL ELEMENT.
 4. ALL DIMENSIONS ARE TO BE TAKEN FROM THE CENTER OF THE FUEL ELEMENT.
 5. ALL DIMENSIONS ARE TO BE TAKEN FROM THE CENTER OF THE FUEL ELEMENT.

000010 A


SECTION I.I.


PLATE #	000010
REVISION	
DATE	
BY	
CHECKED	
APPROVED	





NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	11/15/51
2	ISSUED FOR CONSTRUCTION	11/15/51
3	ISSUED FOR RECORD	11/15/51
4	ISSUED FOR AS-BUILT	11/15/51
5	ISSUED FOR FINAL REVIEW	11/15/51
6	ISSUED FOR ARCHIVE	11/15/51

PLATE # 4	00110	
NO.	DESCRIPTION	DATE
1	ISSUED FOR PERMIT	11/15/51
2	ISSUED FOR CONSTRUCTION	11/15/51
3	ISSUED FOR RECORD	11/15/51
4	ISSUED FOR AS-BUILT	11/15/51
5	ISSUED FOR FINAL REVIEW	11/15/51
6	ISSUED FOR ARCHIVE	11/15/51










1	CONCRETE	3000 P.S.I.
2	GRAVEL	4\"/>
3	GRAVEL	4\"/>
4	GRAVEL	4\"/>
5	GRAVEL	4\"/>
6	GRAVEL	4\"/>
7	GRAVEL	4\"/>
8	GRAVEL	4\"/>
9	GRAVEL	4\"/>
10	GRAVEL	4\"/>
11	GRAVEL	4\"/>
12	GRAVEL	4\"/>
13	GRAVEL	4\"/>
14	GRAVEL	4\"/>
15	GRAVEL	4\"/>
16	GRAVEL	4\"/>
17	GRAVEL	4\"/>
18	GRAVEL	4\"/>
19	GRAVEL	4\"/>
20	GRAVEL	4\"/>
21	GRAVEL	4\"/>
22	GRAVEL	4\"/>
23	GRAVEL	4\"/>
24	GRAVEL	4\"/>
25	GRAVEL	4\"/>
26	GRAVEL	4\"/>
27	GRAVEL	4\"/>
28	GRAVEL	4\"/>
29	GRAVEL	4\"/>
30	GRAVEL	4\"/>
31	GRAVEL	4\"/>
32	GRAVEL	4\"/>
33	GRAVEL	4\"/>
34	GRAVEL	4\"/>
35	GRAVEL	4\"/>
36	GRAVEL	4\"/>
37	GRAVEL	4\"/>
38	GRAVEL	4\"/>
39	GRAVEL	4\"/>
40	GRAVEL	4\"/>
41	GRAVEL	4\"/>
42	GRAVEL	4\"/>
43	GRAVEL	4\"/>
44	GRAVEL	4\"/>
45	GRAVEL	4\"/>
46	GRAVEL	4\"/>
47	GRAVEL	4\"/>
48	GRAVEL	4\"/>
49	GRAVEL	4\"/>
50	GRAVEL	4\"/>
51	GRAVEL	4\"/>
52	GRAVEL	4\"/>
53	GRAVEL	4\"/>
54	GRAVEL	4\"/>
55	GRAVEL	4\"/>
56	GRAVEL	4\"/>
57	GRAVEL	4\"/>
58	GRAVEL	4\"/>
59	GRAVEL	4\"/>
60	GRAVEL	4\"/>
61	GRAVEL	4\"/>
62	GRAVEL	4\"/>
63	GRAVEL	4\"/>
64	GRAVEL	4\"/>
65	GRAVEL	4\"/>
66	GRAVEL	4\"/>
67	GRAVEL	4\"/>
68	GRAVEL	4\"/>
69	GRAVEL	4\"/>
70	GRAVEL	4\"/>
71	GRAVEL	4\"/>
72	GRAVEL	4\"/>
73	GRAVEL	4\"/>
74	GRAVEL	4\"/>
75	GRAVEL	4\"/>
76	GRAVEL	4\"/>
77	GRAVEL	4\"/>
78	GRAVEL	4\"/>
79	GRAVEL	4\"/>
80	GRAVEL	4\"/>
81	GRAVEL	4\"/>
82	GRAVEL	4\"/>
83	GRAVEL	4\"/>
84	GRAVEL	4\"/>
85	GRAVEL	4\"/>
86	GRAVEL	4\"/>
87	GRAVEL	4\"/>
88	GRAVEL	4\"/>
89	GRAVEL	4\"/>
90	GRAVEL	4\"/>
91	GRAVEL	4\"/>
92	GRAVEL	4\"/>
93	GRAVEL	4\"/>
94	GRAVEL	4\"/>
95	GRAVEL	4\"/>
96	GRAVEL	4\"/>
97	GRAVEL	4\"/>
98	GRAVEL	4\"/>
99	GRAVEL	4\"/>
100	GRAVEL	4\"/>

NO.	DESCRIPTION	DATE
1	DOUBLE STORAGE CISTERN	10/1/50
2	REVISION	
3	REVISION	
4	REVISION	
5	REVISION	
6	REVISION	
7	REVISION	
8	REVISION	
9	REVISION	
10	REVISION	
11	REVISION	
12	REVISION	
13	REVISION	
14	REVISION	
15	REVISION	
16	REVISION	
17	REVISION	
18	REVISION	
19	REVISION	
20	REVISION	
21	REVISION	
22	REVISION	
23	REVISION	
24	REVISION	
25	REVISION	
26	REVISION	
27	REVISION	
28	REVISION	
29	REVISION	
30	REVISION	
31	REVISION	
32	REVISION	
33	REVISION	
34	REVISION	
35	REVISION	
36	REVISION	
37	REVISION	
38	REVISION	
39	REVISION	
40	REVISION	
41	REVISION	
42	REVISION	
43	REVISION	
44	REVISION	
45	REVISION	
46	REVISION	
47	REVISION	
48	REVISION	
49	REVISION	
50	REVISION	
51	REVISION	
52	REVISION	
53	REVISION	
54	REVISION	
55	REVISION	
56	REVISION	
57	REVISION	
58	REVISION	
59	REVISION	
60	REVISION	
61	REVISION	
62	REVISION	
63	REVISION	
64	REVISION	
65	REVISION	
66	REVISION	
67	REVISION	
68	REVISION	
69	REVISION	
70	REVISION	
71	REVISION	
72	REVISION	
73	REVISION	
74	REVISION	
75	REVISION	
76	REVISION	
77	REVISION	
78	REVISION	
79	REVISION	
80	REVISION	
81	REVISION	
82	REVISION	
83	REVISION	
84	REVISION	
85	REVISION	
86	REVISION	
87	REVISION	
88	REVISION	
89	REVISION	
90	REVISION	
91	REVISION	
92	REVISION	
93	REVISION	
94	REVISION	
95	REVISION	
96	REVISION	
97	REVISION	
98	REVISION	
99	REVISION	
100	REVISION	



NO.	DESCRIPTION	QUANTITY	UNIT	AMOUNT
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100


APPENDIX C

TEMPERATURE DISTRIBUTIONS ON THE TEST FIXTURE
FOR TEST E-4

APPENDIX C

TEMPERATURE DISTRIBUTIONS ON THE TEST FIXTURE
FOR TEST E-4

<u>Page Descriptions</u>	<u>Page</u>
Thermocouple Locations for Test E-4	C-2
Temperature Records for Test E-4	C-3



Thermocouple locations for Test E-4

Figure C-1

THERMOCOUPLE RECORDINGS FOR TEST E-4

(degrees F)

TIME	CH 32	CH 36	CH 40	CH 42	CH 46	CH 50	CH 54	CH 55	CH 56
11:30:07	64.9	64.9	65.0	64.7	65.1	66.0	64.2	64.2	64.1
11:44:01	64.9	65.0	65.1	64.9	65.1	66.0	64.1	64.1	64.1
11:44:30	64.9	64.9	65.0	64.9	65.0	65.9	64.1	64.1	64.0
11:45:00	294.2	293.4	292.2	62.2	274.8	272.1	249.0	304.1	305.7
11:45:30	350.6	347.6	349.7	68.0	346.1	346.6	340.8	348.2	347.7
11:46:00	348.9	345.9	347.7	66.4	345.4	347.2	344.2	346.5	346.2
11:46:30	347.8	344.7	346.8	67.9	344.3	346.1	344.5	345.4	345.4
11:47:00	347.1	344.1	346.2	70.9	343.9	345.8	343.5	344.8	345.0
11:47:30	346.6	343.6	345.8	77.8	343.4	345.5	343.1	344.2	344.7
11:48:00	346.3	343.3	345.3	86.5	343.1	345.3	343.0	343.8	344.5
11:48:30	345.9	343.0	345.1	97.7	342.6	344.8	342.6	343.4	344.3
11:49:00	345.8	342.7	344.8	110.9	342.5	345.1	342.5	343.3	344.2
11:49:30	345.8	342.8	344.9	125.3	342.6	345.2	342.5	343.2	344.2
11:50:00	345.7	342.7	344.8	139.9	342.5	345.1	342.5	343.1	344.1
11:55:01	346.6	343.7	345.8	262.4	343.4	346.6	343.5	344.1	344.1
12:10:30	358.7	355.8	358.1	349.3	355.6	358.9	355.6	356.3	356.3
12:25:00	362.1	359.2	361.6	359.7	359.0	362.2	358.9	359.4	360.8
12:40:00	362.0	359.1	361.5	360.5	359.0	362.2	358.8	359.2	360.6
12:55:00	361.9	359.0	361.4	360.5	359.0	362.2	358.7	359.2	360.6
13:10:00	360.8	357.8	360.3	359.4	357.9	361.0	357.6	358.0	359.5
13:25:00	361.3	358.4	360.8	359.7	358.4	361.6	358.1	358.6	360.0
13:40:00	361.6	358.6	361.0	359.8	358.6	361.9	358.3	358.8	360.3
13:55:00	361.8	358.8	361.2	359.9	358.7	362.1	358.6	359.0	360.5
14:10:00	361.7	358.8	361.3	360.3	358.8	362.1	358.6	359.0	360.5
14:25:00	361.3	358.4	360.9	359.2	358.4	361.8	358.2	358.6	360.0
14:40:00	362.0	359.1	361.6	360.2	359.1	362.5	358.8	359.3	360.7
14:55:00	361.9	359.0	361.4	360.2	358.9	362.3	358.8	359.1	360.6
15:10:00	362.0	359.1	361.6	360.2	359.1	362.4	358.9	359.3	360.8
15:25:00	361.8	358.9	361.3	360.1	358.9	362.3	358.6	359.1	360.5
15:40:00	361.9	359.0	361.4	360.1	359.0	362.3	358.8	359.2	360.7
15:41:00	361.9	359.0	361.4	360.1	359.0	362.4	358.8	359.2	360.6
16:00:00	362.0	359.1	361.5	360.2	359.0	362.5	358.8	359.1	360.6
17:00:00	361.7	358.9	361.3	360.1	358.9	362.1	358.7	358.9	360.4
18:00:00	361.7	358.8	361.2	360.0	358.8	362.0	358.5	358.9	360.4
19:00:00	361.7	358.8	361.2	360.0	358.8	362.2	358.6	358.9	360.5
20:00:00	361.7	358.8	361.1	360.0	358.8	362.1	358.6	358.8	360.5
21:00:00	361.8	359.0	361.3	360.1	359.0	362.3	358.8	358.9	360.8
22:00:00	361.8	358.9	361.2	360.1	358.8	362.3	358.6	358.8	360.6
23:00:00	362.1	359.3	361.5	360.3	359.2	362.7	358.9	359.2	360.9
0:00:00	362.0	359.0	361.4	360.2	359.0	362.6	358.9	359.2	360.9
1:00:00	362.0	359.1	361.5	360.2	359.1	362.6	358.8	359.1	360.9
2:00:00	362.0	359.0	361.4	360.2	358.9	362.5	358.8	359.1	360.8
3:00:00	361.9	358.8	361.2	360.1	358.8	362.3	358.7	358.9	360.7
4:00:00	361.8	358.7	361.2	360.0	358.7	362.3	358.6	358.9	360.6
5:00:00	361.7	358.7	361.1	360.0	358.6	362.1	358.4	358.7	360.5
6:00:00	361.7	358.7	361.1	359.9	358.6	362.1	358.4	358.8	360.4
6:15:01	361.7	358.8	361.2	359.9	358.7	362.1	358.6	358.8	360.6

THERMOCOUPLE RECORDINGS FOR TEST E-4

(degrees F)

TIME	CH 32	CH 36	CH 40	CH 42	CH 46	CH 50	CH 54	CH 55	CH 56
6:30:00	366.8	367.9	368.8	360.6	359.6	367.3	359.4	370.0	370.0
6:45:00	380.3	381.1	386.9	360.4	372.9	372.3	361.1	379.7	388.8
7:00:00	404.0	403.6	409.6	360.9	390.2	380.9	387.9	403.4	411.9
7:15:00	424.4	423.9	430.4	366.3	407.6	395.3	403.8	423.4	434.3
7:30:00	438.3	438.0	445.6	376.4	420.5	406.7	417.9	438.0	450.1
7:45:00	447.6	447.1	454.8	386.9	430.4	416.4	427.0	447.2	458.8
8:00:00	454.6	453.4	461.8	396.9	436.9	424.6	434.1	453.9	467.4
8:15:00	460.2	458.7	466.6	406.5	442.6	432.8	440.1	459.8	471.5
8:30:00	464.4	462.4	470.6	415.0	446.2	437.4	445.6	463.4	476.3
8:45:00	467.3	465.4	473.1	422.6	450.0	442.9	449.4	466.9	478.7
9:00:00	470.4	468.3	475.9	429.5	453.9	447.6	452.8	470.0	480.6
9:15:00	473.1	470.5	477.9	435.5	456.8	451.4	456.5	472.0	482.0
9:30:00	474.9	472.5	479.5	440.8	459.5	454.7	458.7	473.7	483.7
9:45:00	478.1	475.4	482.1	445.6	462.8	460.2	462.6	477.0	485.9
10:00:00	480.3	477.5	484.3	450.2	465.2	464.6	466.3	479.1	487.8
10:15:00	481.8	479.1	486.0	454.6	467.9	468.5	469.4	480.9	489.0
10:30:01	483.1	480.6	487.4	458.5	470.2	471.8	471.6	482.4	489.7
10:45:00	484.4	481.8	488.1	462.0	471.8	473.5	473.6	483.6	490.1
11:00:00	486.2	483.0	489.6	465.1	473.9	476.1	475.6	484.4	490.8
11:15:00	487.1	484.3	490.4	468.0	474.6	477.8	477.2	485.7	492.1
11:30:00	487.6	485.2	490.9	470.3	476.1	478.8	478.4	486.3	491.9
11:45:00	489.0	485.3	491.3	472.4	476.7	480.6	479.6	486.5	492.4
12:00:00	489.3	486.0	492.3	474.4	477.8	481.3	480.7	477.5	493.0
12:15:00	490.1	486.5	492.6	476.0	478.5	482.2	481.6	488.5	493.3
12:30:00	490.6	487.3	493.1	477.5	479.4	483.2	482.1	488.3	493.4
12:45:00	491.1	487.6	493.5	478.7	479.8	483.9	483.0	489.3	494.2
13:00:00	491.6	488.2	493.8	479.8	480.5	484.3	483.6	489.6	494.1
13:15:00	491.6	487.9	493.4	480.9	480.6	484.7	483.9	489.6	493.6
13:30:00	498.1	494.8	501.3	481.7	485.5	488.0	488.3	496.0	502.8
13:45:00	502.7	499.0	506.2	483.3	489.1	491.7	491.6	500.7	507.8
14:00:00	505.8	502.1	509.4	485.4	492.2	494.8	494.9	503.8	510.7
14:15:00	512.3	508.7	516.5	487.9	497.2	498.3	499.2	510.9	519.1
14:30:00	516.8	514.0	521.9	491.0	502.6	502.9	504.3	516.6	525.4
14:45:00	520.7	518.0	525.5	494.4	505.7	506.9	508.0	520.0	528.9
15:00:00	524.3	521.2	529.0	498.3	509.2	510.1	512.0	523.6	531.5
15:15:00	526.7	523.4	530.8	501.8	512.2	513.4	513.9	525.8	533.4
15:30:00	529.4	525.8	532.9	505.4	513.9	516.8	517.2	527.5	535.4
15:45:00	498.7	496.1	498.1	508.2	501.6	504.5	504.1	495.9	500.5
16:00:01	467.9	455.2	452.1	506.8	475.5	482.5	484.3	458.0	465.4
17:00:00	437.4	431.5	438.1	474.5	440.1	444.1	441.2	42.1	424.3
18:00:00	398.1	397.2	403.7	438.6	402.7	406.7	408.3	397.7	393.8
19:00:00	373.9	369.8	377.9	398.7	374.0	378.9	379.9	375.7	370.4
20:00:00	363.4	361.0	365.9	368.5	362.0	367.1	366.7	360.3	362.2
21:00:00	362.4	359.7	362.4	362.7	359.7	364.3	361.7	359.6	361.1
22:00:00	362.2	359.4	361.7	361.1	359.6	363.3	359.9	359.5	361.1
23:00:00	362.1	359.3	361.6	360.5	359.4	362.8	359.2	359.3	361.1
0:00:00	362.2	359.4	361.7	360.5	359.4	362.7	359.2	359.4	361.1

THERMOCOUPLE RECORDINGS FOR TEST E-4

(degrees F)

TIME	CH 32	CH 36	CH 40	CH 42	CH 46	CH 50	CH 54	CH 55	CH 56
1:00:00	362.3	359.4	361.6	360.4	359.3	362.7	359.2	359.4	361.2
2:00:00	362.2	359.3	361.6	360.5	359.2	362.7	359.1	359.3	361.1
3:00:00	362.0	359.1	361.4	360.4	359.1	362.5	358.9	359.1	360.9
4:00:00	361.6	358.7	361.0	360.0	358.6	362.2	358.6	358.7	360.5
5:00:00	360.9	358.0	360.2	359.4	357.9	361.5	358.0	358.0	359.9
6:00:00	359.4	356.5	358.9	358.5	356.5	360.3	356.9	356.5	358.4
6:23:59	361.8	358.9	361.3	359.9	358.9	362.3	358.8	358.9	360.7
6:30:01	361.7	358.8	361.2	360.0	358.9	362.2	358.6	358.8	360.5
6:45:00	361.9	359.0	361.3	359.8	359.0	362.3	358.8	359.0	360.7
7:00:00	361.8	358.9	361.3	360.1	358.8	362.2	358.6	358.9	360.5
7:15:00	361.3	358.4	360.8	359.7	358.4	361.7	358.2	358.5	360.0
7:30:00	359.8	356.9	359.4	358.9	357.0	360.3	356.8	357.1	358.6
7:45:00	386.3	365.9	399.7	360.2	380.0	377.3	370.5	390.3	390.9
8:00:00	466.1	469.0	481.0	366.1	439.6	419.7	436.5	469.1	482.4
8:15:00	501.0	501.8	516.6	383.9	465.9	447.5	465.3	504.4	521.9
8:30:00	518.9	519.4	534.5	405.6	489.1	466.9	482.0	523.2	539.6
8:45:00	541.8	540.4	555.1	428.2	507.6	491.4	507.6	544.2	561.0
9:00:00	555.7	554.0	566.0	451.2	523.5	512.4	522.4	557.8	574.8
9:15:00	562.4	559.6	572.8	472.0	533.4	521.8	533.5	565.4	578.8
9:30:00	568.5	567.0	578.7	489.8	542.6	532.2	540.8	571.4	582.9
9:45:00	574.4	570.7	581.3	505.3	547.0	542.7	549.1	575.2	587.7
10:00:00	576.1	573.7	583.5	518.1	552.9	549.7	555.6	577.5	588.8
10:15:00	577.2	574.0	583.9	528.7	556.5	554.4	558.9	578.2	589.0
10:16:35	576.9	574.4	584.0	529.7	557.2	553.2	559.1	577.9	588.7
10:17:34	577.6	574.7	583.3	530.4	556.1	554.3	559.0	578.1	588.9
10:32:34	575.7	573.3	582.3	538.4	557.1	556.2	559.5	576.5	586.2
10:47:34	584.8	581.7	588.9	544.7	563.8	567.3	567.7	586.9	594.4
11:02:34	589.2	586.6	593.5	551.3	569.9	572.3	572.9	589.6	597.9
11:17:34	592.0	589.1	596.1	557.5	573.9	577.0	577.6	593.0	600.7
11:32:34	595.1	592.5	600.2	563.1	577.3	580.9	581.8	596.0	603.6
11:47:34	601.0	598.0	605.9	568.4	583.0	585.0	586.8	600.9	608.6
12:02:34	607.3	604.6	611.9	575.5	588.6	592.2	592.7	609.2	615.1
12:17:34	612.3	608.6	616.2	579.1	593.2	596.8	598.1	614.1	620.3
12:32:34	615.2	611.3	618.8	584.3	597.0	600.5	601.3	617.2	622.1
12:47:34	617.7	613.7	621.3	589.3	599.8	604.7	605.2	619.2	624.1
13:02:34	619.3	615.7	623.0	593.8	602.2	607.2	607.2	621.6	625.5
13:17:34	621.0	617.5	624.6	597.8	603.8	609.0	609.8	623.9	626.2
13:32:34	621.9	618.2	626.3	601.2	606.1	611.0	610.7	625.3	627.7
13:47:34	623.2	619.0	627.1	604.1	607.7	612.6	612.6	626.0	628.2
14:02:34	620.5	617.0	623.2	606.5	606.6	612.5	611.1	621.4	623.0
14:17:34	617.9	614.9	620.3	608.3	606.4	611.5	610.0	619.4	619.0
14:32:34	612.4	609.8	615.0	608.9	603.4	608.9	607.5	611.2	611.0
14:47:34	607.5	606.5	612.1	608.6	600.9	606.0	605.3	606.4	605.7
15:02:34	603.1	601.3	606.9	607.5	598.3	602.8	602.3	601.5	600.9
15:03:15	603.0	600.8	606.1	607.4	598.1	602.8	602.2	601.8	600.9
15:18:14	589.5	588.4	592.1	605.5	589.6	595.0	594.2	588.1	585.4
15:33:14	576.1	576.6	578.9	601.8	580.6	585.1	583.8	573.4	572.7

THERMOCOUPLE RECORDINGS FOR TEST E-4

(degrees F)

TIME	CH 32	CH 36	CH 40	CH 42	CH 46	CH 50	CH 54	CH 55	CH 56
15:33:48	575.2	575.8	581.2	601.6	580.0	584.6	583.4	572.9	572.2
16:00:01	554.5	548.8	557.1	590.2	563.1	566.7	564.5	561.5	547.0
17:00:00	505.4	497.3	505.2	551.1	514.0	518.5	514.7	510.4	493.1
18:00:00	460.0	452.7	460.4	505.9	467.6	468.8	466.2	465.8	443.9
19:00:00	412.9	411.2	417.3	463.3	417.3	420.1	421.3	420.4	404.6
20:00:00	381.3	381.0	384.0	419.2	382.5	386.4	386.0	380.8	378.2
21:00:00	370.6	367.3	368.3	391.7	367.5	373.1	371.3	369.7	366.8
22:00:00	365.3	361.6	362.7	376.8	363.2	367.9	365.8	364.4	362.6
23:00:00	362.2	360.0	361.6	368.7	361.1	365.3	362.4	361.1	361.9
0:00:00	361.4	359.0	361.1	363.6	358.4	363.7	360.3	359.8	360.9
1:00:00	361.2	358.3	360.8	360.8	358.2	362.5	359.2	358.7	360.3
2:00:00	360.7	357.9	360.4	359.8	357.8	361.7	358.3	358.0	359.7
3:00:00	360.4	357.5	359.9	359.1	357.4	361.1	357.8	357.5	359.4
4:00:00	360.2	357.3	359.5	358.6	357.2	360.8	357.3	357.2	359.1
5:00:00	360.1	357.2	359.5	358.4	357.2	360.7	357.2	357.2	359.0
6:00:00	360.8	357.9	360.2	359.7	357.8	361.3	357.7	357.9	359.8
6:15:01	388.7	396.0	402.6	359.5	382.0	378.3	382.0	398.8	403.4
6:30:00	493.4	496.3	509.3	365.2	452.7	430.3	453.8	495.5	511.2
6:45:00	545.3	547.1	566.4	387.3	503.5	472.7	499.2	550.0	571.9
7:00:00	579.4	579.5	598.6	419.0	537.4	505.2	532.9	585.0	605.3
7:15:00	603.0	602.0	622.2	452.9	559.4	534.1	558.2	608.0	628.9
7:30:00	619.7	617.5	635.3	485.3	579.8	556.7	579.5	623.9	643.5
7:45:00	633.6	630.4	647.0	514.4	593.3	577.1	593.8	637.9	655.9
8:00:00	645.2	641.5	655.8	540.4	608.6	594.1	610.4	648.3	664.0
8:15:00	654.5	650.2	665.1	562.8	620.1	608.9	624.8	657.8	673.1
8:30:00	662.3	658.8	670.0	582.1	631.4	623.3	633.1	664.7	679.6
8:45:00	669.1	665.1	676.2	598.9	640.4	634.1	642.7	670.6	684.4
9:00:00	674.4	670.4	681.0	613.4	647.9	644.8	650.5	675.3	689.4
9:15:00	679.0	674.6	684.0	625.7	653.3	653.3	658.0	679.9	691.4
9:30:00	682.4	679.3	687.6	636.2	657.7	661.1	662.7	684.1	694.4
9:45:00	684.9	681.4	690.9	645.0	661.9	665.4	667.9	686.3	695.7
10:00:00	687.3	683.8	692.6	652.5	665.2	670.0	672.0	689.7	697.1
10:15:00	689.3	685.8	694.7	658.8	668.9	673.7	675.2	690.9	698.2
10:30:00	691.1	687.6	695.6	664.2	671.4	676.0	678.4	692.5	699.1
10:45:00	692.5	688.7	697.8	668.6	673.4	678.4	679.7	693.3	700.1
11:00:00	693.5	689.6	698.3	672.3	674.7	680.6	681.7	694.9	700.8
11:15:00	694.1	690.6	698.8	675.4	676.5	682.3	682.4	695.9	700.7
11:30:00	695.4	691.3	699.2	678.0	678.1	683.7	684.1	697.3	701.3
11:45:00	696.4	692.5	700.3	680.2	679.0	684.8	685.2	697.8	701.9
12:00:00	697.3	693.0	701.2	682.0	680.1	686.1	686.6	698.2	702.3
12:15:00	697.4	693.7	701.8	683.5	680.9	686.9	687.3	698.5	702.8
12:30:00	697.8	693.9	701.9	684.9	681.3	687.5	687.8	699.2	703.1
12:45:00	698.6	694.5	701.7	685.9	682.0	688.6	688.1	700.0	703.2
13:00:00	698.9	695.0	702.6	686.7	682.6	689.1	689.2	700.7	703.7
13:15:00	701.5	697.9	705.7	687.6	684.2	690.8	691.2	702.7	707.4
13:30:00	703.3	699.7	708.1	688.6	686.1	692.3	693.1	704.0	708.9

NRC FORM 338 (2-84) NRCM 1102, 3201, 3202 SEE INSTRUCTIONS ON THE REVERSE	U.S. NUCLEAR REGULATORY COMMISSION BIBLIOGRAPHIC DATA SHEET	1 REPORT NUMBER (Assigned by TDC, add Vol. No., if any) NUREG/CR-5096 SAND88-7016			
2 TITLE AND SUBTITLE Evaluation of Seals for Mechanical Penetrations of Containment Buildings	3 LEAVE BLANK 4 DATE REPORT COMPLETED <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">MONTH</td> <td style="width: 50%; text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">June</td> <td style="text-align: center;">1988</td> </tr> </table>	MONTH	YEAR	June	1988
MONTH	YEAR				
June	1988				
5 AUTHOR(S) D. A. Brinson G. H. Graves	6 DATE REPORT ISSUED <table border="1" style="width: 100%; border-collapse: collapse;"> <tr> <td style="width: 50%; text-align: center;">MONTH</td> <td style="width: 50%; text-align: center;">YEAR</td> </tr> <tr> <td style="text-align: center;">August</td> <td style="text-align: center;">1988</td> </tr> </table>	MONTH	YEAR	August	1988
MONTH	YEAR				
August	1988				
7 PERFORMING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code) ERC International Under Contract to: 1717 Louisiana NE Sandia National Laboratories Suite 202 Albuquerque, NM 87185 Albuquerque, NM 87110	8 PROJECT/TASK WORK UNIT NUMBER 9 FIN OR GRANT NUMBER FIN A1375				
10 SPONSORING ORGANIZATION NAME AND MAILING ADDRESS (Include Zip Code) Division of Engineering Office of Nuclear Regulatory Research U.S. Nuclear Regulatory Commission Washington, DC 20555	11a TYPE OF REPORT Topical 11b PERIOD COVERED (Inclusive dates)				
12 SUPPLEMENTARY NOTES					
13 ABSTRACT (200 words or less) This report describes tests of elastomeric seals that are used in the mechanical penetrations of nuclear power plant containments. These tests assessed the effects of thermal aging, radiation and thermal aging, sealing surface separation, and squeeze on the performance of several gasket designs: O-ring, gum drop, double dog ear, and tongue and groove. Both ethylene propylene rubber and silicone rubber gaskets were tested. The environment for testing enveloped a hypothetical severe accident: 143 psig and up to 700°F. The seal's performance is quantified in terms of the leakage onset point on the time-temperature curve.					
14 DOCUMENT ANALYSIS -- KEYWORDS-DESCRIPTORS elastomeric seals mechanical penetrations severe accident 9 IDENTIFIERS-OPEN ENDED TERMS	15 AVAILABILITY STATEMENT Unlimited 16 SECURITY CLASSIFICATION (This page) Unclassified (This report) Unclassified 17 NUMBER OF PAGES 18 PRICE				

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

OFFICIAL BUSINESS
PENALTY FOR PRIVATE USE, \$300

SPECIAL FOURTH-CLASS RATE
POSTAGE & FEES PAID
USNRC
PERMIT NO. G-67

120555139125 1 1AN1R11RD
US NRC-OARM-ADM
DIV FOIA & PUBLICATIONS SVCS
RRES-TECH PUB UNIT
P-210
WASHINGTON DC 20555