



Log # TXX-88697  
File # 10110  
903.8  
Ref. # 10CFR50.55(e)

William G. Council  
Executive Vice President

October 3, 1988

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

SUBJECT: COMANCHE PEAK STEAM ELECTRIC STATION (CPSES)  
DOCKET NOS. 50-445 AND 50-446  
DEFICIENCIES IN STEAM GENERATOR CUBICLE STEEL PLATFORM  
FRAMING AND PRESSURIZER SUPPORT SLAB  
SDAR: CP-87-131 (SUPPLEMENTAL REPORT)


Gentlemen:

On February 5, 1988, TU Electric letter logged TXX-88177 notified the NRC Staff of a deficiency involving unacceptable subcompartment pressurization effects resulting from a postulated pressurizer surge line break. The last report on this issue, logged TXX-88331, was submitted March 21, 1988.

Pressurizer surge line breaks are eliminated by showing that the line will leak before it breaks. The Leak Before Break analysis was submitted for approval via TXX-88382 dated April 15, 1988. Additional analysis on the pressurizer surge line is being performed to address thermal stratification effects. This additional analysis is scheduled for completion by March 1, 1989 for Unit 1. The analysis for Unit 2 will be completed prior to Unit 2 Hot Functional Test.

Very truly yours,

W. G. Council

By:   
John W. Beck  
Vice President,  
Nuclear Engineering

HAM/mlh

c - Mr. R. D. Martin, Region IV  
Resident Inspectors, CPSES (3)

BB101 0292 BB1003  
PDR ADOCK 05000446  
S PNU

IF27  
110