

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555 May 27, 1988

Docket No. 50-382

Mr. J. G. Dewease Senior Vice President - Nuclear Operations Louisiana Power and Light Company 317 Baronne Street, Mail Unit 17 New Orleans, Louisiana 70112

Dear Mr. Dewease:

SUBJECT: APPROVAL OF FRACTURE MECHANICS ANALYSIS OF REACTOR VESSEL FLAW INDICATIONS IN HOT LEG NOZZLE TO SHELL WELD - WATERFORD STEAM ELECTRIC STATION, UNIT 3 (TAC NO. 67977)

By letter dated May 16, 1988, the Louisiana Power and Light Company provided results of a recent Inservice Inspection (ISI) examination of Waterford 3. During the second refueling outage, ISI examinations of certain reactor vessel welds and ligaments were performed in accordance with the ASME Code, Section XI. The examinations were completed on May 9, 1988.

During the scheduled ISI of the reactor vessel, three flaw indications were detected in the nozzle located at 0 degrees that exceeded or approached the acceptance standards of ASME Code, Section XI. To provide enhanced characterization and sizing of these indications, the Ultrasonic Data Recording and Processing System (UDRPS) was used. The UDRPS data revealed three indications in the hot leg nozzle to shell weld within the weld at or near the weld/nozzle forging fusion line. The UDRPS examination determined that the three flaws exceed the standards of ASME Code, Section XI. Therefore, the component would be unacceptable for service unless flaws are removed or repaired. However, as allowed by ASME Code, a fracture mechanics evaluation, needed to demonstrate acceptance for service by evaluation and reexamination, was provided for our approval. We have completed our review.

Our enclosed safety evaluation concludes the following:

 The fracture mechanics analysis demonstrates that the three flaw indications in the hot leg nozzle-to-shell weld will not grow during the life of the plant to a size that will affect the integrity of the reactor vessel.

8806150277 880527 PDR ADOCK 05000382 P PDR 2. These flaw indications are conditionally acceptable for service and, therefore, require augmented inservice inspection during the next three inspection periods pursuant to ASME Section XI paragraph IWB-2420(b).

Please contact us should you have any questions.

Sincerely,

David L. Wigginton, Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects

Enclosure: Safety Evaluation

1.8

cc w/enclosure: See next page Mr. Jerrold G. Dewease Louisiana Power & Light Company

cc:

W. Malcolm Stevenson, Esq. Monroe & Leman 1432 Whitney Building New Orleans, Louisiana 70103

Mr. E. Blake Shaw, Pittman, Potts & Trowbridge 2300 N Street, NW Washington, D.C. 20037

Resident Inspector/Waterford NPS Post Office Box 822 Killona, Louisiana 70066

Mr. Ralph T. Lally Manager of Quality Assurance Middle South Services, Inc. Post Office Box 61000 New Orleans, Louisiana 70161

Chairman Louisiana Public Service Commission One American Place, Suite 1630 Baton Rouge, Louisiana 70825-1697

Mr. R. F. Burski, Acting Nuclear Safety and Regulatory Affairs Manager Louisiana Power & Light Company 317 Baronne Street New Orleans, Louisiana 70112

Waterford 3

Regional Administrator, Region IV U.S. Nuclear Regulatory Commission Office of Executive Director for Operations 611 Ryan Plaza Drive, Suite 1000 Arlington, Texas 76011

Mr. William H. Spell, Administrator Nuclear Energy Division Office of Environmental Affairs Post Office Box 14690 Baton Rouge, Louisiana 70898

President, Police Jury St. Charles Parish Hahnville, Louisiana 70057

William A. Cross Bethesda Licensing Office 3 Metro Center Suite 610 Bethesda, Maryland 20814 2. These flaw indications are conditionally acceptable for service and, therefore, require augmented inservice inspection during the next three inspection periods pursuant to ASME Section XI paragraph IWB-2420(b).

Please contact us should you have any questions.

Sincerely,

151

David L. Wigginton, Project Manager Project Directorate - IV Division of Reactor Projects - III, IV, V and Special Projects

Enclosure: Safety Evaluation

cc w/enclosure: See next page

DISTRIBUTION Docket File L. Rubenstein OGC-Rockville PD4 Plant File

PD4/LA Men PNoonan 05/22/88 NRC PDR J. Calvo E. Jordan

PD4/PN DWigginton:sr 055 88

Local PDR P. Noonan J. Partlow

PD4/D Me JCalvo

05/27/88

PD4 Reading D. Wigginton ACRS (10)

-2-