



GPU Nuclear, Inc.  
U.S. Route #9 South  
Post Office Box 388  
Forked River, NJ 08731-0388  
Tel 609-971-4000

October 26, 1998  
1940-98-20634

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington DC 20555

Dear Sir:

Subject: Oyster Creek Nuclear Generating Station  
Docket No. 50-219  
Secondary Containment Capability Results

The Oyster Creek Nuclear Generating Station Technical Specifications require:

- 4.5.G.2 "(Secondary Containment) tests shall be performed at least once per operating cycle..."
- 4.5.G.3 "A secondary containment capability test shall be conducted at each refueling outage prior to refueling."
- 4.5.G.4 "The results of the secondary containment capability tests shall be in the subject of a summary technical report..."

Attachment I to this letter documents the completion of requirements 4.5.G.2 and 4.5.G.3 by docketing the report required in 4.5.G.4.

If any additional information or assistance is required, please contact Mr. John Rogers of my staff at 609.971.4893.

Very truly yours,

Michael B. Roche  
Vice President and Director  
Oyster Creek

9811030304 981026  
PDR ADOCK 05000219  
P PDR

MBR/JJR  
Attachment

cc: Administrator, Region I  
NRC Project Manager  
Senior Resident Inspector

1/1  
A001

## Attachment I

### Summary Technical Report Secondary Containment Capability Test

Oyster Creek Nuclear Generating Station  
Operating Cycle 16; Prior to Refueling Outage 17R  
Date Performed: September 12, 1998

#### 1. Wind Speed

Test Prerequisite	Observed
"...calm wind ..."	10.3 mph

#### 2. Standby Gas Treatment System Flow Rate

Test Requirement	Test Results
< 4000 cfm	2505 cfm

#### 3. Reactor Building Differential Pressure

Test Requirements	Test Results
Both Reactor Airlock Doors Closed $\geq 0.25$ inches W.G.	0.436 inches W.G.
Outer Railroad Airlock Door Open $\geq 0.25$ inches W.G.	0.440 inches W.G.
Inner Railroad Airlock Door Open $\geq 0.25$ inches W.G.	0.358 inches W.G.