

Commonwealth Edison Company
Quad Cities Generating Station
22710 206th Avenue North
Cordova, IL 61212-9710
Tel 309-654-2211



SVP-98-331

October 27, 1998

U.S. Nuclear Regulatory Commission
Washington, DC 20555

Attn: Document Control Desk

Reference: Quad Cities Nuclear Power Station
Docket Number 50-254, DPR-29, Unit One

Enclosed is Licensee Event Report (LER) 98-001, Revision 1, for Quad Cities Nuclear Power Station. This event report is associated with the Unit One Emergency Diesel Generator (EDG) failure to start when the EDG received an inadvertent start signal. This signal was received when a relay was bumped during testing. Following the failure to start, the EDG was inadvertently started 15 minutes later due to an error by an operator who was responding to the failure to start event.

The purpose of this revision is to update the aforementioned LER with respect to corrective actions.

All Corrective Actions to be Completed in Section D of Revision 0 have been closed. No further actions are required.

Any other actions described in the submittal represent intended or planned actions by ComEd. They are described for the NRC's information and are not regulatory commitments.

//


Jerr

9811040046 981027
PDR ADOCK 05000254
S PDR

October 27, 1998

If there are any questions or comments concerning this letter, please refer them to Charles Peterson, Regulatory Affairs Manager at 309-654-2241, ext. 3609.

Sincerely,



Joel P. Dimmette, Jr.
Site Vice President
Quad Cities Nuclear Power Station

JPD/CP/ea

Enclosure

cc: Regional Administrator -NRC Region III
R. Pulsifer, Project Manager, NRR
C. Miller, Senior Resident Inspector, Quad Cities
W. Leech, MidAmerican Energy Company
D. Tubbs, MidAmerican Energy Company
B. Ganser, IDNS, Quad Cities
S. Focht, American Nuclear Insurers
INPO Records Center
Office of Nuclear Facility Safety, IDNS

bcc: N. Reynolds, Winston & Strawn
R. Krich, VP Regulatory Services, Downers Grove
B. Rybak, Licensing, Downers Grove
F. Spangenberg, Regulatory Assurance Manager, Dresden
C. Peterson, Regulatory Assurance Manager, Quad Cities
W. Beck, Deputy Regulatory Assurance Manager, Quad Cities
K. Bethard, NRC Coordinator, Quad Cities
R. Baumer, SRB Site Coordinator, Quad Cities
O. Kingsley, President and CNOO, Downers Grove, ComEd
Shift Manager Routing, Quad Cities
R. Chrzanowski, Nuclear Oversight, Quad Cities
F. Tsakeres, Training Manager, Quad Cities
T. Barber, Nuclear Oversight, Quad Cities (2 copies)
R. Baumer, OPEX Coordinator, Quad Cities (electronic copy only)
D. Dillinger, OPEX Coordinator, Byron (electronic copy only)
R. Leigh, OPEX Coordinator, Zion (electronic copy only)
J. Wujciga, OPEX Coordinator, Dresden (electronic copy only)
M. Hurst, OPEX Coordinator, Braidwood (electronic copy only)
G. Kusnick, OPEX Coordinator, PTC (electronic copy only)
J. Tokarz, OPEX Coordinator, LaSalle (electronic copy only)
R. Hynes, OPEX Coordinator, Downers Grove (electronic copy only)
J. Sirovy, Nuclear Oversight, Quad Cities (electronic copy only)
DCD Licensing (both electronic and hard copies)
SVP Letter File