

NOTICE OF DEVIATION

Illinois Power Company

Docket No. 50-461

As a result of the inspection conducted on February 24 through March 13, 1986, and in accordance with the "General Policy for NRC Enforcement Actions," 10 CFR Part 2, Appendix C (1985), the following deviation was identified:

In the Final Safety Analysis Report, the licensee committed to preoperational/ acceptance test the Security battery in accordance with the Institute of Electrical and Electronics Engineers (IEEE) Standard 450-1980.

Contrary to the above, the capacity of the Security battery was not determined during acceptance testing as required by the IEEE Standard 450-1980. (461/86013-03)

This is a Deviation (Supplement II).

Pursuant to the provisions of 10 CFR 2.201, you are required to submit to this office within thirty days of the date of this Notice a written statement or explanation in reply, including: (1) corrective action taken and results achieved; (2) corrective action to be taken to avoid further deviations; and (3) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

4/11/86
Dated

Carl J. Paperiello
Carl J. Paperiello, Director
Division of Reactor Safety

8604170471 860411
PDR ADOCK 05000461
Q PDR