

OCT 5 1988

In Reply Refer To:
Docket: 50-382


Louisiana Power & Light Company
ATTN: J. G. Dewease, Senior Vice President
Nuclear Operations
317 Baronne Street
New Orleans, Louisiana 70160

Gentlemen:

This acknowledges the granting of enforcement discretion to Waterford 3 from the provisions of Technical Specification 3.3.1, "Reactor Protective Instrumentation." Your letter (W3P88-1817) to this office, dated September 30, 1988, provides your basis for the enforcement discretion request. Enforcement discretion was granted by NRC Region IV on September 29, 1988, at 7 p.m. (CDT) to allow continued power operation for a period of 24 hours while missing seismic brackets were installed in a drawer of the core protection calculator (CPC) cabinets.

We understand that the installation of the missing seismic brackets was completed for all four affected CPC cabinets by 10:30 a.m. (CDT) on September 30, 1988.

Sincerely,



E. J. Callan, Director
Division of Reactor Projects

cc:
Louisiana Power & Light Company
ATTN: G. E. Wuller, Onsite
Licensing Coordinator
P.O. Box B
Killona, Louisiana 70066

Louisiana Power & Light Company
ATTN: N. S. Carns, Plant Manager
P.O. Box B
Killona, Louisiana 70066

Middle South Services
ATTN: Mr. R. T. Lally
P.O. Box 61000
New Orleans, Louisiana 70161

JGF
RIV:C:PSA
DDChamberlain;df
10/5 /88

D:DRP
LJCallan
10/5 /88

IE01
1/0

Louisiana Power & Light Company

-2-

Louisiana Power & Light Company
ATTN: R. F. Burski, Acting Manager
Nuclear Safety and Regulatory
Affairs
317 Baronne Street
P.O. Box 60340
New Orleans, Louisiana 70160

Louisiana Radiation Control Program Director

bcc to DMB (IE01)

bcc distrib. by RIV:

RRI
Section Chief (DRP/A)
RPB-DRS
Project Engineer, DRP/A
RIV File
DRS

R. D. Martin, RA
DRP
MIS System
RSTS Operator
D. Wigginton, NRR Project Manager
Lisa Shea, RM/ALF



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

OCT 7 1988

Docket No. 50-445

MEMORANDUM FOR:

THRU:

FROM:

SUBJECT:

Date and Time:

Location:

Purpose:

Participants:

Christopher I. Grimes, Director
Comanche Peak Project Division
Office of Special Projects

James H. Wilson, Assistant Director
for Projects
Comanche Peak Project Division
Office of Special Projects

Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects

FORTHCOMING MEETING WITH TU ELECTRIC

October 19-20, 1988
8:00 am - 6:00 pm (each day)

One White Flint North
11555 Rockville Pike
Rockville, Maryland 20852
Room 4-B-11

Discussion of proposed changes to the Comanche Peak
Unit 1 Technical Specifications and preparation of the
"Proof & Review" version of the Technical Specifications
(agenda later)

NRC
M. Malloy
R. Giardina

TU Electric
D. Woodlan
J. Kelley
N. Hood

Melinda Malloy
Melinda Malloy, Project Manager
Comanche Peak Project Division
Office of Special Projects

cc: See next page
CONTACT(s): Melinda Malloy or James H. Wilson
(301) 492-0738 (301) 492-3308

ings between NRC technical staff and applicants for licenses are o
members of the public, petitioners, intervenors, or other
pursuant to "Open Meetings and Statement of NR
28058, 6/28/78.

Dfo