

James A. FitzPatrick
Nuclear Power Plant
268 Lake Road
P.O. Box 41
Lycoming, New York 13093
315-342-3840



Michael J. Colomb
Site Executive Officer

October 27, 1998
JAFP-98-0348

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Mail Station P1-137
Washington, D.C. 20555

SUBJECT: James A. FitzPatrick Nuclear Power Plant
Docket No. 50-333
Supplemental Letter Regarding Proposed Changes to the Technical Specification for Logic System Functional Test Frequency

Reference: 1. NYPA Letter, J. Knubel to the NRC, "Proposed Change to the Technical Specifications Regarding Logic System Functional Test Frequency (JPTS-96-013)," (JPN-98-011), dated March 30, 1998


Dear Sir:

This letter is submitted to inform the NRC of the completion of a commitment made in the referenced Technical Specification (TS) submittal for the James A. FitzPatrick Nuclear Power Plant.

The referenced TS change request commits to lowering the field setting for timer 17RTM-157 prior to implementation of the NRC approved changes. On 10/23/98, the field setting of 17RTM-157 was lowered. With this setting change, the Off-Gas Line Isolation Logic System Functional Test can be extended to 24 months.

The completion of this commitment does not affect the bases and conclusions of the no significant hazards consideration described in Reference 1.

There are no new commitments made by the Authority in this letter. If you have any questions, please contact Mr. Art Zaremba at (315) 349-6365.


Michael J. Colomb
Site Executive Officer

MJC:JJC:las

9811050117 981027
PDR ADOCK 05000333
P PDR

1/0

Adol

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Subject: Information Regarding LSFT
Page -2-

cc: JPTS-96-013 File

Regional Administrator
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, PA 19406

Office of the Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 136
Lycoming, New York 13093

Mr. J. Williams, Project Manager
Project Directorate I-1
Division of Reactor Projects - I/II
U.S. Nuclear Regulatory Commission
Mail Stop 14B2
Washington, DC 20555

M. F. William Valentino, President
New York State Energy, Research and Development Authority
Corporate Plaza West
286 Washington Avenue Extension
Albany, NY 12203-6399