

ELECTRICAL EQUIPMENT PROTECTIVE DEVICES

SAFETY-RELATED MOTOR-OPERATED VALVES THERMAL OVERLOAD PROTECTION AND BYPASS DEVICES

LIMITING CONDITION FOR OPERATION

---

---

3.8.4.2 The thermal overload protection bypass devices of each safety-related motor-operated valve given in Table 3.8-1 shall be OPERABLE.

APPLICABILITY: Whenever the motor-operated valve is required to be OPERABLE.

ACTION:

With the thermal overload protection bypass devices for any one or more safety-related motor-operated valves inoperable, declare the affected valve(s) inoperable and apply the appropriate ACTION Statement(s) of the affected valve(s).

SURVEILLANCE REQUIREMENTS

---

---

4.8.4.2 The above required thermal overload protection bypass devices shall be verified to be OPERABLE.

- a. Following maintenance on the valve motor starter, and
- b. Following any periodic testing during which the thermal overload device was temporarily placed in force.
- c. At least once per 18 months.