

SEP 23 1988

official

Docket Nos. 50-325, 50-324
License Nos. DPR-71, DPR-62

Carolina Power and Light Company
ATTN: Mr. E. E. Utley
Senior Executive Vice President
Power Supply and Engineering
and Construction

P. O. Box 1551
Raleigh, NC 27602

Gentlemen:

SUBJECT: NRC INSPECTION REPORT NOS. 50-325/88-28 AND 50-324/88-28

This refers to the Nuclear Regulatory Commission (NRC) inspection conducted by C. A. Hughey on August 1-5, 1988. The inspection included a review of activities authorized for your Brunswick facility. At the conclusion of the inspection, the findings were discussed with those members of your staff identified in the enclosed inspection report.

Areas examined during the inspection are identified in the report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observation of activities in progress.

Within the scope of the inspection, no violations or deviations were identified.

The NRC expressed their concern regarding the apparent lack of management attention to the inoperability of gaseous effluent monitoring instrumentation in their letter to you, dated October 1, 1987, NRC Inspection Report Nos. 50-325/87-33 and 50-324/87-32. Your letter of June 20, 1988, postpones your commitment to have the Reactor Building and Turbine Building ventilation flow rate measurement devices operational by January 13, 1989 until January 13, 1990, due to project scheduling considerations. Your letter does not provide a basis for Brunswick to continue in an ACTION statement of the Technical Specifications. The intent of ACTION statements for Technical Specifications is to provide licensees an alternative reasonable short-time operability period until corrective actions can be taken to place the system, equipment, etc., in an operable condition. You are requested to provide the NRC with your basis for continuing in an ACTION statement condition of the Technical Specifications until January 13, 1990.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter and its enclosure will be placed in the NRC Public Document Room.

8810130007 880923
PDR ADOCK 05000324
G PNU

IEOB
11/1/88

Should you have any questions concerning this letter, please contact us.

Sincerely,

J. Nelson Grace
Regional Administrator

Enclosure:
Inspection Report

cc w/encl:

- / P. W. Howe, Vice President
Brunswick Nuclear Project
- ✓ C. R. Dietz, Plant General Manager
State of North Carolina

bcc w/encl:

- ✓ NRC Resident Inspector
- DRS Technical Assistant
- Document Control Desk

RII
[Signature]
CHughey
9/1/88

RII
[Signature]
JKahle
9/1/88

RII
[Signature]
DCollins
9/20/88

RII
[Signature]
JPStohr
9/20/88

RII
[Signature]
PFredrickson
9/10/88
Subst
LW

RII
[Signature]
MErnst
9/21/88