

Amendments Nos. 30, 59, 97, 103, 105, 113, 121
 3.1-4

Table 3.1-1 (Continued)

Scram Number (a)	Source of Scram Trip Signal	Operable Channels Required Per Trip System (b)	Scram Trip Setting	Source of Scram Signal is Required to be Operable Except as Indicated Below
5	High Drywell Pressure	2	≤ 1.92 psig	Not required to be operable when primary containment integrity is not required.
6	Reactor Vessel Water Level (Low) (Level 3)	2	≥ 10.0 inches	
7	Scram Discharge Volume High High Level			Permissible to bypass (initiates control rod block) in order to reset RPS when the Mode Switch is in the REFUEL or SHUTDOWN position.
	a. Float Switches	2	≤ 71 gallons	
	b. Thermal Level Sensors	2	≤ 71 gallons	
8	APRM Flow Referenced Simulated Thermal Power Monitor	2	$S \leq 0.58W+62\%$ (Not to exceed 117%) Tech Spec 2.1.A.1.c(1)	
	Fixed High High Neutron Flux	2	$S \leq 120\%$ Power Tech Spec 2.1.A.1.c(2)	
	Inoperative	2	Not Applicable	An APRM is inoperative if there are less than two LPRM inputs per level or there are less than 11 LPRM inputs to the APRM channel.

B604210164 B6040B
 PDR ADOCK 05000321
 P PDR