



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 9, 1988

Docket No. 50-366

MEMORANDUM FOR: Sholly Coordinator

FROM: Lawrence P. Crocker, Project Manager
Project Directorate II-3
Division of Reactor Projects-I/II

SUBJECT: REQUEST FOR PUBLICATION IN BIWEEKLY FR NOTICE - NOTICE
OF ISSUANCE OF AMENDMENT TO FACILITY OPERATING LICENSE
(TAC 66788)

Georgia Power Company, Oglethorpe Power Corporation, Municipal Electric
Authority of Georgia, City of Dalton, Georgia, Docket No. 50-366, Edwin I.
Hatch Nuclear Plant, Unit 2, Appling County, Georgia

Date of application for amendment: February 9, 1988

Brief description of amendment: The amendment revised the Technical
Specifications to explain that the Reactor Water Cleanup System high
differential flow isolation signal includes a 45-second time delay.

Date of issuance: June 9, 1988

Effective date: June 9, 1988

Amendment No.: 93

Facility Operating License No. NPF-5. Amendment revised the Technical
Specifications.

Date of initial notice in FEDERAL REGISTER: May 4, 1988 (53 FR 15911)

The Commission's related evaluation of the amendment is contained in a
Safety Evaluation dated June 9, 1988.