

Georgia Power Company  
Post Office Box 282  
Waynesboro, Georgia 30830  
Telephone 404 554-9961  
404 724-8114

Southern Company Services, Inc.  
Post Office Box 2625  
Birmingham, Alabama 35202  
Telephone 205 870-6011



Vogtle Project

September 30, 1988

U.S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555

File: X7BC35  
Log: GN-1494

PLANT VOGTLE - UNIT 2  
NRC DOCKET NUMBER 50-425  
CONSTRUCTION PERMIT NUMBER CPPR-109  
SER CONFIRMATORY ITEM 26: OVERRIDE OF ISOLATION SIGNALS

Gentlemen:

Supplement 4 to the Vogtle Safety Evaluation Report, Section 7.3.3.8 concluded that confirmatory item 26 was resolved for Unit 1. This confirmatory item concerned the redesign of the reset/override circuitry for several instrument channels which provide isolation signals so that each reset/override switch would affect only a single instrument channel.

GPC has reviewed the Unit 2 design and concluded that it is the same as the Unit 1 design accepted in Supplement 4. The installation of this circuitry has also been completed in Unit 2. This should allow the resolution of confirmatory item 26 for Unit 2.

If your staff requires any additional information, please do not hesitate to contact me.

Sincerely,

J. A. Bailey  
Project Licensing Manager

JAB/sem

xc: NRC Regional Administrator	J. B. Hopkins (2)
NRC Resident Inspector	G. Bockhold, Jr.
P. D. Rice	J. E. Joiner, Esquire
J. P. Kane	R. J. Goddard, Esquire
R. A. Thomas	R. W. McManus
B. W. Churchill, Esquire	Vogtle Project File

8810130178 880930  
PDR ADOCK 05000425  
PNU

*Adol 1/0*