

Public Service of New Hampshire

New Hampshire Yankee Division

April 2, 1986

SBN-986 T.F. Q2.2.2

United States Nuclear Regulatory Commission Region I 631 Park Avenue King of Prussia, PA 19406

Attention:

Mr. Richard W. Starostecki, Director

Division of Project and Resident Programs

References:

(a) Construction Permits CPPR-135 and CPPR-136, Docket Nos. 50-443 and 50-444

(b) Telecon of July 31, 1985, D. E. Groves (YAEC) to J. Bell (NRC Region I)

(c) PSNH Letter SBN-862, dated August 22, 1985, "Interim 10CFR50.55(e) Report: Brown Boveri K-Line Circuit Breaker

with Overcurrent Trip Device Model OD-4 or OD-5

Subject:

Final 10CFR50.55(e) Report: Brown Boveri K-Line Circuit Breaker with Overcurrent Trip Device Model OD-4 or OD-5 (CDR 85-00-11)

Dear Sir:

In References (b) and (c), we reported a 10CFR50.55(e) deficiency regarding Brown Boveri K-Line circuit breakers with overcurrent trip devices Model OD-4 or OD-5. Incorrect short time delay band levers (links) were supplied in these trip devices. The incorrect levers may limit the travel of the short-time armature and cause the short-time element to be inoperative in the maximum band. This could inhibit a safety-related circuit breaker from performing its intended safety function.

The corrective action, as specified in Reference (c) (i.e., replacement of the incorrect levers), has been completed for Unit 1. As such, this is considered our final report on this item for Unit 1.

8604210462 360402 PDR ADDCK 05000443 S PDR

The corrective action for applicable Unit 2 equipment is being tracked by a Nonconformance Report (NCR). We will inform Region I when the corrective action for the Unit 2 equipment has been completed.

John DeVincentis, Director Engineering and Licensing

cc: Atomic Safety and Licensing Board Service List

Director, office of Inspection and Enforcement U.S. Nuclear Regulatory Commission Washington, DC 20555

Diane Curran Harmon & Weiss 20001 S. Street, N.W. Suite 430 Washington, D.C. 20009

Sherwin E. Turk, Esq.
Office of the Executive Legal Director
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Robert A. Backus, Esquire 116 Lowell Street P.O. Box 516 Manchester, NH 03105

Philip Ahrens, Esquire Assistant Attorney General Department of The Attorney General Statehouse Station #6 Augusta, ME 04333

Mrs. Sandra Gavutis
Designated Representative of
the Town of Kensington
RFD 1
East Kingston, NH 03827

Jo Ann Shotwell, Esquire Assistant Attorney General Environmental Protection Bureau Department of the Attorney General One Ashburton Place, 19th Floor Boston, MA 02108

Senator Gordon J. Humphrey U.S. Senate Washington, DC 20510 (ATTN: Tom Burack)

Diana P. Randall 70 Collins Street Seabrook, NH 03874

Richard A. Hampe, Esq. Hampe and McNicholas 35 Pleasant Street Concord, NH 03301

Donald E. Chick Town Manager Town of Exeter 10 Front Street Exeter, NH 03833

Brentwood Board of Selectmen RFD Dalton Road Brentwood, NH 03833 Peter J. Mathews, Mayor City Hall Newburyport, MA 01950

Calvin A. Canney City Manager City Hall 126 Daniel Street Portsmouth, NH 03801

Stephen E. Merrill Attorney General Dana Bisbee, Esquire Assistant Attorney General Office of the Attorney General 25 Capitol Street Concord, NH 03301-6397

Mr. J. P. Nadeau Selectmen's Office 10 Central Road Rye, NH 03870

Mr. Angie Machiros Chairman of the Board of Selectmen Town of Newbury Newbury, MA 01950

Mr. William S. Lord Board of Selectmen Town Hall - Friend Street Amesbury, MA 01913

Senator Gordon J. Humphrey 1 Pillsbury Street Concord, NH 03301 (ATTN: Herb Boynton)

H. Joseph Flynn Office of General Counsel Federal Emergency Management Agency 500 C Street, SW Washington, DC 20472

Matthew T. Brock, Esq. Shaines, Madrigan & McEachern 25 Maplewood Avenue P.O. Box 360 Portsmouth, NH 03801

Gary W. Holmes, Esq. Holmes & Ells 47 Winnacunnet Road Hampton, NH 03841

Ed Thomas FEMA Region I John W. McCormack PO & Courthouse Boston, MA 02109