

#### UNITED STATES NUCLEAR REGULATORY COMMISSION

REGION III 801 WARRENVILLE ROAD LISLE, ILLINOIS 60532-4351

November 3, 1998

NOTE TO: NRC Document Control Desk Mail Stop 0-5-D-24

FROM: Mary Ann Bies, Licensing Assistant / Operating Licensing Branch, RIII

many marses

SUBJECT: OPERATOR LICENSING EXAMINATION ADMINISTERED THE WEEK OF SEPTEMBER 14, 1998, AT BYRON NUCLEAR POWER STATION, DOCKET NOS. 50-454 AND 50-455

During the week of September 14, 1998, Operator Licensing Examinations were administered at the referenced facility. Attached, you will find the following information for processir.g through NUDOCS and distribution to the NRC staff, including the NRC PDR:

- Item #1 -
- Facility submitted outline and initial exam submittal, designated for distribution under RIDS Code A070.
- As-given operating examination, designated for distribution under RIDS Code A070.
- Item #2 Examination Report with the as-given written examination attached, designated for distribution under RIDS Code IE42.

Attachments: As stated

a)

## FINAL AS-ADMINISTERED OPERATING TEST IN ITS ENTIRETY FOR THE BYRON EXAMINATION - THE WEEK OF SEPTEMBER 14, 1998



FINAL AS-ADMINISTERED ADMINISTRAT: VE JPMS FOR BYRON EXAM - SEP 1998

ES-301

Administrative Topics Outline

Form-ES-301-1

Facili Exam	ity: Byron 1 & 2 hination Level: RO		Date of Examination:	September 14, 1998
	Administrative Topic/Subject Description	Describe method of evaluation: 1. ONE Administrative JPM, OR 2. TWO Administrative Ouestion	is	1
Al	Plant Parameter Verification / Complete An Estimated Critical Condition Checklist	1. JPM K/A 2.1.7 3.7/4.4		
	Performing a Surveillance/ Normal and Alternate Offsite AC Power Availability Weekly Surveillance	1. JPM K/A 2.1.18 2.9/3.0		
A2	Clearance And Tagging / Identify And Replace Blown Fuse	1. JPM K/A 2.2.13 3.6/3.8		
A.3	Protection From Radiation Exposure / Prepare For Entry Into High Radiation Area > 1000 mr/hr	1. JPM K/A 2.3.10 2.9/3.3		
A.4	Emergency Plan / Emergency Plan Directions	2. a. K/A 2.4.39 3.3/3.1 Emergen	cy Exposures	
		2. b. K/A 2.4.29 2.6/4.0 Emergen	cy facilities	

\*

# Byron Station Operations Training Job Performance Measure

.

LO TASK DESCRIPTION:	Complete Calcula Estimated Critic	complete Calculation of an Istimated Critical Condition				
NLO TASK DESCRIPTION:	N/A					
K/A NUMBER 2.2.36 2.1.25	RO/SRO RATING 2.8/3.2* 2.8/3.1					
JPM NUMBER ADMIN 1.1 RO	Task Number	Jol	D Position NSO			
Revision: Date:						
REVIEWED:						
I	NSTRUCTOR		DATE			
APPROVED:						
CD	OUD LEADED	ALCONE THE OWNER OF THE OWNER	האתנו			
GR	OUP LEADER		DITTE			
Start Time:	Stop	Time				
Start Time:	Stop	Time	;			
Start Time: Estimated Time	Stop	Time	:			
Start Time: Estimated Time This JPM was [ ] Per	for Completion:	Time	Control Room			
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim	StopStop	Time	Control Room Plant			
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth	for Completion: formed in the ulated er **	Time [ ] [ ] [ ]	Control Room Plant Simulator			
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth	Stop for Completion: formed in the ulated er **	Time [ ] [ ] [ ] [ ] [ ]	Control Room Plant Simulator Mockup			
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth **	StopStop	Time [ ] [ ] [ ] [ ] [ ] [ ] [ ]	Control Room Plant Simulator Mockup Other			
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE:	StopStop	Time [ ] [ ] [ ] [ ] [ ] LUATO	Control Room Plant Simulator Mockup Other			
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE: DATE:	StopStop for Completion: formed in the ulated er ** EVA	Time [ ] [ ] [ ] [ ] [ ] LUATO	Control Room Plant Simulator Mockup Other			
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth ** EXAMINEE: DATE: [ ] SATISFAC	StopStop	Time [ ] [ ] [ ] [ ] LUATO	Control Room Plant Simulator Mockup Other R:			
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE: DATE: [] SATISFAC Comments:	Stop for Completion: formed in the ulated er ** EVA	Time [ ] [ ] [ ] [ ] LUATO	Control Room Plant Simulator Mockup Other R:			
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE: DATE: [] SATISFAC	Stop	Time [ ] [ ] [ ] [ ] LUATO	Control Room Plant Simulator Mockup Other R:			

"Specific Information:

- These items were used as reference material in the development of this JPM: 1BGP 100-7T1 (RRD); 1BGP 100-7T3; Curve Book BCB-1
- 2. These items are expected to be used by the examinee in the performance of the task: 1BGP 100-7T3; BCB-1
- 3. Information to the Examinee and the Evaluator:

a. Initial Conditions:

Unit 1 is performing a plant startup following a reactor trip 18 hours previous. Operation prior to the trip was for a period of 80 days at 100% power, following initial startup with current core (Cycle 9).

b. Task Initiating Condition:

1BGP 100-7T3 is being performed to provide the ESTIMATED CRITICAL CONDITION (ECC) for the plant startup. Current plant conditions and the most recent Reference Reactivity Data (RRD) worksheet are provided. The process computer is currently unavailable. The Critical Rod Position is desired at 138 steps on Control Bank D.

- c. <u>Initiating Cue</u>: The US directs you to complete the ECC for the planned startup in 2 hours.
- d. <u>Your Position</u>: NSO (ADMIN)
- Terminal Performance Objective: (TPO)
   Calculate ECC including administrative limits.
- 5. Critical Steps(\*)
  5. 6, 10, 12, 14, 16, 19, 20, 21, 22 (1BGP 100-7T3
  Sections A.3, A.4, A.5.d, A.6.b, A.6.d, A.8, A.9.c, A.9.d,
  A.9.e, A.9.g, A.9.h and A.9.i.)

ADMIN1.1(9/14/98)/2 Byron98EXAM Identification of Impacted Systems: If this task is performed incorrectly, the following adverse reactions could occur: The reactor could be taken critical in conditions NOT allowed by the facility license.

ADMIN1.1(9/14/98)/3 Byron98EXAM

.

6.

PERFORMANCE CHECKLIST STANDARDS

N/A

RECORD START TIME \_\_\_\_.

\*\*\*\*\*\*\*\*\*\*\*\* NOTE \* The candidate is to be supplied with the completed RRD \* (15GP 100-7T1) and a blank copy of 18GP 100-7T3. \*\*\*\*\*\* 1. Refer to 1BGP 100-7T3. Refer to 1BGP 100-7T3. 0 0 C (May be done at any time.) Record the following 0 0 0 2. Record Admin Data. information: (CUE: SU # - 98-2-1TESTOUnit 1 SU #: 98-2-Startup Date - TODAYITESTTime - 2 HOURS FROMOSU date & time: 2CURRENT TIMEhrs from current CURRENT TIME Shutdown Date & Time - 18 HOURS BEFORE CURRENT TIME.) O BO date & time: 2 hrs from current O SD date & time: 18 hrs before current O Time Interval since shutdown: 20 hrs Enter 100% power value 0 0 0 3. Determine Change in Power Defect. for Power Defect from RRD: -1317 pcm Calculate difference: +1317 pcm. \*\*\*\*\* NOTE \* ITC at SU Tave & RCS Boron Conc. may be determined from \* \* BCB-1 Table 2-3 but is NOT required since Tave will NOT \* \* deviate from 557°F. Value at 1092 ppm (1717 EFPH) = -\* 8.8 pcm/°F. \*\*\*\*\* Enter 557 from given 4. Change in RCS Temperature. conditions. Calculate temperature change reactivity: 0 pcm

ADMIN1.1(9/14/98)/4 Byron98EXAM

#### PERFORMANCE CHECKLIST

5. Change in Samarium. (BCB-1 Table 1-4)

6. Change in Xenon. (BCB-1 Table 1-2 or Fig. 8c)

7. Determine Overall Poisons.

8. Determine SD integral boron worth for RRD burnup, RRD RCS boron Conc and HZP Tave. (BCB-1 Table 1-5)

9. Determine Poison Correction Factor for Integral Boron Worth (BCB-1 Figure 8b calculation)

Interpolate and determine boron: -9349pcm (-9300 to -9400 pcm).

Calculate Poison 0 0 Correction factor: +0.888 (+0.887 to +0.889).

\* 10. Determine corrected poisons reactivity worths. Determine/calculate corrected poisons worths: -372 pcm.

ADMIN1.1(9/14/98)/5 Byron98EXAM

## STANDARDS UN SAT SAT N/A Enter 1700 EFPH and 100% 0 0 from RRD and 20 hours as elapsed time since shutdown. Determine SU Samarium Worth of -1002 pcm. (20 hours after SD from 100% at 1717 EFPH) Enter -919 pcm from RRD. Calculate Difference Samarium: -83 pcm. Enter 1700 EFPH and 100% from RRD and 20 hours as elapsed time since shutdown. Determine SU Xenon Worth of -3318 pcm. (20 hours after SD from 100% at 1717 EFPH) Enter -2982 pcm from RRD. Calculate Difference Xenon: -336 pcm. Enter Differences -83 pcm 0 0 Sm and -336 pcm Xe. Calculate Overall Poisons: -419 pcm.

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN <u>SAT</u>	N/A
11. Record desired Control Bank position.	Enter 138 steps CB D.	0		
* 12. Determine desired Control Bank Worth. (BCB-1 Table 1-8 or Fig 2D)	Enter 138 steps CBD Bank Worth: -250.1 pcm.		٥	۵
<ol> <li>Record HFP inserted Rod Worth prior to Shutdown.</li> </ol>	Entor -9.5 pcm from RRD.			
* 14. Determine change in reactivity due to change in rod position.	Calculate total reactivity of -240.6 pcm.	٥		
15. Determine change in burnup correction.	Section is N/A per NOTE. Places N/A in proper sections.	٥		٥
* 16. Determine Reactivity Balance.	Record reactivity worths from appropriate Sections: o Power Defect (A.1)	٥		
	<pre>[+1317 pcm] o Isothermal Temp. Defect (A.2) [0 pcm] o Corrected Poisoning Defect (A.5.d) [-372 pcm]</pre>			
	<ul> <li>o Rod Adjustments (A.6.d) [-240.6 pcm]</li> <li>o Burnup correction (A.7.d) [0 pcm]</li> </ul>			
	AND Calculate difference of +704.4 pcm (+704 to +705 pcm).			

ADMIN1.1(9/14/98)/6 Byron98EXAM

## PERFORMANCE C

.

.

- 17. Determin Boron Wo critical concencr Table 2-
- 18. Determin RCS Boro

\* 19. Determin RCS Boro

\*

\*\*\*\*\*

CHECKLIST	STANDARDS	SAT	UN <u>SAT</u>	<u>N/A</u>
rmine Differential n Worth at assumed ical boion encration. (BCB-1 e 2-4, Fig. 10A)	Interpolate and determine Differential Boron Worth at 1100 ppm and 557°F: -8.82 pcm/ppm (-8.80 to -8.90 pcm/ppm).		n	. 🗆
rmine the change in Boron needed.	Calculate the boron concentration change of -80 ppm (-79 to -81 ppm).		٥	
rmine initial critical Boron concentration.	Enter RCS boron concentration from RRD: +1010 ppm.			
	Enter calculated RCS boron change required: -80 ppm.			
	Calculated critical boron concentration: 1090 ppm (1089 to 1091 ppm).			
**************************************	<u>NOTE</u> the candidate that it is Norm of Section 9.a through 9 boron concentration and ca	<pre>******** &gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;&gt;</pre>	*** * d * * *	
* The following steps c * Administrative Limit * associated Control Ba * performs these steps * the three values, the * Threshold Control Ban	NOTE ombine the steps of calculation values and determining the nk position. The procedure separately: Calculation of determining the associated k position.	ating th e f each o d	* e * * f * *	

\*\*\*

ADMIN1.1(9/14/98)/7 Byron98EXAM

#### PERFORMANCE CHECKLIST

\* 20. Calculate +500 pcm inserted rod worth threshold. Determine corresponding Control Bank Upper Administrative Threshold position. (BCB-1 Table 1-8 or Fig 2D)

\* 21. Calculate -500 pcm inserted rod worth threshold. Determine corresponding Control Bank Lower Administrative Threshold position. (BCB-1 Table 1-8 or Fig 2D)

\* 22. Calculate -750 pcm inserted rod worth threshold. Determine corresponding Control Bank Upper Administrative Threshold position. (BCB-1 Table 1-8 or Fig 2D) Enter Desired Rod Worth: -250.1 pcm.

Calculate +500 pcm worth: +249.9 pcm.

### AND

STANDARDS

Determine that maximum allowed value is full out park position on CBD (228 steps).

Enter Desired Rod Worth:

Calculate -500 pcm worth: -750.1 pcm.

## AND

Determine that minimum allowed value is 41 steps on CBD. (37 to 45 steps)

Enter Desired Rod Worth: -250.1 pcm.

0 0 0

UN

SAT

SAT

N/M

Calculate -750 pcm worth: -1000.1 pcm.

#### AND

Determine that minimum allowed value is 5 steps on CBD [OR 121 steps on CBC]. (1 to 10 steps CBD OR 117 to 125 steps CBC)

## PERFORMANCE CHECKLIST

### 23. Complete Critical Condition Summary.

Record the following information:

STANDARDS

SAT 1

UN

SAT

0 0

N/A

- Present boron conc
   1400 ppm
- o Est. Critical Boron conc - 1090 ppm (or value determined)
- o Est. Critical Bank position - CB D at 138 steps
- o Upper Admin Limit CB D at 228 steps
- o Lower Admin Limit -CB D at 41 steps (or value determined)
- o -750 pcm Admin Limit - CB D at 5 steps OR CB C at 121 steps (or value determined)

### AND

Sign & date for ECC performed by.

RECORD STOP TIME \_\_\_\_.

COMMENTS:

ADMIN1.1(9/14/98)/9 Byron98EXAM

## DATA SHEET

## CURRENT

. . . .

.

.

RCS Boron concentration	•	1400 ppm
RCS temperature		557°F
RCS pressure	-	2235 psig
Power level	-	0%
Rod Position	-	All control and shutdown banks inserted
Time since trip	-	18 hours

Startup planned to occur in 2 hours

Desired	boron con	icent	tration	-	110	00 ppm				
Desired	critical	rod	position		66	steps	withdrawn	on	CBD	
Desired	critical	RCS	temp	-	55	7°F				

# HISTORY

RRD Data taken at time of trip.

ADMIN1.1(9/14/98)/10 Byron98EXAM

## TASK CONDITIONS:

1BGP 100-7T3 "Calculation Of Estimated Critical Condition Based On A Known Rod Position" is being performed to provide the ESTIMATED CRITICAL CONDITION (ECC) for the plant startup. Current plant conditions and the most recent Reference Reactivity Data (RRD) worksheet are provided. The process computer is currently unavailable. The Critical Rod Position is desired at 138 steps on Control Bank D.

### INITIATING CUES:

The US directs you to complete the ECC for the planned startup in 2 hours.

## DATA SHEET

#### CURRENT

RCS Boron concentration	-	1400 ppm
RCS temperature	-	557°F
RCS pressure	-	2235 psig
Power level	-	0%
Rod Position	-	All control and shutdown banks inserted
Time since trip	-	18 hours

Startup planned to occur in 2 hours	
Desired boron concentration -	1100 ppm
Desired critical rod position -	66 steps withdrawn on CBD
Desired critical RCS temp -	557°F

### HISTORY

RRD Data taken at time of trip.

ADMIN1.1(9/14/98)/11 Byron98EXAM File Location: 1.02.0128

CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION

**NOTE** IF this procedure is performed by an NSO, THEN this procedure shall be reviewed by a Qualified Nuclear Engineer; or, IF this procedure is performed by a Qualified Nuclear Engineer, THEN this procedure shall be reviewed by an NSO. Typically, the Systems Engineering Dept. Nuclear Group should perform this procedure.

Unit 1 Startup	Number		-				
		YR	-	SU#	•	ECC#	
Startup Date	/		_/_		Star	tup Time	i
Shutdown Date	/. F.2.a)		_/_		Shut (Fro	down Time m RRD Ster	; F.2.a)

Time Interval Since Shutdown \_\_\_\_\_ Hours

NOTE

1BGP 100-7T3, Calculation of Estimated Critical Condition Based on a Known Rod Position, can be used to manually calculate Critical Rod Position based on a known rod position. If a manual ECC for a Critical Rod Position based on a known boron concentration is required, use 1BGP 100-7T2, Calculation of Estimated Critical Condition Based on a Known Boron Concentration. 1BGP 100-7T3, Calculation of Estimated Critical Condition Based on a Known Rod Position, will be retained as plant documentation. DO NOT DISCAPD. Forward completed form to the Systems Engineering Dept. Nuclear G oup for review when no longer required on shift for reference. Upon completion of their review this form will be forwarded to Central Sile for permanent retention.

> APPROVED MAY 2.1 1998

(0645VV/WPF/042398)

\*, 2.c

### NOTE

When referencing graphs or tables, use <u>Hot Full Power</u> (HFP) data prior to shutdown and <u>Hot Zero Power</u> (HZP) data prior to startup. Also, verify data corresponds to the proper core burnup.

### A. MANUAL CALCULATIONS

1. Change in Power Defect:

DETERMINE the startup and shutdown Power Defect values and their difference using RRD step F.1.f or equivalent:

0	pcm	-	(-)	pcm	-	(+)	pcm	
Startup			Shutdown			Difference		
Power Defect			Power Defect			Power Defect		
			(RRD Step F.1.1	:)				

### 2. Change in RCS Temperature:

DETERMINE the startup Isothermal Temperature Defect (ITD) value by multiplying the temperature deviation from program Tave by the Isothermal Temperature Coefficient (ITC) determined at the startup RCS Tave, and at the projected startup RCS Boron concentration with the aid of BCB-1 Table 2-3 or equivalent:

(°F	- <u>557°F</u> ) *	pcm/°F =	pcm
Expected	Program Tave	ITC at Expected	Startup ITD
Tave at	at Startup	Startup Tave and	
Startup		RCS Boron	
		Concentration	

APPROVED MAY 21 1998

#### NOTE

During non-equilibrium Samarium conditions, different methods of predicting Samarium Worth should be consulted. If a different method (other than specified in this procedure) for determining Samarium Worth for Step A.3 is used, two QNE's shall concur.

3. Change in Samarium:

DETERMINE the startup and shutdown Samarium worth values and their difference at the applicable burnup, the Samarium Equivalent Power(s) and at the elapsed hours since shutdown with the aid of BCB-1 Table 1-4 or equivalent:

## Startup

Loplicable Burnup: (RRD Step F.2.b)	-	EFPH
Samarium Equivalent Power: (RRD Step F.2.c)		*
Elapsed Time Since Shutdown:		hours
(-)     pcm - (-)     pcm = (-)       Startup     Shutdown     Differ       Samarium Worth     Samarium Worth     Samarium	rence	pcm

### NOTE

(RRD Step F.1.h)

During nonequilibrium Xenon conditions, different methods of predicting Xenon worth should be consulted. The empirical method of estimating Xenon Worth of Startup (36 hr weighted average) is only valid beyond approximately 16 hours after shutdown. If a different method (other than specified in this procedure) for determining Xenon Worth for Step A.4 is used, two QNE's shall concur.

\*, 2.i

APPROVED

### NOTE

The Systems Engineering Dept. Nuclear Group shall verify that the Process/Prime inputs to the BEACON computer are accurate by performing BVP 500-14, Beacon Operability Verification, and BVP 500-16, Beacon Estimated Critical Condition Calculation, if the BEACON program is used to support ECC calculations.

\*, 2.d

### 4. Change in Xenon:

DETERMINE the startup and shutdown Xenon worth values and their difference at the applicable burnup, the Xenon Equivalent Power(s) and at the elapsed hours since shutdown with the aid of ECB-1 Table 1-2, Figure 8c, or equivalent:

		Startup	
Applicable Burnup:	(RRD Step F.2.b)		EFPH
Xenon Equivalent Po	wer: (RRD Step F.2.d)		\$
Elapsed Time Since	Shutdown:		hours
(-) pcm Startup Xenon Worth	- (-) pcm = Shutdown Xenon Worth (RRD Step F.1.i)	() Difference Xenon	pcm

## 5. Change in Overall Poisons:

DETERMINE the change in poisons by correcting Xenon and Samarium with respect to RCS Boron.

a. DETERMINE the overall sum of poisons by adding the Samarium difference to the Xenon difference:

(-)	pcm	4	() Xeuon	pcm	*	() Overall	pcm
Difference			Difference			Poisons	
(A.3)			(A.4)				

APPROVED

 DETERMINE the shutdown Integral Boron Worth at the RRD Step F.1.g burnup, the RRD Step F.1.d RCS Boron concentration and HZP Tave with the aid of BCB-1 Table 1-5 or equivalent:

Integral Boron Worth: (-) pcm

c. DETERMINE the poison correction factor by substituting the Integral Boron Worth from step A.5.b into the equation shown on BCB-1 Figure 8b:

Poison Correction Factor: (+)

d. DETERMINE the corrected poisons reactivity worth from the original sum of Xenon and Samarium from step A.5.a multiplied by the determined correction factor from step A.5.c:

() Overall	pcm	*	(+) pcm Poison	1 ==	() pcm Corrected
Poisons (A.5.a)			Correction Factor (A.5.c)		Overall Poisons

APPROVED MAY 21 1998

6. Change in Rods:

DETERMINE the reactivity change due to adjustments in rod position.

## NOTE

A control bank position of CBD withdrawn to at least 130 steps should be used as the desired control bank position for all ECCs. This will exchange rod worth for boron worth. There is less uncertainty associated with boron worth as compared with rod worth. Boron worth also changes less throughout core life when compared to rod worth. If plant conditions do not allow a choice of CBD position withdrawn to at least 130 steps, then the reason for the deviation shall be documented in Section D under the remarks. Either way, the CBD position SHALL be within 750 pcm of the fully withdrawn position.

\*, 2.c

a. RECORD the desired Control Bank position:

CB \_\_\_\_\_ at \_\_\_\_ steps.

b. DETERMINE the desired Control Bank position worth recorded in step A.6.a at the RRD Step F.2.b burnup with the aid of BCB-1 Table 1-8, Figure 2D, or equivalent:

Desired Control Bank Worth: (-) pcm

c. RECORD the HFP inserted rod worth prior to shutdown from RRD step F.1.c or equivalent:

HFP Inserted Rod Worth: (-) pcm (RRD Step F.1.c)

APPROVED

d. DETERMINE the change of reactivity due to the change in rod position by subtracting the HFP Inserted Rod Worth (A.6.c) from the Desired Inserted Rod Worth (A.6.b):

(-)	pcm	(-)	pcm	-	()	pcm
Desired Rod		HFP Inserted			Change in	
Worth		Rod Worth			Rod Position	
(A.6.b)		(A.6.C)				

					1	NOTE				
If	RRD	Steps	F.1.g	and	F.2.b	contain	the	same	burnup,	step
A. 1	7 may	be ma	arked	"N/A	۰.					

7. Change in Burnup:

DETERMINE the calculation for correcting burnup.

a. DETERMINE the RRD Step F.1.g burnup design Boron concentration by using BCB-1 Figure 11 or equivalent:

Stable Reference Design Boron Concentration: \_\_\_\_\_ ppm

b. DETERMINE the RRD Step F.2.b burnup design Boron concentration by BCB-1 Figure 11 or equivalent:

Final Power Operation Design Boron Concentration: \_\_\_\_\_ ppm

APPROVED

#### NOTE

If BCB-1 Figure 10a, Table 2-4 does NOT contain HFP data, the FOLLOW code method for determining DBW at HFP would be the preferred method. Using HZP data will result in a DBW value -0.5 to -1.0 pcm/ppm more negative than a HFP value. For purposes of NSO Independent Verification of FOLLOW code output, Figure 10a may be used as a qualitative check against the attached FOLLOW code output.

c. DETERMINE the Differential Boron Worth (DBW) of the RRD Step F.1.g Burnup and RRD Step F.1.d Boron Concentration by one of the following methods (circle method used):

1). Figure 10a, Table 2-4, or equivalent

2).

FOLLOW Code Output (attach copy of output)

Differential Boron Worth = (-) pcm/ppm

d. DETERMINE the burnup correction by subtracting the Final Power Operation Design Boron Concentration (A.7.b) from the Stable Reference Design Boron Concentration (A." and multiplying by the Differential Boron Worth (A.')

[ ppm - Stable Reference	Final Power Operation	* pcm/ DBW (A.7.c)	ppm =	() pcm Burnup Correction
Design Boron	Design			
(A.7.a)	Concentration		•	
	(A.7.b)			

APPROVED

DETERMINE the Reactivity Balance by summing the	following value	es:
Power Defect (A.1)	<u>(+)</u>	pcm
Isothermal Temperature Defect (A.2)	()	pcm
Corrected Poisoning Defect (A.5.d)	()	pcm
Rod Adjustments (A.6.d)	()	pcm
Burnup Correction (A.7.d) +	<u>()</u>	pcm

REACTIVITY BALANCE () pcm

9. Determination of Critical RCS Boron:

This	section	may	need	to	be	NOTE repeate	d if	the	8.661	med	critical	
Boron deter	Concent mined is	trati	on fo p A.S	or s	ter	A.9.a	diff	ers :	Erom	that	•	

a. DETERMINE the Differential Boron Worth at the RRD Step F.2.b burnup, assumed critical RCS Boron concentration, and at the startup RCS Tave with the aid of BCB-1 Table 2-4, Figure 10A, or equivalent:

Differential Boron Worth: (-) pcm/ppm

b. DETERMINE the change in RCS Boron needed by dividing the Reactivity Balance in step A.8 by the Differential Boron Worth in step A.9.a:

()	pcm	(-)	pcm/ppm	=	()			ppm
Reactivity Balance (A.8)		Differential Boron Worth (A.9.a)			Change Boron	in	RCS	

## APPROVED

MAY 21 1998

8.

c. DETERMINE the critical RCS Boron concentration by adding the change in RCS Boron step A.9.b to the RRD step F.1.d Boron Concentration:

()ppm - ()ppm = \_\_\_\_\_ ppmRCS Boron atChange in RCSCritical RCS BoronRRD Step 1.dBoron (A.9.b)

\* d. CALCULATE the + 500 pcm inserted rod worth threshold:

(-) pcm + 500 pcm = () pcm Desired Rod worth (A.6.b)

\* e.

CALCULATE the - 500 pcm inserted rod worth threshold:

(-) pcm - 500 pcm = (-) pcm Desired Rod worth (A.6.b)

f. CALCULATE the (-) 750 pcm inserted rod worth limit:

(-) pcm - 750 pcm = (-) pcm Desired Rod worth (A.6.b)

\* g. DETERMINE the control bank position corresponding to the Upper Administrative Threshold by using BCB-1, Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.d at the RRD Step F.2.b burnup. Do not exceed the full-out park position on Control Bank D:

Upper Administrative Threshold: CB \_\_\_\_\_ at \_\_\_\_\_ steps \*, 2.c

\* h. DETERMINE the control bank position corresponding to the Lower Administrative Threshold by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.e at the RRD Step F.2.b burnup. Do not use a position below 47 steps on Control Bank C:

Lower Admini ative Threshold: CB \_\_\_\_\_ at \_\_\_\_\_ steps

\*, 2.0

\*, 2.0

\*, 2.c

APPROVED

 DETERMINE the control bank position corresponding to the -750 Administrative Limit by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.f at the RRD Step F.2.b burnup. Do not use a position below 47 steps on Control Bank C:

- 750 pcm Administrative Limit: CB \_\_\_\_\_ at \_\_\_\_\_ steps

#### NOTE

Notify the Duty Station Manager if the hand calculated ECC differs by more than 250 pcm from the BEACON generated ECC (if BEACON is used). Station Duty Officer concurrence is required before proceeding with the startup.

#### B. ESTIMATED CRITICAL CONDITION SUMMARY

	Presen Estima	t Boron Con ted Critica	acentrat al Boron	Concent	rat	ion	ppm	ppm (A	.9.c)		
	Estima	ted Critica	al Bank	Position	CB	-	at		_ steps	(A.6.a)	
	* Opper	Administra	tive Th	reshold:	CB	-	at		steps	(A.9.g	) *, 2.c
	* Lower	Administrat	tive The	reshold:	CB		at		steps	(A.9.h)	) *, 2.c
	- 750 pc	m Administ	rative I	Limit:	CB	and the second distance of the	at	ARL MARK OF A LOT AND A	steps	(A.9.i)	)
ECC	performe	d by	NAME			DATE	(NSC	, Qual	ified Nu	clear E	ngineer)
ECC	reviewed	by	NAME			DATE	(NSC	, Qual	ified Nu	clear En	ngineer)

\* Complete the "ECC parameters" placard and give to the Startup NSO.

\*, 2.0

\*, 2.f

Startup SRO

APPROVED

C. ESTIMATED CRITICAL POSITION FROM COUNTS INCREASING EIGHTFOLD

Atpt	<b>NOTE</b> any difference between the estimated time and the actual time for criticality could impact the final critical position. Contact Systems Engineering Dept. Nuclear Group to estimate the magnitude of this effect.	
1.	Base Count Rate With Shutdown Banks Out cps.	
	Source Range Channel N	
2.	Counts Increase Eightfold at Control Bank atstep	6.
з.	Predicted Critical Position From BCB-1, Figure 9.	
	Control Bank at steps.	

#### NOTE

If the eight-fold curve indicates that criticality will be achieved below the -750 pcm Administrative Limit, GO TO 1BGF 100-2A1, ATTACHMENT A, Contingency for Suspended Reactor Startup Due to Unanticipated Reactivity Deviation (Page 16).

\*, 2.c

\*, 2.c

4. VERIFY the predicted Critical Control Bank Position in C.3 is ABOVE the Rod Insertion Limit (i.e. CBC is greater than 47 steps withdrawn) and - 750 pcm Administrative Limit. If not, DO NOT PROCEED WITH APPROACH TO CRITICALITY. The RCS Boron Concentration must be increased and the ECC recalculated.

SRO Date Time

5. VERIFY the predicted Critical Control Bank Position in C.3 is within the ± 500 pcm Administrative Threshold. If not, a PIF shall be generated and ICRR data points shall be obtained at < 20 step intervals until criticality is achieved.</p>

QNE Date Time

APPROVED

6.	RECOR	D the for is stal	bilized a	informat t 10 <sup>-8</sup> au	tion if c mps on th	riticalit e highest	ty is ach: t reading	IR C	and hannel
	a.	Actual	Time of	Critical	Data.				
	b.	Actual	Critical	Bank Po	osition.	4.	at		_ step
	c.	Actual	Critical	Boron (	Concentra	tion.	-	enterita Mili dessate any filo	pp
	đ.	Actual	Temperat	ure at t	time of C	riticalit	су		e
REMAR	KS :	•							
		NAME AND ADDRESS OF ADDRESS OF ADDRESS	-		-				
					Ar programme provid with an owner				
			-						
							-		
							and by here an an and the second s		
									Land Barrison in Street
							and a sector of rectange and a sector of the		
								/.	
							NUCLI	AR	DATE

APPROVED MAY 21 1998

D.

E. MARGIN TO CRITICALITY WITH SHUTDOWN BANKS WITHDRAWN

NOTE The purpose of this section is to ensure: 1. The basis to the BDPS Analysis is met (- 1300 pcm Shutdown), and 2. An inadvertent Mode Change does not occur (K<sub>eff</sub> < 0.99).

1. DETERMINE the Total Control Bank Worth (CBA @ 0 steps) at the RRD Step F.2.b burnup with the aid of BCB-1 Table 1-8, Figure or equivalent:

Total Control Bank Worth: (-) pcm

NOTE									
The	following	step	takes	into	account	500	pcm	uncertainty	on
the	ECC calcul	lation	for	conser	rvatism.				

2. DETERMINE the Required Borol Reactivity to satisfy the Margin to Criticality by completing the following arithmetic:

Total Control Bank Worth (E.1):	+ (-) par
Control Bank Required Reactivity (A.6.b):	- <u>(-)</u> par
Bounding Margin to Criticality:	- (-) 1300 pc
Conservatism:	+ 500 pcm
Required Boron Reactivity	= (_) pcm

APPROVED MAY 21 1998

- Determination of the Minimum RCS Boron Concentration which satisfies the Margin to Criticality:
  - a. DETERMINE the difference between the RCS Boron Concentration necessary to meet the Margin to Criticality requirements and the ECC Boron Concentration by dividing the Required Boron Reactivity calculated in Step E.2 by the Differential Boror Worth in Step A.9.a:

() ppm / (-) Required Boron	pcm/ppm » Differential Boron	() ppm Difference in		
Reactivity	Worth (A.9.a)	RCS Boron		
(E.2)		Concentration		

b. DETERMINE THE Minimum RCS Boron Concentration necessary to meet the Margin to Criticality requirements by subtracting the difference in RCS Boron Concentration calculated in Step E.3.a from the ECC Boron Concentration:

() - mcg -	() ppm =	() ppm
ECC Boron	Difference in	Minimum Required
Concentration	RCS Boron	RCS Boron
(A.9.c)	Concentration	Concentration
	(E.3.a)	

- 4. VERIFY Sufficient Margin to Criticality:
  - a. RECORD the present RCS Boron Concentration from the most recent Boron sample:

Sample Time

Present RCS Boron Concentration \_\_\_\_\_ Date

 b. Is the present RCS Boron Concentration GREATER THAN OR EQUAL TO the Minimum RCS Boron Concentration calculated in Step E.3.b? (Circle one)

YES NO

## APPROVED

5.

If the answer in Step E.4.b is "NO", DO NOT withdraw Shutdown Banks until the RCS Boron Concentration is greater than or equal to the Minimum RCS Boron Concentration calculated in Step E.3.b.

1\_ SRO Date Time

APPROVED

(Final)

-16-

APPROVED 07/14/97

Facsimile

File Location: 1.02.0128

REFERENCE REACTIVITY DATA WORKSHEET

NOTE This worksheet will be retained as plant documentation. DO NOT DISCARD. Forward completed form to the Operating Staff when no longer required on shift for reference.

Unit One Startup Number Year

- S/U#

RRD#

Stable Reference Reactivity Data 1.

> NOTE The data recorded in Step 1 shall be data from a stable core condition. Contact the Nuclear Group for assistance, if necessary. An exception to the stability criteria would be if this RRD were for a recent reactor startup.

20 hours prior ) 1.a. Reference Date: \_\_\_\_\_\_ Reference Time: \_\_\_\_\_\_

1.b. Control Bank D at 213 steps.

\* 1.c. Inserted Control Bank Worth

BCB-1 Table 1-7, Figure 2, Figure 2C, or equivalent (-) 9.5 pcm

\* 1.d. Critical Boron Concentration from (CIRCLE mode of analysis used):

1). Accurate sample at a recent known stable condition,

2). Calculated by the Qualified Nuclear Engineer

(Attach calculations, logs, point history used)

· CB = 1010 ppm Time/Date: \_\_\_\_ (24 hours prior to)

1.e. Reference power level from BURP:

Stable Power: /00 %

Facsimile

REFERENCE REACTIVITY DATA WORKSHEET (continued)

1.f. Total Power Defect from:

BCB-1 Figure 17A. Table 2-1, or equivalent (-) 1317 pcm

1.g. RECORD accumulated core average burnup from BURP:

Core Average Burnup: 17.00 EFPH

NOTE	
If this RRD is being performed to reference a recent react	01
sta tup, obtain the Samarium Worth from the applicable ECC	
Step 3 for Startup Samarium Worth or 1BVS XPT-13, as	
applicable. N/A the Samarium Equivalent Power.	

1.h. Equivalent Power for Samarium Calculation from (BURP and Samarium Worth):

Sm Eq. PWR = Unweighted average power over 5 days (120 hrs)

Sm Eq. PWR = 100 %

Sm Worth from BCB-1 Table 1-4 or equivalent at 0 hrs after shutdown (-) 919 pcm

NOTE

If this RRD is being performed to reference a recent reactor startup, obtain the Xe Worth from the applicable ECC Step 4 for Startup Xenon Worth or 1BVS XPT-13, as applicable.

 Determine the Xen in Worth from power in Step 1.e and BCB-1 Figure 8c, Table 1-2, or equivalent:

Xe Worth (-) 2982-pcm

APPROVED 07/14/97

Facsimile

## REFERENCE REACTIVITY DATA WORKSHEET (continued)

2. Final Power Operation Reference Reactivity Data:

NCTE The data recorded in Step 2 shall include the operating history of the reactor until it is shutdown. If the reactor tripped from a stable condition, record the applicable data from Step 1 into Step 2.

to correct time. a. Reference Date: \_\_\_\_\_\_ Reference Time:

2.b. RECORD accumulated core average burnup from BURP:

Core Average Burnup: 1700 EFPH

2.c. Equivalent Power for Samarium Calculation from BURP:

Sm Eq. PWR = Unweighted average power over 5 days (120 hrs)

Sm Eq. PWR = 100 %

2.d. Determine the Equivalent Power for Xenon Calculation from BURP or equivalent:

.

.

### Facsimile

## REFERENCE REACTIVITY DATA WORKSHEET (continued)

## 2.d. (continued)

Hours Prior to	Average Power			
Shutdown	(%)	Multiplier		Product
0 to 1	100	x 6	=	600
1 to 2	100	x 5	=	500
2 to 3	100	x 5	=	500
3 to 4	100	x 5	=	500
4 to 5	100	x 4	=	400
5 to 6	100	x 4	=	400
6 to 7	100	x 4	=	400
7 to 8	100	x 4	=	400
8 to 9	100	x 4	z	400
9 to 10	100	х 3	B	300
10 to 11	100	x 3	5	300
11 to 12	100	x 3	z	300
12 to 13	100	x 3	=	300
13 to 14	100	х 3	=	300
14 to 15	100	x 3	E	300
15 to 16	100	x 3	E	300
16 to 17	100	x 2	z	200
17 to 18	100	x 2	E	200
18 to 19	100	x 2	=	200
19 to 20	100	x 2	=	200
20 to 21	100	x 2	æ	200
21 to 22	100	x 2	=	200
22 to 23	100	x 2	=	200
23 to 24	100	x 2	=	200
24 to 25	100	x 2	=	200
25 to 26	106	x 1	=	100
26 to 27	100	x 1	=	100
27 to 28	100	x 1	=	100
28 to 29	100	x 1	=	100
29 to 30	100	x 1	=	100
30 to 31	100	x 1 .	12	100
31 to 32	100	x 1	2	100
32 to 33	100	x 1	=	100
33 to 34	100	x 1	=	100
34 to 35	100	x 1	=	100
35 to 36	100	x 1	=	100

TOTAL = 9100

APPROVED 07/14/97

Facsimile

REFERENCE REACTIVITY DATA WORKSHEET (continued)

2.d. (continued)

Equivalent Power for Xenon =  $\frac{Total}{91} = \frac{9/00}{91}$ 

Xe Eq. PWR: 100 %

Remarks: None

#### NOTE

IF this procedure is performed by an NSO. THEN this procedure shall be reviewed by a Qualified Nuclear Engineer; or, IF this procedure is performed by a Qualified Nuclear Engineer, THEN this procedure shall be reviewed by the NSO. Typically, this procedure should be prepared by the Systems Engineering Dept. Nuclear Group. An independent member of the SED Nuclear Group should review the assumptions and calculations of the RRD for accuracy.

Performed	by:		1	(NSO,	Qualified	Nuclear	Engineer)
		Name	Date				
Reviewed	by:		/	(NSO,	Qualified	Nuclear	Engineer)
		Name	Date				
5	SRO:		1				
		Name	Date				

(Final)

(1403VV/WPF/062497)

- 5 -
Facsimile

1BGP 100-7T3 Revision 8

\*, 2.c

File Location: 1.02.0128

CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION

**NOTE** IF this procedure is performed by an NSO. THEN this procedure shall be reviewed by a Qualified Nuclear Engineer; or, IF this procedure is performed by a Qualified Nuclear Engineer, THEN this procedure shall be reviewed by an NSO. Typically, the Systems Engineering Dept. Nuclear Group should perform this procedure.

Unit 1 Startup Numb	er -		
	YR - SU#	- ECC#	
Startup Date	//	Startup Time _	<u> </u>
Shutdown Date (From RRD Step F.2.	///a)	Shutdown Time (From RRD Step	: F.2.a)

Time Interval Since Shutdown 20 Hours

NOTE

1BGP 100-7T3 can be used to manually calculate Critical Rod Position based on a known rod position. If a manual ECC for a Critical Rod Position based on a known boron concentration is required, use 1BGP 100-7T2. 1BGP 100-7T3 will be retained as plant documentation. DO NOT DISCARD. Forward completed form to the Systems Engineering Dept. Nuclear Group for review when no longer required on shift for reference. Upon completion of their review this form will be forwarded to Central File for permanent retention.

6

Facsimile

### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

**NOTE** When referencing graphs or tables, use <u>Hot Full Power</u> (HFP) data prior to shutdown and <u>Hot Zero Power</u> (HZP) data prior to startup. Also, verify data corresponds to the proper core burnup.

# A. MANUAL CALCULATIONS

1. Change in Power Defect:

DETERMINE the startup and shutdown Power Defect values and their difference using RRD step 1.f or equivalent:

0 pci	n -	(-) 1317 pcm	=	(+) 1317	pcm
Startup		Shutdown		Difference	
Power Defect		Power Defect		Power Defect	
		(AAD SLED I.I)			

### 2. Change in RCS Temperature:

DETERMINE the startup Isothermal Temperature Defect (ITD) value by multiplying the temperature deviation from program Tave by the Isothermal Temperature Coefficient (ITC) determined at the startup RCS Tave, and at the projected startup RCS Boron concentration with the aid of BCB-1 Table 2-3 or equivalent.

( <u>557</u> °F - Expected	<u>557°F</u> ) * Program Tave	-4.52.7 pcm/°F = ITC at Expected	Startup	pcm ITD
Tave at.	at Startup	Startup Tave and		
Startup		RCS Boron		
		Concentration		

### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

#### NOTE

During non-equilibrium Samarium conditions, different methods of predicting Samarium Worth should be consulted. If a different method (other than specified in this procedure) for determining Samarium Worth for Step A.3 is used, two QNE's shall concur.

3. Change in Samarium:

DETERMINE the startup and shutdown Samarium worth values and their difference at the applicable burnup, the Samarium Equivalent Power(s) and at the elapsed hours since shutdown with the aid of BCB-1 Table 1-4 or equivalent:

	Startup
Applicable Burnup: (RRD Step 2.b)	1700 - PPH
Samarium Equivalent Power: (RRD Step 2.c)	100 \$
Elapsed Time Since Shutdown:	20 hours
(-) 1002 pcm - $(-) 919$ pcm = $(-)$	<u>83</u> p.m
Samarium Worth Samarium Worth Samar	ium

### NOTE

(RRD Step 1.h)

During nonequilibrium Xenon conditions, different methods of predicting Xenon worth should be consulted. The empirical method of estimating Xenon Worth of Startup (36 hr weighted average) is only valid beyond approximately 16 hours after shutdown. If a different method (other than specified in this procedure) for determining Xenon Worth for Step A.4 is used, two QNE's shall concur.

\*, 2.i

\*, 2.d

### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

# NOTE

The Systems Engineering Dept. Nuclear Group shall verify that the Process/Prime inputs to the BEACON computer are accurate the performing BVP 500-14 and BVP 500-16 if the BEACON program is used to support ECC calculations.

4. Change in Xenon:

DETERMINE the startup and shutdown Xenon worth values and their difference at the applicable burnup, the Xenon Equivalent Power(s) and at the elapsed hours since shutdown with the aid of BCB-1 Table 1-2, Figure 8c, or equivalent:

Startup Xenon Worth	Shutdown Xenon Worth (RRD Step 1.i)	Difference Xenon	
(-) 3318 pcm -	(-) 2982 pcm =	(-) 336	_ pcm
Elapsed Time Since SI	hutdown:	_20	hours
Xenon Equivalent Powe	er: (RRD Step 2.d)	100	8
Applicable Burnup:	(RRD Step 2.b)	1700	EFPH
		Startup	

5. Change in Overall Poisons:

DETERMINE the change in poisons by correcting Xenon and Samarium with respect to RCS Boron.

a. DFTERMINE the overall sum of poisons by adding the Samarium difference to the Xenon difference:

(-) 83	pcm	+	(-) 336	pcm	=	L) 469	pcm
Samarium			Xenon			Overall	
Difference			Difference			Poisons	
(A.3)			(A.4)				

-4-

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

b. DETERMINE the shutdown Integral Boron Worth at the RRD Step 1.g burnup, the RRD Step 1.d RCS Boron concentration and HZP Tave with the aid of BCE-1 Table 1-5 or equivalent:

Integral Boron Worth: (-) 9349 pcm

c. DETERMINE the poison correction factor by substituting the Integral Boron Worth from step A.5.b into the equation shown on BCB-1 Figure 8b:

Poison Correction Factor: (+) 0.888

d. DETERMINE the corrected poisons reactivity worth from the original sum of Xenon and Samarium from step A.5.a multiplied by the determined correction factor from step A.5.c:

(-) 419 pcm	(+) 0.888 pcm =	(-) 372 pcm
Poisons	Correction Factor	Overall Poisons
(A. 5. a)	(A.5.C)	

# 1BGP 100-7T3 Revision 8

# CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

Facsimile

6. Change in Rods:

DETERMINE the reactivity change due to adjustments in rod position.

### NOTE

A control bank position of CBD withdrawn to at least 130 steps should be used as the desired control bank position for all ECCs. This will exchange rod worth for boron worth. There is less uncertainty associated with boron worth as compared with rod worth. Boron worth also changes less throughout core life when compared to rod worth. If plant conditions do not allow a choice of CBD position withdrawn to at least 130 steps, then the reason for the deviation shall be documented in Section D under the remarks. Either way, the CBD position SHALL be within 750 pcm of the fully withdrawn position.

\*, 2.c

a. RECORD the desired Control Bank position:

b. DETERMINE the desired Control Bank position worth recorded in step A.6.a at the RRD Step 2.b burnup with the aid of BCB-1 Table 1-8, Figure 2D, or equivalent:

Desired Control Bank Worth: (-) 250, / pcm

c. RECORD the HFP inserted rod worth prior to shutdown from RRD step 1.c or equivalent:

HFP Inserted Rod Worth: (-) 9.5 pcm (RRD Step 1.c)

(0645VV/WPF/110897)

-6-

#### Facsimile

# CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

d. DETERMINE the change of reactivity due to the change in rod position by subtracting the HFP Inserted Rod Worth (A.6.c) from the Desired Inserted Rod Worth (A.6.b):

(-) 250.1	pcm -	(-) 9.5	pcm =	1-1 240.6	pcm
Desired Rod		HFP Inserted		Change in	
Worth		Rod Worth		Rod Position	
(A.6.b)		(A.6.C)			

### NOTE

If RRD Steps 1.g and 2.b contain the same burnup, step A.7 may be marked "N/A".

7. Change in Burnup:

DETERMINE the calculation for correcting burnup.

a. DETERMINE the RRD Step 1.g burnup design Boron concentration by using BCB-1 Figure 11 or equivalent:

Stable Reference Design Boron Concentration: \_\_\_\_\_\_\_ ppm

b. DETERMINE the RRD Step 2.b burnup design Boron concentration by BCB-1 Figure 11 or equivalent:

Final Power Operation Design Boron Concentration:

### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

#### NOTE

If BCB-1 Figure 10a, Table 2-4 does NOT contain HFP data, the FOLLOW code method for determining DBW at HFP would be the preferred method. Using HZP data will result in a DBW value -0.5 to -1.0 pcm/ppm more negative than a HFP value. For purposes of NSO Independent Verification of FOLLOW code output, Figure 10a may be used as a qualitative check against the attached FOLLOW code output.

- c. DETERMINE the Differential Boron Worth (DBW) of the RRD Step 1.g Burnup and RRD Step 1.d Boron Concentration by one of the following methods (circle method used):
  - 1). Figure 10a, Table 2-4, or equivalent
  - 2). FOLLOW Code Output (attach copy of output)

Differential Boron Worth = (-) N/H pcm/ppm

d. DETERMINE the burnup correction by subtracting the Final Power Operation Design Boron Concentration (A.7.b) from the Stable Reference Design Boron Concentration (A.7.a) and multiplying by the Differential Boron Worth (A.7.c):

 $\frac{N/A}{\text{Stable}} ppm - \frac{N/A}{\text{Final Power}} pm] * \frac{N/A}{\text{DBW}/(A.7.c)} pm = ()N/A pcm$ Reference Operation Correction Design Boron Design Concentration Boron (A.7.a) Concentration (A.7.b)

Facsimile

# CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

8. DETERMINE the Reactivity Balance by summing the following values:

Power Defect (A.1)	(+) 1317 pcm
Isothermal Temperature Defect (A.2)	() <b>O</b> pcm
Corrected Poisoning Defect (A.5.d)	(-) <u>372</u> pcm
Rod Adjustments (A.6.d)	(-) 240.6 pcm
Burnup Correction (A.7.d)	+ () 0 pcm

REACTIVITY BALANCE 1 704.4 pcm

9. Determination of Critical RCS Boron:

This	section	may n	eed to	be be	NOTE repeate	d if	the	Assumed	critical
Boron deter	Concent mined in	ratio n step	n for A.9.0	ster c.	A.9.a	diffe	ers	from tha	t

a. DETERMINE the Differential Boron Worth at the RRD Step 2.b burnup, assumed critical RCS Boron concentration, and at the startup RCS Tave with the aid of BCB-1 Table 2-4. Figure 10A, or equivalent:

Differential Boron Worth: (-) 8.82 pcm/ppm

b. DETERMINE the change in RCS Boron needed by dividing the Reactivity Balance in step A.8 by the Differential Boron Worth in step A.9.a:

(+) 704.4 pcm /	(-) 8.82	pcm/ppm	11	(-) 8	30	ppm
Reactivity	Differential			Change	in RCS	
Balance (A.8)	Boron Worth			Boron		
	(A.9.a)					

### (0645VV/WPF/110897)

-9-

#### Facsimile

1BGP 100-7T3 Revision 8

### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

c. DETERMINE the critical RCS Boron concentration by adding the change in RCS Boron step A.9.b to the RRD step 1.d Boron

change in RCS Boron step A.9.b to the RRD step 1.d Boron Concentration: (\*) 1010 ppm = (\*) 80 ppm = 1090 ppm

\* d. CAI

(-) 250.1 pcm + 500 pcm = (+) 249.9 pcm Desired Rod worth (A.6.b)

\* e. CALCULATE the - 500 pcm inserted rod worth threshold:

(-) 250./ pcm - 500 pcm = (-) 750./ pcm Desired Rod worth (A.6.b)

f. CALCULATE the (-) 750 pcm inserted rod worth limit:

 $\frac{(-) 250.1}{\text{Desired Rod worth}} \text{ pcm} - 750 \text{ pcm} = (-) 1000.1 \text{ pcm}$  (A.6.b)

\* g. DETERMINE the control bank position corresponding to the Upper Administrative Threshold by using BCB-1, Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.d at the RRD Step 2.b burnup. Do not exceed the full-out park position on Control Bank D:

Upper Administrative Threshold: CB D at 228 steps

\*, 2.c

\* 1. DETERMINE the control bank position corresponding to the Lower Administrative Threshold by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.e at the RRD Step 2.b burnup. Do not use a position below 47 steps on Control Bank C:

Lower Administrative Threshold: CB D at 41 steps

(0645VV/WPF/110897)

-10-

\*, 2.c

\*, 2.c

Facsimile

1BGP 100-7T3 Revision 8

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

- DETERMINE the control bank position corresponding to the -750 Administrative Limit by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.f at the RRD Step 2.b burnup. Do not use a position below 47 steps on Control Bank C:
  - 750 pcm Administrative Limit: CB D(C) at 5(121) steps

# NOTE

Notify the Duty Station Manager if the hand calculated ECC differs by more than 250 pcm from the BEACON generated ECC (if BEACON is used). Station Duty Officer concurrence is required before proceeding with the startup.

\*, 2.f

B. ESTIMATED	CRITICAL	CONDITION	SUMMARY
--------------	----------	-----------	---------

	Present Boron Concentration 14 Estimated Critical Boron Concent Estimated Critical Bank Position	DD rat CB	ion 109	D pp	m (A.9.c) 38 steps	(A.6.a)	
	* Upper Administrative Threshold:	СВ	a	at _22	28 step	os (A.9.g)	*, 2.c
	* Lower Administrative Threshold:	CB	a	at	11 ster	os (A.9.h)	*, 2.c
	- 750 pcm Administrative Limit:	СВ	D (c) .	at _5	(121)ster	os (A.9.i)	
cc	performed byNAME	_	DATE	(NSO,	Qualified N	Nuclear En	gineer)
cc	reviewed byNAME	-	DATE	(NSO,	Qualified N	Nuclear En	gineer)

\* Complete the "ECC parameters" placard and give to the Startup NSO.

\*, 2.c

Startup SRO

(0645VV/WPF/110897)

E

E

-11-

\*

Facsimile

### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

C. ESTIMATED CRITICAL POSITION FROM COUNTS INCREASING EIGHTFOLD

A 1/M plot shall be maintained during startup.

	NOTE
Any difference between the	estimated time and the actual
time for criticality could	impact the final critical
position. Contact Systems	Engineering Dept. Nuclear Group
to estimate the magnitude of	of this effect.

\*, 3.c

1. Base Count Rate With Shutdown Banks Out \_\_\_\_\_ cps.

Source Range Channel N \_\_\_\_\_.

- 2. Counts Increase Eightfold at Control Bank \_\_\_\_\_ at \_\_\_\_steps.
- 3. Predicted Critical Position From BCB-1, Figure 9.

Control Bank \_\_\_\_\_ at \_\_\_\_ steps.

4. ENSURE the predicted Critical Control Bank Position in C.3 is ABOVE the Rod Insertion Limit (i.e. CBC is greater than 47 steps withdrawn) and - 750 pcm Administrative Limit. If not, DO NOT PROCEED WITH APPROACH TO CRITICALITY. The RCS Boron Concentration must be increased and the ECC recalculated.

SRO Date Time

5. ENSURE the predicted Critical Control Bank Position in C.3 is within the ± 500 pcm Administrative Threshold. If not, Shift Manager and Qualified Nuclear Engineer concurrence is required to proceed with the reactor startup.

QNE Date Time SRO Date Time

(0645VV/WPF/110897)

-12-

1BGP 100-7T3 Revision 8

# CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

### NOTE

If the predicted critical bank position is not above the - 750 pcm administrative limit, then re-insert all Control Bank rods until the Systems Engineering Dept. Nuclear Group documents an evaluation in Section D under remarks and concurs to bring the reactor critical. A new ECC may be performed.

\*, 2.c

5.	RECORD th	he followir	ng in	nform	ation	if	cri	ticality	is ach:	leved	and
	power is Channel.	stabilized	i at	10-*	amps	on	the	highest	reading	IR	

a	Actual	Time	at	Critical	Data.	

- b. Actual Critical Bank Position. CB \_\_\_\_\_ at \_\_\_\_\_ steps
- c. Actual Critical Boron Concentration. \_\_\_\_ ppm
- d. Actual Temperature at time of Criticality. \_\_\_\_\_ •F

D. REMARKS :

NUCLEAR DATE GROUP

(0645VV/WPF/110897)

-13-

Facsimile

CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

E. MARGIN TO CRITICALITY WITH SHUTDOWN BANKS WITHDRAWN

NOTE The purpose of this section is to ensure: 1. The basis to the BDPS Analysis is met (- 1300 pcm Shutdown), and 2. An inadvertent Mode Change does not occur (K<sub>eff</sub> < 0.99).

 DETERMINE the Total Control Bank Worth (CBA @ 0 steps) at the RRD Step 2 b burnup with the aid of BCB-1 Table 1-8, Figure 2A, or equivalent:

Total Control Bank Worth: (-) pcm

**NOTE** The following step takes into account 500 pcm uncertainty on the ECC calculation for conservatism.

 DETERMINE the Required Boron Reactivity to satisfy the Margin to Criticality by completing the following arithmetic:

Total Control Bank Worth (E.1):	+ (-)		pcm
Control Bank Required Reactivity (A.6.b):	- ()		pcm
Bounding Margin to Criticality:	- (-)	1300	pcm
Conservatism:	٠	500	pcm
Required Boron Reactivity	= ( )		pcm

# CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

- Determination of the Minimum RCS Boron Concentration which 3. satisfies the Margin to Criticality:
  - a. DETERMINE the difference between the RCS Boron Concentration necessary to meet the Margin to Criticality requirements and the ECC Boron Concentration by dividing the Required Boron Reactivity calculated in Step E.2 by the Differential Boron Worth in Step A.9.a:

() ppm / (-)	pcm/ppm =	() ppm
Required Boron	Differential Boron	Difference in
Reactivity	Worth (A.9.a)	RCS Boron
(E.2)		Concentration

b. DETERMINE THE Minimum RCS Boron Concentration necessary to meet the Margin to Criticality requirements by subtracting the difference in RCS Boron Concentration calculated in Step E.3.a from the ECC Boron Concentration:

() pp	m -	() ppm	=	() ppm
ECC Boron		Difference in		Minimum Required
Concentration		RCS Boron		RCS Boron
(A.9.c)		Concentration		Concentration
		(E.3.a)		

- VERIFY Sufficient Margin to Criticality: 4.
  - 8.

RECORD the present RCS Boron Concentration from the most recent Boron sample:

and the second sec	A Design of the Address of the Addre	
Present RCS	Sample Time	Date
Boron		
Concentration		

b. Is the present RCS Boron Concentration GREATER THAN OR EQUAL TO the Minimum RCS Boron Concentration calculated in Step E.3.b? (Circle one)

YES NO

(0645VV/WPF/110897)

-15-

.4

.

# CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

5. If the answer in Step E.4.b is "NO", DO NOT withdraw Shutdown Banks until the RCS Boron Concentration is greater than or equal to the Minimum RCS Boron Concentration calculated in Step E.3.b.

SRO Date Time

-16-

JOB PERFORMANCE MEASURE TASK TITLE: Perform Offsite AC Power	Rev. <u>7</u> , 11/12/96
TASK TITLE: Perform Offsite AC Power	
Availability Surveillance.	ADMIN 1.2 RO
TPO No: IV.C.AP-06 K&A No.: 062000A305 K&A	IMP. 3.5/3.6
TRAINEE: DAT	'E://
The Trainee: PASSED this JPM TIME STA	ARTED:
FAILED TIME FIN	ISHED:
EVALUATION METHOD: PERFORM SIMULATE	
LOCATION: IN PLANT SIMULATOR	_

MATERIALS:

1BOS 8.1.1.1.a-1, Normal and Alternate Offsite AC Power Availability Weekly Surveillance.

GENERAL REFERENCES:

1BOS 8.1.1.1.a-1, Normal and Alternate Offsite AC Power Availability Weekly Surveillance.

TASK STANDARDS:

Correctly perform the steps required to complete the surveillance and determine Tech Spec. Compliance is met.

TASK CONDITIONS:

1. You are an Extra NSO.

2. Unit 1 is in Mode 1, Steady State Power.

INITIATING CUES:

The 1A DG has been declared inoperable and the Unit Supervisor has directed youto perform 1BOS 8.1.1.1.a-1, Normal and Alternate Offsite AC Power Availability Surveillance.

CRITICAL ELEMENTS: (\*)

2 thru10

APPROXIMATE COMPLETION TIME: 15 Minutes

ADMIN1.2(9/14/98)/2 Byron98EXAM

# STANDARDS

# NOTE:

Evaluator should provide candidate with a copy of 1BOS 8.1.1.1.a-1 to be used in completing this JPM.

# RECORD START TIME

# NOTE

If this JPM is given on the simulator, only the cues underlined are required to be given to the Trainee. If possible, actual indications should be used for all steps.

1. Check 345 KV Line status.

NOTE: BUS ALIVE light is NOT adequate verification of bus status.

Line 0621

• Line 15501

• Line 0624

Cue: 
 All 345 KV Lines are ENERGIZED.

ADMIN1.2(9/14/98)/3 Byron98EXAM

for all 345 KV Lines:

Observe Line Amp's & MW's

• Line 0622

 Circle ENERGIZED for all 345 KV Lines.

# PERFORMANCE CHECKLIST

14

# STANDARDS

- SAT UNSAT N/A

*2.	Indicate all closed and open disconnects, breakers and SAT link status.	<ul> <li>Record:</li> <li>Open disconnects, breakers &amp; removed SAT</li> </ul>		
Cue:	<ul> <li>ACB's 2412 &amp; 2422 closed <u>lites are LIT, ACB's 2414 &amp;</u> 2424 open lites are LIT.</li> <li>All disconnects and SY breakers <u>indicate closed</u>.</li> <li>Both Units SAT x-tie links are <u>REMOVED</u>.</li> <li>Both Units SAT disconnect links are INSTALLED.</li> </ul>	<ul> <li>Inks with an</li> <li>* O *</li> <li>Closed</li> <li>disconnects,breakers &amp;</li> <li>installed SAT links with an</li> <li>* X *</li> </ul>		
*3.	Trace single path along dashed lines from any energized offsite power source to Unit <u>ONE</u> SAT bank.	Trace path correctly on data sheet: • Line energized, breakers & disconnects closed.		•
*4.	Trace second path from second independent power source to Unit <u>TWO</u> SAT bank to verify independent paths exist from officite power thru switchyard to both Units SAT banks.	<ul> <li>Trace second path correctly on data sheet:</li> <li>L0621 &amp; L0622 not BOTH used.</li> <li>Two paths do not overlap.</li> <li>Enter YES in space for step 5 of data sheet</li> </ul>		•

ADMIN1.2(9/14/98)/4 Byron98EXAM

PERF	DRMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	N/A
*5.	Check Normal and Alternate 345 KV Buses energized.	Verify BUS ALIVE Light & voltmeter indications for:		٦	۵
Cue:	• 345 KV Bus 6 indicates it's ENERGIZED.	• 345 KV Bus 6			
	+ 345 KV Bus 12 indicatos itia	• 345 KV Bus 13			
	ENERGIZED.	Enter YES in 6a & 6b space.			
*6.	Check Normal and Alternate power SAT's available.	Verify X and Y winding MW and Amp indications for:		a	٩
Cue:	• X & Y winding MW and Amp's indicate SAT's 142-1 & 142-2 are ENERGIZED.	• SAT's 142-1 and 142-2			
	· X & Y winding MW and	<ul> <li>SAT's 242-1 and 242-2</li> </ul>			
	Amp's indicate SAT's 242-1 & 242-2 are ENERGIZED.	Enter YES in 7a & 7b space.			
*7.	Check Normal power to ESF Buses 141 and 142 supplied.	Check BUS ALIVE Lights lit, SAT feed breaker to bus position, and bus voltmeter indication for:			
Cue:	ACB 1412 closed lite is LIT, Bus 141 indicates it's	• Bus 141			
	ENERGIZED.	• Bus 142			
	• ACB 1422 closed lite is LIT, Bus 142 indicates it's	Enter YES in 8a & 8b space.			

ENERGIZED.

PERF	ORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
*8.	Check Alternate power to ESF Buses 241 and 242 supplied.	Check BUS ALIVE Lights lit, SAT feed breaker to bus position, and bus voltmeter indication for:			
Cue:	• ACB 2412 closed lite is LIT,	• Bus 241			
	ENERGIZED.	• Bus 242			
	• <u>ACB 2422 closed lite is LIT.</u> <u>Bus 242 indicates it's</u> <u>FNERGIZED.</u>	Enter YES in 9a & 9b space.			
*9.	Check ESF Crosstie Breakers available.	Verify Control power available and breaker position for:			
Cue:	• <u>ACB's 1414 &amp; 2414 open</u>	• ACB 1414			
	<u>intes LIT.</u>	• ACB 2414			
Cue:	• <u>ACB's 1424 &amp; 2424 open</u>	• ACB 1424			
	Intes LIT.	• ACB 2424			
		Enter YES in 10a &10b space.			
*10.	Verify acceptance criteria met.	YES has been entered for all spaces with ¢ sign on data sheet.			•

RECORD STOP TIME\_\_\_\_

COMMENTS:

ADMIN1.2(9/14/98)/6 Byron98EXAM

# JOB PERFORMANCE MEASURE

# CANDIDATE CUE SHEET

# TASK CONDITIONS:

- 1. You are an Extra NSO.
- 2. Unit 1 is in Mode 1, Steady State Power.

# INITIATING CUES:

The 1A DG has been declared inoperable and the Unit Supervisor has directed you to perform 1BOS 8.1.1.1.a-1, Normal and Alternate Offsite AC Power Availability Surveillance.

ADMIN1.2(9/14/98)/1 Byron98EXAM



ATHS:	L	A	B	C	D	E	F	G	H	J	K
	A	Sector A.	NO	NO	NO	YES	YES	YES	NO	NO	NO
	B	NO		NO	NO	NO	NO	YES	NO	NO	NO
	С	NO	NO		NO	NO	NO	YES	NO	YES	NO
	D	NO	NO	NO	(1,1,1,1)	NO	YES	YES	NO	YES	YES
	E	YES	NO	NO	NO	· · · · · · ·	NO	NO	NO	NO	NO
	F	YES	NO	NO	YES	NO	1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 - 1997 -	NO	NO	NO	NO
	G	YES	YES	YES	YES	NO	NO		NO	NO	NO
	Н	NO	NO	NO	NO	NO	NO	NO		YES	NO
	J	NO	NO	YES	YES	NO	NO	NO	YES		NO
	K	NO	NO	NO	YES	NO	NO	NO	NO	NO	
	the set of								CONTRACT OF A DESCRIPTION OF A DESCRIPTI	Concerning the second second second	

KEY

1805 8.1.1.1.a-1 Revision 5



JUL 1 9 1996

# Facsimile

KEY

1BOS 8.1.1.1.a-1 Ravision 5

# DATA SHEET

5.	Two i avail	independent offsite sources to the SATs are lable.	YES	¢
6.	a.	Normal power 345 KV Bus 6 energized.	YES	¢
	b.	Alternate power 345 KV Bus 13 energized.	785	¢
7.	a.	Normal power:	YES	¢
		1). SAT 142-1 and 142-2 energized or,		
		<ol> <li>U-1 SAT crosstie links installed and either SAT 142-1 or 142-2 energized.</li> </ol>		
	b.	Alternate power:	YES	¢
		1). SAT 242-1 and 242-2 energized or,		
		<ol> <li>U-2 SAT crosstie links installed and either SAT 242-1 or 242-2 energized.</li> </ol>		
8.	a.	Normal power supplied to 4160 volt ESF Bus 141.	YES	¢
	b.	Normal power supplied to 4160 volt ESF Bus 142.	YES	¢
9.	a.	Alternate power 4160 volt ESF Bus 241 available.	YES	¢
	ъ.	Alternate power 4160 volt ESF Bus 242 available.	YES	¢
10.	a.	4160 volt ESF Bus 141-241 crosstie breakers available.	YES	¢
	b.	4160 volt ESF Bus 142-242 crosstie breakers available.	YES	¢

(Final)

-D3-

(1751VV/WPF/070596/6)

	NSWP-WM-04 Revision 0 Predefine Cover Sheet	
PREDE	FINE DATA PACKAGE COV	EXHIBIT A Page 1 of 1 /ER SHEET
Procedure # 1805 8. 1. 1. 1 "itle NORMAL AND ALTER	. 9-1 Unit: / PM ID: WATE AC POWER AVAILABILIT	Y WEEKLY SURVEILLANCE
REDEFINE INFORMATION: Due Date:	Work Request #: <u>N/A</u> Critical Date: <u>Tomonece</u> L Performance record step(s) performed in comments	<u></u>
Opposite Train Operable Authorization to Start Work Work Started By	SIGNATURE AUTHORIZATION/APPRO YES NO N/A Acott Q. Asim	
Vork Completed By Surveiliance Found Within Accept Surveillance Left Within Accepta Supv Review of Work Complete	ptance Criteria YES NO ance Criteria YES NO	Time Date
	COMMENTS	
	REVIEW OF RESULTS	
		· · ·

# NORMAL AND ALTERNATE OFFSITE AC POWER AVAILABILITY WEEKLY SURVEILLANCE

#### A. STATEMENT OF APPLICABILITY:

This procedure applies to the weekly verification of operability of A.C. Electrical Power Sources in Modes 1-4.

### B. REFERENCES:

1. Technical Specification

a. 4.8.1.1.1.a.

### C. PREREQUISITES:

 Receive permission from the Shift Engineer or designated SRO licensed assistant prior to performing this surveillance by having the Data Package Cover Sheet signed and dated.

### D. PRECAUTIONS:

1. None.

## E. LIMITATIONS AND ACTIONS:

- As stated in Technical Specification Limiting Condition for Operation 3.8.1.1.a.
- In the event the Acceptance Criteria is not met during the performance of this surveillance, immediately notify the Shift Engineer to initiate LCOAR 1BOS 8.1.1-1a, LCOAR - AC Sources -Operating.
- 3. The normal and alternate AC power system should be considered as having 3 major sections, each of which must provide two physically separate and electrically independent circuit paths between the onsite power system and the transmission network (the transmission network excludes the station switchyard). The three sections are:
  - a. The transmission lines entering the station switchyard from the transmission network.
  - b. The station switchyard.

Facsimile

1BOS 8.1.1.1.a-1 Revision 5

# E.3. continued

c. The overhead transmission lines, SATs, and buses between the SATs and the onsite power system.

The words "independent transmission circuit" should be interpreted as meaning both electrically independent and physically separate through all 3 sections of the system. When these definitions are not met and only a single "independent transmission circuit" is available Action A of LCO 3.8.1.1 should be entered. No single event such as a breaker failing open, a bus fault in the switchyard, or a transmission tower failure should cause simultaneous loss of both offsite power sources when assuming two independent transmission circuits are available. (LBB is not considered a single failure event).

### F. MAIN BODY:

- On the Data Sheet drawing, circle the appropriate status of the offsite power sources either energized or deenergized by observing BUS ALIVE lights, line amps and MW for all 345 KV lines.
- 2. On the Data Sheet drawing of 345 KV switchyard SATs and 4160 Volt ESF buses, indicate all closed disconnects and breakers with an X and indicate all open disconnects and breakers with an O. Also, indicate the status of the U-1 and U-2 SAT links. Use an "X" to indicate the links installed and "O" to indicate the links removed.
- On the Data Sheet drawing, trace a single path along the dashed lines from any energized offsite power source to the Unit 1 SAT banks.

#### NOTE

Lines 0621 and 0622 cannot be considered "Independent Transmission Ckts" since they are on a common tower.

4. On the Data Sheet trace a second path from a second independent power source to the Unit 2 SAT Banks. This path cannot retrace over any portion of the path drawn in Step F.3.

Facsimile

### F. continued

- ¢ 5. Verify two independent paths exist from offsite power through the switchyard to the Unit SAT Banks based on completion of Step F.3 and F.4. If two independent sources are available write YES in the space provided on the data sheet.
- ¢ 6. VERIFY normal and alternate power 345KV buses energized by observing BUS ALIVE light lit and bus voltmeter indication. If bus is energized write YES in space provided on data sheet.
  - a. Normal power 345 KV bus is Bus 6.
  - b. Alternate power 345 KV bus is Bus 13.
- ¢ 7. VERIFY normal and alternate power SAT's available by observing X and Y winding megawatt and ampere indications. If SAT's are energized, write YES in space provided on data sheet.
  - a. Normal power SAT is:
    - 1). 142-1 and 142-2 or,
    - U-1 SAT crosstie links installed and either 142-1 or 142-2.
  - b. Alternate power SAT is:
    - 1). 242-1 and 242-2 or,
    - 2). U-2 SAT crosstie links installed and either 242-1 or 242-2.
- ¢ 8. VERIFY normal power being sublied to 4160 volt ESF Buses 141 and 142 by observing SAT feed breaker to bus position indication, BUS ALIVE light lit and bus voltmeter indication. If normal power is being supplied and bus is energized write YES on data sheet in space provided.
  - a. Bus 141, ACB 1412 CLOSED.
  - b. Bus 142, ACB 1422 CLOSED.

-3-

Facsimile

### F. continued

- ¢ 9. VERIFY alternate power 4160 volt ESF buses available by observing their normal SAT feed breaker indication, BUS ALIVE light lit and bus voltmeter indication. If alternate power 4160 volt ESF buses are available write YES in space provided on data sheet.
  - a. Bus 241, ACP 2412 CLOSED.
  - b. Bus 242, ACB 2422 CLOSED.
- ¢ 10. VERIFY 4160 volt ESF bus crosstie breakers are OPEN and available by indication of position and control power availability. If crosstie breakers are OPEN and available write YES in space provided on data sheet.
  - a. 4160 volt Bus 141 to 241 crosstie breakers ACB 1414 and 2414 OPEN.
  - b. 4160 volt Bus 142 to 242 crosstie breakers ACB 1424 and 2424 OPEN.

### G. ACCEPTANCE CRITERIA:

As a minimum the following AC electrical power sources shall be OPERABLE:

- 1. In Modes 1-4:
  - a. Each class 1E 4160 volt bus capable of being powered from:
    - 1). Either transformer of the associated units normal System Auxiliary Transformer Bank, and
    - 2). Either transformer of the other units System Auxiliary Transformer Bank, with

Each units System Auxiliary Transformer Bank energized from an independent transmission circuit.

(Final)

1BOS 8.1.1.1.a-1 Revision 5



.

.

-

Facsimile

1BOS 8.1.1.1.a-1 Revision 5

DATA SHEET

5.	Two avai	independent offsite sources to the SATs are	¢
6.	a.	Normal power 345 KV Bus 6 energized.	¢
	b.	Alternate power 345 KV Bus 13 energized.	¢
7.	a.	Normal power:	¢
		1). SAT 142-1 and 142-2 energized or,	
		<ol> <li>U-1 SAT crosstie links installed and either SAT 142-1 <u>cr</u> 142-2 energized.</li> </ol>	
	b.	Alternate power:	¢
		1). SAT 242-1 and 242-2 energized or,	
		<ol> <li>U-2 SAT crosstie links installed and either SAT 242-1 or 242-2 energized.</li> </ol>	
8.	a.	Normal power supplied to 4160 volt ESF Bus 141.	¢
	b.	Normal power supplied to 4160 volt ESF Bus 142.	¢
9.	a.	Alternate power 4160 volt ESF Bus 241 available.	¢
	ъ.	Alternate power 4160 volt ESF Bus 242 available.	¢
10.	a.	4160 volt ESF Bus 141-241 crosstie breakers available.	¢
	b.	4160 volt ESF Bus 142-242 crosstie breakers available.	¢

(Final)

-D3-

(1751VV/WPF/070596/6)

# Byron Station Operations Training Job Performance Measure

LO TASK DESCRIPTION:	Identify And Rep	lace	Blown Fuse	9
NLO T. SK DESCRIPTION:	N/A			
X/A NUMBER 2.2.13	RO/SRO RATING 3.6/3.8			
JPM NUMBER ADMIN 2 RO	<u>Task Number</u>	Jc	b Position NSO	1
Revision: Date:				
REVIEWED:				
I	NSTRUCTOR			DATE
APPROVED:				
GR	OUP LEADER			DATE
Start Time:	Stop	Time	·:	
Estimated Time	for Completion:			
This JPM was [] Per	formed in the	[]	Control R	oom
[ ] Sim	ulated	[]	Plant	
[ ] Oth	er	1 1	Mockup	
**		[]	Other	
FXAMINEE	FVA		р.	
ANTERA REA & ATANAN P	EV71	DUAIC	K.	
DATE:				
DATE:[] SATISFAC	TORY [] [	UNSAT	ISFACTORY	
DATE:[] SATISFAC	TORY [] (	UNSAT	ISFACTORY	
DATE:[] SATISFAC Comments:	TORY [] (	JNSAT	ISFACTORY	

Specific Information:

- These items were used as reference material in the development of this JPM: BAP 350-6
- 2. These items are expected to be used by the examinee in the performance of the task: BAP 350-6; BAP 350-6T1 "Fuse Discrepancy Form"; BAP 350-6T2 "Fuse Discrepancy Document Control"
- 3. Information to the Examinee and the Evaluator:
  - <u>Initial Conditions</u>:
     Unit 1 is at 100% power. Unit 2 is at 100% power.
     All systems are normal.
  - <u>Task Initiating Condition</u>: A fuse has blown on 1AF013F control power.
  - c. <u>Initiating Cue</u>: The SM directs you to replace the fuse.
  - d. <u>Your Position</u>: NSO (ADMIN)
- Terminal Performance Objective: (TPO) Replace fuse with non-like fuse.
- Critical Steps(\*)
   3, 7, & 8
- 6. Identification of Impacted Systems: If this task is performed incorrectly, the following adverse reactions could occur: The associated equipment would remain inoperable.

ADMIN2(9/14/98)/2 Byron98EXAM

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	<u>n/a</u>
RECORD START TIME				
<ol> <li>Refer to BAP 350-6.</li> <li>(May be done at any time.)</li> </ol>	Refer to BAP 350-6.	D		D
<ol> <li>Check Byron Station Fuse List. (Center Desk of Control Room)</li> </ol>	Determine/record information for fuse to be replaced:	۵		
	<ul> <li>Panel No 1AP2SE</li> <li>Fuse type - BAF 3</li> <li>Fuse rating - 3/120 amp/volt</li> </ul>			
* 3. Determine replacement fuse availability.	Determine like for like replacement fuse is NOT available.	۵	D	D
(CUE: The only available fuse is as provided)	AND			
(CUE: Emergency replacement is required and authorized.)	Check with Fuse Coordinator, SSE Electrical Group or SM for Emergency replacement authorization.			
**************************************	**************************************	******* 1 Fuse	**** * *	
******	****	******	***	
<ol> <li>Record Part 1 information on BAP 350-6T1.</li> </ol>	Record in Part 1 of Fuse Discrepancy Form:		۵	
	<ul> <li>Date [Current]</li> <li>Originator/phone</li> <li>System - AF</li> </ul>			

• WR # - N/A

• Safety Class - Safety

### PERFORMANCE CHECKLIST

5. on BAP 350-6T1.

- Fuse Discrepancy Record Part 2 information Form:
  - Schematic/WD 6E-1-
  - 4030AF08 / 6E-1-4687B
  - Panel No. 1AP28E
  - Fuse ID FU

STANDARDS

- Service 1AF013F
- · Reason for replacement - Blown
- ID on Fuse List Y Fuse Manufacturer/type
- BAF 3
- Fuse rating 3/120 amp/volt
- 6. Record Part 2 information on BAP 350-6T1.
- Is unlike fuse the same physical size as the original - Y
  - 0 0

0 0

- QRI Number per red tag
- Stores item number -XXX
- · Fuse Manuf. As per fuse
- Fuse Rating 3/120 amp/volt

\* 7. Replace fuse.

Determine replacement acceptable and obtain replacement fuse. Initial and date in Part 3 of Fuse Discrepancy Form.

(CUE: As SM, Approval for replacement is given.)

Obtain SM or designee permission to replace fuse

Should bring m \*\*\*\*\*\* \* NOTE \* Cue candidate that fuse will be installed in the \* Electrical Maintenance Shop in the Training Building at the appropriately marked breaker. \*\*\*\*\*

ADMIN2 (9/14/98)/4 Byron98EXAM

UN SAT SAT N/A
PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	N/A
* 8. Install approved fuse.	Replace fuse in proper fuse holder location.		D	
(CUE: Fuse is installed.)	Sign in Part 3 of Fuse Discrepancy Form.			
	Identifics and to			

Coordinator

9. Send completed Fuse Identifies need to provide Fuse Discrepancy Form to Fuse Coordinator Form to Fuse Coordinator.

(CUE: I will be responsible for forwarding of Form (Accept Form)

This completes this JPM.)

RECORD STOP TIME \_\_\_\_.

COMMENTS:

ADMIN2(9/14/98)/5 Byron98EXAM

# TASK CONDITIONS:

Unit 1 is at 100% power. Unit 2 is at 100% power. All systems are normal.

A fuse has blown on 1AF013F control power.

# INITIATING CUES:

The US directs you to replace the fuse.

ADMIN2(9/14/98)/6 Byron98EXAM

S	AR	GENT&LUNDY	IDY ELECTRICAL DEPARTMENT STATION BYRON UNIT 1 FUSE LIST FUSE LIST DATE 04/27/80 SYS REMON			YSTEN AF	IN AP							
T	1	SCRIMATEC	94	PAREL	3		6.2	rest	T		19	13	85	Ø
!		BHIWARD T I	CINCHIT	NUMBER OF		1	F	MF 9	20	10		WISIRC	CALC NO.	
		URAWING	ACE L'VEE	SIRTUS R PARE INSTRUMENT		e e	24	TTPE	ses	FLB	N. M. SMCS	14 RENTIFICATION	IE STORES	IS COMMENT
		65-1-4030AF03	_	1AP24E/ 132X3	L						IAFOIPB-A	L	1	
A	F	5 68-1-46850	120VAC	COMPT.03		FU			AE		AF PP 18 LUBE	FUSE BAF 3		
		6E-1-4030AF04		1AP24E/ 132X3	b1						1AFOQ68	L		
A	F	5 6E-1-4685A	120VAC	COMPT. A4		FU			34		AF PP SX VLV	FUSE BAF 3		
		6E-1-4030AF11	_	1AP24E/132X3	02						14F0178	1		
A	F	S 6E-1-4685A	120VAC	COMPT.AS		FU			34		AF PP SX VLV	FUSE BAF 3		
		6E-1-4030AF07		1AP28E/ 13234					_		IAFO13E	1		
A	F	S 6E-1-46878	120VAC	COMPT.B2		FU			34		SOTA AF VLV	FUSE BAF 3		
		6E-1-4030AF08	-	1AP28E/ 13284	61						IAFO13F	1		
-	F	\$ 6E-1-4687B	120VAC	COMPT.81		FU			34		SGIB AF VLV	FUSE BAF 3		
		6E-1-40304F09		1AP28E/132X4	62						14F0136	1		
4	F	5 6E-1-4687C	120VAC	COMPT.C1	_	FU			34		SQIC AF VLV	FUSE BAF 3		
		6E-1-4030AF 10		1AP28E/132X4	63						1450134	1		
A	F	S 6E-1-4687B	120VAC	COMPT.84		FU			34		SGID AF VLY	FUSE BAF 3		
		6E-1-4030AF 17	1	1AP28E/132X4	64						JAFO1PB-C	1	1	
A	F	5 6E-1-4687H	120VAC	COMPT.H5		FU			AE		AF PP 18 LUBE	FUSE BAF 3		
		6E-1-4030AF14	_	1145-AF 121	-	1			_		IAFOO4A	AF4AP	1	
-	1	5 6E-1-49428	125000	LCP	_	FU			34		DSCH TEST VLV	FU		
		6E-1-4030AF 14	_	1HS-AF 121	61						14F9Q44	AFAAN	1	
4	F	S 6E-1-48428	125400	LCP	_	FU			SA		DSCH TEST VLV	FU		-
		GE-1-4030AF 14	_	1HS-4F122	-				1		1AF0048	AF48P	_	
	F	5 6E-1-48428	125400	LCP		FU					SCH TEST VLV	FU		
		8E-1-4030AF 14	_	1H5-AF 122	bi						1450045	AF48N		

\*

LELU BIRUNT

1

-

13

1-14-84 : 14:24

SENT BY:

PART

# Facsimile

# FUSE DISCREPANCY FORM

NETS has evaluated Bussmann rejection fuse types FRN-R, KTK-R, KTN-R, KWN-R and FRS-R and determined that these fuses may be used as substitutes for fuse types FRN, KTK, KTN, KWN and FRS respectively. Based on this information, the above listed fuses shall be considered Like-For-Like replacements (Refer to Chron #179149 dated January 21, 1991 and Chron #182536 dated March 16, 1992).

PART 1 - General Information:

File No:	Discrepancy No: B-
Date:	FDSR Updated (F.C.):/
Originator:	Phone Extension:
System:	Work Request No.:
Safety Class: Safety	Non-Safety Regulatory
2 - Blown/Installed Fuse Information	L
Schematic Drawing:	Fuse ID on Schematic:
Wiring Drawing:	Fuse ID on Wiring:
Panel No.:	
Service:	
Reason for Fuse Replacement or Desc	ription of Discrepancy:
Does the Fuse List Identify the blo	wn/installed fuse? Yes No
Fuse Manufacturer:	
Fuse Type:	
Fuse Rating: Amps	_ Volts

(9914AA/WPF/011197)

APPROVED 01/17/97	Facsimile	BAP 350-6T1 Revision 4
PART 3 - Substitute Fuse I	nformation:	
Is Unlike Fuse the s	ame size (physical dimension)	) as the original?
Yes No		
* QRI Number:	(N/A i	f not applicable) *, 3.g
Stores Item No.:		
Fuse Manufacturer: _		
Fuse Type:		
Fuse Rating:	Amps Volts	
F.C., SSE or SM Fase	Approval:	Date:
Fuse Installation:		
Shift Manager (or designee) permis	sion obtained:	Date:
Fuse Replacer:		Date:
F.C. Approval:		Date:
Evaluation Complete	(F.C.):	Date:

··· ,4

.

Facsimile

# FUSE DISCREPANCY FORM

	NETS has evaluated Bussmann re KTK-R, KTN-R, KWN-R and FRS-R fuses may be used as substitut KTN, KWN and FRS respectively. the above listed fuses shall b replacements (Refer to Chron # and Chron #182536 dated March	DTE ejection fuse types FRN-R, and determined that these es for fuse types FRN, KTK, Based on this information, be considered Like-For-Like 179149 dated January 21, 1991 16, 1992).
PART 1	- General Information:	
F	ile No: N/A	Discrepancy No: <u>B- N/A</u>
D	ate: TODAY	FDSR Updated (F.C.): N/A /
0	riginator: CANDIDATE	Phone Extension: Por O. Macroky
S	ystem: AF	Work Request No .: N/A
S	afety Class: X Safety	Non-Safety Regulatory
PART 2	- Blown/Installed Fuse Informat:	ion:
S	chematic Drawing: 6E - 1- 403	OAFO <sup>®</sup> Fuse ID on Schematic:
W	iring Drawing:	Fuse ID on Wiring:
P	anel No.: IAP 28E - 132X4	comp. 1
S	ervice: <u>Control</u> Power	
R 	eason for Fuse Replacement or De	escription of Discrepancy:
D F F	use Type: BAF 3	blown/installed fuse? X Yes No BUSSMANN SO M

EXAM KEY

,		BAP 350-6T1
APPROVED 01/17/97	Facsimile	Revision 4
PART 3 - Substitute Fuse 1	Information:	
Is Unlike Fuse the s	same size (physical dimension)	as the original?
X Yes No		
* QRI Number: PER R	EO TAG (N/A if	not applicable)
Stores Item No.:	XXX	
Fuse Manufacturer:	BUSSMANN	
Fuse Type: MO	1	
Fuse Rating: 3	Amps 420 Volts	
F.C., SSE or SM Fuse	Approval: SHIFT MANAG	Date: 4/ /98
Fuse Installation:		
Shift Manager	ssion obtained: SHIFT MANA	AGER Date: 9/198
Fuse Replacer:	CANDIDATE	Date: 9/198
F.C. Approval:		Date:
Fraluation Complete	(F.C.):	Date:

, 3.g

. .

PAR



# FUSE DISCREPANCY FORM

NETS has evaluated Bussmann rejection fuse types FRN-R, KTK-R, KTN-R, KWN-R and FRS-R and determined that these fuses may be used as substitutes for fuse types FRN, KTK, KTN, KWN and FRS respectively. Based on this information, the above listed fuses shall be considered Like-For-Like replacements (Refer to Chron #179149 dated January 21, 1991 and Chron #182536 dated March 16, 1992).

PART 1 - General Information:

File No:	Discrepancy No: B-
Date:	FDSR Updated (F.C.):/
Originator:	Phone Extension:
System:	Work Request No.:
Safety Class: Safety	Non-Safety Regulatory
T 2 - Blown/Installed Fuse Information:	
Schematic Drawing:	Fuse ID on Schematic:
Wiring Drawing:	Fuse ID on Wiring:
Panel No.:	
Reason for Fuse Replacement or Desc	ription of Discrepancy:
Does the Fuse List Identify the blo	wn/installed fuse? Yes No
Fuse Manufacturer:	
Fuse Type:	
Fuse Rating: Amps	Volts

-1-

PA

. .

### Facsimile

### FUSE DISCREPALCY FORM

NETS has evaluated Bussmann rejection fuse types FRN-R, KTK-R, KTN-R, KWN-R and FRS-R and determined that these fuses may be used as substitutes for fuse types FRN, KTK, KTN, KWN and FRS respectively. Based on this information, the above listed fuses shall be considered Like-For-Like replacements (Refer to Chron #179149 dated January 21, 1991 and Chron #182536 dated March 16, 1992).

PART 1 - General Information:

File No:	Discrepancy No: B-
Date:	FDSR Updated (F.C.):/
Originator:	Phone Extension:
System:	Work Request No.:
Safety Class: Safety	Non-Safety Regulatory
RT 2 - Blown/Installed Fuse Informat	ion:
Schematic Drawing:	Fuse ID on Schematic:
Wiring Drawing:	Fuse ID on Wiring:
Panel No.:	
Reason for Fuse Replacement or D	Description of Discrepancy:
	Ves No
Does the Fuse List Identify the	blown/installed fuser feb no
Fuse Manufacturer:	
Fuse Type:	
Fuse Rating: Amps	Volts

APPROVED 01/17/97 Facsimile	BAP 350-6T1 Revision 4
PART 3 - Substitute Fuse Information:	
Is Unlike Fuse the same size (physical dimension	as the original?
YesNo	
* QRI Number: (N/A i	if not applicable) *, 3.g
Stores Item No.:	
Fuse Manufacturer:	
Fuse Type:	
Fuse Rating: Amps Volts	
F.C., SSE or SM Fuse Approval:	Date:
Fuse Installation:	
Shift Manager (or designee) permission obtained:	Date:
Fuse Replacer:	Date:
F.C. Approval:	Date:
Evaluation Complete (F.C.):	Date:

. . .

.

....

· · · · ·

	BAP 350-	-6T1
Facsimile	Revision	1 4
Fuse Information:		
same size (physical dimensi	on) as the original?	
(N/A	if not applicable)	*, 3.g
Amps Volts		
proval:	Date:	
	14 ·	
ssion obtained:	Date:	
	Date:	
	Date:	
	Fuse Information: same size (physical dimensi (N/A (N/A 	EAP 350- Revision  Fuse Information: same size (physical dimension) as the original?  (N/A if not applicable)  (N/A if not applicable)  Amps

. . .

44.6

# Byron Station Operations Training Job Performance Measure

Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE: DATE: [] SATISFAC	Stop for Completion: formed in the ulated er ** EVA TORY []	Time [ ] [ ] [ ] [ ] LUATO	Control Ro Plant Simulator Mockup Other R: ISFACTORY	Dom
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE: DATE: [] SATISFAC	Stop for Completion: formed in the ulated er ** EVA TORY []	Time [ ] [ ] [ ] [ ] LUATO	Control Ro Plant Simulator Mockup Other R: ISFACTORY	om
Start Time: Estimated Time This JPM was [] Per [] Sim [] Oth ** EXAMINEE: DATE:	Stop for Completion: formed in the ulated er ** EVA	Time [ ] [ ] [ ] [ ] [ ] LUATO	Control Ro Plant Simulator Mockup Other R:	Dom
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth **	Stop for Completion: formed in the ulated er **  EVA	Time [ ] [ ] [ ] [ ] [ ] LUATO	Control Ro Plant Simulator Mockup Other R:	DOM
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth **	Stop for Completion: formed in the ulated er **	Time [ ] [ ] [ ] [ ] [ ] [ ]	Control Ro Plant Simulator Mockup Other	DOM
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth	Stop for Completion: formed in the ulated er **	Time [ ] [ ] [ ] [ ] [ ]	Control Ro Plant Simulator Mockup	Dom
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim [ ] Oth	Stop for Completion: formed in the ulated er **	Time [ ] [ ] [ ]	Control Ro Plant Simulator	oom
Start Time: Estimated Time This JPM was [ ] Per [ ] Sim	Stop for Completion: formed in the ulated	Time [ ] [ ]	Control Ro Plant	oom
Start Time: Estimated Time This JPM was [ ] Per	Stop for Completion: formed in the	Time	Control Ro	Dom
Start Time:	Stop	Time	:	
Start Time:	Stop	Time	:	
GR	OUP LEADER			DATE
APPROVED:		-11		
I	NSTRUCTOR			DATE
EVIEWED:			ningina (Salama) diganar, diga ningi ana si sana ataup	
Revision: Date:				
ADMIN 3 RO			NSO	
JPM NUMBER	Task Number	Jo	b Position	
<u>K/A NUMBER</u> 2.3.10	RO/SRO RATING 2.9/3.3			
NLO TASK DESCRIPTION:	N/A			
ILO TACK DECODIDATON.				
VIO TACK DESCRIPTION.	1000 mr/hr	reate	r Than	

# Specific Information:

- These items were used as reference material in the development of this JPM: BAP 1450-2; BRP 5000-7
- 2. These items are expected to be used by the examinee in the performance of the task: RWP 98-XXX; BRP 6200-5T10
- 3. Information to the Examinee and the Evaluator:
  - a. Initial Conditions:

Unit 1 and Unit 2 are operating at 100% power. The Unit 2 Unit Supervisor has asked that a valve lineup be performed on valve 2CV XXX in the closed position.

b. Task Initiating Condition:

Entry into an area with expected dose rates of 105° mrem/hr is required to check the position of a specific valve and perform a general inspection of the area. Due to staffing restrictions, the entry is to be made by only ONE individual and RPT is NOT in attendance.

- c. <u>Initiating Cue</u>: The US directs you to perform the necessary steps to prepare to make the entry into the area.
- d. Your Position: IPSS (SRO)
- Terminal Performance Objective: (TPO) Perform actions necessary to allow entry into HIGH RADIATION AREA >1000 mrem/hr (HRA).
- 5. Critical Steps(\*) 1, & 3

ADMIN3(9/14/98)/2 Byron98EXAM 6.

Identification of Impacted Systems:

If this task is performed incorrectly, the following adverse reactions could occur:

Failure to comply with CFR regulations, NRC Regulatory Guides, and station administrative procedures controlling high radiation areas and access to these areas. Potential for radiation overexposure to self and others.

ADMIN3(9/14/98)/3 Byron98EXAM

# RECORD START TIME

\* MOTE \*
\* The first two steps address the required dosimetry and \*
\* radiation monitoring required by the individual. These \*
\* items should be obtained prior to entry into RPA and \*
\* must be obtained prior to entry into HRA. The \*
\* requirements may be met by single device with multiple \*
\* functions. The candidate may refer to the RWP to ensure \*
\* proper monitoring devices are acquired. \*
\*

 Obtains a radiation monitoring device which continuously indicates radiation dose, has alarming capability, and continuously integrates the radiation dose rate.

. .

Also obtain radiological requirements for area to be entered.

Obtains and wears electronic dosimetry (and TLD).

Obtain information from the RWF.:

- Where Highest Dose rate area? 2.5 R/hr contact & 1.2 R/hr at 12" (upper left on survey map)
- What does "ANS" stand for by the ladder? Area not Surveyed How long are you allowed into the area?, . 17 minutes (per BRP 6200-5T10).
- What protective clothing is required? Per page 1 of the RWP need Class 1.
- If asked to wait after the survey mapped area was entered? Per survey map, wait in area by the door (low dose area)
- What does 25/8 mean? (see upper right hand corner of the survey map) 25mr/hr contact and 8mr/hr at 12"

AND

 Review and sign onto RWP 98XXX

ADMIN3(9/14/98)/4 Byron98EXAM 0

PERFORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UN SAT	<u>N/A</u>
<ul> <li>Review current survey of area.</li> </ul>	Locate and review survey map(s) of area to be entered.	ł	٥	D
* 3. Obtain key for access to area.	Obtain proper key from HE Services (RP) Supv or designee.	,	D	D
<ol> <li>Ensure information on BRP 6200-5T10, 'Maximum Stay Time Worksheet For Areas &gt;1000 mrem/hr When RPT is Not in Attendance" is complete.</li> </ol>	Ensure/fill in appropriate information: • RWP # • Date • Work Group Job Desc • Authorized Daily Dose • Working Dose Bate	r	D	
(CUE: RP SUPV approval provided.)	<ul> <li>Maximum Stay Time</li> <li>RP Supv Initials</li> </ul>			

1 .

.

CUE: This completes this JPM.)

. .

.

....

RECORD STOP TIME \_\_\_\_.

COMMENTS : 

ADM "N3 (9/14/98)/5 Byron98EXAM

# TASK CONDITIONS:

Unit 1 and Unit 2 are operating at 100% power. The Unit 2 Unit Supervisor has asked that a valve lineup be performed on valve 2CV XXX.

INITIATING CUES:

Fntry into an area with expected dose rates of 1050 mrem/hr is required to check the position of a specific valve and perform a general inspection of the area. Due to staffing restrictions, the entry is to be made by only ONE individual and RPT is NOT in attendance.

ADMIN3(9/14/98)/6 Byron98EXAM APPROVED 12/06/94

Facsimile

BRP 6200-5T9 Revision 0

# RWP 981XXIXX

# RWP ACKNOWLEDGEMENT LOG

I certify that I have read, understand, and will comply with the requiremnts of the RWP. I have reviewed the radiological conditions for my work area, and that I will not exceed the authorized exposure limit for this RWP.

SIGNATURE	DATE	BADGE #	SIGNATURE	DATE	BADGE #
					Paratemeters and the second of the second
ار موجع المراجع ال					
					}
			g		1
10 Au		Car Car	<u>;                                    </u>		
8 00	50 1				
e 1 6		1 W			
141	300 1 944	R R	1.42		
			1		
and an experimentary device device the second s					
		1			1
					1

(Final)

•		ALARA ACTION REVIEW *			
		Cover Sheet			
		AAR # 98 RWP #	16 > 30	R/Rem Y	507
		Station / Year / Sequence SARC Required	naintenance	P/Rem 1	<u>av</u>
Job De	ascripti	on: LHHA entres: Including inspections, ops founds and COO, mind.	LL		
WORK L	Locación	# Various Work Analyst:	NA		
KWP P	walkdow	ms recommended: Yes No Comments:			
ALLANA	Chate 1	the condition, from BRP 6200-5T8, that requires this	LHRA	entry. Multiple	e dose field
1.	Determ	ine which of the following will contr_bute to reducin	g exposur	e for this	work:
	a.	Shielding in area or equipment? (use historical and/o current surveys to determine needs). Comments: Review for each application.	or	Yes	No
	b.	Portable Ventilation? (Hepa size/type, tent size etc Comments: Review for each application.	.)	¥ Yes	No
	с.	Mock up training? (Available photos, tapes, etc.) Comments: Review for each application.		Yes	No
	a.	Source Term reduction? (Identify flushing, points, v systems and procedures. Comments: Review for each application.	alves,	V Yes	No
	e.	Remote handling tools, Robotics? (underwater work, r rods, cameras: Comments: Review for each application.	each	Yes Yes	No
	f.	Decontamination of area or equipment? (Consider pre/ decon of work area based on historical/current surv Comments:	post eys:	1 Yes	No
		•			
	g.	Is Surrogate Tour or video maintenance information a	vailable	? Yes	No []
3.	Access	comments: s to Reactor Cavity Incore Area?		Yes	No
	(Appro	oval, if Yes)			
		Station Manager	Daçe		
		Health Physics Supervisor	Date		
	LCCOS	s to whole body dose rates >/= 15 Rem/hour?		Yes	No
•.	(Appro	oval, if Yes)	-		
	(npp-	Health Physics Supervisor	Date		No
5.	ALARA	Brief required for this work?	4 1	Ies	NO
	Initia	al Shiftly Other Date:		12/22/97	
	*/EA	251-82-01200-07			
			*		

(1692AA/DOC/120597)

744:3

1 . \*\*

	NOVIDICAL 15
ALARA	BRIEF CHECKLIST
06 / 98	NWR # Various
	(or activity description)
tork scope: LHRA entries: Including inspections, ops roun	ds and OOS, minor maintenance.
Nork location: All RPA's	
accommended personnel to attend briefing:	Work group supervisor Work group
UPLS RPT V QC Shift Manager (	Operations SQV
thers	
Survey information: Current Historical	RPT in attendance
Type of Brief: Pre-job g YES NO (	with front desk or Control Point RPT).
ALARA Z YES NO I	nitial Shiftly Other
Briefi	ng Notes
. RWP Requirements PC Class X 1 X 2 X 3 X 4	Daily: 100 Alarm: 80 Rate: 300
Face Shield: Y V N Respirator: Y V N	Type of waterproof outer layer as needed
forking area dose rates per surveys	Contamination Levels: per SU veys
EDE ALARA evaluations will determine respiratory needs.	a desimpted stay times and timekeeping
). RPT Coverage Requirements: Coverage type:	Continuous or documented stay times and unrecepting
Surveys needed: Air Samples as needed IRP/Fro	equency per survey Beta evaluation/contined space
timekeep/staytime requirements: Stay times docume	ented on RWP and for beta assessment if needed.
C. Contingency Plan: Dose rales exceed planned or his	Provide and a set an
	orical information - Stop work, exit area immediately, contact HPL
	orical information - Stop work, exit area immediately, contact APL
	orical information - Stop work, exit area immediately, contact APL
Dose fales exceed plained of the	LERA V ECA V A/E V Red Zone V
D. ALARA Brief requirements: Entry into: HRA	$\underline{V}$ LERA $\underline{V}$ ECA $\underline{V}$ A/B $\underline{V}$ Red Zone $\underline{V}$
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys.	$\swarrow$ LERA $\checkmark$ ECA $\checkmark$ $\lambda/E \checkmark$ Red Zone $\checkmark$
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi	LERA $\swarrow$ ECA $\checkmark$ A/E $\checkmark$ Red Zone $\checkmark$ ng needs or potential.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider:	LERA $\swarrow$ ECA $\checkmark$ A/E $\checkmark$ Red Zone $\checkmark$ ng needs or potential. see below
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super	LERA $\swarrow$ ECA $\checkmark$ A/E $\checkmark$ Red Zone $\checkmark$ ng needs or potential. see below visor.
DOSE TAILOS CROEDE Planned of the DOSE TAILOS CROEDE Planned of the DOSE TAILOS CROEDE Planned of the Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shielding Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i	LERA V ECA V A/B V Red Zone V ng needs or potential. see below visor. f needed?As needed Results
DOSE THESE CROEDED PLANNED OF THE DOSE THESE CROEDED PLANNED OF THE READ Holdpoints: As per current surveys. Areas for shielding: Check each application for shielding Contamination Control techniques to consider: Safety needs and/or exemptions: As per work superv Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba	LERA V ECA V A/B V Red Zone V ng needs or potential. see below visor. f needed?As needed sed on current surveys.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are	LHRA ECA   M LHRA   LHRA ECA   A/B Red Zone   Ing needs or potential.   see below   visor.   f needed? As needed   Results   sed on current surveys.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are	LHRA K   K LHRA   LHRA K   ECA A/E   Red Zone   Ing needs or potential.   see below   visor.   f   needed?   As needed   Results   sed on current surveys.   identified as per survey.   documented and communicated to workers. Working area dose
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are NPT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are	Image: Stop work, exit area immediately, contact API   Image: LHRA I FCA I A/E Red Zone I   Ing needs or potential.   see below   visor.   f needed? As needed   sed on current surveys.   identified as per survey.   documented and communicated to workers. Working area dose   identified.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are PT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are ny maintenance activities require RP review before entry.	Iterical information - Stop work, exit area immediately, contact APP   Iterical information - Stop work, exit area immediately, contact APP   Iterical information - Stop work, exit area immediately, contact APP   Iterical information - Stop work, exit area immediately, contact APP   Iterical information - Stop work, exit area immediately, contact APP   Iterical information - Stop work, exit area immediately, contact APP   Iterical information - Stop work, exit area immediately, contact APP   Ing needs or potential.   see below   visor.   If needed?As needed   Results   sed on current surveys.   Identified as per survey.   documented and communicated to workers. Working area dose identified.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work supen Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are NPT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are ny maintenance activities require RP review before entry. The and exposure should be estimated prior to entry.	Image: Stop work, exit area immediately, contact API   Image: LHRA I FCA I A/B Red Zone I   Ing needs or potential.   see below   visor.   f needed? As needed   sed on current surveys.   identified as per survey.   bocumented and communicated to workers. Working area dose identified.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work supen Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are NPT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are ny maintenance activities require RP review before entry. The and exposure should be estimated prior to entry. Papproval required before entry on this RWP. NO ACCESS TO AREAS > 15 REM/Hr on this RWP.	LERRA X ECA X A/B K Red Zone K ng needs or potential. see below visor. f needed?As needed sed on current surveys. identified as per survey. bocumented and communicated to workers. Working area dose identified.
Dose failes exceed planned of the Dose failes exceed planned of the Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are APT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are any maintenance activities require RP review before entry. Time and exposure should be estimated prior to entry. AP approval required before entry on this RWP. DO ACCESS TO AREAS > 15 REM/Hr on this RWP. Determine entry requirements are IAW BAP 1450-2.	LERA V FCA V A/B V Red Zone V ng needs or potential. see below visor. f needed?As needed sed on current surveys. identified as per survey. tocumented and communicated to workers. Working area dose identified.
DOSE Takes Exceed planted of the DOSE Takes Exceed planted of the Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work supen Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are APT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are any maintenance activities require RP review before entry. Time and exposure should be estimated prior to entry. AP approval required before entry on this RWP. NO ACCESS TO AREAS > 15 REM/Hr on this RWP. Determine entry requirements are IAW BAP 1450-2.	Image: Stop work, exit area immediately, contact APT   Image: LHRA I FCA I A/E Red Zone I   Ing needs or potential.   see below   visor.   f needed? As needed   sed on current surveys.   identified as per survey.   bocumented and communicated to workers. Working area dose   identified.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are NPT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are ny maintenance activities require RP review before entry. Time and exposure should be estimated prior to entry. Papproval required before entry on this RWP. IO ACCESS TO AREAS > 15 REM/Hr on this RWP. Determine entry requirements are IAW BAP 1450-2.	Lerical information - Stop work, exit area immediately, contact APT
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work supen Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are NPT coverage or stry times MUST be in place prier to entry, d ates also required. Insure Low dose and high dose areas are iny maintenance activities require RP review before entry. Time and exposure should be estimated prior to entry. AP approval required before entry on this RWP. NO ACCESS TO AREAS > 15 REM/Hr on this RWP. Determine entry requirements are IAW BAP 1450-2.	LERA V ECA V A/B V Red Zone V ng needs or potential. see below visor. f needed?As needed sed on current surveys. identified as per survey. bocumented and communicated to workers. Working area dose identified.
D. ALARA Brief requirements: Entry into: HRA Rad Holdpoints: As per current surveys. Areas for shielding: Check each application for shieldi Contamination Control techniques to consider: Safety needs and/or exemptions: As per work super Has a TEDE ALARA evaluation been completed, i Insure work area pre/post decon as needed, ba Insure all hotspot, low & high dose areas are NPT coverage or stry times MUST be in place prior to entry, d ates also required. Insure Low dose and high dose areas are ny maintenance activities require RP review before entry. The and exposure should be estimated prior to entry. Papproval required before entry on this RWP. NO ACCESS TO AREAS > 15 REM/Hr on this RWP. Determine entry requirements are IAW BAP 1450-2.	LERRA $\swarrow$ ECA $\checkmark$ A/B $\checkmark$ Red Zone $\checkmark$ ng needs or potential. see below visor. f needed?As needed sed on current surveys. identified as per survey. bocumented and communicated to workers. Working area dose identified.
Description of the provided of	LERA X FCA X A/B X Red Zone X ng needs or potential. see below visor. f needed?As needed sed on current surveys. identified as per survey. bocumented and communicated to workers. Working area dose identified.

APPROVED 1200207

Additional Comments

1	FILTRAING
. 1	USE ONLY

Tagan,

ALAR	A Brief Information	Co	ment	B				A DECEMPTOR OF THE ADDRESS OF THE OWNER OF THE
1	Radiological Hold points identified?	~	YES		NO		N/A	
2	Shielding of areas and/or equipment.	V	YES		NO		N/A	
3	Contamination control techniques.	V	YES		NO		N/A	
4	Safety needs and/or exemptions for work identified.	V	YES		NO		N/A	
5	TEDE ALARA evaluation needed?	V	YES		NO		N/A	
6	Decon of areas and/or equipment.	V	YES		NO		N/A	
7	Not spots, low and high dose waiting areas identified?	~	YES		NO		N/A	
8	Airborne concerns	V	YES		NO		N/A	
9	Not particle controls needed?	V	YES		NO		N/A	
10	Procedural requirements # BAP 1450-2	V	YES		NO		N/A	
11	HEPA Requirements?	V	YES		NO		N/A	
12	Source Term concerns. Flushing / hydrolazing?	V	YES		NO		N/A	
17	Use of Remote handling tools?		YES	V	NO		N/A	
14	Use of high speed tools needed?		YES		NO	~	N/A	
15	Outside work group interference?		YES	V	NO		N/A	
16	Ventilation/radiological release concerns? Containment/FHE area rad monitor setpoints reset?	~	YES	-	NO	-	N/A	Determine affect on any area rad monitors
17	Communication needs?	V	YES		NO		N/A	
18	Use of robotics?	V	YES	T	NO		N/A	
19	Lighting / work area concerns?	V	YES		NO		N/A	
20	Photos, tapes, prints available? Surrogate Tour info?	v	YES		NO		N/A	
21	Wireless Remote Monitoring?	v	YES		NO		N/A	
22	Equipment train changes?	V	YES		NO		N/A	

Completed by

- 3 -

Date: \_\_\_\_\_ 12/22/97

				PWP #	
# 06	1 98				
k scope:	LHRA entries: In	cluding inspections,	ops rounds and OOS	5, minor maintenan	ce.
r proper	A# 0041-				
k locatio	all HPA's			CONTRACTOR CONTRACTOR OF CASE	

On the lines below dosument any or all of the following information:

Changes to the original AAR. 1.

Suggestions, based on job performance, for enhancing this AAR for future work. 2.

Revision in

- Additional information for the current AAR. 3.
- Any other comments or concerns. 4.

(Final)

-4-

FOR TRAINING

ł

APPROVED 12/06/97	Facsimile	Revision 7	,
	RADIATION WORK PERMIT ALARA RECOMMENT HECKLIST		
Date/Time	<u>/_04:15</u>	-Carrierante	
I. Radiation Pr	otection Personnel	]	
If an	NOTE item(s) listed in section A have been answere An ALARA Action Review is required per BAP A Job Specific RWP is required per BAP 575-	d yes: 700-2. 9. YES	_NO
A. Do any	of the following conditions exist?	[ • ]	[]
1.	Total dose equivalent for the planned job is expected to equal or exceed <u>one (1)</u> <u>Rem</u> and job duration to be less than 100 man hours.	[]	(*)
2.	Planned work will involve prolonged [ > 1 (one) hour] occupancy in an Airborne Radioactivity Area. (>.3 DAC)	[ ]	[ • ]
* 3.	Entry into either unit's reactor cavity incore area is planned (BAP 1450-3 addresses requirements to access reactor cavity incore space)	• . []	[ 🛩 ]
4.	Entry into locked High Radiation Area (>1000 mrem/hr) Ensure RPT in attendance or complete maximum stay time worksheet BRP 6200-5T10	[ 🖌 ]	[]
5.	Items will be <u>removed</u> from the Spent Fuel Pool or <u>flooded</u> Reactor Cavity	. []	[ 🖌 ]
6.	Entry inside the containment missile barrier at $\geq$ 10% Reactor Power	. [ ]	[ 🖌 ]
7	Entry to containment 426' el. re-fuel floor cavity area at $\geq$ 10% Reactor Power	. 1 1	[ 🖌 ]
8.	Work will include tasks involving the Incore Detector System	. [ ]	[ 🖌 ]
9.	Work in areas where Hot Particles have been <u>identified</u>	. [ ]	[ 🖌 ]
10.	Work will involve diver activities in radiologically posted areas	[]	[*]
11.	Work will involve radiography	. [ ]	[•]
12.	Task will require workers to transient > 15 rem/hr whole body dose fields	[ ]	[ • ]
** 13. * 454-251-91-0 * 454-251-88-3	Work will involve accessing areas adjacent to spent fuel transfer tube where dose rates increase		[ 🖌 ]
** 454-251-78-0	0020		

THE SMILY

(1170SS/WPF/120597)

. APPROVED 12/06/97

# Facsimile

CITED IS			
;		YES	NO
в.	Are any of the following conditions expected?	[,] ]	[ ]
	1. Primary or contaminated system work		
	involving system breech. (Hot Particles?) System transfer of high level radioactive		
	fluids/resins, etc. > 100 mrem/hr @ contact		
	3. Work involves the waste Gas system.		
с.	Will work include any of the following Fuel <u>Pool/flooded</u> Reactor Cavity area activities?	[]	[ • ]
	1. Items will be moved in the fuel pool/ cavity but not removed	[ ]	[1]
	2. Involves work with tools/equipment that have	[]	[1]
	3. Involves work with fuel pool/cavity filter	[ ]	111
	changes		
D.	Will work involve containment entry to the following areas?	[ ]	[ 🖌 ]
	<ol> <li>Entry into containment, inside missile barrier @ ≥ 10% reactor power</li> <li>Entry into the Steam Generator or</li> </ol>	[]]	[ • ]
	2. Entry into the steam deneration $\geq 10\%$ reactor Pressurizer Coffin area(s) $@ \geq 10\%$ reactor	[]]	111
	3. Involves access to the Polar Crane	( )	141
	@ > 10% reactor power		
Ε.	Will tasks involve handling of Radioactive		
	of the following criteria?	[ ]	
	1. Sorting or transporting trash/rad materials		
	container	[]	[ 🖌 ]
	<ol> <li>Sorting trash/laundry bags marked as coming from a Hot Particle (Red) zone</li> </ol>	[ ]	[1]
	3. Processing sludge from drums to HIC		
	NOTE		
	If any of the items in sections B through E are antic	ipated	
	1. A Job Specific RWP is required as described in		
	BAP 575-9. 2. An ALARA Review may be requested at the discret	ion of	
	Rad Protection Supervision or upon the request	or the	
AAR	Required: [Y ] [N ]	12-18-97	
RPT	Sign:		
	ERR TRA		
	(Final)	,	
	- 111	N	
	1911 I I I I I I I I I I I I I I I I I I	. 1	
	-2- U3		

--

### Facsimile

\* \* \* .

### ATTACHMENT B

# PROTECTIVE CLOTHING CLASSIFICATIONS AND GUIDELINES

CLASS 1 (GREEN)

COTTON GLOVE LINERS RUBBER GLOVES CLOTH BOOTIES RUBBER SHOE COVERS CAP

CLASS 2 (BLUE)

ONE PAIR OF COVERALLS CAP (optional) CLOTH HOOD COTTY GLOVE LINERS RUBBER GLOVES CLOTH BOOTIES RUBBER SHOE COVERS

CLASS 3 (WHITE)

DOUBLE COVERALLS DOUBLE CLOTH HOOD COTTON GLOVE LINERS DOUBLE RUBBER GLOVES CLOTH BOOTIES DOUBLE RUBBER SHOE COVERS

CLASS 4 (RED)

ONE PAIR OF COVERALLS WATERPROOF OUTER LAYER CAP (optional) DOUBLE CLOTH HOOD COTTON GLOVE LINERS DOUBLE RUBBER GLOVES CLOTH BOOTIES PLASTIC BOOTIES DOUBLE RUBBER SHOES

# Guidelines:

In lieu of a cloth hood, a cap may be substituted unless:

1).	The worker	will	be	entering	a	high	contamination	area,	or .
-----	------------	------	----	----------	---	------	---------------	-------	------

2). The worker will be wearing a face shield or respiratory protection, or

- 3). The worker will be carrying smearable contaminated items over their shoulder(s), or
- 4). The worker will be in a congested area, or
- 5). When specified by Radiation Protection.

For contamination control, hair should be tucked inside the cap or goveralls.

### ATTACHMENT B

PROTECTIVE CLOTHING CLASSIFICATIONS AND GUIDELINES, Cont.

# Guidelines:

For Class 1 and Class 2 Protective Clothing the following substitutions may be made:

- Double or multi-layers of surgical gloves may be substituted for rubber 1). gloves for contamination control for the following job evolutions or tasks with prior RP approval:
  - Performing light work a).
  - b). Inspections/walkdowns
  - 0.0.S. when no climbing is involved c).
  - Instrument cals. (vellow tight surgical type gloves may be worn as d). substitute)
  - Minor decon of small equipment or parts e).
  - Performing routine RP surveys for radiation/contamination £).
  - g). Handling/filling out paperwork during job evolutions
  - Any activity approved by RP dept. h).
- It is acceptable to wear, with prior RP approval, surgical gloves and/or 2). colored cotton glove liners in clean (non-contaminated) areas of the RPA for handling of potentially contaminated materials or equipment such as:

-25-

- Informational radiological smears a).
- Maslin wipes or smears of equipment or floor b).
- Lead Blankets c).
- Bagged equipment coming from a posted contaminated area d) .
- Laundry bags from SOPs e).
- Whenever RP gives prior approval £).

FOR TRAINING

# Byron Station Radiation Work Permit

RWP #:		Rev:	
--------	--	------	--

Worker Information

I I mit :	Building:	Elevation:	Location:	
0	AUX AND RW	ALL	LHRAs	and the second

Equipment Name: NA

# RWP Description: LHRA ENTRILS: INCLUDING INSPECTIONS / OPS ROUNDS AND OOS / MINOR MAINTENANCE

RWP Dose Approval: 100 mrem/day Accumulated Dose Alarm: 80 mrem Dose Rate Alarm: 300 mrem/hr

# Exposure Monitoring Requirements

TLD and DIGI (Electronic Dosimeter) required.

# Special Instructions

AL . WORK ON THIS RWP MUST HAVE PRIOR RP

NO ENTRY INTO AREAS REQUIRING PERSONNEL NEUTRON MONITORING

REVIEW SURVEYS OF RADIATION AND CONTAMINATED AREAS.

CLASS 1 CLOTHING (MINS) REQ. FOR VISUAL INSPECTION / NO CLIMBING.

CLASS 2 CLOTHING (FULL SET) REQ. FOR CLIMBING ABOVE 6 FT. / TIGHT AREAS POSTED CA.

WATERPROOF OUTER LAYER REQ. FOR WORK WITH RUNNING OR SPLASHING WATER.

THIS RWP IS FOR ALL WORK GROUPS, BUT ONLY FOR MINOR ACTIVITIES SUCH AS: STAGING EQUIPMENT / OPER. ROUNDS / INSPECTIONS / MINOR MAINT.

NO ENTRY INTO 15R/HR WHOLE BODY DOSE RATE WITHOUT PRIOR HPSS APPROVAL.

# **Respiratory Protection Required**

None

# Protective Clothing Required

No PCs required in clean areas.

Class 1 (Mins) Cloth Booties Rubber Gloves Cotton Glove Liners Rubber Shoe Covers Cap Lab Coat

Class 2 (Full Set) Cloth Booties Rubber Gloves Cotton Glove Liners Rubber Shoe Covers Cap Cloth Hood Coveralls

FOR TRAINING

USE ONLY

RWP #

Rev: 0

Survey Frequency Requirements		
Radiation:	ROUTINE / New work Location	
Contamination:	ROUTINE / New Work Location	
Airborne:	ROUTINE	

# Pre-Job Briefing Required Yes

ENTRY INTO R-LOCKED HIGH RAD. AREAS REQ. RPT IN ATTENDANCE OR CALC. STAY TIMES DOCUMENTED AND COMMUNICATED TO WORKERS.

# R.T. Coverage / Comments:

Intermitent: Yes

Continuous tech coverage required if no current survey available for areas to be entered or if RP Supervision feels it necessary.

# FOR TRAINING

RP Supervisor	12/31/97 10:02:56 AM	ALARA Review By CURT REPASS AAR 06-98-A011	10/20/97 12:00:29 PM
Completed By ROBERTSON MARTA J	10/20/97 12:00:11 PM	Terminated By BARTON BARRY M	2/16/98 10:17:19 AM
Job Supervisor			

RADIATION WOR	K PERMIT RI	EQUEST	r		RW	P REQUEST	
ATION NUMBER: BYR	UNIT NUMBER:	00		RWP/REV:	90000	F 00	
ILDING: ALL OCATION DESCRIPTION: AL	ELEVATION:	ALL		ROOM/ARE	A: ALL	COL:	ROW:
QUIP. NAME:							
WR NUMPER: CTIVITY LHRA ENTRIES I	NCL. MISC MINOR W	ORK				EPN:	TASK/DEP
ESCRIPTION OF WORK (Be specifi	c or attach clarifying do	cuments):	P. MATN	T			
HECK WHICH ITEMS ARE REQ Checklist N/A Draining of Vessel or Tank Component Disassembly Confined/Enclosed Space Entry Use of Controlled Rad. Sources Work > than 6 feet Above Floor Scaffolding Surface Preparation Type:	UIRED OR APPLY: Sweeping Brushing Weld/Brazing Insulation Rei Radiography Open Process Splash/Runni	/Solder moval Lines ng Water	Asbo Drill Rob Plas Mov Paci Cut	estos Remova ling otic Welding ma/Air Arc C ement of Shie ćing Removal or Grind Typ	utting Iding e:	- Change Remova Pools as Use of ( (glove b Work B	s in Ventilation d of Equip. from Fuel sociated cavities/Pits. Containment Devices ags) elow Grating
LIST ALL TASKS (Includi	ng Support Groups)				FO	R RAD. PROT	TECTION USE
			H	PERSON OURS IN ORK AREA	WC I RAT	DRK AREA DOSE 'E (mR/HR)	PERSON-REM ESTIMATE
INSPECTIONS/ ROUNDS / 00	S / MINOR MAINT			350.0		.00	. 000
	N.	TOTAL	s	350.0	1		.000
EST. START DATE : EST. COMPL DATE: REQUESTOR: NAME (PRINT) BARTON	USE	ar ar	<u></u>	DEPARTM	ENT	PHON	VE 2975
ADDITIONAL RP COMMENTS					-		
					-		
REP DATA							,
AD PROTECTION REVIEW BY: AD PROTECTION REV DATE : D PROTECTION REV TIME :	BARTON 01/07/98 09:00	BARR	Y				
SEE ATTACHED LIST	ana ana ina katala Baharay sebaharan ang ang ang ang ang ang ang ang ang a		and the second of Automa				

# **RWP INFORMATION LOG**

.....

• •

1.1

DATE / TIME	INITIALS	RWP INFORMATION
		s · · · · · ·
A reprint and water and a second strate and a second strate of the secon	1	
or notice contractory and table or sold		
annin a start bezalan dan manajaran dan		
of lands part of the state of the state of the state of the		
r		
and and a sub-stand of the stand of the sub-		
THE PARTY OF THE REPORT OF THE PARTY OF THE		
		C.
		*****
10 an ann an an ann an Arice anns an ann an Arice anns anns anns anns anns anns an Arice anns anns anns anns anns anns anns ann		W & & LOW AT THE WAY
		and a set of the set o
		a contra-
		" Silve contact
and a second		
and a survey of the statement of the state o		THAT
		THE LUND
		113ra
and the second		
	· .	
alan ay hay day an init dalah kata kata kata kata kata kata kata ka		
and a product of a second s		
And the second		
Strengt to the state of the state of the state of		

111.4

h: vnydocuments vddata vinfolog.xls

# **APPROVED 02/03/94**

# Facsimile

# OT-XXX OUTSIDE BUILDING BLANK



HCP. MAILV

BRP 2000-T411 Revision 2 APPROVED 12/26/97

.

KEY ?

BRP 6200-5T10 Revision 1

# Maximum Stay Time Worksheet For Areas >1000 mrem/hr When RPT Is Not In Attendance

Max stay time required in areas >1000 mrem/hr when a RPT is not in attendance (Tech spec 6.12.2)

RWP # 98XXXX

	IN CASE IS, MARK THE REAL PROPERTY AND ADDRESS AND ADDRESS ADDRES	and a start water and the competition of the second start of the		sample design and an an a statement of a statement of the	Party care some side management and the local state and the
Date	Work Group Job Description	Authorized Daily Dose (mrem)	Working Dose Rate (mrem/hr)	** Maximum Stay Time	Radiation Protection Supervision Initials
Example: 01-01-95	CV resin transfer	300	1500	12	JAD
9/14/98	VALVE LINE-UP	300	1050	17	JRT
			END	RALLASS	
			in		
				ANTY	
			USE	UNL	(indi
					1

\*\*Worker MUST leave the area when stay time has expired OR upon electronic dosimeter alarm due to accumulated dose, whichever occurs first.

(Final)

# ADMINISTRATIVE TOPICS SECTION A.4 RO Questions

Question No: 1

.

**REFERENCE USE: YES** 

An Alert Emergency has been declared on Unit 1. All equipment is functioning normally. A leak has the potential for affecting one train of ECCS equipment. A person will have to enter the 383' Penetration and operate the valve handwheel to isolate the leak. The primary exposure will be to the hands and lower forearms. When asked, you volunteered to perform the operation.

What are the radiation exposure limits that should apply to this action and what individual must approve this exposure?

# **Expected Answer:**

Exposure Limits:

- 10 rem TEDE (Whole Body)
- 30 rem to lens of the eye
- 100 rem to extremities (and any organs and skin)

Approval: The Station Director (CMEO, or Manager of Emergency Operations)

# **Actual Answer:**

Candidate's response matched expected answer.

Sat Unsat \_.

# K/A: 2.3.1 2.6/3.0

 Reference(s): BZP 380-1 " Emergency Dose Limits and Radiological Controls for Rescue and Recovery Operations", Rev. 9, Section C.1
 BZP 100-T1 "Station Director Checklist", Page 1
 BZP's/GSEP Lesson Plan, Rev. 1, III.F.3 & F.2, page 70-71, LO 4.

# ADN.INISTRATIVE TOPICS SECTION A.4 RO

# **REFERENCE USE: YES**

# Question No: 2

a. A Site Emergency has been declared and the Evacuation Alarm has been sounded. What are the areas of asembly for both Licensed and Non-Licensed Operators?

b. What is required if the Operation Support Center (OSC) is experiencing dose rates of 120mr/hour?

# **Expected Answer:**

a.Control Room, Operation Support Center (OSC), and the Machine Shop. b. Evacuate the OSC to the the Shift Engineers Office.

### **Actual Answer:**

Candidate's response matched expected answer.

K/A: 2.4.29 2.6/4.0

Sat \_\_\_\_ Unsat \_\_\_.

Reference(s): BZP 310-4 "Assembly and Evacuation of Personnel", Rev. 18. BZP 400-2 "Role and Staffing of OSC", Rev. 9. BZP 310-4A2 "Assembly Areas", Rev. 1. BZP's/GSEP Lesson Plan, Rev. 1, III.H.4.b.2), page 76, LO 8. BZP's/GSEP Lesson Plan, Rev. 1, III.J.2 & 7, page 80-82, LO 1.

ADMIN4(9/14/98)/2 Byron98EXAM

# ADMINISTRATIVE TOPICS SECTION A.4 RO CANDIDATE QUESTION SHEET

# Question No: 1

An Alert Emergency has been declared on Unit 1. All equipment is functioning normally. A leak has the potential for affecting one train of ECCS equipment. A person will have to enter the 383' Penetration and operate the valve handwheel to isolate the leak. The primary exposure will be to the hands and lower forearms. When asked, you volunteered to perform the operation.

What are the radiation exposure limits that should apply to this action and what individual must approve this exposure?

# Question No: 2

A Site Emergency has been declared and the Evacuation Alarm has been sounded. What are the areas of asembly for both Licensed and Non-Licensed Operators?

What is required if the Operation Support Center (OSC) is experiencing dose rates of 120mr/hour?

ADMIN4(9/14/98)/3 Byron98EXAM ES-301

Administrative Topics Outline

Form-ES-301-1

ty: Byron 1 & 2 ination Level: SRO-I		Date of Examination: Operating Test Number	September14, 1998
Administrative Topic/Subject Description	Describe method of evaluation: 3. ONE Administrative JPM, OR 4. TWO Administrative Question	IS	•
Plant Parameter Verification / Review A Completed Estimated Critical Condition	1. JPM K/A 2.1.7 3.7/4.4		
Conduct of Operations / Shift Turnover with Staffing Complications	1. JPM K/A 2.1.3 3.0/3.4; 2.1.4	2.3/3.4	
Clearance And Tagging / Identify And Replace Blown Fuse	1. JPM K/A 2.2.13 3.6/3.8		
Protection Fron. Radiation Exposure / Prepare For Entry Into High Radiation Area > 1000 mr/hr	1. JPM K/A 2.3.10 2.9/3.3		
Emergency Plan / GSEP Classification And Protective Action Recommenadtions	1. JPM K/A 2.4.38 2.2/4.0		
	<ul> <li>ty: Byron 1 &amp; 2 ination Level: SRO-1 Administrative Topic/Subject Description</li> <li>Plant Parameter Verification / Review A Completed Estimated Critical Condition</li> <li>Conduct of Operations / Shift Turnover with Staffing Complications</li> <li>Clearance And 'fagging / Identify And Replace Blown Fuse</li> <li>Protection Fron. Radiation Exposure / Prepare For Entry Into High Radiation Area &gt; 1000 mr/hr</li> <li>Emergency Plan / GSEP Classification And Protective Action Recommenadtions</li> </ul>	<ul> <li>ty: Byron 1 &amp; 2 ination Level: SRO-I Administrative Topic/Subject Description</li> <li>Plant Parameter Verification / Review A Completed Estimated Critical Condition</li> <li>Conduct of Operations / Shift Turnover with Staffing Complications</li> <li>Clearance And Tagging / Identify And Replace Blown Fuse</li> <li>Protection Fron. Radiation Exposure / Prepare For Entry Into High Radiation Area &gt; 1000 mr/hr</li> <li>Energency Plan / GSEP Classification And Protective Action Recommenadtions</li> <li>I. JPM K/A 2.1.38 2.2/4.0</li> </ul>	ty: Byron 1 & 2 Date of Examination: ination Level: SRO-1 Operating Test Number: Administrative Topic/Subject 3. ONE Administrative JPM, OR Description J Review A Completed Estimated Critical Condition 1. JPM K/A 2.1.7 3.7/4.4 Conduct of Operations / Shift Turnover with Staffing Complications 1. JPM K/A 2.1.3 3.0/3.4; 2.1.4 2.3/3.4 Clearance And Tagging / Identify And Replace Blown Fuse 1. JPM K/A 2.3.10 2.9/3.3 Protection Fron. Radiation Exposure / Prepare For Entry Into High Radiation Area > 1000 mr/hr Emergency Plan / GSEP Classification And Protective Action Recommenadtions 1. JPM K/A 2.4.38 2.2/4.0
## Byron Station Operations Training Job Performance Measure

LO TASK DESCRIPTION:	Review a Complet Critical Conditi	ed Es cn	timated
NLO TASK DESCRIPTION:	N/A		
K/A NUMBER 2.2.36 2.1.25	RO/SRO RATING 2.8/3.2* 2.8/3.1		
JPM NUMBER ADMIN 1.1 SRO	Task Number	Jo	b Position US
Revision: Date:			
REVIEWED:			
I	NSTRUCTOR		DATE
APPROVED:			
GF	OUP LEADER		DATE
Start Time:	Stop	Time	·
Ectimated Time	for Completion:		
This JPM was [] Per	formed in the	[]	Control Room
[ ] Sim	ulated	[]	Plant
[ ] Oth	er **	[]	Simulator
		[]	Mockup
**	· · · · · · · · · · · · · · · · · · ·	[]	Other
EXAMINEE:	EVA	LUATO	R:
DATE:			
[ ] SATISFAC	TORY []	UNSAT	ISFACTORY
Comments:			
ADMIN1.1(9/14/98)/1			

Byron98EXAM

Specific Information:

- These items were used as reference material in the development of this JPM: 1BGP 100-7T1 (RRD); 1BGP 100-7T3; Curve Book BCB-1
- 2. These items are expected to be used by the examinee in the performance of the task: 1BGP 100-7T3; BCB-1
- 3. Information to the Examinee and the Evaluator:

a. Initial Conditions:

Unit 1 is performing a plant startup following a reactor trip 18 hours previous. Operation prior to the trip was for a period of 80 days at 100% power, following initial startup with current core (Cycle 9).

b. Task Initiating Condition:

1BGP 100-7T3 for the ESTIMATED CRITICAL CONDITION (ECC) for the plant startup in 2 hours has been completed. Current plant conditions and the most recent Reference Reactivity Data (RRD) worksheet are provided. The process computer is currently unavailable. The Critical Rod Position is desired at 138 steps on Control Bank D.

c. Initiating Cue:

The NSO has provided the completed copy of 1BGP 100-7T3 to you for review. Complete the review.

d. <u>Your Position</u>: US (Startup SRO, QNE)

ADMIN1.1(9/14/98)/2 Byron98EXAM Terminal Performance Objective: (TPO) Determine the provided ECC is incorrect:

4.

- The incorrect value for S/U rod worth is used for Desired Critical Position (HFP instead of HZP).
- Lower Administrative Threshold rod position and the -750 Administrative Limit rod position are adversely affected.
- 5. Critical Steps(\*) 12, 14, 16, 21, 22 (1BGP 100-7T3 Sections A.6.b, A.6.d, A.8, A.9.e, A.9.f, A.9.h and A.9.i.)
- 6. Identification of Impacted Systems: If this task is performed incorrectly, the following adverse reactions could occur: The reactor could be taken critical in conditions NOT allowed by the facility license.

PERFORMANCE CHECKLIST

STANDARDS

UN

N/A

RECORD START TIME

\*\*\*\*\*\* NOTE \* The candidate is to be supplied with the completed RRD \* (1BGP 100-7T1) and a blank copy of 1BGP 100-7T3. \*\*\*\*\*\*\*\*\* 1. Refer to 1BGP 100-7T3. Refer to 1BGP 100-7T3. 0 0 (May be done at any time.) Determine information 0 0 0 2. Review Admin Data. recorded correctly: (CUE: SU # - 98-2-ITEST0Unit 1 SU # - 98-2-<br/>ITESTStartup Date - TODAY0SU date 4 time - 2<br/>hrs from currentTime - 2 HOURS FROM<br/>CURRENT TIME0SU date 4 time - 2<br/>hrs from currentShutdown Date 4 Time<br/>- 18 HOURS BEFORE<br/>CURRENT TIME.)0SD date 4 time - 18<br/>hrs before currentO Time Interval since<br/>shutdown - 20 hrs shutdown - 20 hrs 0 0 0 3. Determine Change in Power Determines 100% power Defect. value for Power Defect from RRD: -1317 pcm Calculate difference: +1317 pcm. \*\*\*\* NOTE \* ITC at SU Tave & RCS Boron Conc. may be determined from \* BCB-1 Table 2-3 but is NO: required since Tave will NOT \* deviate from 557°F. Value at 1092 ppm (1717 EFPH) = -\* 8.8 pcm/°F. \*\*\*\*\* Determines temperature 0 0 4. Change in RCS Temperature. change reactivity: 0 pcm

ADMIN1.1(9/14/98)/4 Byron98EXAM

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	N/A
5. Change in Samariem.(BCB-1 Table 1-4)	Determine SU Samarium Worth of -1002 pcm. (20 hours after SD from 100% at 1717 EFPH)	۵		. 0
	Determine -919 pcm from RRD.			
	Calculate Difference Samarium: -83 pcm.			
<ol> <li>Change in Xenon. (BCB-1 Table 1-2 or Fig. 8c)</li> </ol>	Determine SU Xenon Worth of -3318 pcm. (20 hours after SD from 100% at 1717 EFPH)		٥	
	Determine -2982 pcm from RRD.			
	Calculate Difference Xenon: -336 pcm.			
7. Determine Overall Poisons.	Determine Overall Poisons: -419 pcm.	٥		٥
<ol> <li>Determine SD integral boron worth for RRD burnup, RRD RCS boro: Conc and HZP Tave. (BCB-1 Table 1-5)</li> </ol>	Interpolate and determine boron: -9349pcm (-9300 to -9400 pcm).	٥		
9. Determine Poison Correction Factor for Integral Boron Worth (BCB-1 Figure 8b calculation)	Determine Poison Correction factor: +0.888 (+0.887 to +0.889).	٥		
<ol> <li>Determine corrected poisons reactivity worths.</li> </ol>	Determine/calculate corrected poisons worths: -372 pcm.		٥	٥

Notify/Correct value of -215.6 pcm recorded.

ADMIN1.1(9/14/98)/5 Byron98EXAM

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	N/A
13. Record HFP inserted Rod Worth prior to Shutdown.	Determine -9.5 pcm from RRD recorded.		۵	
<ul> <li>* 14. Determine change in reactivity due to change in rod position.</li> </ul>	Determine total reactivity of -240.6 pcm instead of -206.1 pcm.			
15. Determine change in burnup correction.	Section is N/A per NOTE.			
* 16. Determine Reactivity Balance.	Determine reactivity worths recorded from appropriate Sections:			
	0 Power Defect (A.1) [+1317 pcm]			
	o Isothermal Temp. Defect (A.2) [0 pcm]			
	<pre>o Corrected Poisoning Defect (A.5.d) [-372 pcm]</pre>			
	<ul> <li>Rod Adjustments (A.6.d) [-240.6 pcm instead of -206.1 pcm]</li> </ul>			
	O Burnup correction (A.7.d) [0 pcm]			
	AND Determine difference of			

+704.4 pcm (+704 to +705 pcm) instead of +738.9 pcm.

ADMIN1.1(9/14/98)/6 Byron98EXAM

.

PERFORMANCE	CHECKLIST
-------------	-----------

.

1

.

## STANDARDS

RFO	RMANCE CHECKLIST	STANDARDS	SAT	UN SAT	<u>N/A</u>
17.	Def rmine Differential Bogrn Worth at assumed c i'ical boron concentration. (BCB-1 Table 2-4, Fig. 10A)	Determine Differential Boron Worth at 1100 ppm and 557°F: -8.82 pcm/ppm (-8.80 to -8.90 pcm/ppm).		D	
	**************************************	<u>NOTE</u> ctivity Balance value will a cal boron concentration. He atively insignificant, so the error is NOT Critical.	********* affect owever, hat the ********	***	
18.	Determine the change in RCS Boron needed.	Determine the boron concentration change of -80 ppm (-79 to -81 ppm) instead of -84 ppm.	0		۵
9.	Determine initial critical RCS Boron concentration.	Determine RCS boron concentration from RRD: +1010 ppm entered.			
		Determine calculated RCS boron change required: -80 ppm.			
		Determine critical boron concentration: 1090 ppm (1089 to 1091 ppm) instead of 1094 ppm.			
	**************************************	<u>NOTE</u> combine the steps of calcula values and determining the ank position. The procedure separately: Calculation of e determining the associated nk position.	********* ating the B f each of d	** * *	
	ANALUDICAN UUNCAUA DO	the management		+	

\*\*\*\*\*\*\*

ADMIN1.1(9/14/98)/7 Byron98EXAM

## PERFORMANCE CHECKLIST

20. Calculate +500 pcm inserted rod worth threshold. Determine corresponding Control Bank Upper Administrative Threshold position. (CBC-1 Table 1-8 or Fig 2D)

21. Calculate -500 pcm inserted rod worth threshold. Determine corresponding Control Bank Lower Administrative Threshold position. (CBC-1 Table 1-8 or Fig 2D)

22. Calculate -750 pcm inserted rod worth threshold. Determine corresponding Control Bank Upper Administrative Threshold position. (CBC-1 Table 1-8 or Fig 2D)

Rod Worth: -250.1 pcm.

Calculate -500 pcm worth: -750.1 pcm instead of -715.6.

### AND

Determine that minimum allowed value is 41 steps on CBD (37 to 45 steps) instead of 48 steps on CBD.

Determine/enter Desired Rod Worth: -250.1 pcm.

Calculate -750 pcm worth: -1000.1 pcm instead of -965.6.

## AND

Determine that minimum allowed value is 5 steps on CBD [OR 121 steps on CBC] (1 to 10 steps CBD OR 117 to 125 steps CBC) instead of 11 steps on CBD.

ADMIN1.1(9/14/98)/8 Byron98EXAM

Determine/enter Desired 

AND Determine that maximum

Calculate +500 pcm worth:

Determine/enter Desired

Rod Worth: -250.1 pcm.

+249.9 pcm instead of

STANDARDS

+284.4.

allowed value is full out park position on CBD (228 steps).

SAT

[]

N/A SAT

UN

## PERFORMANCE CHECKLIST

## 23. Complete Critical Condition Summary.

STANDARDS

N/A

Verify/correct the following information:

0 0

- Present boron conc
   1400 ppm
- e Est. Critical Boron conc: 1090 ppm (or value determined)
- o Est. Critical Bank position: CB D at 138 steps
- O Upper Admin Limit: CB D at 228 steps
- o Lower Admin Limit: CB D at 41 steps instead of 48
- o -750 pcm Admin Limit: CB D at 5 steps instead of 11

RECORD STOP TIME \_\_\_\_.

COMMENTS:

ADMIN1.1(9/14/98)/9 Byron98EXAM

## DATA SHEET

## CURRENT

.

.

RCS Boron concentration	-	1400 ppm
RCS temperature	-	557°F
RCS pressure	-	2235 psig
Power level	-	0%
Rod Position	•	All control and shutdown banks inserted
Time since trip	-	18 hours

Startup planned to occur in 2 hours

Desired	boron con	ncent	tration	-	110	00 ppm				
Desired	critical	rod	position	-	66	steps	withdrawn	on	CBD	
Desired	critical	RCS	temp	-	55	7°F				

## HISTORY

RRD Data taken at time of trip.

## TASK CONDITIONS:

1BGP 100-7T3 "Calculation Of Estimated Critical Condition Based On A Known Rod Position" has just been performed to provide the ESTIMATED CRITICAL CONDITION (ECC) for the plant startup. Current plant conditions and the most recent Reference Reactivity Data (RRD) worksheet are provided. The process computer is currently unavailable. The Critical Rod Position is desired at 138 steps on Control Bank D.

## INITIATING CUES:

The NSO has provided the completed copy of 1BGP 100-7T3 to you for review. Complete the review.

## DATA SHEET

#### CURRENT

RCS Boron concentration	-	1400 ppm
RCS temperature		557°F
RCS pressure	-	2235 psig
Power level		08
Rod Position	-	All control and shutdown banks inserted
Time since trip	-	18 hours

Startup planned	to occur in 2 h	ours		
Desired boron c	oncentration		1100 ppm	
Desired critica	l rod position	-	66 steps withdrawn on CE	D
Desired critica	l RCS temp	-	557°F	

## HISTORY

RRD Data taken at time of trip.

ADMIN1.1(9/14/98)/11 Byron98EXAM

\*, 2.c

File Location: 1.02.0128

CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION

**NOTE** IF this procedure is performed by an NSO, THEN this procedure shall be reviewed by a Qualified Nuclear Engineer; or IF this procedure is performed by a Qualified Nuclear Engineer, THEN this procedure shall be reviewed by an NSO. Typically, the Systems Engineering Dept. Nuclear Group should perform this procedure.

Unit 1 Startup Number	1998 -	02	- ITEST	
	YR -	SU#	- ECC#	
Startup Date/	/		Startup Time	<u>.</u>
Shutdown Date/ (From RRD Step F.2.a)	·/		Shutdown Time (From RRD Step	: F.2.a)

Time Interval Since Shutdown 20 Hours

NOTE

1BGP 100-7T3 can be used to manually calculate Critical Rod Position based on a known rod position. If a manual ECC for a Critical Rod Position based on a known boron concentration is required, use 1BGP 100-7T2. 1BGF 100-7T3 will be retained as plant documentation. DO NOT DISCARD. Forward completed form to the Systems Engineering Dept. Nuclear Group for review when no longer required on shift for reference. Upon completion of their review this form will be forwarded to Central File for permanent retention.

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

NOTE

When referencing graphs or tables, use <u>Hot Full Power</u> (HFP) data prior to shutdown and <u>Hot Zero Power</u> (HZP) data prior to startup. Also, verify data corresponds to the proper core burnup.

#### A. MANUAL CALCULATIONS

1. Change in Power Defect:

DETERMINE the startup and shutdown Power Defect values and their difference using RRD step 1.f or equivalent:

0	pcm -	(-) 1317 pcm	=	(+) 1317	pcm
Startup		Shutdown		Difference	
Power Defect		Power Defect (RRD Step 1.f)		Power Defect	

#### 2. Change in RCS Temperature:

DETERMINE the startup Isothermal Temperature Defect (ITD) value by multiplying the temperature deviation from program Tave by the Isothermal Temperature Coefficient (ITC) determined at the startup RCS Tave, and at the projected startup RCS Boron concentration with the aid of BCE-1 Table 2-3 or equivalent:

(	<u>557°F</u> ) *	-4,522 pcm/°F =	0	pcm
Expected	Program Tave	ITC at Expected	Startup	ITD
Tave at	at Startup	Startup Tave and		
Startup		RCS Boron		
		Concentration		

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

NOTE

During non-equilibrium Samarium conditions, different methods of predicting Samarium Worth should be consulted. If a different method (other than specified in this procedure) for determining Samarium Worth for Step A.3 is used, two QNE's shall concur.

3. Change in Samarium:

DETERMINE the startup and shutdown Samarium worth values and their difference at the applicable burnup, the Samarium Equivalent Power(s) and at the elapsed hours since shutdown with the aid of BCB-1 Table 1-4 or equivalent:

	Startup	
Applicable Burnup: (RRD Step 2.b)	1700	EFPH
Samarium Equivalent Power: (RRD Step 2.c)	100	*
Elapsed Time Since Shutdown:	20	hours
(-) $1002$ pcm - (-) $919$ pcm = (-)	83	_ pcm
Startup Shutdown Diffe	rence	

#### NOTE

(RRD Step 1.h)

During nonequilibrium Xenon conditions, different methods of predicting Xenon worth should be consulted. The empirical method of estimating Xenon Worth of Startup (36 hr weighted average) is only valid beyond approximately 16 hours after shutdown. If a different method (other than specified in this procedure) for determining Xenon Worth for Step A.4 is used, two QNE's shall concur.

\*, 2.1

(0645VV/WPF/110897)

-3-

1BGP 100-7T3 Revision 8

\*, 2.d

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

## NOTE

The Systems Engineering Dept. Nuclear Group shall verify that the Process/Prime inputs to the BEACON computer are accurate by performing BVP 500-14 and BVP 500-16 if the BEACON program is used to support ECC calculations.

4. Change in Xenon:

DETERMINE the startup and shutdown Xenon worth values and their difference at the applicable burnup, the Xenon Equivalent Power(s) and at the elapsed hours since shutdown with the aid of ECB-1 Table 1-2, Figure 8c, or equivalent:

Startup Shutdown Xenon Worth (RRD Step 1.i)	Diffe	arence	
(-) 3318 pcm - (-) 2982 pcm =		336	_ pcm
Elapsed Time Since Shutdown:		20	hours
Xenon Equivalent Power: (ERD Step 2.d)		100	8
Applicable Burnup: (RRD Step 2.b)		1700	EFPH
		Startup	

5. Change in Overall Poisons:

DETERMINE the change in poisons by correcting Xenon and Samarium with respect to RCS Boron.

a. DETERMINE the overall sum of poisons by adding the Samarium difference to the Xenon difference:

(-) 83	pcm	+	(-) 336	pcm	(-) 419	pcm
Samarium			Xenon		Overall	
Difference			Difference		Poisons	
(A.3)			(A.4)			

#### Facsimile

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

b. DETERMINE the shutdown Integral Boron Worth at the RRD Step 1.g burnup, the RRD Step 1.d RCS Boron concentration and HZP Tave with the aid of BCB-1 Table 1-5 or equivalent:

Integral Boron Worth: (-) 9349 pcm

c. DETERMINE the poison correction factor by substituting the Integral Boron Worth from step A.5.b into the equation shown on BCB-1 Figure 8b:

Poison Correction Factor: (+) 0,888

d. DETERMINE the corrected poisons reactivity worth from the original sum of Xenon and Samarium from step A.5.a multiplied by the determined correction factor from step A.5.c:

(-) 419	pcm *	(+) 0. 888 pcm	 (-) 372 pcm
Overall		Poison	Corrected
Poisons		Correction Factor	Overall Poisons
(A.5.a)		(A.5.c)	

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

6. Change in Rods:

DETERMINE the reactivity change due to adjustments in rod position.

#### NOTE

A control bank position of CBD withdrawn to at least 130 steps should be used as the desired control bank position for all ECCs. This will exchange rod worth for boron worth. There is less uncertainty associated with boron worth as compared with rod worth. Boron worth also changes less throughout core life when compared to rod worth. If plant conditions do not allow a choice of CBD position withdrawn to at least 130 steps, then the reason for the deviation shall be documented in Section D under the remarks. Either way, the CBD position SHALL be within 750 pcm of the fully withdrawn position.

\*, 2.c

a. RECORD the desired Control Bank position:

b. DETERMINE the desired Control Bank position worth recorded in step A.6.a at the RRD Step 2.b burnup with the aid of BCB-1 Table 1-8, Figure 2D, or equivalent:

Desired Control Bank Worth: (-) 215,6 pcm

c. RECORD the HFP inserted rod worth prior to shutdown from RRD step 1.c or equivalent:

HFP Inserted Rod Worth: (-) 9.5 pcm (RRD Step 1.c)

(0645VV/WPF/110897)

-6-

#### Facsimile

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

d. DETERMINE the change of reactivity due to the change in rod position by subtracting the HFP Inserted Rod Worth (A.6.c) from the Desired Inserted Rod Worth (A.6.b):

(-) 215.6 pcm	- (-) 9,5 pcm =	(-) 206. pcm
Desired Rod	HFP Inserted	Change in
Worth	Rod Worth	Rod Position
(A.6.b)	(A.6.C)	

### NOTE

If RRD Steps 1.g and 2.b contain the same burnup, step A.7 may be marked "N/A".

7. N/A Change in Burnup:

DETERMINE the calculation for correcting burnup.

 DETERMINE the RRD Step 1.g burnup design Boron concentration by using BCB-1 Figure 11 or equivalent:

Stable Reference Design Boron Concentration: \_\_\_\_/A\_\_ ppm

b. DETERMINE the RRD Step 2.b burnup design Boron concentration by BCB-1 Figure 11 or equivalent:

Final Power Operation Design Boron Concentration: N/A ppm

#### Facsimile

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

### NOTE

If BCB-1 Figure 10a, Table 2-4 does NOT contain HFP data, the FOLLOW code method for determining DBW at HFP would be the preferred method. Using HZP data will result in a DBW value -0.5 to -1.0 pcm/ppm more negative than a HFP value. For purposes of NSO Independent Verification of FOLLOW code output, Figure 10a may be used as a qualitative check against the attached FOLLOW code output.

- c. DETERMINE the Differential Boron Worth (DBW) of the RRD Step 1.g Burnup and RRD Step 1.d Boron Concentration by one of the following methods (circle method used):
  - 1). Figure 10a, Table 2-4, or equivalent
  - 2). FOLLOW Code Output (attach copy of output)

Differential Boron Worth = (-) N/4 pcm/ppm

d. DETERMINE the burnup correction by subtracting the Final Power Operation Design Boron Concentration (A.7.b) from the Stable Reference Design Boron Concentration (A.7.a) and multiplying by the Differential Boron Worth (A.7.c):

Stable ppm -	N/A ppm] ' Final Power	$\frac{N/A}{DBW} pcm/ppm = DBW (A.7.c)$	()N/A pcm Burnup
Reference	Operation		Correction
Design Boron	Design		
Concentration	Boron		
(A.7.a)	Concentration		
	(A.7.b)		

(0645VV/WPF/110897)

- 8 -

8.

#### Facsimile

1BGP 100-7T3 Revision 8

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

DETERMINE the Reactivity Balance by summing the	following value	es:
Power Defect (A.1)	(+) 1317	pcm
Isothermal Temperature Defect (A.2)	() 0	pcm
Corrected Poisoning Defect (A.5.d)	(-) 372	pcm
Rod Adjustments (A.6.d)	(-) 206.1	pcm
Burnup Correction (A.7.d) +	() 0	pcm

REACTIVITY BALANCE (TT 738.9 pcm

9. Determination of Critical RCS Boron:

**NOTE** This section may need to be repeated if the assumed critical Boron Concentration for step A.9.a differs from that determined in step A.9.c.

a. DETERMINE the Differential Boron Worth at the RRD Step 2.b burnup, assumed critical RCS Boron concentration, and at the startup RCS Tave with the aid of BCB-1 Table 2-4, Figure 10A, or equivalent:

Differential Boron Worth: (-) 8.82 pcm/ppm

b. DETERMINE the change in RCS Boron needed by dividing the Reactivity Balance in step A.8 by the Differential Boron Worth in step A.9.a:

() 738,9 pc	m /	(-) 8.82 pcm/ppm	(-) 84	ppm
Reactivity		Differential	Change in RCS	
Balance (A.8)		Boron Worth	Boron	
		(A.9.a)		

(0645VV/WPF/110897)

-9-

#### Facsimile

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

c. DETERMINE the critical RCS Boron concentration by adding the change in RCS Boron step A.9.b to the RRD step 1.d Boron Concentration:

 $\frac{(4) / 0 / 0}{\text{RCS Boron at}} \text{ ppm} - \underbrace{(-) 84}_{\text{Change in RCS}} \text{ ppm} = \underbrace{1094}_{\text{Critical RCS Boron}} \text{ ppm}$ RRD Step 1.d Boron (A.9.b)

\* d.

CALCULATE the + 500 pcm inserted rod worth threshold:

(-) 215.6 pcm + 500 pcm = (+) 284.4 pcm Desired Rod worth (A.6.b)

\* e. CALCULATE the - 500 pcm inserted rod worth threshold:

(-) 215.6 pcm - 500 pcm = (-) 71.5.6 pcm Desired Rod worth (A.6.b)

f. CALCULATE t.e (-) 750 pcm inserted rod worth limit:

$$(-)$$
 215.6 pcm - 750 pcm = (-) 965.6 pcm  
Desired Rod worth  
(A.6.b)

\* g. DETERMINE the control bank position corresponding to the Upper Administrative Threshold by using BCB-1, Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.d at the RRD Step 2.b burnup. Do not exceed the full-out park position on Control Bank D:

Upper Administrative Threshold: CB D at 228 steps

\*, 2.c

\*, 2.c

\*, 2.c

\* h. DETERMINE the control bank position corresponding to the Lower Administrative Threshold by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.e at the RRD Step 2.b burnup. Do not use a position below 47 steps on Control Bank C:

(0645VV/WPF/110897)

-10-

1

E

E

Facsimile

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

- DETERMINE the control bank position corresponding to the -750 Administrative Limit by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.f at the RRD Step 2.b burnup. Do not use a position below 47 steps on Control Bank C:
  - 750 pcm Administrative Limit: CB D at 11 steps

## NOTE

Notify the Duty Station Manager if the hand calculated ECC differs by more than 250 pcm from the BEACON generated ECC (if BEACON is used). Station Duty Officer concurrence is required before proceeding with the startup.

\*, 2.f

З.	ESTIMATED	CRITICAL	CONDITION	SUMMARY

	Present Boro Estimated Cr Estimated Cr	n Concentration itical Boron Concent itical Bank Position	rati CB	2 pp lon 12 D	at	ppm (A.	9.c) steps	(A.6.a)	
	* Upper Admini	strative Threshold:	CB	D	at _	228	_ steps	(A.9.g)	*, 2.c
	* Lower Admini	strative Threshold:	CB	2	at	4.8	_ steps	(A.9.h)	*, 2.c
	- 750 pcm Admi	nistrative Limit:	CB	$\mathcal{P}$	at _	11	steps	(A.9.i)	
cc	performed by _	NAME		DATE	_ (NSC	), Quali:	fied Nu	clear En	gineer)
cc	reviewed by _	NAME		DATE	(NSC	), Quali	fied Nu	clear En	ginæer)

\* Complete the "ECC parameters" placard and give to the Startup NSO.

\*, 2.c

1\_\_\_\_ Startup SRO

(0645VV/WPF/110897)

-11-

\*, 2.c

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

C. ESTIMATED CRITICAL POSITION FROM COUNTS INCREASING EIGHTFOLD

A 1/M plot shall be maintained during startup.

NOTE

Any difference between the estimated time and the actual time for criticality could impact the final critical position. Contact Systems Engineering Dept. Nuclear Group to estimate the magnitude of this effect.

1. Base Count Rate With Shutdown Banks Out \_\_\_\_\_ cps.

Source Range Channel N \_\_\_\_\_.

- Counts Increase Eightfold at Control Bank \_\_\_\_\_ at \_\_\_\_steps.
- 3. Predicted Critical Position From BCB-1, Figure 9.

Control Bank \_\_\_\_\_ at \_\_\_\_ steps.

4. ENSURE the predicted Critical Control Bank Position in C.3 is ABOVE the Rod Insertion Limit (i.e. CBC is greater than 47 steps withdrawn) and - 750 pcm Administrative Limit. If not, DO NOT PROCEED WITH APPROACH TO CRITICALITY. The RCS Boron Concentration must be increased and the ECC recalculated.

5. ENSURE the predicted Critical Control Bank Position in C.3 is within the ± 500 pcm Administrative Threshold. If not, Shift Manager and Qualified Nuclear Engineer concurrence is required to proceed with the reactor startup.

QNE Date Time SRO Date Time

1BGP 100-7T3 Revision 8

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

## NOTE

If the predicted critical bank position is not above the - 750 pcm administrative limit, then re-insert all Control Bank rods until the Systems Engineering Dept. Nuclear Group documents an evaluation in Section D under remarks and concurs to bring the reactor critical. A new ECC may be performed.

\*, 2.c

6.	RECORD	the	following	, ir	nform	ation	if	cri	ticality	is	achi	eved	and
	power i Channel	s s	tabilizeđ	at	10-*	amps	on	the	highest	rea	ding	IR	

a	Actual Time	ot Critical Data.		
b.	Actual Criti	cal Bank Position.	CB at step	s
c.	Actual Criti	ical Boron Concentra	ation. pp	m

d. Actual Temperature at time of Criticality. OF

------

D.

REMARKS :

NUCLEAR DATE GROUP

(0645VV/WPF/110897)

-13-

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

E. MARGIN TO CRITICALITY WITH SHUTDOWN BANKS WITHDRAWN

# $\frac{\text{NOTE}}{\text{The purpose of this section is to ensure:}}$

1.	The basis to the BDPS Analysis is met (- 1300 pcm
2.	Shutdown), and An inadvertent Mode Change does not occur (K <sub>eff</sub> < 0.99).

 DETERMINE the Total Control Bank Worth (CBA @ 0 steps) at the RRD Step 2.b burnup with the aid of BCB-1 Table 1-8, Figure 2A, or equivalent:

Total Control Bank Worth: (-) pcm

	NOTE									
The	follo	wing	step	takes	into	account	500	pcm	uncertainty	on
the	ECC C	alcul	ation	for	conser	rvatism.				

 DETERMINE the Required Boron Reactivity to satisfy the Margin to Criticality by completing the following arithmetic:

Total Control Bank Worth (E.1):	+ (-)		pcm
Control Bank Required Reactivity (A.6.b):	- (-)	-	pcm
Bounding Margin to Criticality:	- (-)	1300	pcm
Conservatism:	•	500	pcm
Required Boron Reactivity	= ( )	2344.49944.40944.44944.449454.4	pcm

• •

1 .

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

5. If the answer in Step E.4.b is "NO", DO NOT withdraw Shutdown Banks until the RCS Boron Concentration is greater than or equal to the Minimum RCS Boron Concentration calculated in Step E.3.b.

SRO Date Time

(Final)

-16-

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

- Determination of the Minimum RCS Boron Concentration which satisfies the Margin to Criticality:
  - a. DETERMINE the difference between the RCS Boron Concentration necessary to meet the Margin to Criticality requirements and the ECC Boron Concentration by dividing the Required Boron Reactivity calculated in Step E.2 by the Differential Boron Worth in Step A.9.a:

() ppm / (-)	pcm/ppm =	() ppm
Required Boron	Differential Boron	Difference in
Reactivity	Worth (A.9.a)	RCS Boron
(E.2)		Concentration

b. DETERMINE THE Minimum RCS Boron Concentration necessary to meet the Margin to Criticality requirements by subtracting the difference in RCS Boron Concentration calculated in Step E.3.a from the ECC Boron Concentration:

() ppr	n -	() ppm	() ppm
ECC Boron		Difference in	Minimum Required
Concentration		RCS Boron	RCS Boron
(A.9.c)		Concentration (E.3.a)	Concentration

- 4. VERIFY Sufficient Margin to Criticality:
  - RECORD the present RCS Boron Concentration from the most recent Boron sample:

Drecent DCC	Campio Trimo	Date
Fresent Rus	Squibre Line	Date
Boron		
Concentration		

 b. Is the present RCS Boron Concentration GREATER THAN OR EQUAL TO the Minimum RCS Boron Concentration calculated in Step E.3.b? (Circle one)

1

YES NO

(0645VV/WPF/110897)

-15-

#### APPROVED 07/14/97

Facsimile

File Location: 1.02.0128

REFERENCE REACTIVITY DATA WORKSHEET

NOTE This worksheet will be retained as plant documentation. DO NOT DISCARD. Forward completed form to the Operating Staff when no longer required on shift for reference.

Unit One Startup Number S/U# RRD# Year

Stable Reference Reactivity Data 1.

> NOTE The data recorded in Step 1 shall be data from a stable core condition. Contact the Nuclear Group for assistance, if necessary. An exception to the stability criteria would be if this RRD were for a recent reactor startup.

20 houis prior 1.a. Reference Date: \_\_\_\_\_\_ Reference Time: \_\_\_\_\_\_\_ to currentime ) 1.a. Reference Date: \_\_\_\_\_\_ Reference Time: \_\_\_\_\_\_

1.b. Control Bank D at 213 steps.

\* 1.c. Inserted Control Bank Worth

BCB-1 Table 1-7, Figure 2, Figure 2C, or equivalent (-) 9.5 pcm

\* 1.d. Critical Boron Concentration from (CIRCLE mode of analysis used):

1). Accurate sample at a recent known stable condition,

2). Calculated by the Qualified Nuclear Engineer

(Attach calculations, logs, point history used)

· CB = 1010 ppm Time/Date: \_\_\_\_ (24 hours prior to)

1.e. Reference power level from BURP:

Stable Power: 100 %

(1403VV/WPF/062497)

-1-

REFERENCE REACTIVITY DATA WORKSHEET (continued)

1.f. Total Power Defect from:

BCB-1 Figure 17A. Table 2-1, or equivalent (-) /3/7 pcm

1.g. RECORD accumulated core average burnup from BURP:

Core Average Burnup: 17.00 EFPH

	~	2024	-
- 15.1		rp,	w
7.4	$\sim$		متكل
-	-		

If this RRD is being performed to reference a recent reactor startup, obtain the Samarium Worth from the applicable ECC Step 3 for Startup Samarium Worth or 1BVS XPT-13, as applicable. N/A the Samarium Equivalent Power.

1.h. Equivalent Power for Samarium Calculation from (BURP and Samarium Worth):

Sm Eq. PWR = Unweighted average power over 5 days (120 hrs)

Sm Eq. PWR = 100 %

Sm Worth from BCB-1 Table 1-4 or equivalent at 0 hrs after shutdown (-) 919 pcm

NOTE

If this RRD is being performed to reference a recent reactor startup, obtain the Xe Worth from the applicable ECC Step 4 for Startup Xenon Worth or 1BVS XPT-13, as applicable.

 Determine the Kenon Worth from power in Step 1.e and BCB-1 Figure 8c; Table 1-2, or equivalent:

Xe Worth (-) 2982-pcm

(1403VV/WPF/062497)

## REFERENCE REACTIVITY DATA WORKSHEET (continued)

2. Final Power Operation Reference Reactivity Data:

**NOTE** The data recorded in Step 2 shall include the operating history of the reactor until it is shutdown. If the reactor tripped from a stable condition, record the applicable data from Step 1 into Step 2.

to current time .a. Reference Date: \_\_\_\_

Reference Time:

2.b. RECORD accumulated core average burnup from BURP:

Core Average Burnup: 1700 EFPH

2.c. Equivalent Power for Samarium Calculation from BURP:

Sm Eq. PWR = Unweighted average power over 5 days (120 hrs)

Sm Eq. PWR = 100 %

2.d. Determine the Equivalent Power for Xenon Calculation from BURP or equivalent:

(1403VV/WPF/062497)

.

## REFERENCE REACTIVITY DATA WORKSHEET (continued)

## 2.d. (continued)

Hours Prior to	Average Power			
Shutdown	(%)	Multiplier		Product
0 to 1	100	хб	=	600
1 to 2	100	x 5	22	500
2 to 3	100	x 5		500
3 to 4	100	x 5	2	500
4 to 5	100	x 4	=	400
5 to 6	100	x 4	=	400
6 to 7	100	x 4	=	400
7 to 8	100	x 4	=	400
8 to 9	100	x 4	=	400
9 to 10	100	x 3	=	300
10 to 11	100	x 3	=	300
11 to 12	100	x 3	=	300
12 to 13	100	x 3	=	300
13 to 14	100	x 3	#	300
14 to 15	100	x 3	=	300
15 to 16	100	x 3	=	300
16 to 17	100	x 2	=	200
17 to 18	100	x 2	=	200
18 to 19	100	x 2	22	200
19 to 20	100	x 2	2	200
20 to 21	100	x 2	=	200
21 to 22	100	x 2	=	200
22 to 23	100	x 2	=	2.00
23 to 24	100	x 2	=	200
24 to 25	100	x 2	=	. 200
25 to 26	106	x 1		100
26 to 27	100	x 1	2	100
27 to 28	100	x 1	m	100
28 to 29	100	x 1		100
29 to 30	100	x 1	=	100
30 to 31	100	x 1	=	100
31 to 32	100	x 1	=	100
32 to 33	100	x 1	#	100
33 to 34	100	x 1	=	100
34 to 35	100	x 1		100
35 to 36	100	x 1	=	100

TOTAL = 9100

(1403VV/WPF/062497)

APPROVED 07/14/97

Facsimile

REFERENCE REACTIVITY DATA WORKSHEET (continued)

2.d. (continued)

Equivalent Power for Xenon =  $Total = \frac{9/00}{91}$  91

Xe Eq. FWR: 100 %

Remarks: \_None

### NOTE

IF this procedure is performed by an NSO, THEN this procedure shall be reviewed by a Qualified Nuclear Engineer; or, IF this procedure is performed by a Qualified Nuclear Engineer, THEN this procedure shall be reviewed by the NSO. Typically, this procedure should be prepared by the Systems Engineering Dept. Nuclear Group. An independent member of the SED Nuclear Group should review the assumptions and calculations of the RRD for accuracy.

Performed	by:		1	(NSO,	Qualified	Nuclear	Engineer)
		Name	Date				
Reviewed	by:		/	(NSO,	Qualified	Nuclear	Engineer)
		Nam	Date				
5	SRO:		1				
		Name	Date				

(Final)

(1403VV/WPF/062497)

-5-

1BGP 100-7T3 Revision 8

\*, 2.0

File Location: 1.02.0128

CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION

Facsimile

**NOTE** IF this procedure is performed by an NSO. THEN this procedure shall be reviewed by a Qualified Nuclear Engineer; or. IF this procedure is performed by a Qualified Nuclear Engineer. THEN this procedure shall be reviewed by an NSO. Typically, the Systems Engineering Dept. Nuclear Group should perform this procedure.

Unit 1 Startup Number	1998	-	02	- ITEST	
	YR		SU#	- ECC#	
(Todaci's date + 2 hours for consistantup Date	/	_/		Startup Time	4
(Current -18 hours hutdown Date (From RRD Step F.2.a)	/	_/		Shutdown Time (From RRD Step	: F.2.a)

Time Interval Since Shutdown 20 Hours

NOTE

1BGP 100-7T3 can be used to manually calculate Critical Rod Position based on a known rod position. If a manual ECC for a Critical Rod Position based on a known boron concentration is required, use 1BGP 100-7T2. 1BGP 100-7T3 will be retained as plant documentation. DO NOT DISCARD. Forward completed form to the Systems Engineering Dept. Nuclear Group for review when no longer required on shift for reference. Upon completion of their review this form will be forwarded to Central File for permanent retention.

(0645VV/WPF/110897)

.....

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

**NOTE** When referencing graphs or tables, use <u>Hot Full Power</u> (HFP) data prior to shutdown and <u>Hot Zero Power</u> (HZP) data prior to startup. Also, verify data corresponds to the proper core burnup.

## A. MANUAL CALCULATIONS

1. Change in Power Defect:

DETERMINE the startup and shutdown Power Defect values and their difference using RRD step 1.f or equivalent:

0	pcm -	1-11317 1	pcm =	(+) 1317	pcm
Startup Power Defect		Shutdown Power Defect (RRD Step 1.f)		Difference Power Defect	

#### 2. Change in RCS Temperature:

DETERMINE the startup Isothermal Temperature Defect (ITD) value by multiplying the temperature deviation from program Tave by the Isothermal Temperature Coefficient (ITC) determined at the startup RCS Tave, and at the projected startup RCS Boron concentration with the aid of BCB-1 Table 2-3 or equivalent:

557 °F -	<u>557°F</u> ) *	$-4.522  \text{pcm/}^{\circ}\text{F} =$	_0_	pcm
Expected	Program Tave	ITC at Expected	Startup	ITD
Tave at	at Startup	Startup Tave and		
Startup		RCS Boron		
		Concentration		

#### Facsimile

1BGP 100-7T3 Revision 8

## CALCULATION OF ESTIMATEL CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

NOTE During non-equilibrium Samarium conditions, different methods of predicting Samarium Worth should be consulted. If a different method (other than specified in this procedure) for determining Samarium Worth for Step A.3 is used, two QNE's shall concur.

3. Change in Samarium:

DETERMINE the startup and shutdown Samarium worth values and their difference at the applicable burnup, the Samarium Equivalent Power(s) and at the elapsed hours since shutdown with the aid of BCB-1 Table 1-4 or equivalent:

StartupShutdownDiffeSamarium WorthSamarium WorthSamar(RED Step 1 h)Samarium	rence	
(-) 1002 pcm - $(-)$ 919 pcm = $(-)$	83	_ pcm
Elapsed Ti 3 Since Shutdown:	20	hours
Samarium Equivalent Power: (RRD Step 2.c)	100	. 8
Applicable Burnup: (RRD Step 2.b)	1700	EFPH
	Startup	

## NOTE

During nonequilibrium Xenon conditions, different methods of predicting Xenon worth should be consulted. The empirical method of estimating Xenon Worth of Startup (36 hr weighted average) is only valid beyond approximately 16 hours after shutdown. If a different method (other than specified in this procedure) for determining Xenon Worth for Step A.4 is used, two QNE's shall concur.

\*, 2.1

1BGP 100-7T3 Revision 8

\*, 2.d

## CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

#### NOTE

The Systems Engineering Dept. Nuclear Group shall verify that the Process/Prime inputs to the BEACON computer are accurate by performing BVP 500-14 and BVP 500-16 if the BEACON program is used to support ECC calculations.

4. Change in Xenon:

DETERMINE the startup and shutdown Xenon worth values and their difference at the applicable burnup, the Xenon Equivalent Power(s) and at the elapsed hours since shutdown with the aid of BCB-1 Table 1-2, Figure 8c, or equivalent:

Xenon Worth (RRD Step 1.i)	Xenon	
(-) 3318 pcm - (-) 2982 pcm =	(-) <u>336</u>	_ pcm
Elapsed Time Since Shutdown:	_20	hours
Xenon Equivalent Power: (RRD Step 2.d)	100	8
Applicable Burnup: (RRD Step 2.b)	1700	EFPH
	Startup	

5. Change in Overall Poisons:

DETERMINE the change in poisons by correcting Xenon and Samarium with respect to RCS Boron.

a. DETERMINE the overall sum of poisons by adding the Samarium difference to the Xenon difference:

(-) <u>83</u> Samarium	pcm	+	(	pcm	=	(-) 419 Overall	pcm
Difference			Difference			Poisons	
(A.3)			(A.4)				

## (0645VV/WPF/110897)

-4-
#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

b. DETERMINE the shutdown Integral Boron Worth at the RRD Step 1.g burnup, the RRD Step 1.d RCS Boron concentration and HZP Tave with the aid of BCB-1 Table 1-5 or equivalent:

Integral Boron Worth: (-) 9349 pcm

c. DETERMINE the poison correction factor by substituting the Integral Boron Worth from step A.5.b into the equation shown on BCB-1 Figure 8b:

Poison Correction Factor: (+) 0.888

d. DETERMINE the corrected poisons reactivity worth from the original sum of Xenon and Samarium from step A.5.a multiplied by the determined correction factor from step A.5.c:

(-) 419	pcm *	(+) 0.888 pcm	=	(-) 372 pcm
Overall		Poison		Corrected
Poisons		Correction Factor		Overall Poisons
(A.5.a)		(A.5.c)		

(0645VV/WPF/110897)

#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

6. Change in Rods:

> DETERMINE the reactivity change due to adjustments in rod position.

#### NOTE

A control bank position of CBD withdrawn to at least 130 steps should be used as the desired control bank position for all ECCs. This will exchange rod worth for boron worth. There is less uncertainty associated with boron worth as compared with rod worth. Boron worth also changes less. throughout core life when compared to rod worth. If plant conditions do not allow a choice of CBD position withdrawn to at least 130 steps, then the reason for the deviation shall be documented in Section D under the remarks. Either way, the CBD position SHALL be within 750 pcm of the fully withdrawn position.

\*, 2.c

RECORD the desired Control Bank position: a.

Value taben Fron<sup>b.</sup> DETERMINE the desired Control Bank position in step A.6.a at the RRD Step 2.b burnup with BCB-1 Table 1-8, Figure 2D, or equivalent: in Stead of Table Desired Control De DETERMINE the desired Control Bank position worth recorded in step A.6.a at the RRD Step 2.b burnup with the aid of

Actual value 250.1

RECORD the HFP inserted rod worth prior to shutdown from RRD step 1.c or equivalent:

DCM

(0645VV/WPF/110897)

1-8, HZPCUTVE

#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION EASED ON A KNOWN ROD POSITION (continued)

d. DETERMINE the change of reactivity due to the change in rod position by subtracting the HFP Inserted Rod Worth (A.6.c) from the Desired Inserted Rod Worth (A.6.b):

Desired Rod	H	FP Inserted	Change in
Worth	R	od Worth	Rod Position ~
(A.6.b)	(	A.6.C)	

NOTE

If RRD Steps 1.g and 2.b contain the same burnup, step A.7 may be marked "N/A".

7. Change in Burnup:

DETERMINE the calculation for correcting burnup.

a. DETERMINE the RRD Step 1.g burnup design Boron concentration by using BCB-1 Figure 11 or equivalent:

Stable Reference Design Boron Concentration: N/A ppm

b. DETERMINE the RRD Step 2.b burnup design Boron concentration by BCB-1 Figure 11 or equivalent:

Final Power Operation Design Boron Concentration: N/A ppm

(0645VV/WPF/110897)

-7-

#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

#### NOTE

If BCB-1 Figure 10a, Table 2-4 does NOT contain HFP data, the FOLLOW code method for determining DBW at HFP would be the preferred method. Using HZP data will result in a DBW value -0.5 to -1.0 pcm/ppm more negative than a HFP value. For purposes of NSO Independent Verification of FOLLOW code output, Figure 10a may be used as a qualitative check against the attached FOLLOW code output.

- c. DETERMINE the Differential Bor n Worth (DBW) of the RRD Step 1.g Burnup and RRD Step 1.d Boron Concentration by one of the following methods (circle method used):
  - 1). Figure 10a, Table 2-4, or equivalent
  - 2). FOLLOW Code Output (attach copy of output)

Differential Boron Worth = (-) N/H pcm/ppm

d. DETERMINE the burnup correction by subtracting the Final Power Operation Design Boron Concentration (A.7.b) from the Stable Reference Design Boron Concentration (A.7.a) and multiplying by the Differential Boron Worth (A.7.c):

NIA ppm] *	NA pcm/ppm = DBW (A.7.c)	= () N/A pcm Burnap
ration		Correction
ign		
on		
centration		
	Al Power ration ign con centration 7, b)	NA ppm] * NA pcm/ppm = al Power DBW (A.7.c) ration ign con centration 7.b)

(0645VV/WPF/110897)

Facsimile

1BGP 100-7T3 Revision 8

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

8. DETERMINE the Reactivity Balance by summing the following values:

Power Defect (A.1)	(+) 1317	pcm
Isothermal Temperature Defect (A.2)	() O F	pcm
Corrected Poisoning Defect (A.5.d)	(-) <u>372</u> F	pcm
Rod Adjustments (A.6.d)	IT 206.1 E	pcm
Burnup Correction (A.7.d)	+ () 0 5	pcm

REACTIVITY BALANCE (+) 7.38.9 pcm

704.4

9. Determination of Critical RCS Boron:

**NOTE** This section may need to be repeated if the assumed critical Boron Concentration for step A.9.a differs from that determined in step A.9.c.

a. DETERMINE the Differential Boron Worth at the RRD Step 2.b burnup, assumed critical RCS Boron concentration, and at the startup RCS Tave with the aid of BCB-1 Table 2-4, Figure 10A, or equivalent:

Differential Boron Worth: (-) 8.82 pcm/ppm

b. DETERMINE the change in RCS Boron needed by dividing the Reactivity Balance in step A.8 by the Differential Boron Worth in step A.9.a:

(+) 738.9 pcm	(-) 8.82 pcm/ppm	n = )	(-) 8	4	ppm
Reactivity	Differential	(	Change	in RCS	
Balance (A.8)	Boron Worth	1	Boron	E	
	(A.9.a)				

(0645VV/WPF/110897)

#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

c. DETERMINE the critical RCS Boron concentration by adding the change in RCS Boron step A.9.b to the RRD step 1.d Boron Concentration:

$$\begin{array}{c|c} (+) \ 1010 \\ \hline \text{RCS Boron at} \\ \hline \text{RRD Step 1.d} \end{array} \quad ppm - \ (-) \ 84 \\ \hline \text{Change in RCS} \\ \hline \text{Boron (A.9.b)} \\ \hline \ 1090 \\ \hline \ 1090 \\ \hline \end{array}$$

\* d.

CALCULATE the + 500 pcm inserted rod worth threshold:

$$\frac{(-) \ 215.6}{\text{Desired Rod worth}} \text{ pcm} + 500 \text{ pcm} = (+) \ 284.4 \text{ pcm} \\ 249.9 \text{ (A.6.b)}$$

\* e. CALCULATE the - 500 pcm inserted rod worth threshold:

 $\frac{(-) \ 215.6}{\text{Desired Rod worth}} \ pcm - 500 \ pcm = (-) \ 715.6 \ pcm \\ 750.1$ 

f. CALCULATE the (-) 750 pcm inserted rod worth limit:

 $\frac{(-) 215.6}{\text{Desired Rod worth}} \text{ pcm} - 750 \text{ pcm} = (-) 965.6 \text{ pcm} \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.0 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 1000.1 \\ 100$ 

\* g. DETERMINE the control bank position corresponding to the Upper Administrative Threshold by using BCB-1. Table 1-8. Figure 2D, or equivalent and the value obtained in Step A.9.d at the RRD Step 2.b burnup. Do not exceed the full-out park position on Control Bank D:

Upper Administrative Threshold: CB D at 228 steps

\*, 2.c

\*, 2.c

\*, 2.c

\* h. DETERMINE the control bank position corresponding to the Lower Administrative Threshold by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.e at the RRD Step 2.b burnup. Do not use a position below 47 steps on Control Bank C:

(0645VV/WPF/110897)

-10-

Facsimile

1BGP 100-7T3 Revision 8

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

 DETERMINE the control bank position corresponding to the -750 Administrative Limit by using BCB-1 Table 1-8, Figure 2D, or equivalent and the value obtained in Step A.9.f at the RRD Step 2.b burnup. Do not use a position below 47 steps on Control Bank C:

- 750 pcm Administrative Limit: CB D at \_\_\_\_\_

#### NOTE

Notify the Duty Station Manager if the hand calculated ECC differs by more than 250 pcm from the BEACON generated ECC (if BEACON is used). Station Duty Officer concurrence is required before proceeding with the startup.

\*, 2.f

steps

5

В.	ESTIMATED CR	ITICAL CONDITION SUM	ARY						
	Present Bord Estimated Cr Estimated Cr	n Concentration itical Boron Concentr itical Bank Position	40 rati CB		294 at	ppm (A.9 138	).c) steps	(A.6.a)	
	* Upper Admini	strative Threshold:	СВ	D	. at	2.28	steps	(A.9.g)	*, 2.c
	* Lower Admini	strative Threshold:	СВ	D	at _	48	steps	(A.9.h)	*, 2.0
	- 750 pcm Admi	nistrative Limit:	СВ	D	at	_11	steps	(A.9.i)	
*ECC	performed by _	NAME		DATE	_ (NSC	), Qualif	fied Nuc	clear En	igineer)
ECC	reviewed by _	NAME		DATE	_ (NSC	), Qualif	fied Nuc	clear Er	gineer)

\* Complete the "ECC parameters" placard and give to the Startup NSO.

\*, 2.c

\_/\_\_\_ Startup SRO

(0645VV/WPF/110897)

-11-

\*

#### Facsimile

\*, 2.c

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

C. ESTIMATED CRITICAL POSITION FROM COUNTS INCREASING EIGHTFOLD

NOTE A 1/M plot shall be maintained during startup.

#### NOTE

Any difference between the estimated time and the actual time for criticality could impact the final critical position. Contact Systems Engineering Dept. Nuclear Group to estimate the magnitude of this effect.

Base Count Rate With Shutdown Banks Out \_\_\_\_\_ cps. 1.

Source Range Channel N

Counts Increase Eightfold at Control Bank \_\_\_\_\_ at \_\_\_\_steps. 2.

Predicted Critical Position From BCB-1, Figure 9. 3.

Control Bank \_\_\_\_\_ at \_\_\_\_ steps.

ENSURE the predicted Critical Control Bank Position in C.3 is 4. ABOVE the Rod Insertion Limit (i.e. CBC is greater than 47 steps withdrawn) and - 750 pcm Administrative Limit. If not, DO NOT PROCEED WITH APPROACH TO CRITICALITY. The RCS Boron Concentration must be increased and the ECC recalculated.

SRO Date Time

ENSURE the predicted Critical Control Bank Position in C.3 is 5. within the ± 500 pcm Administrative Threshold. If not, Shift Manager and Qualified Nuclear Engineer concurrence is required to proceed with the reactor startup.

QNE Date Time SRO Date Time

(0645VV/WPF/110897)

\*

#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

#### NOTE

If the predicted critical bank position is not above the - 750 pcm administrative limit, then re-insert all Control Bank rods until the Systems Engineering Dept. Nuclear Group documents an evaluation in Section D under remarks and concurs to bring the reactor critical. A new ECC may be performed.

\*, 2.c

6.	RECORD	the	following	i in	nform	ation	if	cri	ticality	is	achi	eved	and
	power i Channel	s st	abilized	at	10-9	amps	on	the	highest	rea	ding	IR	

a.	Actual	Time	of	Critical	Data.	

- b. Actual Critical Bank Position. CB \_\_\_\_\_ at \_\_\_\_\_ steps
- c. Actual Critical Boron Concentration. ppm
- d. Actual Temperature at time of Criticality. \_\_\_\_\_ •F

D. REMARKS :

NUCLEAR DATE GROUP

(0645VV/WPF/110897)

-13-

Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

E. MARGIN TO CRITICALITY WITH SHUTDOWN BANKS WITHDRAWN

# NOTE The purpose of this section is to ensure: 1. The basis to the BDPS Analysis is met (- 1300 pcm Shutdown), and 2. An inadvertent Mode Change does not occur (K<sub>eff</sub> < 0.99).</td>

 DETERMINE the Total Control Bank Worth (CBA @ 0 steps) at the RRD Step 2.b burnup with the aid of BCB-1 Table 1-8, Figure 2A, or equivalent:

Total Control Bank Worth: (-) pcm

				N	OTE				
The	following	step	takes	into	account	500	pcm	uncertainty	on
the	ECC calcul	lation	n for	conser	rvatism.				

 DETERMINE the Required Boron Reactivity to satisfy the Margin to Criticality by completing the following arithmetic:

Total Control Bank Worth (E.1):	+ (-)		pcm
Control Bank Required Reactivity (A.6.b):	- (-)		pcm
Bounding Margin to Criticality:	- (-)	1300	pcm
Conservatism:	•	500	pcm
Required Boron Reactivity	= ( )		pcm

(0645VV/WPF/110897)

-14-

Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

- Determination of the Minimum RCS Boron Concentration which satisfies the Margin to Criticality:
  - a. DETERMINE the difference between the RCS Boron Concentration necessary to meet the Margin to Criticality requirements and the ECC Boron Concentration by dividing the Required Boron Reactivity calculated in Step E.2 by the Differential Boron Worth in Step A.9.a:

() ppm / (-) Required Boron	pcm/ppm = Differential Boron	() ppm Difference in
Reactivity	Worth (A.9.a)	RCS Boron
(E.2)		Concentration

b. DETERMINE THE Minimum RCS Boron Concentration necessary to meet the Margin to Criticality requirements by subtracting the difference in RCS Boron Concentration calculated in Step E.3.a from the ECC Boron Concentration:

() pp	m -	() ppm	=	() ppm
ECC Boron		Difference in		Minimum Required
Concentration		RCS Boron		RCS Boron
(A.9.c)		Concentration		Concentration
		(E.3.a)		

4. VERIFY Sufficient Margin to Criticality:

a. F

RECORD the present RCS Boron Concentration from the most recent Boron sample:

Present RCS	Sample	Time	Date
Boron			
Concentration			

 b. Is the present RCS Boron Concentration GREATER THAN OR EQUAL TO the Minimum RCS Boron Concentration calculated in Step E.3.b? (Circle one)

YES NO

(0645VV/WPF/110897)

-15-

4

\*

#### Facsimile

#### CALCULATION OF ESTIMATED CRITICAL CONDITION BASED ON A KNOWN ROD POSITION (continued)

5. If the answer in Step E.4.b is "NO", DO NOT withdraw Shutdown Banks until the RCS Boron Concentration is greater than or equal to the Minimum RCS Boron Concentration calculated in Step E.3.b.

SRO Date Time

(Final)

-16-

(0645VV/WPF/110897)

### Byron Station Operations Training Job Performance Measure

LO TASK DESCRIP	TION: Shift Turno	wor With		
NLO TASK DESCRI	Complication	ns (SRO)	S	taffing
	PTION: N/A			
K/A NUMBER 2.1.3 2.1.4	RO/SRO RATI 3.0/3.4 2.3/3.4	NG		
JPM NUMBER ADMIN 1.2 SRC	<u>Task Numbe</u>	<u>er</u>	Jo	b Position US
Revision: 1	Date:			
REVIEWED:				
	INSTRUCTOR			DAI
APPROVED:				
	GROUP LEADER			DATE
Start T	ime:	Stop Ti	ne	
Estimate	ed Time for Complet:	ion:		
This JPM was	[] Performed in t	the [	]	Control Room
	[] Simulated	[	]	Plant
	[ ] Other **	[	]	Simulator
		[	]	Mockup
	**	(	]	Other
			POI	R:
EXAMINEE:		EVALUA	10	
EXAMINEE:		_ EVALUA	10	
EXAMINEE: DATE: [ ] SA	ATISFACTORY	_ EVALUA	AT	ISFACTORY
EXAMINEE: DATE: [ ] SA Comments:	ATISFACTORY	_ EVALUA' [ ] UNSJ	AT	ISFACTORY
EXAMINEE: DATE: [ ] SA Comments:	ATISFACTORY	_ EVALUA'	AT	ISFACTORY

Specific Information:

- These items were used as reference material in the development of this JPM: BAP 335-1; BAP 335-1T2 UNIT SUPERVISOR TURNOVER SHEET; BAP 320-1; Byron Units 1 & 2 ITS, 5.2.2 Facility Staff.
- 2. These items are expected to be used by the examinee in the performance of the task: UNIT SUPERVISOR TURNOVER SHEET; BAP 320-1
- 3. Information to the Examinee and the Evaluator:
  - <u>Initial Conditions</u>: Both Units status are described on the STATUS SHEET. Crew staffing levels are currently at the minimum allowable Tech Spec levels.
  - <u>Task Initiating Condition</u>: You are the on-coming Unit Supervisor for Unit 1. Use the appropriate plant status for information.
  - c. Initiating Cue: Perform shift turnover. (Current time is 0450)
  - d. <u>Your Position</u>: Unit Supervisor
- Terminal Performance Objective: (TPO)
   Perform Shift Turnover.
   Respond to improper ITS Action Statement Entry
   Respond to condition for staffing less than allowed.
- 5. Critical Steps(\*) 7, 8, 9.

6. Identification of Impacted Systems: If this task is performed incorrectly, the following adverse reactions could occur: Failure to convey shift information for turnover and operation in a condition less than allowed by Technical Specifications (ITS).

ADMIN1.2(11/14/97)/2 Z98EXAM

STANDARDS

N/A

UN

SAT

RECORD START TIME \*\*\*\*\* NOTE \* Inform the candidate to use current Unit status for any \* conditions NOT specifically identified on provided \* STATUS SHEET. If NOT performed in Control Room, inform \* the candidate to assume status is "normal" unless \* indicated on provided STATUS SHEET. \*\*\*\*\* 1. Obtain Unit Supervisor Obtain UNIT SUPERVISOR C Turnover Sheet. TURNOVER SHEET. (May be done at any time.) Ensure the following 2. Review PLANT STATUS information filled in: Section. • Mode - 1 Reactor Power - 100% Boron Conc - 900 ppm Main Generator - 1175 MW \*3. Review IN PROGRESS Ensure the following 0 0 Section. information filled in: O Steady State Operations · Low oil on 1A D/G Governor due to faulty gasket. Maintenance has been dispatched to add oil and replace gasket. Air Regulator for 1RY455 has been isolated and removed due to leakage. Containment Entry planned for later to replace · LCOAR Status change -0 3.6.3 ITS (VQ) · LCOAR AC Sources -3.8.1 Action B.4 has NOT been initiated. . LCOAR PZR PORV -3.4.11 Action B.3 has NOT been initiated O Major Surv - None O Major OOS, T/L, R/S -None ADMIN1.2(11/14/97)/3 **Z98EXAM** 

#### STANDARDS

#### O Maintenance - Adding oil to DG 1A

O Major Proc. - None

4. Complete PENDING Section.

Ensure the following information filled in:

CNMT Entry to replace . air regulator on 1RY455

5. Review ADMINSTRATIVE Areas.

Ensure the following are reviewed:

- Unit log books
- Train Inoperability Status Board
- · Degraded Eqpt Log

#### AND

The following should be/may be reviewed depending on status:

- · Temp Procedures
- · Temp Alterations
- · Caution Cards
- · Aux Elec Room AEER Access
- · Daily Orders
- · Special Op Orders
- · PIFs
- · AR Focus Reports review
- · Temp Lifts

ADMIN1.2(11/14/97)/4 **Z98EXAM** 

UN SAT

N/A

#### STANDARDS

## SAT SAT

SAT N/A

6. Review TURNOVER items area.

Ensure the following are reviewed:

The following should be/may be reviewed depending on status:

- NSO Shiftly & Daily Surveillances
- SSPS Channels/Bistables
- Sys-Safeguards
- Sys-Primary
- Sys-Balance of Plant
- Nuclear Instr
- MCB Instr
- MCB Controllers
- · Elec Dist AC
- Elec Dist DC
- BPO/System status
- · Fire Protection
- · Blowdown (CW, SD)
- MCB Alarms
- Chemistry
- Radiation Precautions
- Reactivity Management

   approved to add 150
   gal. Of Primary Water
   with 50 gallons equal
   to .3F

ADMIN1.2(11/14,97)/5 Z98EXAM PERFORMANCE CHECKLIST STANDARDS

\*

******	********	******	***	
•	NOTE		*	
* The next steps are di	rected at addressing minimu	m	*	
* staffing requirements	. Direct attention of cand	idate	*	
* away from reporting r	equirements (if that direct	ion is	*	
* taken) and toward the	staffing area.		*	
******************	***************************************	******	***	
CUE: The time is now 0800. You severe chest pains, and re the hospital. The ambular	ar Unit NSO is experiencing equires transportation to nce has been dispatched.			
<ol> <li>Determine minimum staffing NOT met.</li> </ol>	Note that shift staffing is NOW 1 person less than minimum.			D
8. Address shift staffing.	Take action to address less than minimum shift staffing:	s.,	D	0
(CUE: CALLOUT has been				
initiated. An NSO	o Notify SM			
is in route.	o notity sh			
Expected arrival is in one-half hour.)	0 Initiate CALLOUT			
9. Determines action is satisfactory.	Determine NO further action required.		D	0
Jacoblaccory	(Allowable to have staffing one less than minimum required for unexpected absence of on- duty member, for up to 2 hours, as long as action immediate initiated to restore staffing.)			

(CUE: This completes this JPM.)

RECORD STOP TIME \_\_\_\_.

COMMENTS:

ADMIN1.2(11/14/97)/6 Z98EXAM

#### TASK CONDITIONS:

Both Units status are described on the TURNOVER SHEET. Crew staffing levels are currently at the Tech Spec minimum allowable levels.

You are the on coming Unit Supervisor for Unit 1. Use the appropriate plant status for information.

#### INITIATING CUES:

Perform shift turnover. (Current time is 0450)

ADMIN1.2(11/14/97)/7 Z98EXAM

#### -APPROVED 07/21/98

File Location: Training Use Only

Facsimile

# Unit Supervisor Turnover

	I -			PLA	NTSTATUS	3			
Grid Status: G	Freen	"A" Train	Week	WWM:	Marcum	Shif	ft: Current	Ir	ate: Today
	L L	INIT 1					UN	IT 2	Jule. Today
Mode: 1	% Pwr:	100%	MW:	1176	Mode:	3	% Pwr: 0		IMW: 0
CB: 900 ppm	Xenon	equilibrium	Rod He	ight: D @ 211	CB: 1	150 ppm	Xenon: e	quilibrium	Rod Height:
	IN PI	ROGRESS					IN PRO	GRESS	······································
Steady State Operation	6				ECC bei	ng performed for	r Unit 2 Reactor S	Startup. Plans	are for the the Startup in 4
Low oil level on 1A D/G dispatched to add cil an	Rovemor, due nd replace gasi	to faulty gasket. ket.	Maintenance	e has been	hours.				
Air Regulator for 1 RY4 Containment Entry plan	55 has been he ined for later to	plated and remove replace.	ed due to lea	ikage.					
3.6.3 ITS (VO)	UR	00	SITAI	RTS		LCOAR		003	TL/RTS
	. ,								
KA A IN INVESTIC	NOF								
MAINTENA	INCE					MAINTENAN	CE		
Oil addition to 1A	D/G				None				
MAJOR PR	100,	-				MAJOR PRO	<u>c.</u>		
					2BGP	100-2 & 100-2	2A1		
	PE	NDING				*****	PEN	DING	
Containment							1 -14	Surg	
containment entr	y to replace	air regulator	on 1RY4	56.	Mode 2	and 1			

APPROVED 07/21/98		Facsimile	BAP 335-1T2
	Unit	Supervisor Turnovor	Revision 13
	UIII	oupervisor runnover	
ADMINISTRATIVE	E	COMMENTS	
Temporary Alterations	YES		ner sol et deleter bener hener hener an de staat besteler kommensen in deleter in televisie oor de staat oor d
Unit 0 Logbook	YES		
Unit 1 Logbook	YES		
Unit 2 Logbook	YES		
Train Inop Status Board	YES		
Degraded Equipment Log	YES		
Daily Orders	YES		
- PIFs	125		
TURNOVER ITEMS	NORMAL VESSIO	COMMENTS	
NSO Shiftly and Daily Surv.	YES	Svs Primary see front 4DV455A	
SYS-Primary	NO	Sys Finnary See Hom IN 1400A	
SYS-Balance of Plant	YES		
Nuclear Instrumentation	YES		
MC8 Instrumentation	YES		
MCB Controllers	YES		
Electrical Distribution-AC	NO	Electrical Distribution AC - See 1A Diesel Generator	
Electrical Distribution-DC	YES		
BPO	YES		
Blowdown (CW/SD)	YES		
Alarms (MCB)	YES		
Chemistry	YES		
Radiation Precautions	YES		
U-1 Reactivity, Dilution	50 Gais =	0.2 *F Planned reactivity changes for oncoming shift:	
Plan to dilute 150 gallons to c	compensate f	or fuel depletion. K. Elam Nuclear Engineer on call.	
U-2 Reactivity, Dilution	Gals =	*F Planned reactivity changes for oncoming shift:	
Reactor Startup. Kevin Elam i	is the QNE		
	a and the second state of the s		RE-MANY MEMORY AND A TOTAL ADDRESS OF THE ADDRESS OF
		MISCELLANEOUS	
		modelenicoog	

## Post Review: MCR Tour, Unit NSO, CD NSO Turnovers, Logs, Daily Orders

OFF-GOING	Sector and the sector of the s	ON-COMING
Unit 1 Supervisor	U-1 Unit Supervisor	
Unit 2 Supervisor	U-2 Unit Supervisor	
L	STA	

## Byron Station Operations Training Job Performance Measure

LO INSK DESCK	IPTION: Identif	y And Kepi	ace Blown	Fuse
NLO TASK DESC	RIPTION: N/A			
K/A NUMBE 2.2.13	<u>R</u> <u>RO/SRO</u> 3.6/	RATING /3.8		
JPM NUMBE ADMIN 2 S	<u>R</u> <u>Task</u> RO	Number	Job Pos U-1 US	ition
Revision:	Date:			
REVIEWED:				
	INSTRUCTO	R		DATE
APPROVED:				
	GROUP LEAD	ER		DATE
Start	Time:	Stop	rime:	
Estim	ated Time for Com	pletion:		
'his .TPM was	[] Performed	in the	[] Conti	rol Room
AAN W WEEE THEED			1 1 51	-
	[ ] Simulated		[] Plant	-
	<pre>[ ] Simulated [ ] Other **</pre>		[ ] Plant [ ] Simul	lator
	[ ] Simulated [ ] Other **		[] Plant [] Simul [] Mocku	lator 1p
	[ ] Simulated [ ] Other **		[ ] Plant [ ] Simu: [ ] Mocku [ ] Other	lator up r
XAMINEE:	[ ] Simulated [ ] Other ** **	EVALU	[ ] Plant [ ] Simu: [ ] Mocku [ ] Other JATOR:	Lator 1p r
XAMINEE:	[ ] Simulated [ ] Other ** **	EVALU	[ ] Plant [ ] Simu: [ ] Mocku [ ] Other JATOR:	lator up r
EXAMINEE: DATE:[]	[ ] Simulated [ ] Other ** ** SATISFACTORY	EVALU [ ] UI	[ ] Plant [ ] Simu: [ ] Mocku [ ] Other JATOR:	Lator up r
XAMINEE: ATE:[]	[ ] Simulated [ ] Other ** ** SATISFACTORY	EVALU [ ] UI	<pre>[ ] Plant [ ] Simu: [ ] Mocku [ ] Othes JATOR:</pre>	Lator up r
XAMINEE: DATE:[] Comments:	[ ] Simulated [ ] Other ** ** SATISFACTORY	EVALU [ ] UI	[ ] Plant [ ] Simu: [ ] Mocku [ ] Other JATOR:	Lator up r

Specific Information:

- These items were used as reference material in the development of this JPM: BAP 350-6
- 2. These items are expected to be used by the examinee in the performance of the task: BAP 350-6; BAP 350-6T1 "Fuse Discrepancy Form"; BAP 350-6T2 "Fuse Discrepancy Document Control"
- 3. Information to the Examinee and the Evaluator:
  - <u>Initial Conditions</u>:
     Unit 1 is at 100% power. Unit 2 is at 100% power.
     All systems are normal.
  - <u>Task Initiating Condition</u>: A fuse has blown on 1AF013F control power.
  - c. <u>Initiating Cue</u>: The SM asks you for your recommendation.
  - d. <u>Your Position</u>: Unit 1 Unit Supervisor
- Terminal Performance Objective: (TPO) Replace fuse with non-like fuse.
- Critical Steps(\*)
   3, 7, & 8
- Identification of Impacted Systems: If this task is performed incorrectly, the following adverse reactions could occur: The associated equipment would remain inoperable.

ADMIN2(9/14/98)/2 Byron98EXAM

PERFORMANCE CHECKLIST	STANDARDS	SAT	UN SAT	N/A
RECORD START TIME				
1. Refer to BAP 350-6. (May be done at any time.)	Refer to BAP 350-6.		D	O
<ol> <li>Check Byron Station Fuse List. (Center Desk of Control Room)</li> </ol>	Determine/record information for fuse to be replaced:			٥
	<ul> <li>Panel No 1AP28E</li> <li>Fuse type - BAF 3</li> <li>Fuse rating - 3/120 amp/volt</li> </ul>			
* 3. Determine replacement fuse availability.	<ul> <li>Determine like for like replacement fuse is NOT available.</li> </ul>	D	٥	
(CUE: The only available fuse is as provided and the Shift Manager would like a recommendation)	<ul> <li>AND</li> <li>Check with SM for emergency replacement authorization.</li> <li>Recommendation shall</li> </ul>			
	be to replace the fuse non-like for like emergency.			
*****	*****	******	***	
* Provide candidate wit * Discrepancy Form.	NOTE h blank copy of BAP 350-673	I Fuse	*	
********	*****	******	****	
<ol> <li>Record Part 1 information on BAP 350-6T1.</li> </ol>	Record in Part 1 of Fuse Discrepancy Form:	٥	۵	۵
	<ul> <li>Date [Current]</li> <li>Originator/phone</li> <li>System - DF</li> </ul>			

- WR # N/A
- Safety Class Safety

5. Record Part 2 information on SAP 350-6T1.

- Fuse Discrepancy Form:
- Schematic/WD 6E-1-4030AF08 / 6E-1-4687B
- Panel No. 1AP28E
- Fuse ID FU

STANDARDS

- Service
- Reason for replacement - Blown
- ID on Fuse List Y
- Fuse Manufacturer/type - BAF 3
- Fuse rating 3/120 250 V amp/volt
- 6. Record Part 2 information on BAP 350-6T1.
- Is unlike fuse the same physical size as the original - Y
- QRI Number per red tag
- Stores item number -XXX BUSSMANN
- Fuse Manuf. -. MOL 3 AMP fuse
- Fuse Pating 3/120 diff amp/volt 250V

\* 7. Replace fuse.

Determine replacement acceptable and obtain

Obtain SM or designee permission to replace

## (NOW REQUIRE SAO APPLICANT TO REPLACE FUS

8. Dispatch EO to install X/ approved fuse. INSTALL APPROVED FUSE (CIF EQ is disputched)

given.)

(CUE: As SM, Approval for replacement is

> Sign in Part 3 of Fuse Discrepancy Form.

ADMIN2 (9/14/98)/4 Byron98EXAM

#### replacement fuse. Initial and date in Part 3 of Fuse Discrepancy Form.

fuse

Ensure fuse is replaced. 

0

0

2

UN

SAT

N/A

SAT

#### STANDARDS

0

9. Send completed Fuse Discrepancy Form to Fuse provide Fuse Discrepancy Form to Fuse Coordinator Coordinator

Identifies need to ŋ Form to Fuse Coordinator.

(CUE: I will be responsible for forwarding of Form (Accept Form)

This completes this JPM.)

RECORD STOP TIME 

COMMENTS:

ADMIN2(9/14/98)/5 Byron98EXAM

#### TASK CONDITIONS:

Unit 1 is at 100% power. Unit 2 is at 100% power. All systems are normal.

A fuse has blown on 1AF013F control power.

#### INITIATING CUES:

The US directs you to replace the fuse.

ADMIN2(9/14/98)/6 Byron98EXAM

#### Facsimile

FUSE DISCREPANCY FORM

NETS has evaluated Bussmann rejection fuse types FRN-R, KTK-R, KTN-R, KWN-R and FRS-R and determined that these fuses may be used as substitutes for fuse types FRN, KTK, KTN, KWN and FRS respectively. Based on this information, the above listed fuses shall be considered Like-For-Like replacements (Refer to Chron #179149 dated January 21, 1991 and Chron #182536 dated March 16, 1992).
PART 1 - General Information:
File No: N/A Discrepancy No: B- N/A
Date: Topay FDSR Updated (F.C.): N/A /
Originator: R. Brown Phone Extension: 3133
System:AF Work Request No.:N/A
Safety Class: X Safety Non-Safety Regulatory
PART 2 - Blown/Installed Fuse Information:
Schematic Drawing: 6E-1-4030 4Fot Fuse ID on Schematic: 101
Wiring Drawing: Fuse ID on Wiring:
Panel No .: IAP 28E - 192X4 ComP.
Service: Controi Ponse
Reason for Fuse Replacement or Description of Discrepancy:
BLOWN TOB
Does the Fuse List Identify the blown/installed fuse? X Yes No
Fuse Manufacturer: BUSSMANN
Fuse Type: BAF 3 2500
Fuse Rating: Amps Voits
(KEY)

-1-

APPROVED 61/17/97	BAP 350-6T1 Revision 4
PART 3 - Substitute Fuse Information:	
Is Unlike Fuse the same size (physical d	limension) as the original?
X Yes No	
* QRI Number: Per Reo TAG	(N/A if not applicable) *,
Stores Item No.: XXX	
Fuse Manufacturer: BUSSMANN	
Fuse Rating: 3 6 Amps 250 HP volt	s
F.C., SSE-or SM Fuse Approval:	MANALER Date: TODAY
Fuse Installation:	
Shift Manager (or designee) permission obtained:	Date:
Fuse Replacer:	Date:
F.C. Approval:	Date:
Evaluation Complete (F.C.):	Date:

3.

· · · ·

....

PAR'

Facsimile

FUSE DISCREPANCY FORM

		 _
-		 5-60 M
100.1		
-	1.00	 -

NETS has evaluated Bussmann rejection fuse types FRN-R, KTK-R, KTN-R, KWN-R and FRS-R and determined that these fuses may be used as substitutes for fuse types FRN, KTK, KTN, KWN and FRS respectively. Based on this information, the above listed fuses shall be considered Like-For-Like replacements (Refer to Chron #179149 dated January 21, 1991 and Chron #182536 dated March 16, 1992).

PART 1 - General Information:

File No:	Discrepancy No: B-
Date:	FDSR Updated (F.C.):
Originator:	Phone Extension:
System:	Work Request No .:
Safety Class: Safety	Non-Safety Regulatory
2 - Blown/Installed Fuse Informa	tion:
Schematic Drawing:	Fuse ID on Schematic:
Wiring Drawing:	Fuse ID on Wiring:
Panel No.:	
Service:	
Reason for Fuse Replacement or	Description of Discrepancy:
Does the Fuse List Identify the	e blown/installed fuse? Yes No
Fuse Manufacturer:	
Fuse Type:	
Fuce Rating: Amps	Volts

-1-

		BAP 350-6T1 Revision 4	
APPROVED 01/17/97	Pacsinue		
PART 3 - Substitute Fuse Info	ormation:		
Is Unlike Fuse the same	e size (physical dimension	) as the original?	
Yes No			
* QRI Number:	(N/A i	f not applicable)	*, 3.g
Stores Item No.:			
Fuse Manufacturer:			
Fuse Type:			
Fuse Rating: Ar	mps Volts		
F.C., SSE or SM Fuse A	oproval:	Date:	-
Fuse Installation:		· · ·	
Shift Manager (or designee) permission	on obtained:	Date:	-
Fuse Replacer:		Date:	-
F.C. Approval:		Date:	-
Evaluation Complete (F	.C.):	Date:	-

\*

, 18

APPROVED 01/17/97	Facsimile		BAP 350-6TI Revision 4	
PART 4 - Other Substitute	Fuse Information:			
Is Unlike Fuse the s	ame size (physical dimension	) as the or	iginal?	
Yes No				
* ORT Number:	(N/A i	f not appli	cable)	
Acre version or a summer s				*, 3.g
Stores Item No.:				
Fuse Manufacturer: _				
Fuse Type:				
Fuse Rating:	Amps Volts			
F.C. or SSE Fuse App	roval:	C	)ate:	
Fuse Installation:		1.1		
Shift Manager		r	Date:	
(or designee) permis	sion obtained:			
Fuse Replacer:		[	Date:	
F.C. Approval:	e e e e e e e e e e e e e e e e e e e	[	Date:	

(Final)

i și

-3-

L	SAH	G		ELECTRICAL DEPARTMENT FUSE LIST							Di Ri	PROJECT NO 8739-04 DATE 04/27/80 SYSTEM AP REVISED 12/12/91 PAGE 3 OF 6				
R F Y			SCHE MATHC	CHICHT	PAREL HERMIN R	3 10 10	py		ITARE DE	A.5	APS Itel	19	ea weesac	APPLICABLE CALC ND.	E7	
	242		ns	ns	rt Saraj	aray wine into Cirka wine c	ADEAVEE	1 INRTHE R PANEL INFORMATION		86 19	26	1174	BES	FLB	NE RANCE	I MENTIFICATION
			6E-1-4030AF03		1AP24E/132X3		1					IAFO1PB-A	1			
4	AF	5	6E-1-4685D	120VAC	COMPT.D3		FU			34		AF PP 18 LUBE	FUSE BAF 3			
			6E-1-4030AF04		1AP24E/132X3	61						JAFOQ68	l		1	
	AF	s	6E-1-4685A	120VAC	COMPT. A4		FU			34		AF PP SX VLV	FUSE BAF 3		1	
			6E-1-4030AF11		1AP24E/132X3	02						1450178	1			
1	AF	s	6E-1-4685A	120VAC	COMPT.AS		FU			34		AF PP SX VLV	FUSE BAF 3		1	
			6E-1-4030AF07		1AP26E/ 132X4							IAFO13E	1			
	AF	s	68-1-46878	120VAC	COMPT.B2		FU			38		SGIA AF VLV	FUSE BAF 3			
			6E-1-4030AF08		1AP28E/132X4	bi						IAF013F	1		1	
	AF	15	SE-1-46878	120VAC	COMPT.81		FU			34		SGIB AF VLV	FUSE BAF 3	1	1	
			6E-1-4030AF09		1AP28E/ 132X4	62						14F0136	1			
	AF	s	6E-1-4687C	120VAC	COMPT.C1		FU			34		SOTC AF VLV	FUSE BAF 3	1	1	
			6E-1-4030AF 10		1AP28E/132X4	03						14F013H	1			
	AF	5	6E-1-4687B	120VAC	COMPT.84		FU			-		SGID AF VLV	FUSE BAF 3		1	
			6E-1-4030AF 17		1AP28E/132X4	64						IAFO1PB-C	1	1		
	AF	s	6E-1-4687H	120VAC	COMPT.HS		FU			34		AF PP 18 LUBE	FUSE BAF 3			
			8E - 1 - 4030AF 14		1H5-AF121							1AFOD4A	AF4AP			
	AF	5	6E-1-4942B	125400	LCP		FU			ЗА		DSCH TEST VLV	FU			
			6E-1-4030AF 14		IHS-AF 121	61						IAFOORA	AFAAN			
	AF	5	6E-1-4942B	125400	LCP		FU			34		DSCH TEST VLV	FU	-		
			6E-1-4030AF 14		1HS-4F122			T		1		IAF JOIR	AF48P			
	AF	5	6E-1-49428	125VDC	LCP		eu	1		-		SCH TEST VLV	FU			
1			8E-1-4030AF 14		1H5-AF 122	6.	T					IAFOOAR	AFARM			

.

CECU BYRON:# 1/

T

13

1-14-94 : 14:24 .

SENT BY:

#### Facsimile

#### \* FUSE CONTROL PROGRAM

#### A. STATEMENT OF APPLICABILITY:

The purpose of this procedure is to provide guidelines for replacing blown/installed fuses used for Safety Related, Regulatory Related and Non-Safety Related applications. This procedure also provides guidelines for resolving fuse discrepancies under the fuse walkdown program.

#### B. <u>REFERENCES</u>:

- XAP-0001, Control and Maintenance of Fuses and the Fuse List (Corporate Draft Procedure).
- 2. Station Procedures:
  - a. BAP 350-6A1, Proper Fuse Orientation.
  - b. BAP 350-6T1, Fuse Discrepancy Form.
  - c. BAP 350-6T2, Fuse Discrepancy Document Control.
  - d. BAP 350-6T3, Operating "Like-For-Like" Fuse Log.
  - e. BAP 1600-1, Action/Work Request Processing Procedure.
  - f. BAP 1600-14, Processing And Control of Minor Work Activities Completed As Action Requests, Minimal Work Request, or Pre-Reviewed Work Requests.
- 3. Station Commitments:
  - a. 454-251-81-02300
  - b. 454-251-83-03400
  - c. 454-251-91-10300
  - d. 454-230-93-00400-05
  - e. 454-230-93-00400-06
  - f. 454-315-94-003301F-04
  - g. 454-251-92-04805
- 4. Byron Station Unit 1 and Unit 2 Fuse Lists.

\*, 3.c

Facsimile

- B. continued
  - \* 5. ENC-QE-84, Fuse Evaluations and Fuse List Updates.
  - \* 6. TID-E/I&C-09, Fuse Selection Guidelines.
    - 7. EIA-3, Interface Agreement for Generation and Control of Byron Station Fuse Discrepancy Resolutions.
    - 8. Instruction PI-BB-537, Byron Fuse Discrepancy Resolution.

#### C. PREREQUISITES:

- 1. Obtain the Shift Manager or his designee's permission prior to removing or replacing any fuses.
- Discrepancy forms (BAP 350-6T1, Fuse Discrepancy Form) shall be delivered to the Fuse Coordinator located in the Station Support Engineering (SSE) Electrical Group.
- The fuse replacer and the Fuse Coordinator shall sign Part 3 or 4 of BAP 350-6T1, Fuse Discrepancy Form, whenever a Non-Like-For-Like fuse is replaced.
- D. PRECAUTIONS:
  - Where applicable, ensure any special precautions or procedures are implemented prior to fuse removal and replacement (ie. SSPS, Ground Return Fuse, Rod Drive Fuses, etc.).

#### E. LIMITATIONS AND ACTIONS:

- 1. Prior to installing a fuse, the end caps should be checked to ensure they are not loose.
- Orient the fuse as shown in BAP 350-6A1, Proper Fuse Orientation, to allow easy identification in the future.
- Ensure fuse clips are tight and make firm contact with the end caps.
- Where applicable, verify there are no abnormalities after fuse replacement.

\*, 3.f

\*, 3.f

Facsimile

- E. continued
  - Whenever possible, verify power is resupplied to the circuit by observing indicating lights, hearing a relay pickup or by using a Volt Ohm Meter (VOM) to check coil energization or contact position.
  - \* 6. Fuse Replacement Responsibilities:
    - a. Operating may replace fuses that are blown or in a degraded condition in any equipment.
    - b. Instrument Maintenance (IMs) may replace any fuse that is part of the 7300 system or circuit board related fuses pertaining to instrumentation.
    - c. Electrical Maintenance (EMs) may replace fuses under an NWR (BAP 1600-1, Action/Work Request Processing Procedure), Minor Maintenance Work Request (BAP 1600-14, Processing And Control of Minor Work Activities Completed As Action Requests, Minimal Work Request, or Pre-Reviewed Work Requests), or as required in welding receptacles and miscellaneous lighting.

\*, 3.e

#### F. MAIN BODY:

- 1.0 Definitions:
  - a. <u>F.C.</u>: For the purpose of this procedure means ".use Coordinator".
  - <u>Like-For-Like-Fuse:</u> A fuse which is identical in all respects (ie. manufacturer, type, size (physical dimension), amperage and voltage) to the fuse being replaced.
  - c. <u>Non-Like-For-Like (Non Emergency)</u> Fuse: A fuse that has at least one characteristic different from the fuse being replaced, and has been approved by the F.C. and/or SSE Electrical Group prior to installation.

(9984AA/WPF/011197)
Facsimile

### F.1. continued

- d. <u>Non-Like-For-Like (Emergency) Fuse:</u> A fuse that has at least one characteristic different from the fuse being replaced and has been approved by the Shift Manager, F.C. or SSE Electrical Group prior to installation. An emergency condition requiring expeditious Non-Like-For-Like replacement is limited to any of the following conditions:
  - 1). Personnel or plant safety.
  - 2). Avoidance of unit shutdown or outage extension.
  - 3). Plant operating in an unsafe manner.
  - Any other condition which is determined to be an emergency by the Shift Manager or Designee.
- e. <u>Controlled Location:</u> An F.C. designated fuse storage location. The following are controlled locations:
  - 1). Stores.
  - 2). Main Control Room chart paper supply room.
- f. <u>Fuse Discrepancy Status Report (FDSR)</u>: A log maintained by ComEd for recording and tracking station fuse discrepancy status.
- 2.0 Fuse Replacement Classification Index

### NOTE

Nuclear Engineering and Technology Services (NETS) has evaluated Bussmann rejection fuse types FRN-R, KTK-R, KTN-R, KWN-R and FRS-R and determined that these fuses may be used as substitutes for fuse types FRN, KTK, KTN, KWN and FRS respectively. Based on this information, the above listed fuses shall be considered Like-For-Like replacements (Refer to Chron #179149 dated January 21, 1991 and Chron #182536 dated March 16, 1992).

### NOTE

The F.C. or SSE Electrical Group can be contacted for fuse information collected from fuse verification walkdowns if the fuse is not included in the Byron Station Fuse List.

Facsimile

### F.2. continued

### CAUTION

If the same fuse continues to blow, a NWR should be issued to investigate and repair the problem.

\*, 3.a,b

\*, 3.d

### CAUTION

Safety Related Non-Like-For-Like size (amperage) discrepancies shall be evaluated by Sargent & Lundy or SSE Electrical Group, except in an emergency where the Shift Manager or designee may evaluate and determine a replacement.

- a. PERFORM section F.5 only during the fuse walkdown process for fuse replacement and discrepancy resolution when the correct fuse was specified in the pre-walkdown drawing verification.
- b. CHECK the Byron Station Fuse List located in Central Files or at Center Desk in the Control Room prior to replacing any fuse or contact SSE Electrical Group for fuse information collected from fuse verification walkdowns.
- c. If the blown/installed fuse is listed in the fuse list/walkdown verifications and matches the data in the fuse list /walkdown verifications, and:
  - \* 1). correct fuse is available from a controlled location, replace the blown fuse, document replacement in BAP 350-6T3, Operating "Like-For-Like" Fuse Log, and exit this procedure.
    - correct fuse is not available from a controlled location, go to step F.2.f.
    - if that fuse is currently installed, leave as is and exit the procedure.
- d. If the blown/installed fuse is in but does not match the fuse list, go to step F.2.f.

Facsimile

\*, 3.d

### F.2. continued

- e. If the blown/installed fuse is not in the fuse list/walkdown verifications and:
  - review of the schematic drawings, internal and external wiring drawings, bill of materials or vendor manual identifies the correct size fuse, and
    - a). blown/installed fuse is incorrect or the correct size replacement is not available, go to step F.2.f.
    - \* b). blown fuse is correct and available from a controlled location, replace the blown fuse, document replacement in BAP 350-6T3, Operating "Like-For-Like" Fuse Log, and exit this procedure.
      - c). fuse installed is correct, leave installed and exit this procedure.
  - review of the schematic drawings, internal and external wiring drawings, bill of materials or vendor manual does not identify the correct size fuse, go to step F.2.f.
- f. If the fuse replacement is Non-Like-For-Like and the F.C., Shift Manager or designee determines:
  - Non Emergency replacement is required, go to section F.3.
  - 2). Emergency replacement is required, go to section F.4.

(9984AA/WPF/011197)

Facsimile

### F. continued

- 3.0 Non-Like-For-Like (Non Emergency) Fuse Replacement
  - Record as much information as possible on Part 1 and 2 of BAP 350-6T1, Fuse Discrepancy Form:
    - 1). Part 1 General Information:
      - Date
      - Originator/Phone Number
      - System
      - Work Request Number (if applicable)
      - Safety Classification
    - 2). Part 2 Blown/Installed Fuse Information:
      - Schematic/Wiring Drawing
      - Panel Number
      - Fuse ID on Schematic
      - Service
      - Reason for Fuse Replacement or Description of Discrepancy
      - Does the Fuse List identify the blown fuse?
      - Fuse Manufacturer/Type/Rating
  - b. Forward BAP 350-6T1, Fuse Discrepancy Form, to the F.C. for review of Parts 1 and 2.
  - c. The F.C. should complete the information missing from the Fuse Discrepancy Form and assign it a number. The F.C. shall then enter the fuse discrepancy information into the FDSR and initial/date BAP 350-6TL, Fuse Discrepancy Form, (Part 1), documenting the FDSR has been updated.

Facsimile

### F.3. continued

- \* d. SSE Electrical Group/Sargent & Lundy (S&L), using the applicable procedures (i.e., TID-E/I&C-09 Fuse Selection Guidelines) and design documentation shall determine a substitute fuse for the blown/installed fuse or determine the correct fuse in the case of a discrepancy between the fuse list or other design documentation and the blown/installed fuse. For the purpose of fuse walkdowns, the F.C. or SSE Electrical Group may perform a review to determine the correct fuse that consists of but is not limited to the following: schematic drawing, internal and external wiring drawing, bill of materials, or vendor manual. If the fuse is adequately documented and identified, the F.C. or SSE Electrical Group may approve replacement of installed fuse with recommended fuse from documentation/vendor review.
- \* e. SSE Electrical Group shall then complete the following information on Part 3 of BAP 350-6T1, Fuse Discrepancy Form, as substitute or correct fuse information:
  - Is Unlike Fuse the same size (physical dimension) as the original?
  - QRI Number on Red Tag ( N/A for Non-Safety Applications)
  - Stores Item Number
  - Fuse Manufacturer/Type/Rating

\*, 3.q

\*, 3.f

f. The SSE Electrical Group Engineer shall sign BAP 350-6T1, Fuse Discrepancy Form, in SSE Electrical Group Approval blank.

### NOTE

If the SSE Electrical Group approved fuse cannot be physically installed in the same location, the F.C. shall resubmit the discrepancy form to SSE Electrical Group for a resolution.

g. The person(s) responsible for replacing the fuse shall use the SSE Electrical Group approved substitute fuse, initial/date in Part 3 of BAP 350-6T1, Fuse Discrepancy Form, verifying that the Shift Manager or designee's permission is obtained prior to replacing the fuse, and then sign as the fuse replacer.

Facsimile

### F.3. continued

- h. The completed form shall then be sent to the F.C. for his/her signature and retention.
- 4.0 Non-Like-For-Like (Emergency) Fuse Replacement
  - Record as much information as possible on Part 1 and 2 of BAP 350-6T1, Fuse Discrepancy Form:
    - 1). Part 1 General Information:
      - Date
      - Originator/Phone Number
      - System
      - Work Request Number (if applicable)
      - Safety Classification
    - 2). Part 2 Blown/Installed Fuse Information:
      - Schematic/Wiring Drawing
      - Panel Number
      - Fuse ID on Schematic
      - Service
      - Reason for Fuse Replacement or Description of Discrepancy
      - Does the Fuse List identify the blown fuse?
      - Fuse Manufacturer/Type/Rating

Facsimile

F.4. continued

### CAUTION

In an emergency the replacement fuse should be one of the same rating and size specified on the prints or other design documentation. Such a fuse should be evaluated within two working days by the F.C. or SSE Electrical Group. Place the affected equipment on the Degraded Equipment Log for tracking purposes.

- \* b. The F.C., SSE Electrical Group or the Shift Manager shall determine a proper substitute fuse using applicable procedures (i.e., TID-E/I&C-09 Fuse Selection Guidelines) and design documentation. Complete the following information in Part 3 of BAP 350-6T1, Fuse Discrepancy Form, and sign/date for fuse approval.
  - Is Unlike Fuse the same size (physical dimension) as the original?
  - QRI Number on Red Tag (N/A for Non-Safety Applications)
  - Stores Item Number
  - Fuse Manufacturer/Type/Rating

\*, 3.f,g

- c. The person(s) responsible for replacing the fuse shall use the F.C., SSE Electrical Group or the Shift Manager's approved substitute fuse, initial/date in Part 3 of BAP 350-6T1, Fuse Discrepancy Form, verifying that the Shift Manager or designee's permission is obtained prior to replacing the fuse, and then sign as the fuse replacer.
- d. Forward BAP 350-6T1, Fuse Discrepancy Form, to the F.C.
- e. The F.C. should complete the information missing from the Fuse Discrepancy Form and assign it a number. The F.C. shall then enter the fuse discrepancy information into the FDSR and initial/date BAP 350-6T1, Fuse Discrepancy Form, (Part 1) documenting the FDSR has been updated.
- f. The F.C., SSE Electrical Group or S&L will then determine if the substitute fuse provides adequate protection or whether the fuse is inadequate and needs to be replaced.

Facsimile

### F.4. continued

- g. If the F.C., SSE Electrical Group or S&L determined the installed fuse is inadequate, the fuse replacer shall:
  - initial/date in Part 4 of BAP 350-6T1, Fuse Discrepancy Form, verifying that the Shift Manager or designee's permission is obtained prior to replacing the fuse,
  - replace the installed fuse with the F.C., SSE Electrical Group or S&L approved fuse and document in Part 4 of BAP 350-6T1, Fuse Discrepancy Form, Other Substitute Fuse Information.
  - sign Part 4 Fuse Replacer on BAP 350-6T1, Fuse Discrepancy Form, and go to step F.4.i.
- h. If the F.C., SSE Electrical Group or S&L determined the installed fuse is adequate, go to step F.4.i.
- i. The completed form shall then be sent to the F.C. for his/her signature and retention.

### 5.0 Fuse Walkdown Non-Like-For-Like Fuse Replacement

- Record as much information as possible on Part 1 and 2 of BAP 350-6T1, Fuse Discrepancy Form:
  - 1). Part 1 General Information
    - Date
    - Originator/Phone Number
    - System
    - Work Request Number (if applicable)
    - Safety Classification
  - 2). Part 2 Blown/Installed Fuse Information:
    - Schematic/Wiring Drawing
    - Panel Number
    - Fuse ID on Schematic
    - Service
    - Reason for Fuse Replacement or Discrepancy
    - Does the Fuse List identify the blown fuse?
    - Fuse Manufacturer/Type/Rating

Facsimile

### F.5. continued

- \* b. If pre-walkdown drawing verification was performed and the correct size and/or type of fuse was identified, the correct size and/or type of fuse can be installed. The person(s) performing the fuse walkdown shall complete the following information in Part 3 of BAP 350-671, Fuse Discrepancy Form.
  - Is Unlike Fuse the same size (physical dimension) as the original?
  - QRI Number on Red Tag (N/A for Non- Safety Applications
  - Stores Item Mumber
  - (Correct) Fuse Manufacturer/Type/Rating

\*, 3.g

- c. The person(s) responsible for replacing the fuse shall use the pre-walkdown verified fuse, initial/date in Part 3 of BAP 350-6T1, Fuse Discrepancy Form, verifying that the Shift Manager or designee's permission is obtained prior to replacing the fuse, and then sign as the fuse replacer.
- d. Return BAP 350-6T1, Fuse Discrepancy Form, to the F.C. or SSE Electrical Group for SSE Electrical Group or F.C. approval and signature in Part 3.
- e. The F.C. shall fill in as much of the information missing from the Fuse Discrepancy form as possible and assign it a number. Then, the F.C. shall enter the fuse discrepancy information into the FDSR and initial/date BAP 350-6T1. Fuse Discrepancy Form, (Part 1) documenting the FDSR has been updated.
- f. SSE Electrical Group, F.C. or S&L shall perform an evaluation or attach documentation identifying the correct fuse. This evaluation will be attached to discrepancy form BAP 350-6T1, Fuse Discrepancy Form, to document resolution.
- g. The completed form shall then be sent to the F.C. for his/her signature and retention.

Facsimile

### F. continued

- 6.0 Completion of Fuse Discrepancy Forms
  - a. Once the substitute fuse has been replaced satisfactorily, the F.C. shall review BAP 350-6T1, Fuse Discrepancy Form, and determine if the fuse replacement has altered any controlled documents. Such documents may include, but are not limited to the following:
    - Fuse List
    - Schematic drawing showing the replaced fuse
    - Wiring drawing showing the replaced fuse
    - Single line drawing showing the replaced fuse
    - Phase diagrams showing the replaced fuse
    - Key diagrams
    - Vendor or other equipment manual, description or procedures depicting or describing the replaced fuse
    - Vendor or other operating manual, description or procedures depicting or describing the replaced fuse
  - b. If any controlled document is affected, the F.C. shall markup the affected document and prepare a "Document Change Request" in accordance with the applicable Station procedures.
  - c. The F.C. shall complete BAP 350-6T2, Fuse Discrepancy Document Control form.

#### NOTE

For fuse discrepancies related to walkdowns, the fuse list does not need to be updated immediately because updates will be made in large numbers using the DCR process.

d. The F.C. shall place a marked-up copy of the fuse list showing the DCR number in the Byron Station Fuse List located in Central File and at Center Desk. The F.C. should also keep a copy in his/her files.

1 11

Facsimile

### F.6. continued

- e. The F.C. shall prepare a package for the fuse replacement consisting of the following completed documents:
  - BAP 350-6T1, Fuse Discrepancy Form
  - BAP 350-6T2, Fuse Discrepancy Document Control, form.
  - Supporting documentation (if fuse selected by F.C, SSE Electrical Group or S&L).
  - Marked-up drawings.

This information will be maintained with the Fuse Coordinator.

\* f. F.C. shall send package to SEC File Clerk for file retention.

\*, 3.f

\* g. SEC File Clerk shall package in file location 1.02.0411.

\*, 3.f

### 7.0 Fuse Removal For Maintenance or Testing

- a. To ensure fuses are returned to their proper location after maintenance (OOS, WRs, etc.) or testing, all removed fuses, under any circumstance should be individually tagged and secured. The tag label shall state the proper fuse location.
- b. After the fuses are removed, they should be stored in a secure area or in a spare clip, to preclude their loss or damage.

(Final)

# Byron Station Operations Training Job Performance Measure

LO TASK DESCRIPTION:	Prepare For Entr Radiation Area G 1000 mr/hr	y Into High reater Than	
NLO TASK DESCRIPTION:	N/A		
K/A. NUMBER 2.3.10	RO/SRO RATING 2.9/3.3		
JPM NUMBER ADMIN 3 SRO	Task Number	Job Position IPSS (SRO)	
Revision: Date:			
REVIEWED:			
II	NSTRUCTOR		DATE
APPROVED:GR(	OUP LEADER		DATE
Start Time:	Stop	Time:	
Estimated Time	for Completion:		
This JPM was [ ] Peri [ ] Simu [ ] Othe	formed in the ulated er **	[ ] Control Ro [ ] Plant [ ] Simulator	DOM
**		[] Mockup [] Other	
EXAMINEE:	EVA	LUATOR:	
[ ] SATISFAC	FORY []	UNSATISFACTORY	
Comments:			

Specific Information:

- These items were used as reference material in the development of this JPM: BAP 1450-2; BRP 5000-7
- 2. These items are expected to be used by the examinee in the performance of the task: RWP 98-XXX; BRP 6200-5T10

3. Information to the Examinee and the Evaluator:

- a. <u>Initial Conditions</u>: Unit 1 and Unit 2 are operating at 100% power. The Unit 2 Unit Supervisor has asked that a valve lineup be performed on valve 2CV XXX in the closed position.
- b. Task Initiating Condition:

Entry into an area with expected dose rates of 1050 mrem/hr is required to check the position of a specific valve and perform a general inspection of the area. Due to staffing restrictions, the entry is to be made by only ONE individual and RPT is NOT in attendance.

- c. <u>Initiating Cue</u>: The US directs you to perform the necessary steps to prepare to make the entry into the area.
- d. <u>Your Position</u>: IPSS (SRO)
- Terminal Performance Objective: (TPO) Perform actions necessary to allow entry into HIGH RADIATION AREA >1000 mrem/hr (HRA).
- 5. Critical Steps(\*) 1, & 3

ADMIN3(9/14/98)/2 Byron98EXAM 6. Identification of Impacted Systems:

If this task is performed incorrectly, the following adverse reactions could occur:

Failure to comply with CFR regulations, NRC Regulatory Guides, and station administrative procedures controlling high radiation areas and access to these areas. Potential for radiation overexposure to self and others.

ADMIN3 (9/14/98) / 3 M Byron98EXAM RECORD START TIME

 Obtains a radiation monitoring device which continuously indicates radiation dose, has alarming capability, and continuously integrates the radiation dose rate.

. .

Also obtain radiological requirements for area to be entered.

Obtains and wears electronic dosimetry (and TLD).

Obtain information from the RWP.:

- Where Highest Dose rate area? 2.5 R/hr contact & 1.2 R/hr at 12" (upper left on survey map)
- What does "ANS" stand for by the ladder? Area not Surveyed How long are you allowed into the area?, 17 minutes (per BRP 6200-5T10).
- What protective clothing is required? Per page 1 of the RWP need Class 1.
- If asked to wait after the survey mapped area was entered? Per survey map, wait in area by the door (low dose area)
- What does 25/8 mean? (see upper right hand corner of the survey map) 25mr/hr contact and 8mr/hr at 12"
- AND
- Review and sign onto RWP 98XXX

ADMIN3(9/14/98)/4 Byron98EXAM 0

D

3	PERFORMANCE CHECKLIST	STANDARDS	SAT	UN <u>SAT</u>	<u>N/A</u>
	2. Review current survey of area.	Locate and review survey map(s) of area to be entered.	ì	٥	D
	* 3. Obtain key for access to area.	Obtain proper key from HE Services (RP) Supv or designee.		۵	D
	<ul> <li>4 Ensure information on BRP 6200-5T10, "Maximum Stay Time Worksheet For Areas &gt;1000 mrem/hr When RPT is Not in Attendance" is complete.</li> <li>(CUE: RP SUPV approval provided.)</li> </ul>	Ensure/fill in appropriate information: • RWP # • Date • Work Group Job Desc • Authorized Daily Dose • Working Dose Rate • Maximum Stay Time • RP Supv Initials	,	D	

CUE: This completes this JPM.)

1

. · · · · ·

4

RECORD STOP TIME \_\_\_\_.

COMMENTS:

....

ADMIN3(9/14/98)/5 Byron98EXAM

### TASK CONDITIONS:

Unit 1 and Unit 2 are operating at 100% power. The Unit 2 Unit Supervisor has asked that a valve lineup be performed on valve 2CV XXX.

INITIATING CUES:

Entry into an area with expected dose rates of 1050 mrem/hr is required to check the position of a specific valve and perform a general inspection of the area. Due to staffing restrictions, the entry is to be made by only ONE individual and RPT is NOT in attendance.

ADMIN3(9/14/98)/7 Byron98EXAM **APPROVED 12/06/94** 

Facsimile

BRP 6200-5T9 Revision 0

# RWP 981XXIXX

### RWP ACKNOWLEDGEMENT LOG

I certify that I have read, understand, and will comply with the requiremnts of the RWP. I have reviewed the radiological conditions for my work area, and that I will not exceed the authorized exposure limit for this RWP.

SIGNATURE	DATE	BADGE #	SIGNATURE	DATE	BADGE #
10 /6.	10	101101	<u> </u>		
10	88 354-				
		~ 9			
115	FON	IX			
~~					
					<u> </u>
		<u>↓</u>			<u> </u>

(Final)

-1-

(9756SS/WPF/120594)

	Pre-	Winnen ic	
	ALARA ACTION REVIEW *	aurona di	
	RWP # 06 / 98		
	Station / Year / Sequence SARC Required if > 30	P/Rem Y	NV
Tob De	scription, LHRA entries: Including inspections, ops rounds and OOS, minor maintenance		
Work L	ocation: All RPA's Work Group: ALL		
RWP R	equest #: Various Work Analyst: NA		
ALARA	walkdowns recommended: Yes No Comments:	entry. Multiple	dose field
1.	State the condition, from BRP 6200-5T8, that requires this AAR. entry.	o	
2.	Determine which of the following will contribute to reducing exposure	e for this	work:
	<ul> <li>Shielding in area or equipment? (use historical and/or current surveys to determine needs).</li> <li>Comments: Review for each application.</li> </ul>	Yes	No
	b. Portable Ventilation? (Hepa size/type, tent size etc.) Comments: Review for each applicat	Yes	No
	c. Mock up training? (Available photos, tapes, etc.) Comments: Review for each application.	V Yes	No
	d. Source Term reduction? (Identify flushing, points, valves, systems and procedures. Comments: Review for each application.	Yes Yes	No
	e. Remote handling tools, Robotics? (underwater work, reach rods, cameras: Comments: Review for each application	Yes Yes	No
	f. Decontamination of area or equipment? (Consider pre/post decon of work area based on historical/current surveys: Comments:	Yes	No
	g. Is Surrogate Tour or video maintenance information available?	¥ Yes	No []
	Longert to Reactor Cavity Incore Area?	Yes	No
3.	Access to Reactor cavity incore more		L
	(Approval, 11 res) Date Date		
	Health Physics Supervisor Date		
4.	Access to whole body dose rates >/= 15 Rem/hour?	Yes	No 🖌
	(Approval, if Yes)		
	Health Physics Supervisor Date		
5.	ALARA Brief required for this work?	Yes	No
	Initial Other	10/00/07	
	Completed by: Curt Repass Date:	12/22/97	
	*454-251-82-01200-07		
(1692)	AA/DOC/120597)	( jul	

AAR # 06 / 98	ALARA BRIEF CHECKLIST NWR # Various
LHBA entries: Including ins	(or activity description)
All RPA's	
Nork location: Antorio	briefing, Mark man supersizer Work grown V
RPLS RPT V QC Shift M	Manager Operations Vendor SQV
Others	Historical V RPT in attendance V YES NO (with front desk or Control Point RPT). YES NO Initial Other
	Briefing Notes
A. RWP Requirements PC Class X1	LX2X3X4 Daily: 100 Alarm: 80 Rate: 300
Face Shield: Y V N Respirato	or: Y N Type of waterproof outer layer as needed
Norking area dose rates Persurvey	s Contamination Levels: per surveys
EDE ALABA evaluations will determine res	spiratory needs
PPT Coverage Requirements:	Coverage type: Continuous or documented stay times and timekeening
Surveys needed: bir Samples	Other Bota and IRP/Frequency
burveys needed.	s needed per survey beta evaluation/continued space
Minekeen/stautime remuirements:	Startimes desumented as DWD and for bots assessment if paeded
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖌 LHRA 🖌 HCA 🖌 A/E 🖌 Red Zone 🖌 s. plication for shielding needs or potential.
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap Contamination Control techniques	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖌 LHRA 🖌 HCA 🖌 A/E 🖌 Red Zone 🖌 s. plication for shielding needs or potential. s to consider: see below
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap Contamination Control techniques Safety needs and/or exemptions:	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖌 LHRA 🖌 HCA 🖌 A/E 🖌 Red Zone 🖌 s. plication for shielding needs or potential. s to consider: see below As per work supervisor.
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap Contamination Control techniques Safety needs and/or exemptions: Has a TEDE ALARA evaluation been	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖌 LHRA 🖌 HCA 🖌 A/B 🖌 Red Zone 🖌 s. plication for shielding needs or potential. s to consider: see below As per work supervisor. n completed, if needed?As needed Results
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap Contamination Control techniques Safety needs and/or exemptions: Has a TEDE ALARA evaluation been Insure work area pre/post decon	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖌 LHRA 🖌 HCA 🖌 A/E 🖌 Red Zone 🖌 s. plication for shielding needs or potential. s to consider: see below As per work supervisor. n completed, if needed?As needed Results as needed, based on current surveys.
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap Contamination Control techniques Safety needs and/or exemptions: Has a TEDE ALARA evaluation been Insure work area pre/post decon Insure all hotspot, low & high o	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖌 LHRA 🖌 HCA 🖌 A/E 🖌 Red Zone 🖌 s. plication for shielding needs or potential. s to consider: see below As per work supervisor. a completed, if needed?As needed as needed, based on current surveys. dose areas are identified as per survey.
Timekeep/staytime requirements: C. Contingency Plan: Dose rates exce D. ALARA Brief requirements: Ent Rad Holdpoints: As per current surveys Areas for shielding: Check each ap Contamination Control techniques Safety needs and/or exemptions: Has a TEDE ALARA evaluation been Insure work area pre/post decon Insure all hotspot, low & high of RPT coverage or stay times MUST be in pla ates also required. Insure Low dose and h Any maintenance activities require RP reviee Fime and exposure should be estimated pri RPT approval required before entry on this R NO ACCESS TO AREAS > 15 REM/Hr on to Determine entry requirements are IAW BAP	Stay times documented on RWP and for beta assessment if needed. eed planned or historical information - Stop work, exit area immediately, contact RPL try into: HRA 🖉 LHRA 🖉 HCA 🖉 A/B 🖉 Red Zone 🖉 s. plication for shielding needs or potential. s to consider: see below As per work supervisor. In completed, if needed?As needed Results as needed, based on current surveys. dose areas are identified as per survey. ace prior to entry, documented and communicated to workers. Working area dose igh dose areas are identified. w before entry. or to entry. WP. this RWP. 1450-2.

(1692AA/DOC/120597)

-2-

Additional Comments

APPROVED 12/06/57

1	FOR TRAINING
	and own v
. 1	USE UNLY

Facsing C

Forticies, 10

LLAR	A Brief Information	Cor	ment			_		
1	Radiological Hold points identified?	~	YES		NO		N/A	
2	Shielding of areas and/or equipment.	V	YES		NO		N/A	
3	Contamination control techniques.	V	YES		NO		N/A	
4	Safety needs and/or exemptions for work identified.	V	YES		NO		N/A	
5	TEDE ALARA evaluation needed?	V	YES		NO		N/A	
6	Decon of areas and/or equipment.	V	YES		NO		N/A	
7	Hot spots, low and high dose waiting areas identified?	V	YES		NO		N/A	
8	Airborne concerns	V	YES		NO		N/A	
9	Hot parti le controls needed?	V	YES		NO		N/A	
10	Procedural requirements # BAP 1450-2	V	YES		NO		N/A	
11	HEPA Requirements?	V	YES		NO		N/A	
1.2	Source Term concerns. Flushing / hydrolazing?	V	YES		NO		N/A	
13	Use of Remote handling tools?		YES	~	NO		N/A	
14	Use of high speed tools needed?		YES		NO	V	N/A	
15	Outside work group interference?		YES	V	NO		N/A	
16	Ventilation/radiological release concerns? Containment/FHE area rad monitor setpoints reset?	V	YES		NO.		N/A	Determine affect on any area rad monitors
17	Communication needs?	V	YES		NO		N/A	
18	Use of robotics?	V	YES	T	NO	T	N/A	
19	Lighting / work area concerns?	V	YES	T	NO		N/A	
20	Photos, tapes, prints available? Surrogate Tour info?	V	YES		NO		A/M	
21	Wireless Remote Monitoring?	V	YES		NO		N/A	
22	Equipment train changes?	V	YES		NO		N/A	

-3-

Completed by

(1692AA/DOC/120597)

	ALARA REVIEW	CONTINUATION/UPDATE
	/ 98	RWF #
Work scope:	LHRA entries: Including inspections, ope	rounds and OOS, minor maintenance.
Work locatio	on: All RPA's	

On the lines below dosument any or all of the following information:

- 1. Changes to the original AAR.
- 2. Suggestions, based on job performance, for enhancing this AAR for future work.

Revision 10

- 3. Additional information for the current AAR.
- 4. Any other comments or concerns.



-4-

FOR TRAINING USE ONLY

1

			ALARA RECOMMENSE HECKLIST	(Internet	in the second	
ite/	Time _	Contrast in the	/ 04:15 RWP#	-6.4	A State And	
	Radia	tion Pro	otection Personnel			
		If any 1 2	<u>NOTE</u> item(s) listed in section A have been answered An <u>ALARA Action Review is required</u> per BAP A Job Specific RWP is required per BAP 575-9	yes: 100-2.		
				YES	5	NO
	Α.	Do any	of the following conditions exist?	[ •	1	[
		1.	Total dose equivalent for the planned job is expected to equal or exceed <u>one (1)</u> Rem and job duration to be less than 100 man hours.	ſ	1	[~
		2.	Planned work will involve prolonged [ > 1 (one) hour] occupancy in an Airborne Radioactivity Area. (>.3 DAC)	ſ	1	[ •
		3.	Entry into either unit's reactor cavity incore area is planned (BAP 1450-3 addresses requirements to access reactor cavity incore space)	ſ	]	[ ~
		4.	Entry into locked High Radiation Area (>1000 mrem/hr) Ensure RPT in attendance or complete maximum stay time worksheet BRP 6200-5T10	[~	1	ſ
		5.	Items will be <u>removed</u> from the Spent Fuel Pool or <u>flooded</u> Reactor Cavity	[	1	[ •
		6.	Entry inside the containment missile barrier at $\geq$ 10% Reactor Power	[	1	[ •
		7.	Entry to containment 426' el. re-fuel floor cavity area at $\geq$ 10% Reactor Power	ſ	]	[ •
		8.	Work will include tasks involving the Incore Detector System	[	1	[*
		9.	Work in areas where Hot Particles have been identified	[	1	
		10.	Work will involve diver activities in radiologically posted areas	[	1	
		11.	Work will involve radiography	[	]	[ •
		12	Task will require workers to transient > 15 rem/hr whole body dose fields	. (	]	[ •
	454-2	* 13.	Work will involve accessing areas adjacent to spent fuel transfer tube where dose rates increase	τ. [	1	[ ~

BRP C.JU

1

USE ONLY

(1170SS/WPF/120597)

		YES	NO
в.	Are any of the following conditions expected?	(, )	1111
	1. Primary or contaminated system work	•	
	<ol> <li>involving system breech. (Hot Particles?)</li> <li>System transfer of high level radioactive</li> </ol>		
	fluids/resins, etc. > 100 mrem/hr @ contact 3. Work involves the Waste Gas System		11
c.	Will work include any of the following Fuel <u>Pool/flooded</u> Reactor Cavity area activities?	[ ]	[ 🖌 ]
	1. Items will be moved in the fuel pool/	[]	[1]
	2. Involves work with tools/equipment that have	[ ]	[1]
	3. Involves work with fuel pool/cavity filter	r 1	141
	changes		
D.	Will work involve containment entry to the following areas?	[ ]	[ 🖌 ]
	1. Entry into containment, inside missile barrier @ > 10% reactor power	[ ]	[*]
*	2. Entry into the Steam Generator or Processiver Coffin area(s) 6 > 10% reactor		
	power	. [ ]	[ • ]
	3. Involves access to the Polar traffe $0 \ge 10$ % reactor power	. []	[ • ]
Ε.	Will tasks involve handling of Radioactive Waste/Materials/Sources that include any of the following criteria?	[]	[ • ]
	<ol> <li>Sorting or transporting trash/rad materials reading &gt; 100 mrem/hr @ contact with the</li> </ol>	( )	(~)
	<ol> <li>2. Sorting trash/laundry bags marked as coming</li> </ol>		
	from a Hot Particle (Red) zone Processing sludge from drums to HIC		ivi
		]	
	<u>NOTE</u> <u>If</u> any of the items in sections B through E are antion found during pre-job surveys: <ol> <li>A Job Specific RWP is required as described in BAP 575-9.</li> <li>An <u>ALARA Review may be requested</u> at the discre Rad Protection Supervision or upon the request work supervisor.</li> </ol>	cipated tion of of the	
AAR	Required: YV N		
RPT	Sign: Date	12-18-9	7
	(Final) FOR TRAI	MING	

-2-

USE ONLY

### Facsimile

1 . . .

### ATTACHMENT B

PROTECTIVE CLOTHING CLASSIFICATIONS AND GUIDELINES

CLASS 1 (GREEN)

COTTON GLOVE LINERS RUBBER GLOVES CLOTH BOOTIES RUBBER SHOE COVERS CAP

CLASS 3 (WHITE)

DOUBLE COVERALLS DOUBLE CLOTH HOOD COTTON GLOVE LINERS DOUBLE RUBBER GLOVES CLOTH BOOTIES DOUBLE RUBBER SHOE COVERS

CLASS 4 (RED)

ONE PAIR OF COVERALLS WATERPROOF OUTER LAYER CAP (optional) DOUBLE CLOTH HOOD COTTON GLOVE LINERS DOUBLE RUBBER GLOVES CLOTH BOOTIES PLASTIC BOOTIES DOUBLE RUBBER SHOES

### CLASS 2 (BLUE)

ONE PAIR OF COVERALLS (optional) I HOOD ON GLOVE LINERS RUBBER GLOVES CLOTH BOOTIES RUBBER SHOE COVEPS

### Guidelines:

In lieu of a cloth hood, a cap may be substituted unless:

- 1). The worker will be entering a high contamination area, or
- 2). The worker will be wearing a face shield or respiratory protection, or
- 3). The worker will be carrying smearable contaminated items over their shoulder(s), or
- 4). The worker will be in a congested area, or
- 5). When specified by Radiation Protection.
- For contamination control, hair should be tucked inside the cap propoveralls.

### Facsimile

### ATTACHMENT B

PROTECTIVE CLOTHING CLASSIFICATIONS AND GUIDELINES, Cont.

### Guidelines:

For Class 1 and Class 2 Protective Clothing the following substitutions may be made:

- Double or multi-layers of surgical gloves may be substituted for rubber gloves for contamination control for the following job evolutions or tasks with prior RP approval:
  - a). Performing light work
  - b). Inspections/walkdowns
  - c). 0.0.S. when no climbing is involved
  - d). Instrument cals. (yellow tight surgical type gloves may be worn as substitute)
  - e). Minor decon of small equipment or parts
  - f). Performing routine RP surveys for radiation/contamination
  - g). Handling/filling out paperwork during job evolutions
  - h). Any activity approved by RP dept.
- 2). It is acceptable to wear, with prior RP approval, surgical gloves and/or colored cotton glove liners in clean (non-contaminated) areas of the RPA for handling of potentially contaminated materials or equipment such as:
  - a). Informational radiological smears
  - b). Maslin wipes or smears of equipment or floor
  - c). Lead Blankets
  - d). Bagged equipment coming from a posted contaminated area
  - e). Laundry bags from SOPs
  - f). Whenever RP gives prior approval

FOR TRAINING

# Byron Station Radiation Work Permit

Radiation Work Permit Worker Information

RWP #: Rev: 0

			NAMES OF THE OWNER ADDRESS OF	for the residence of the second second second
Unit:	Building:	Elevation:	Location:	
0	AUX AND RW	ALL	LHRAs	

· · · ·

Equipment Name: NA

# RWP Description: LHRA ENTRIES: INCLUDING INSPECTIONS / OPS ROUNDS AND OOS / MINOR MAINTENANCE

RWP Dose Approval:	100	mrem/day
Accumulated Dose Alarm:	80	mrem
Dose Rate Alarm:	300	mrem/hr

# **Exposure Monitoring Requirements**

TLD and DIGI (Electronic Dosimeter) required.

### Special Instructions

ALL WORK ON THIS RWP MUST HAVE PRIOR RP APPROVAL.

NO ENTRY INTO AREAS REQUIRING PERSONNEL NEUTRON MONITORING

REVIEW SURVEYS OF RADIATION AND CONTAMINATED AREAS.

CLASS 1 CLOTHING (MINS) REQ. FOR VISUAL INSPECTION / NO CLIMBING.

CLASS 2 CLOTHING (FULL SET) REQ. FOR CLIMBING ABOVE 6 FT. / TIGHT AREAS POSTED CA.

WATERPROOF OUTER LAYER REQ. FOR WORK WITH RUNNING OR SPLASHING WATER.

THIS RWP IS FOR ALL WORK GROUPS, BUT ONLY FOR MINOR ACTIVITIES SUCH AS: STAGING EQUIPMENT / OPER. ROUNDS / INSPECTIONS / MINOR MAINT.

NO ENTRY INTO 15R/HR WHOLE BODY DOSE RATE WITHOUT PRIOR HPSS APPROVAL.

# **Respiratory Protection Required**

None

### Protective Clothing Required

No PCs required in clean areas.

Class 1 (Mins) Cloth Booties Rubber Gloves Cotton Glove Liners Rubber Shoe Covers Cap Lab Coat

Class 2 (Full Set) Cloth Booties Rubber Gloves Cotton Glove Liners Rubber Shoe Covers Cap Cloth Hood Coveralls



USE ONLY

	RWP	#	Rev:	0
--	-----	---	------	---

Survey Freque	ency Requirements
Radiation:	ROUTINE / New work Location
Contamination:	ROUTINE / New Work Location
Airborne:	ROUTINE

# Pre-Job Briefing Required Yes

ENTRY INTO R-LOCKED HIGH RAD. AREAS REQ. RPT IN ATTENDANCE OR CALC. STAY TIMES DOCUMENTED AND COMMUNICATED TO WORKERS.

# R.T. Coverage / Comments:

Intermitent: Yes

Continuous tech coverage required if no current survey available for areas to be entered or if RP Supervision feels it necessary.

# FOR TRAINING

USE ONLY

RP Supervisor BARTON BARRY M	12/31/97 10:02:56 AM	ALARA Review By CURT REPASS AAR 06-98-A011	10/20/97 12:00:29 PM
Completed By ROBERTSON MARTA J	10/20/97 12:00:11 PM	Terminated By BARTON BARRY M	2/16/98 10:17:19 AM
Job Supervisor			

Page 2

ATTON NUMBER:       EVEN       UNIT NUMBER:       00         "ATTON NUMBER:       EVEN       INTENUMBER:       00         OCATION DESCRIPTION:       ALL LIBRA ENTRIES       IRODMAREA: ALL       COL:       ROW:         OCATION DESCRIPTION:       ALL LIBRA ENTRIES       IRODMAREA: ALL       COL:       ROW:         OUTP. NAME:	PADIATION WORK PERMIT REQUEST	r	DATE A	ND TIME:	01/07/98 09:00
"ATTON NUMBER:       BYR       UNIT NUMBER:       00         JUDING:       ALL       IELEVATION:       ALL       ROW:       00         JUDING:       ALL       LEPA TON:       ALL       ROW:       ROW:	KADIATION NORTERAITT REQUEST		RWPE	REQUEST	
ALDING: ALL   ROM/AREA: ALL COL:ROW: NUTP. NAME:	ATION NUMBER: BYR UNIT NUMBER: 00	RWP/REV:	A A A A A A A A A A A A A A A A A A A	00/	
QUP. NAME:         WR NUMEER:         TTIVITY       LARA ENTRIES INCL. MISC MINOR WORK         ESCRIPTION OF WORK (Be specific or attach clarifying documents):         RAG ENTRIES : INCL. INSPECTIONS / ROUNDS / OOS / MINOR MAINT         BECK WHICH ITEMS ARE REQUIRED OR APPLY:         Confined/Zaclosed or Taak         Component Tassembly         Component Tassembly         Component Tassembly         Component Tassembly         Work S than 6 feet Above Floor         Suffecting         Suffect Preparation Type:         LIST ALL TASKS (Including Support Groups)         PRESON         HOURS IN         WORK AREA         WORK AREA         EQUESTOR:         ALTERNET:         Strict Preparation Type:         TOTALS:         TOTALS:         Strict Preparation Type:         TOTALS:         Strict Preparation Type:         TOTALS:         Strict Preparation Type:         TOTALS:         TOTALS:         Strict ONTON FUNCTION FOR MAINT         PRESON         HOURS IN         Strict Preparation Type:         TOTALS:         Strict Preparation Type:	ILDING: ALL ELEVATION: ALL CATION DESCRIPTION: ALL LHRA ENTRIES	ROOM/AREA	: ALL	COL:	ROW:
WR NUMLER:       LIPA ENTRIES INCL. MISC MINOR WORK       EPN:       TASK/DEP         TIVITY       LIPA ENTRIES INCL. MISC MINOR WORK	QUIP. NAME:				
ESCRIPTION OF WORK (Be specific or attach darifying documents): DATA ENTRUES : INCL INSPECTIONS / NOINDS / OOS / MINOR MAINT HECK WHICH ITEMS ARE REQUIRED OR APPLY: Checkists NA Praining of Vessel or Tank Component Classeembly Confined/Enclosed Space Entry Use of Controlled Rad. Sources - Notability - Noting - Notation Removal - Notat	VR NUMEER: TIVITY LHRA ENTRIES INCL. MISC MINOR WORK		EPN	:	TASK/DEP
HECK WHICH ITEMS ARE REQUIRED OR APPLY:       Sweeping       Asbestos Removal       Changes in Ventilation         Checklist NA       Sweeping       Drilling       Asbestos Removal       Changes in Ventilation         Component Fisassembly       Insulation Removal       Poils associated cavities/Pis.       Classeciated Cavities/Pis.         Confined/Eaclosed Space Entry       Insulation Removal       Packing Removal       Classeciated Cavities/Pis.         Seaffolding       Spitabl/Running Water       Packing Removal       Cut or Grind Type:       Use of Containament Devices         Saffolding       Open Process Lines       Packing Removal       Work Removal       Work Below Grating         Surface Preparation Type:       Its ALL TASKS (Including Support Groups)       FOR RAD. PROTECTION USE       WORK AREA         INSPECTIONS/ ROUNDS / OOS / MINOR MAINT       1000       000       000         St. COMPL DATE:       350.0       .000       .000         St. COMPL DATE:       USEE       Sto.0       .000         St. COMPL DATE:       EARRY       DEPARTMENT       PHONE       2975         DDITIONAL RP COMMENTS       EARRY       DEPARTMENT       PHONE       2975         DDITION REVIEW BY:       EARTON       EARRY       EARRY         D PROTECTION REVIEW BY: <t< td=""><td>ESCRIPTION OF WORK (Be specific or attach clarifying documents): HRA ENTRIES : INCL INSPECTIONS / ROUNDS / 00S / MINOF</td><td>R MAINT</td><td></td><td></td><td></td></t<>	ESCRIPTION OF WORK (Be specific or attach clarifying documents): HRA ENTRIES : INCL INSPECTIONS / ROUNDS / 00S / MINOF	R MAINT			
LIST ALL TASKS (Including Support Groups)  PERSON HOURS IN WORK AREA BY WORK AREA BY WORK AREA BY	IECK WHICH ITEMS ARE REQUIRED OR APPLY:         Checklist N/A       Sweeping         Draining of Vessel or Tank       Brushing         Component Disassembly       Weld/Brazing/Solder         Confined/Enclosed Space Entry       Insulation Removal         Use of Controlled Rad. Sources       Radiography         Work > than 6 feet Above Floor       Open Process Lines         Scaffolding       Splash/Running Water	Asbestos Removal Drilling Robotic Welding Plasma/Air Arc Cut Movement of Shield Packing Removal Cut or Grind Type:	ting ing	- Changes Remova Pools as Use of C (glove ba Work B	s in Ventilation I of Equip. from Fuel sociated cavities/Pits. Containment Devices ags) elow Grating
PERSON HOURS IN WORK AREA     WORK AREA DOSE RATE (mR/HR)     PERSON-REM ESTIMATE       Inspections/ ROUNDS / 005 / MINOR MAINT     355.0     .00     .000	LIST ALL TASKS (Including Support Groups)		FOR R	AD. PROT	TECTION USE
TOTALS       350.0       .000         ST. START DATE:	INSPECTIONS/ ROUNDS / OOS / MINOR MAINT	PERSON HOURS IN WORK AREA	WORF DOS RATE (	( AREA SE mR/HR) . 00	PERSON-REM ESTIMATE .000
ST. START DATE :   ST. START DATE :   ST. COMPL DATE:    EQUESTOR:  AME (PRINT) BARTON BARRY DEPARTMENT PHONE 2975 DDITTIONAL RP COMMENTS  EP DATA  AD PROTECTION REVIEW BY: BARTON BARRY AD PROTECTION REVIEW BY: OUT/07/98 D PROTECTION REV TIME : 09:00 SEE ATTACHED LIST	TOTAL	S : 350.0	25		.000
ADDITIONAL RP COMMENTS           REP DATA           RAD PROTECTION REVIEW BY:         BARTON           BARRY           AD PROTECTION REVIEW BY:         01/07/98           D PROTECTION REV TIME :         09:00	ST. START DATE : USE USE EQUESTOR: AME (PRINT) BARTON BARRY	DEPARTMEN	ат	• PHON	TE 2975
TAD PROTECTION REVIEW BY: BARTON BARRY AD PROTECTION REV DATE : 01/07/98 D PROTECTION REV TIME : 09:00 SEE ATTACHED LIST	DDITIONAL RP COMMENTS				
AD PROTECTION REVIEW BY: BARTON BARRY AD PROTECTION REV DATE : 01/07/98 D PROTECTION REV TIME : 09:00 SEE ATTACHED LIST					
AD PROTECTION REVIEW BY: BARTON BARRY AD PROTECTION REV DATE : 01/07/98 D PROTECTION REV TIME : 09:00 SEE ATTACHED LIST	EP DATA				,
SEE ATTACHED LIST	AD PROTECTION REVIEW BY: BARTON BARRY AD PROTECTION REV DATE : 01/07/98 D PROTECTION REV TIME : 09:00	Y			
	SEE ATTACHED LIST				

# RWP INFORMATION LOG

1
N'BARRARA MREASTAN
Contract, and a lot of the second
Construction of the Lobort State
NOTICE AND ADDRESS OF
and a second and the second

Kive

h: vnydocuments vddata vinfolog.xls

### **APPROVED 02/63/94**

### Facsimile

### BRP 2000-T411 Revision 2

### OT-XXX OUTSIDE BUILDING BLANK



### Facsimile

### Maximum Stay Time Worksheet For Areas >1000 mrem/hr When RPT Is Not In Attendance

Max stay time required in areas >1000 mrem/hr when a RPT is not in attendance (Tech spec 6.12.2)

RWP # 98XXXX

Date	Work Group Job Description	Authorized Daily Dose (mrem)	Working Dose Rate (mrem/hr)	** Maximum Stay Time	Radiation Protection Supervision Initials
Example: 01-01-95	CV resin transfer	300	1500	12	JAD
9/14/98	VALVE LINE-UP	300	1050	17	JRT
				·	
· · · · · · · · · · · · · · · · · · ·					
			FORT	R. S.	
			USE	DNLY	(ma)

\*\*Worker MUST leave the area when stay time has expired OR upon electronic dosimeter alarm due to accumulated dose, whichever occurs first.

(Final)

### Byron Station Operations Training Job Performance Measure

LO TASK DESCRIPTION: GSEP Classification And Protective Action Recommendations NLO TASK DESCRIPTION: N/A K/A NUMBER RO/SRO RATING 2.2/4.0 2.4.38 2.4.41 2.3/4.0 JPM NUMBER Task Number Job Position SM ADMIN 4 SRO Revision: Date: REVIEWED: INSTRUCTOR DATE APPROVED: GROUP LEADER DATE Start Time: \_\_\_\_\_ Stop Time: Estimated Time for Completion: This JPM was [] Performed in the [] Control Room [] Simulated [ ] Plant [ ] Other \*\* [] Simulator [] Mockup \*\* [ ! Other EXAMINEE: \_\_\_\_\_ EVALUATOR: \_\_\_\_\_ DATE: [ ] SATISFACTORY [ ] UNSATISFACTORY Comments: ADMIN04 (9/14/98)/1

Byron98EXAM

Specific Information:

 These items were used as reference material in the development of this JPM:

BZP 200-A1; BZP 300-A1; BZP 300-A2

- 2. These items are expected to be used by the examinee in the performance of the task: BZP 200-1; BZP 200-A1; Byron Station GSEP; BZP 300-A1 NARS Form (BZP 310-2T1); BZP 300-A2 PARS
- 3. Information to the Examinee and the Evaluator:
  - a. <u>Initial Conditions</u>: Accident conditions have existed for BOTH Units for the past 15 minutes. The initiating event was a LOCA on Unit 2 coincident with rupture of the active Waste Gas Decay tank.
  - <u>Task Initiating Condition</u>: The status for each Unit is provided on ATTACHMENT 1.
  - c. <u>Initiating Cue</u>: Based on current event parameters, re-classify the event and complete an associated NARS form to include PARs information.
  - d. Your Position: Acting Station Director (Shift Manager)

4. Terminal Performance Objective: (TPO) Determine the highest accident classification, complete the NARS form, and determine appropriate Protective Action Recommendations.

- Critical Steps(\*)
   3, 4, & 6
- 6. Identification of Impacted Systems: If this task is performed incorrectly, the following adverse reactions could occur: Failure to complete CFR reporting requirements and failure to provide recommendations for public protection due to

to provide recommendations for public protection due to accident conditions.

ADMIN04 (9/14/98)/2 Byron98EXAM PERFORMANCE CHECKLIST

STANDARDS

RECORD START TIME

		* Provide the candid * 300-A1) and PAR DE * A2), as necessary.	dat ETE	<u>NOTE</u> e with blan RMINATION F	k NARS Form orm (BZP 3)	******* m (BZP 00- ******	** * * * *	
	1.	Refer to BZP 200-1 (A1), "Byron Emergency Action Levels".	Lo B2	ocate and Op ZP 200-1.	pen		D	
	Note	a: Candidates may list each i	Indi	vidual EAT. as	follows			
	2.	Classify the Event utilizing BZP 200-A1.	De	termine the f Ls apply:	ollowing	a	0	D
				Both Units	Unit 2			
				•RS-1	•FP 3.a •FP 3.d			
	3.	Determines applicable classification.	De cl fc EM	termine HIGHE assification or BOTH units ERGENCY from	ST of event is SITE RS-1 EAL	D	D	0
•	4.	Completes NARs Form.	Co	mplete NARS F	orm	•	•	0
			0	Status - [A] [B] EXERCISE DRILL	Actual, , or [C]			
				Station - [E]	Byron			
			•	Classification SITE AREA (or determined a	n - [C] r as			
				Time - [curr	rent]			
				Date - [cur	rent]			
				EAL - RS1				
			•	Release - [C] OCCURRING				
			•	Type - [B] R	A GAS			
			•	Wind Dir fr degrees	rom 40			
				Downwind Sect	tor L			
			•	Wind Speed -	10			
				miles/hr (s	u NARS Form u	oled ad	Meterds	ar 1
					and order my	ks/h t	- Qued C	tile) the
					/	1		

ADMIN04 (9/14/98)/3 Byron98EXAM

PERFOR	MANCE CHECKLIST	STANDARDS	SAT	UN <u>SAT</u>	<u>n/a</u>
5.	Refer to BZP 300-1, " Protective Actions Recommendations" and BZP 300-A2, "Recommended Protective Actions".	Locate and Open BZP 360-1 and 300-A2.	0	٥	۵
* 6.	Determines PARs.	<pre>Determine PAR: • Site Area Emergency • Release &gt; 4.85E4 µCi/sec • PAR = (S) S) S) Provide PARs on NARS F section 9: • [C] • [D] (Shelter all sectors 0-2 mil radius) • [F] (Shelter AT LEA sectors K, L, M or downwind 2-5 mile radius) • [G] (Shelter AT LEA sectors K, L, M or downwind 5-5 mile radius)</pre>	C Form le ST 4 5 5		
		mile radius)			

RECORD STOP TIME

COMMENTS :

ADMIN04 (9/14/98)/4 Byron98EXAM
TASK CONDITIONS:

You are the Acting Station Director.

Accident conditions have existed for BOTH Units for the past 15 minutes. The initiating event was a LOCA on Unit 2 coincident with rupture of the active Waste Gas Decay tank.

The status for each Unit is provided on ATTACHMENT 1.

INITIATING CUES:

Based on current event parameters, re-classify the event and complete an associated NARS form to include PARs information.

ADMIN04(9/14/98)/5 Byron98EXAM

# Byron STATUS

PARAMETER	UNIT 1	UNIT 2
Status prior to event	MODE 4, 208°F 300 psig in heatup	MODE 1, 99% power
Initiating Event Diagnosed event/ Procedure status Equipment failures CETC temperatures	Both RHR pumps currently unavailable (Bus 142 deenergized; RHR Pump A stopped) Loss of Shutdown Cooling/ At Attachment B of BOA PRI-10 Ruptured Waste Gas Decay Tank (in-service) Electrical fault on bus 142 RHR Pump A stopped due to erratic indications 212°F	LOCA LOCA, RCPs tripped At step 26 of BEP-0 DG 1B failed to start SI Pump B breaker tripped on start 540°F
PZR/RCS pressure	300 psig stable	250 psig slowly dropping
PZR level	62% and lowering	offscale low
S/G levels (A-D) [NR]	25%, 28%, 24%, 25%	15%, 20%, 22%, 18% increasing
S/G pressures (A-D) [psig]	0, 0, 0, 0	800 , 800, 800, 815
CNMT pressure	.2 psig stable	38 psig and lowering
CNMT radiation AR020/021 MSIVs (A-D) [C-closed; O-open] Aux Bldg Vent Stack Monitors (WRGM)	 C, C, C , C 2.1x10 <sup>6</sup> μci/sec	200 R/hr C, C, C, C 4.2x10 <sup>6</sup> µci/sec
Charging/ECC3 flows: Charging	115 gpm	
cv		530 gpm
SI		750 gpm
RHR		0 gpm
Meteorological	Wind is from 40	CNMT Spray normal degrees at 10 mph

ADMINC4 (9/14/98)/7 Byron98EXAM

APPROVED 12	2/30/97	Facsimile (UTILITY FORM)	BZP 310-2T1 Revision 0
UTILITY MESSAGE N	NUCLEAR ACC	DENT REPORTING SYST JANUARY, 1998	STATE MESSAGE NO. <u>N /A</u> TEM FORM
INITIAL ROLL CALL ELECTRIC OPER. IEMA IDNS WEM (Zion Only) IOWA EMD (QC Only)	Image: Construction of the second	1. STATUS 2 (ADACTUAL (BREXERCISE CORILL (D) TERMINATION	(A) DRESDEN [B] LASALLE [C] QUAD CITIES [D] ZION [B] LASALLE [C] CLINTON [D] ZION
3. ON-SITE ACCIDEN [A] UNUSUAL EVEN [B] ALERT [C] SITE AREA EM	T CLASSIFICATION NT [D] GENERAL EMERGEN [E] RECOVERY ERGENCY [F] NOT APPLICABLE	4. ACCIDENT CLASSIFIED TIME: Current DATE: Current EAL#: RS-1	ACCIDENT TERMINATED TIME: N/A DATE: N/A
6. RELEASE TO ENVI [A] NONE [B] POTENTIAL [C] DOCCURRING [D] TERMINATED	6. TYPE OF RELEAS (A) NOT APPLICA (B) RADIOACTIVE (C) RADIOACTIVE LIQUID	E     7.     WIND DIRECTION:       BLE     FROM     40       GAS     (DEGREES)       DOWNWIND SECTOR:	8. WICD SPEED [A] METERS/SEC.: [B] MILES/HR.*:/O *QUAD CITIES ONLY
9. RECOMMENDED A (A) NONE (B) PREPARE FOR (C) MITIATE PUBL	CTIONS R POSSIBLE ACTION INVOLVING TH LIC NOTIFICATION PROCEDURES II	E PUBLIC	FOLLOWING ACTIONS:
SHELTER	EVACUATE         UT           [H]         0 - 2         MI           [I]         0         MI           [J]         2 - 5         MI           [K]         5 - 10         MI	LE RADIUS LE RADIUS LES FOR SECTORS K L M LES FOR SECTORS K L M	
[L] SHEL [M] EVAC	TER SUB-AREAS: UATE SUB-AREAS:	(5	STATE USE ONLY) STATE JSE ONLY)
(N) RECOMMEND (O) CONFINE MILK (P) COMMENCE RI (Q) OTHER	POTASSIUM IODIDE (KI) IN ACCOR -PRODUCING ANIMALS ON STORE ETURN OF PUBLIC (STATE USE ON	DANCE WITH PROCEDURES (STATE D FEED AND PROTECTED WATER O LY)	USE ONLY) UT TO MILE RADIUS (STATE USE ONLY)
10. ADDITIONAL INFO	NONE NONE		
11. MESSAGE TRAN	SMITTED BY: 12. MESSA CURRE	<u>GE TRANSMITTED:</u> 13. <u>M</u> NT TIME:	ESSAGE RECEIVED BY:
(ORGANIZATION)	CURRE	NT DATE: 0	
(OUTSIDE PHONE	NUMBER)		
OUTSIDE PHONE NU ELECTRIC OPER. IEMA	IMBERS         FINAL RO           630-691-4730         □           217-782-7860         □	APPROVED BY: X	(NAME) (TIME)
IDNS WEM IOWA EMD	217-785-0600         II           800-943-0003 (ZION ONLY)         II           515-281-3231 (QC ONLY)         II	NDO NOTIFIED: (ELECTRIC OPER. ONLY	) (NAME) (TIME/DATE)
(9492AA/DOC/12	2797)	-1- Key	

**APPROVED 12/30/97** 

#### Facsimile

# BZP 310-2T1 Revision 0

### NARS FORM

### INSTRUCTIONS FOR USE (UTILITY FORM)

Complete the NARS as follows:

UTILITY MESSAGE NUMBER - For use by Utility personnel only. Number Messages sequentially, starting with 1, for the Event described. Enter "N/A" if this is a State NARS.

STATE MESSAGE NUMBER - Enter State Message Number when receiving a NARS message from the State. Enter "N/A" if this is a Utility NARS.

INITIAL ROLL CALL - Mark the box by the applicable agencies that are included in the initial roll call.

MESSAGE INITIATED (Utility Only) - Document the time and date at the completion of the initial roll call.

1. STATUS - Mark the letter corresponding to the appropriate status description.

- 2. STATION Mark the letter corresponding to the affected Station.
- ON-SITE ACCIDENT CLASSIFICATION Mark the letter corresponding to the classification issued by the Utility.
- 4. <u>ACCIDENT CLASSIFIED</u> Fill in the time and date at which the most recent accident classification was determined by the Utility. Also fill in the applicable On-Site Emergency Action Level (EAL) code number. Enter "N/A" if this is an accident termination message.

ACCIDENT TERMINATED - Fill in the time and date of the accident termination, if applicable. Enter "N/A" if this is an accident classified message.

- <u>RELEASE TO ENVIRONMENT</u> Mark the letter corresponding to the appropriate description.
- TYPE OF RELEASE Mark the letter corresponding to the appropriate release type.
- 7. WIND DIRECTION Fill in the direction from which the wind is coming, in degrees.

DOWNWIND SECTOR - Fill in the letter corresponding to the Downwind Sector. Use environmental sampling maps or the following table:

SECTOR	WIND FROM	WIND FROM DEGREES	DOWNWIND SECTOR	WIND FROM	WIND FROM DEGREES
J	N	349-11	A	S	169-191
к	NNE	12-33	В	SSW	192-213
L	NE	34-56	С	SW	214-236
M	ENE	57-78	D	WSW	237-258
N	E	79-101	E	w	259-281
P	ESE	102-123	F	WNW	282-303
Q	SE	124-146	G	NW	304-326
R	SSE	147-168	н	NNW	327-348

8. WIND SPEED - Fill in the wind speed under meters/second. For Quad Cities Station only, fill in both meters/seconds and miles/hour.

9. <u>RECOMMENDED ACTIONS</u> - Mark the letter corresponding to the appropriate protective action. Add additional information if [C] is chosen. If recommending shelter or evacuation for letters [F][G][J] or [K], provide the center line sector and at least one sector on each side of center line. Letters [L-P] are for State use only.

10. ADDITIONAL INFORMATION - Additional information should be included when:

- An equal or lesser classification is made on the other unit,
- A wind shift which results in additional downwind sectors,
- A change is made in PARs,
- Corrections to the current NARS are made.
- If the NARS is not being issued for one of the above reasons, this block should read "none".
- 11. MESSAGE TRANSMITTED BY Fill in name, organization and outside phone number of person transmitting the NARS Form information.

12. MESSAGE TRANSMITTED - Fill in the current time and date that the message was transmitted by the person listed in step 11.

13. <u>MESSAGE RECEIVED BY</u> - Fill in name, and mark the applicable organization (IEMA or ComEd), of the person receiving the NARS message and filling out the NARS Form.

"NAL ROLL CALL - Mark the box by the licable agencies that are included in the final roll call.

(9492AA/DOC/122797)

APPROVED	12/30/97	Facsimile (UTILITY FORM)	BZP 310-2T1 Revision 0
UTILITY MESSAGE	NO ST	ATE OF ILLINOIS ENT REPORTING SYSTE JANUARY, 1998	STATE MESSAGE NO
INITIAL ROLL CALL ELECTRIC OPER. IEMA IDNS WEM (Zion Only) IOWA EMD (QC Onl	Image: Message Initiated           Image: Im	1. STATUS 2. [A] ACTUAL [B] EXERCISE [C] DRILL [D] TERMINATION	STATION[A] DRESDEN[E] BYRON[B] LASALLE[F] BRAIDWOOD[C] QUAD CITIES[G] CLINTON[D] ZION
3. <u>ON-SITE ACCID</u> [A] UNUSUAL EV [B] ALERT [C] SITE AREA E	ENT CLASSIFICATION /ENT [D] GENERAL EMERGENC' [E] RECOVERY MERGENCY [F] NOT APPLICABLE	4. ACCIDENT CLASSIFIED TIME: DATE: EAL#:	ACCIDENT TERMINATED TIME: DATE:
<ol> <li><u>RELEASE TO EN</u></li> <li>[A] NONE</li> <li>[B] POTENTIAL</li> <li>[C] OCCURRING</li> <li>[D] TERMINATED</li> </ol>	VIRONMENT       6. TYPE OF RELEASE         [A] NOT APPLICABL         [B] RADIOACTIVE G         [C] RADIOACTIVE         D       LIQUID	7. <u>WIND DIRECTION:</u> E FROM AS	8. <u>WIND SPEED</u> [A] METERS/SEC.: [B] MILES/HR.*: *QUAD CITIES ONLY
9. <u>RECOMMENDER</u> [A] NONE [B] PREPARE F [C] INITIATE PU	O ACTIONS OR POSSIBLE ACTION INVOLVING THE IBLIC NOTIFICATION PROCEDURES INS	PUBLIC TRUCT THE PUBLIC TO TAKE THE FO	DLLOWING ACTIONS:
<u>SHELTER</u> [D] [E] [F] [G] [L] SHE [M] EV.	EVACUATE       UTILI         [H]       0 - 2       MILE         [I]       0       MILE         [J]       2 - 5       MILE         [K]       5 - 10       MILE         ELTER       SUB-AREAS:	TY ONLY RADIUS RADIUS S FOR SECTORS S FOR SECTORS (ST/	ATE USE ONLY) ATE USE ONLY)
[N] RECOMMEN [O] CONFINE MI [P] COMMENCE [Q] OTHER	D POTASSIUM IODIDE (KI) IN ACCORDA LK-PRODUCING ANIMALS ON STORED F RETURN OF PUBLIC (STATE USE ONLY	NCE WITH PROCEDURES (STATE US EED AND PROTECTED WATER OUT )	E ONLY) TO MILE RADIUS (STATE USE ONLY)
10. ADDITIONAL IN	FORMATION:		
11. MESSAGE TRA (NAME) (ORGANIZATIO	ANSMITTED BY: 12. MESSAGE CURRENT CURRENT	TRANSMITTED:         13. MES           TIME:	INAME) MA
(OUTSIDE PHO	NE NUMBER)		an a
OUTSIDE PHONE	630.691.4730 FINAL ROLL	UTILITY USE ONLY	
IEMA	217-782-7860	APPROVED BY:	
IDNS	217-785-0600		(NAME) (TIME)
WEM	800-943-0003 (ZION ONLY)	NDO NOTIFIED:	
IOWA EMD	515-281-3231 (QC ONLY)	(ELECTRIC OPER. ONLY)	(NAME) (TIME/DATE)
		-1-	

(9492AA/DOC/122797)

**APPROVED 12/30/97** 

#### Facsimile

# BZP 310-2T1 Revision 0

## NARS FORM

## INSTRUCTIONS FOR USE (UTILITY FORM)

Complete the NARS as follows:

UTILITY MESSAGE NUMBER - For use by Utility personnel only. Number Messages sequentially, starting with 1, for the Event described. Enter "N/A" if this is a State NARS.

STATE MESSAGE NUMBER - Enter State Message Number when receiving a NARS message from the State. Enter "N/A" if this is a Utility NARS.

INITIAL ROLL CALL - Mark the box by the applicable agencies that are included in the initial roll call.

MESSAGE INITIATED (Utility Only) - Document the time and date at the completion of the initial roll call.

- 1. STATUS Mark the letter corresponding to the appropriate status description.
- 2. STATION Mark the letter corresponding to the affected Station.
- 3. ON-SITE ACCIDENT CLASSIFICATION Mark the letter corresponding to the classification issued by the Utility.
- 4. <u>ACCIDENT CLASSIFIED</u> Fill in the time and date at which the most recent accident classification was determined by the Utility. Also fill in the applicable On-Site Emergency Action Level (EAL) code number. Enter "N/A" if this is an accident termination message.

ACCIDENT TERMINATED - Fill in the time and date of the accident termination, if applicable. Enter "N/A" if this is an accident classified message.

- 5. RELEASE TO ENVIRONMENT Mark the letter corresponding to the appropriate description.
- TYPE OF RELEASE Mark the letter corresponding to the appropriate release type.
- 7. WIND DIRECTION Fill in the direction from which the wind is coming, in degrees.

DOWNWIND SECTOR - Fill in the latter corresponding to the Downwind Sector. Use environmental sampling maps or the following table:

OWNWIND	MAND FROM	WIND FROM	DOWNWIND	WIND FROM	WIND FROM
SECTOR	N N	349-11	A	S	169-191
ĸ	NNE	12-33	B	SSW	192-213
L	NE	34-56	С	SW	214-236
M	ENE	57-78	D	WSW	237-258
N	E	79-101	ε	w	259-281
P	ESE	102-123	F	WNW	282-303
Q	SE	124-146	G	NW	304-326
R	SSE	147-168	н	NNW	327-348

8. WIND SPEED - Fill in the wind speed under meters/second. For Quad Cities Station only, fill in both meters/seconds and miles/hour.

9. <u>RECOMMENDED ACTIONS</u> - Mark the letter corresponding to the appropriate protective action. Add additional information if [C] is chosen. If recommending shelter or evacuation for letters [F][G][J] or [K], provide the center line sector and at least one sector on each side of center line. Letters [L-P] are for State use only.

10. ADDITIONAL INFORMATION - Additional information should be included when:

- An equal or lesser classification is made on the other unit,
- A wind shift which results in additional downwind sectors,
- A change is made in PARs,
- Corrections to the current NARS are made.
- If the NARS is not being issued for one of the above reasons, this block should read "none".

11. MESSAGE TRANSMITTED BY - Fill in name, organization and outside phone number of person transmitting the NARS Form information.

12. MESSAGE TRANSMITTED - Fill in the current time and date that the message was transmitted by the person listed in step 11.

13. <u>MESSAGE RECEIVED BY</u> - Fill in name, and mark the applicable organization (IEMA or ComEd), of the person receiving the NARS message and filling out the NARS Form.

NAL ROLL CALL - Mark the box by the applicable agencies that are included in the final roll call.

(9492AA/DOC/122797)



FIGURE 6.3-1 PROTECTIVE ACTION RECOMMENDATION (PAR) DETERMINATION

APPROVED 03/20/97

Facsimile

# EDOTNOTES TO FIGURE 6.3-1 BYRON STATION

Note 1. Site Specific monitor based on a 1 REM (TEDE) dose projection at 2 miles using annual average meteorology.

Note 2. Site Specific monitor value based on a 1 REM (TEDE) dose projection at 5 miles using annual average meteorology.

Note 3. Clad damage ≥ site specific Containment Fission Product Barrier Threshold Value for containment radiation level.

Note 4. Containment Design Pressure.

Note 5. Continuously reassess the need for additional PARs on changing plant conditions, effluent rates, meteorological conditions and dose projections. Never recommend a less conservative PAR once a more conservative PAR has been issued. **APPROVED 03.20/97** 

Facsimile

## BZP 30C-A2 Revision 12

TABLE 6.3-1
RECOMMENDED PROTECTIVE ACTIONS FOR
GASEOUS RELEASE CONDITIONS *(Note 1)

Contemporary and an an and an an and an and an and an					
Accident Classification	Rem (TEDE)     Rem (CDE)       Projected Doses (Rem)* in Zonal Areas X, Y, & Z       *(Note 2)       Whole Body       X     Y       Z     X       Y     Z	(Note 3) Recommended Protective Actions (S-Shelter, E-Evacuation, P-Prepare for Possible action, I. O info only) X Y Z	NARS Form Section 9		
1. Unusual Event		I. O.	9.A		
2. Alert	(1) No Release (2) Release Occurring.	I. O. PREPARE	(1) 9.A (2) 9.B		
3. Site Emergency	(1) No release in progress. (2) Potential Release or Release Occurring.	PREPARE (S) S) S)	(1) 9.B (2) 9.C,D,F & G		
4. General Emergency °(Note 3)	<ul> <li>(1) No Dose Projections Available</li> <li>(2) Any &lt;1 &lt;1 Any &lt;5 &lt;5</li> </ul>	Fig. 6.3-1 (E) S) S)	(2) 9.C,H,F & G		
	$(3) \geq 1 \geq 1 < 1 \geq 5 \geq 5 < 5$ $(4) \geq 1 \geq 1 \geq 1 \geq 1 \geq 5 \geq 5 \geq 5$	(E) E) S) (E) (E) E) *(Note 5)	(3) 9.C,H,J & G (4) 9.C,I & K *(Note 4)		
5. Recovery	N/A	I. O.	(1) 9.A		
6. Terminate	N/A	I. O.	(1) 9.A		

The symbol "()" represents the entire radius of all sectors of the designated zonal area as defined in Fig. 6.3-2, where a single ")" represents just the affected downwind sectors (minimum of three) of the designated zonal area. Example: (S) S) S). The following recommendation is (S) - shelter 0-2 mile radius, S) - shelter 2-5 mile affected downwind sectors, S) - shelter 5-10 mile affected downwind sectors.

\*For Notes 1 through 5, refer to next page titled <u>"FOOTNOTES TO TABLE 6.3-1"</u>

-3-

## Facsinile

# **EOOTNOTES TO TABLE 6.3-1**

Note 1. Control Room personnel are not expected to perform dose projection calculations. Control Room personnel may have dose projection information if the ODCS A-Model is available.

Note 2. The zones X, Y and Z are:

- X = site boundary out to 2 miles (not including 2 miles)
- Y = 2 miles out to 5 miles (not including 5 miles)
- Z = 5 miles out to 10 miles (including 10 miles)
- Note 3. Continuously reassess the need for additional PARs based on changing plant conditions, effluent release rates, meteorological conditions and dose projections. Never recommend a less conservative PAR once a more conservative PAR has been issued.
- Note 4. If evacuation is recommended for Zonal areas Y and Z and if Zonal areas Y and Z are in Wisconsin, then the recommendation for evacuation should extend only to the range at which the projected dose is 1 Rem TEDE or 5 Rem CDE to the thyroid, whichever is the greater range.

The evaluation of weather and road conditions on the ability to evacuate areas is the responsibility of State and Local governments. It is important to note that the final determination <u>advisability</u> of any Protective Action Recommendations (PARs) lies with the offsite governmental officials. These governmental officials have direct access to key, non-plant related factors necessary to finalize any Protective Action Recommendation; such as EPZ population distributions, transportation availability, special facility requirements, roadway conditions and availability.

Note 5. Recommend 0-5 mile radius evacuation on NARS form.

(Final)

(1284AA/DOC/031997)

- 4 --

FINAL AS-ADMINISTERED WALKTHROUGH JPMS FOR BYRON EXAMINATION - SEP 1998

# JOB PERFORMANCE MEASURE

# CANDIDATE CUE SHEET

# TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. The Unit is in mode 5.
- 3. RCS conditions are 188°F and 360 psig.

# INITIATING CUES:

1 Respond, as necessary, to plant conditions on the 1PM05J.

# NOTES FOR SETUP:

JPM 1 can be run in RCS low temperature and pressure conditions (MODE 5).

The desired conditions are approximately 188°F and 360 psig. This can be done with either RCS solid or Pzr bubble drawn with RCS loops filled. Source Range channel N-31 selected as audio count rate channel.

SRNI N-31 failed low, requires no particular plant conditions and is therefore suited for coupling with JPM 6.

The actions are performed as directed by BOA INST-1. The evaluated steps are 1, APPENDIX C steps 1-3, 5. The actions should include trip of the reactor per T.S. direction?

When directed by floor, MRF RP24 Bypass to bypass A Train of SSPS

# JOB PERFORMANCE MEASURE

TASK TITLE:	Respond to Source Range NI			lure	JPM No.: JPM-1		
TPO No:		K&A 1	No.: 01500	00G120	K&A IMP. 4.3/4.2		
TRAINEE:					DATE:/_/		
The Trainee:	PASSED		this JPM	TIN	IE STARTED:		
	FAILED_			TIN	E FINISHED:		
EVALUATION	METHOD:	PERFORM	-	SIMULATE_			
LOCATION:		IN PLANT_	and an and a second	SIMULATO	R		
MATERIALS:							

None

**GENERAL REFERENCES:** 

BOA INST-1, NUCLEAR INSTRUMENT MALFUNCTION

TASK STANDARDS:

Respond to Source Range NI Failure.

TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. The Unit is in mode 5.
- 3. RCS conditions are 188°F and 360 psig.

INITIATING CUES:

1. Respond, as necessary, to plant conditions on the 1PM05J.

CRITICAL ELEMENTS: (\*)

4,7,10 and 13 (ADD STEP 12; simulated but oritical) the

APPROXIMATE COMPLETION TIME: 11 minutes

PERFORMANCE CHECKLIST

STANDARDS

RECORD START TIME

If this JPM is given on the simulator, only the cues <u>underlined</u> are required to be given to the Trainee.

NOTE

 1.
 Refer to BOA INST-1, Nuclear
 Locate and open
 Image: Comparison of the second second

Note: This step may be performed at any time.

If asked: <u>All Prerequisites have been</u> <u>met.</u>

2. Determine failed channel.

DETERMINE WHICH NI CHANNEL OR FUNCTION FAILED AND GO TO APPROPRIATE ATTACHMENT:

SR CHANNEL FAILURE -ATTACHMENT C (Page 10)

3. Check SR required

Cue: P6 permissive light IS lit.

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	<u>N/A</u>
*4. Check Audio Count Rate Channel	Operable Channel – SELECTED AT 1PM07 J			
Cue: Channel N-31 selected. When operated, Channel N-32 is	Determines Affected Channel selected			
selected.	AND			
	Selects SR N-32 channel.			
5. Check Unit Mode	Unit – IN MODE 3, 4 OR 5			
Cue: Unit in MODE 5	GO TO Step 5 (Page 12).			
6. Determine Mode 5 Actions Cue: SR-31 failed.	Check SR Channels – <u>ONLY</u> <u>ONE FAILED.</u>			
*7. Defeat failed channel trip Cue: Switch is in BYPASS.	Place LEVEL TRIP switch for the affected channel on 1PM07J in <u>BYPASS</u>			
8. Defeat failed channel High Flux at S/D alarm Cue: Switch is in BLOCK	Place HIGH FLUX AT SHUTDOWN switch for the affected channel on 1PM07J in - <u>BLOCK</u>		•	
9. Check BDPS status Cue: ALARM is NOT lit	Check BDPS BLOCKED annunciator alarm (1-10-E4) - <u>NOT LIT</u>			

PERFOR VICE CHECKLIST	STANDARDS	SAT	UNSAT	<u>N/A</u>		
*10. Block BDPS Cue: Switches are in BLOCK	Place both BDPS RESET/BLOCK switches to – BLOCK • Train A • Train B					
11. Check CV pump suction aligned to VCT	Check CV pump suction aligned to VCT:					
Cue: VCT level is 45%.	1) Check VCT level – GREATER THAN 37%	-	-	6		
Cue: VCT pressure is 25 psig.	BETWEEN 15 AND 65 PSIG	u	u	E.		
Cue: Valves are OPEN.	VCT Outlet iol valves – OPEN					
	<ul> <li>1CV112B</li> <li>1CV112C</li> </ul>					
	1001120					
Cue: Valves are CLOSED.	RWST to CV pump suction valves – <u>CLOSED</u>					
	• 1CV112D					

• 1CV112E

.

	PERFORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	<u>N/A</u>
* P	12. Bypass BDPS signal for the affected SR channel	Bypass BDPS signal for the affected SR channel:	۵		
	NOTE: Use in book diagram to show how to operate switch. NOTE: Simulator Operator action: IRF RP24 to BYPASS.	<ol> <li>Place BDPS TEST- NORMAL switch on card NM107 (inside SR drawer) in – <u>TEST</u></li> <li>2)</li> </ol>			
	Cue: Alarm is LIT.	2) Check BDPS BYPASSED alarm (1-10-D3) - <u>LIT</u>			
	*13. BDPS RESET/BLOCK switches to - RESET	Place both BDPS RESET/BLOCK switches to – <u>RESET:</u>			
	Cue: Switches are RESET	<ul> <li>Train A</li> <li>Train B</li> </ul>			
	14. Notify US to evaluate T.S.	Inform US to Evaluate T.S.			
	Cue: US Notified	NOTE TO EXAMINERS ! FOR SROS ask claudying	quest	in on	
	Cue: THIS COMPLETES JPM.	conat T.S. applies.	ф.		
	RECORD STOP TIME				

COMMENTS:

.

# JPM Questions

## Question No: 1

### Reference Use: YES

A reactor startup is underway following a shutdown one day after the initial criticality for Cycle 9 on Unit 1. The estimated Critical Rod Position is 150 steps on Control Bank D. The upper administrative limit is 228 steps on Control Bank D, the lower administrative limit is 45 steps on Control Bank D and the -750 pcm limit is 118 steps on Control Bank C.

With the Shutdown Banks withdrawn, Source Range N32 reads 18 cps. When Source Range N32 reads 144 counts, the rods are at 65 steps on Control Bank C.

Explain the actions are required.

#### Expected Answer:

Since the 8-fold Bank position (65 CBC) gives an ECC Bank position of 95 steps on CBC that is below the -750 admin limit, all Control Bank rods must be fully inserted (until the SE Dept Nuclear Group documents an evaluation).

### Actual Answer:

Candidate's response matched expected answer. K/A: 015000K505 4.1/4.5 Reference(s): 1BGP 100-7T3, Rev. 8, Section C, pages 12-13. BCB-1, Figure 9, Rev. 17, ECP BOL, page 1. II-GP-XL-02, BGP 100-2 Plant Startup, Rev. 21, LO 5,6.

## Question No: 2

## Reference Use: YES

During a reactor startup with Shutdown Banks withdrawn, the following counts are noted for N31 Source Range Channel (Two Phi Meter). At 1000 hours, the operator places the Two Phi Meter TEST switch from TEST position to NORMAL with an initial count of 3 cps read at 1000 hours:

1001	-	3	1011	-	5	1021		9
1002	-	3	1012	-	5	1022	-	9
1003		4	1013		6	1023		8
1004	-	5	1014	-	5	1024	-	8
1005	-	5	1015		7	1025		7
1006	-	5	1016	-	7	1026	-	9
1007	-	4	1017	-	5	1027		9
1008		5	1018	-	7	1028		10
1009	4.75	4	1019	-	8	1029		12
1010	-	4	1020	-	7	1030	-	11

What indication would the operator expect in the control room? Include all actions that may obcur, when they should occur, and why or why not they will occur?

### Expected Answer:

At 1019, the annunciator 1-01-E3 BDPS FLUX DOUBLED should alarm. No other actuation should occur if the operator has manually BLOCKED both trains of BDPS. If NOT BLOCKED, the annunciator 1-10-E5 BDPS ACTUATED CHG SUCT SWITCHOVER will have alarmed. Position indications for 1CV112D & E would change from CLOSED (green) to OPEN (red), and 1CV112B & C would change from OPEN (red) to CLOSE (green).

Note: Follow up, if necessary, if applicant only gives answer related to BDPS manually blocked, ask what if BDPS was NOT blocked.

#### Actual Answer:

Candidate's response matched expected answer. K/A: 015000A102 3.5/3.6 Reference(s): 1BGP 100-2 PLANT STARTUP, Step F.13, page 12 BAR 1-10-E3 BDPS FLUX DOUBLED, Rev. 51. Chp 31, Source Range Nuclear Instrumentation, Pev. 1, II.C.2, pages 46-48.

# OPERATOR QUESTION SHEET

## Question No: 1

### Reference Use: YES

A reactor startup is underway following a shutdown one day after the initial criticality for Cycle 9 on Unit 1. The estimated Critical Rod Position is 150 steps on Control Bank D. The upper administrative limit is 228 steps on Control Bank D, the lower administrative limit is 45 steps on Control Bank D and the -750 pcm limit is 118 steps on Control Bank C.

With the Shutdown Banks withdrawn, Source Range N32 reads 18 cps. When Source Range N32 reads 144 counts, the rods are at 65 steps on Control Bank C.

Explain the actions are required.

## Question No: 2

# Reference Use: YES

During a reactor startup with Shutdown Banks withdrawn, the following counts are noted for N31 Source Range Channel (Two Phi Meter). At 1000 hours, the operator places the Two Phi Meter TEST switch from TEST position to NORMAL with an initial count of 3 cps read at 1000 hours:

-	3	1011	-	5	1021	-	9
-	3	1012	-	5	1022	-	9
-	4	1013		6	1023	-	8
	5	1014	-	5	1024	-	8
	5	1015	-	7	1025	-	7
-	5	1016	-	7	1026		9
-	4	1017	-	5	1027	-	9
-	5	1018	-	7	1028		10
-	4	1019	-	8	1029		12
-	4	1020	-	7	1030	-	11
		- 3 - 4 - 5 - 5 - 4 - 5 - 4 - 4 - 4	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$	-3 $1011 - 5$ $1021$ $-3$ $1012 - 5$ $1022$ $-4$ $1013 - 6$ $1023$ $-5$ $1014 - 5$ $1024$ $-5$ $1015 - 7$ $1025$ $-5$ $1016 - 7$ $1026$ $-4$ $1017 - 5$ $1027$ $-5$ $1018 - 7$ $1028$ $-4$ $1019 - 8$ $1029$ $-4$ $1020 - 7$ $1030$	$\begin{array}{cccccccccccccccccccccccccccccccccccc$

What indication would the operator expect in the control room? Include all actions that may occur, when they should occur, and why or why not they will occur?

# JOB PERFORMANCE MEASURE

# CANDIDATE CUE SHEET

# TASK CONDITIONS:

- 1. You are the Unit 1 NSO.
- 2. Unit 1 is in Mode 1.

# INITIATING CUES:

You have been directed to perform 1BOS 1.3.1.2-1, Unit One Moveable Control Assemblies Quarterly Surveillance for Control Bank B following maintenance to power cabinet.

	JOB PERFO	DRMANCE	MEASURE	E Rev. <u>5</u> , 4/29/94				
TASK TITLE:	Perform M Quarterly S	oveable Co urveillance	ontrol Assem	blies	JPM No.: JPM-2			
TPO No: IV.C.Q	<u>G-04</u>	K&A I	No.: 001000	<u>A403</u>	K&A IMP. 4.0/3.7			
TRAINEE:					DATE://			
The Trainee:	PASSED_		this JPM		TIME STARTED:			
	FAILED				TIME FINISHED:			
EVALUATION N	ETHOD:	PERFORM		SIMULA	TE			
LOCATION:		IN PLANT_		SIMULA	TOR			

MATERIALS:

1BOS 1.3.1.2-1, Unit One Moveable Control Assemblies Quarterly Surveillance.

# GENERAL REFERENCES:

- 1. Technical Specification 3/4.1.3 Moveable Control Assemblies
- 2. 1BOS 1.3.1.2-1 Unit One Moveable Control Assemblies Quarterly Surveillance

TASK STANDARDS:

 Uses the specified Rod Control system mode to perform 1BOS 1.3.1.2-1 while maintaining the following:
 a. ΔI within limits.

b. Tave changes to within -4°F and +1°F.

2. Monitors the Automatic mode of operation following completion of the surveillance to ensure correct operation.

TASK CONDITIONS:

- 1. You are the Unit 1 NSO.
- 2. Unit 1 is in Mode 1.

# INITIATING CUES:

You have been directed to perform 1BOS 1.3.1.2-1, Unit One Moveable Control Assemblies Quarterly Surveillance for Control Bank B following maintenance to power cabinet.

CRITICAL ELEMENTS: (\*) 2,4,5,8,11

APPROXIMATE COMPLETION TIME: 13 Minutes

# PERFORMANCE CHECKLIST

STANDARDS

RECORD START TIME NOTE If this JPM is given on the simulator, only the cues underlined are required to be given to the Trainee. 1. Verify all applicable Verify Data Package Cover 0 0 0 prerequisites are met. sheet is signed and dated by the SM. CUE: Cover sheet is signed and dated by SM. All RD Power Cabinets have been inspected for blown There are no blown fuses in fuses. the RD Power Cabinets \*2 Transfer Rod Control to 0 0 0 Place Rod Bank Selector MANUAL. Switch to MANUAL position. Cue: • Rod Bank Selector Switch is in ·Verify Tave is matched with MANUAL. Tref. ° Tave is MATCHED with Tref. 3. **RECORD** Initial step counter 0 0 0 **RECORD** Initial step counter readings. readings for Control Bank B in column 3a of surveillance. CUE: CBB indicates 228 steps. \*4. SELECT Control Bank B. 0 SELECT CBB Position on 0 Rod Bank Selector Switch. CUE: Rod Bank Selector Switch is in the CBB Position.

PERFORMANCE CHECKLIST STANDARDS SAT UNSAT N/A

\*

*5. CUE:	INSERT Control Bank B. Control Bank B Group Step Counters indicate 213-218 steps.	INSERT Control Bank B 10 to 15 steps.	•	•	٩
6.	RECORD Control Bank B Position.	RECORD Control Bank B Position in column 3d of	۵	٩	a
CUE:	Control Bank B Group Step Counters indicate 213-218 steps.	survemance.			
7. CUE:	VERIFY proper DRPI Indication. DRPI indicates 210-216 for Control Bank B.	VERIFY proper rod movement by DRPI Indication and signify by initialing in the space provided in column 3e of the surveillance.	•	0	٩
*8.	WITHDRAW Control Bank B.	Position Control Bank B to ORIGINAL controlling	٩	٩	a
CUE:	Control Bank B Group Step Counters indicate 228 steps.	position.			
9.	RECORD Control Bank B Position.	RECORD Control Bank B Position in column 3g of	Q	a	0
CUE:	Control Bank B Group Step	surveniditice.			

Counters indicate 228 steps.

PERF	FORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	<u>N/A</u>
10.	VERIFY DRPI and Step Counters.	VERIFY proper DRPI and Group Step Counters showing Control Bank B is restored to original position and signify by initialing in	Q	٩	٩
CUE:	DRPI and Step Counters indicate 228 steps for CBB.	column 3h.			
*11.	Restore Rod Control to Automatic	VERIFY:	Q	Q	٩
CUE	al ow Rower Interlock C.F. in	<ul> <li>Low Power Interlock C-5 is NOT LIT.</li> </ul>			
COE:	<u>NOT LIT</u> and <u>has been</u> <u>independently verified</u> .	$T_{ave}/T_{ref}$ Deviation $\leq 1^{\circ}F$			
	°T <u>ave/Tref Deviation</u> is <u>&lt;1°F</u> and <u>has been independently</u> <u>verified.</u>	•PLACE Rod Bank Selector Switch in AUTO Position			
	• <u>Rod Bank Selector Switch</u> is in AUTO position and <u>has</u> been independently verified.				
12.	Notify Chemistry Department.	Notify Chemistry Department	O	a	a
CUE:	<u>Chemistry Department has</u> been notified.	or Rod Movement.			
Cue:	THIS COMPLETES JPM.				
RECO	ORD STOP TIME				

COMMENTS:

# JPM Questions

# Question No: 1

Reference Use: YES

Given the following conditions:

- 12 hours ago, the reactor tripped from 100% power.
- All control rods were fully withdrawn at the time of the trip.
- Safety Injection was NOT actuated.
- The reactor trip breakers have been reclosed.
- Rod control was reset by manually resetting all control board group step counters to zero individually.
- The Rod Cont Startup Switch was NOT positioned to the Starup position.

How will the control rods in the CONTROL BANKS respond if the operator attempts rod movement?

Expected Answer:

Rods will fail to move regardless of the mode selected (MANUAL or BANK SELECT) because an urgent failure alarm is received.

Actual Answer:

K/A: 001000K402 3.8/3.8

Candidate's response matched expected answer.

Sat \_\_\_\_ Unsat \_\_\_\_.

Reference (s): Chapter 28: Rod Control System, Rev. 1; LO 12,17; II.A,4,b, pg 30, II.A.9.e, pg 50.

RD-7, Rod Drive Notes, Rev. 2, Start-Up Reset,

# JPM Questions

Question No: 2

Reference Use: YES/NO

Given the following conditions for Unit 2:

- Startup is underway following refueling (Cycle 7)
- Reactor power is stable at 75%
- Tavg is on program
- RCS boron concentration is 1375 ppm
- All Pre-conditioning limits have been met.

What are the restrictions on control rod position?

**SRO Only:** And what actions are required per ITS for control rods being below this restriction?

Expected Answer:

For minimum rod position (RIL) control bank D must be maintained greater than  $104 (\pm 2)$  steps.

**SRO Only:** IAW ITS 3.1.7, a boration must be commenced within 1 hour and the controd rods must be > the RIL within 2 hours.

Actual Answer:

Candidate's response matched expected answer.

Sat Unsat .

K/A: 001000A302 3.7/3.6

Reference(s):

RPI Lesson Text, LO-PSC-8b, Rev 2 Sec. 2; LO 4.

Byron Units 1 & 2 ITS, 3.1.3 MTC, page 3.1-4

BCB-2, Figure 18, Rev. 0

# OPERATOR QUESTION SHEET

## Question No: 1

Reference Use: YES

Given the following conditions:

- 12 hours ago, the reactor tripped from 100% power.
- All control rods were fully withdrawn at the time of the trip.
- Safety Injection was NOT actuated.
- The reactor trip breakers have been reclosed.
- Rod control was reset by manually resetting all control board group step counters to zero individually.
- The Rod Cont Startup Switch was NOT positioned to the Starup position.

How will the control rods in the CONTROL BANKS respond if the operator attempts rod movement?

Question No: 2

Reference Use: YES

Given the following conditions for Unit 2:

- Startup is underway following refueling (Cycle 7)
- Reactor power is stable at 75%
- Tavg is on program
- RCS boron concentration is 1375 ppm
- All Pre-conditioning limits have been met.

What are the restrictions on control rod position?

SRO Only: And what actions are required per ITS for control rods being below this restriction?

	NSWP-WM-04 Revision 0 Predefine Cover Sheet	
PREDEFIN	IE DATA PACKAGE CO	EXHIBIT A Page 1 of 1 OVER SHEET
Procedure # 1Bos 1.3.1.2-1 Title Movable Control A	Unit: 1 PM ID: Issemblies Quarterly	3 Surveillance
PREDEFINE INFORMATION: Due Date: Tech Spec: NO YES X COMPLETE or PARTIAD (CIRCLE ONE) if PARTIAL, rec	Work Request #: Critical Date: Performance ord step(s) performed in comments	
. SIC	GNATURE AUTHORIZATION/APPI	ROVALS
Opposite Train Operable	YES NO (N/A)	.1./,
Authorization to Start Work	rott li-Truin	: Now today
Work Started By		APPENDIX BEAMBARANDE CONTRACTOR CONTRACTOR CONTRACTOR
Work Completed By		1007183 EUROPEAND ************************************
Surveillance Found Within Acceptan	ce Criteria YES NO	
Surveillance Left Within Acceptance	Criteria YES NO	
Supv Review of won: Complete	Signature	Time Date
-	nan an	2 m 2 parties and a second stand of an and a second standards and a second standard standard standard standards
Recting on Conti	COMMENTS	
rectorm on seato	DE DANN D DAM	3.
ar the product and the second and any second second as the second second second second second second second sec	REVIEW OF RESULTS	anna a na ann an ann an ann an ann ann
	ALTEN OF ALBOLID	

# MOVEABLE CONTROL ASSEMBLIES QUARTERLY SURVEILLANCE

# A. STATEMENT OF APPLICABILITY:

This procedure applies to the verification of control assembly operability in Modes 1 and 2.

### B. REFERENCES:

- 1. Technical Specifications:
  - a. 4.1.3.1.2
- 2. Station Procedures:
  - a. 1BOS 1.3.1-la, LCOAR Moveable Control Assemblies Group Height.
  - b. BCP 210-20, Silver Determination in an RCS Crud Sample.
- 3. NTS/Commitments:
  - a. 454-200-97-SCAQ00021-12

## C. PREREQUISITES:

- Receive permission from the Shift Manager or designated SRO licensed assistant prior to performing this surveillance by having the Data Package Cover Sheet signed and dated.
- A visual inspection inside of all 5 RD power cabinets indicates that no blown fuse indicators are tripped.

### D. PRECAUTIONS:

- Before transferring to automatic control, ensure permissive C-5 is extinguished.
- Avoid variations in plant load, reactor coolant temperature, and boron concentration.
- During the surveillance, reactor coolant average temperature changes greater than -4°F or +1°F shall be compensated for by moving rods intermittently to match TAVE and TREF.

#### APPROVED 09/05/97

Facsimile

# D. continued

- 4. Maintain AI within prescribed limits.
- Before transferring to automatic reactor control, manually adjust Tavg to within <u>+</u> 1°F of the reference temperature to avoid a transient following the transfer.

## E. LIMITATIONS AND ACTIONS:

- As stated in Technical Specifications Limiting Condition for Operation 3.1.3.1.
- In the event the Acceptance Criteria is not met during the performance of this surveillance, IMMEDIATELY notify the Shift Manager to initiate LCOAR 1BOS 1.3.1-1a, LCOAR - Moveable Control Assemblies Group Height.
- \* 3. During execution of step F.4.k, any control rod motion with the BANK SELECT switch in AUTO or MAN may result in improperly sequenced control rod movement. Necessary control rod motion must be made using individual bank select, and automatic control bank overlap will not be available. Do not insert Control Bank D lower than the overlap engage point.

\*, 3.a

### F. MAIN BODY:

### NOTE

Initial each step in the space provided adjacent to the main body step number <u>AFTER</u> the step has been <u>SUCCESSFULLY</u> completed. Persons performing independent verification should initial in the space provided after the step.

- 1. TRANSFER/VERIFY rod control to manual.
  - a. PLACE/VERIFY bank selector switch to MANUAL position.
  - Utilizing the Rod Motion Control switch MAINTAIN TAVE matched with TREF.

F. continued

# NA 2. Shutdown banks

- ENTER in column 2a. the initial group 1 and group 2 step counter readings for Shutdown Banks A, B, C, D, and E. (Note - There are no group 2 Step Counter Readings for S/D Banks C, D & E)
- SELECT Shutdown Bank E by placing bank select switch in SBE position.
- Utilizing the rod motion control switch, INSERT Shutdown Bank E 10-15 steps.
- RECORD in column 2d group 1 and group 2 step counter readings.
- e. VERIFY, utilizing DRPI, that each rod in Shutdown Bank E moved 10-15 steps and signify this by initialing in space provided in column 2e.
- f. Utilizing the rod motion control switch, WITHDRAW Shutdown Bank E to 228 steps.
- g. RECORD in column 2g final group 1 and group 2 step counter readings.
- h. VERIFY, utilizing DRPI, that all rods in Shutdown Bank E are at 228 steps and signify this by initialing in space provided in column 2h.

## F.2. continued

i. REPEAT steps 2b through 2h for Shutdown Banks D, C, B, A.

Shutdown Rod Bank 2.	2a. Initi Cou	al Step inter iding	2d. Step Read	Counter dings After rtion	2e. Each rod In Bank Moved 10-15 Steps	2g. Fin Cou Rea	al Step unter clings	2h. All Rods In Bank At 228 Steps
	Group 1	Group 2	Group 1	Group 2		Group 1	Group 2	
Shutdown Bank A					e A			
Shutdown Bank B				N				
Shutdown Bank C		N/A		N/A	¢		N/A	
Shutdown Bank D		N/A		N/A	¢		N/A	
Shutdown Bank E		N/A		N/A	¢		N/A	

3. Control Banks

a. ENTER in column 3a the initial group 1 and group 2 step counter readings for Control Banks A, B, C, and D.

### NOTE

If the bank is fully inserted, record the group 1 and group 2 step counter readings, mark all other columns on Data Sheet N/A and do not proceed with surveillance for that bank.

 SELECT Control Bank A by placing bank select switch in CBA position.

### NOTE

Control Banks may be moved 10-15 steps in or out at the discretion of the Shift Manager or designated SKO licensed assistant to meet the requirements of this surveillance. Monitor Reactor Power and Tave closely and correct as necessary to minimize plant transients.

- c. Utilizing the rod motion control switch, MOVE Control Bank A 10-15 steps.
- RECORD in column 3d, group 1 and group 2 step counter readings.

F.3. continued

- e. VERIFY, utilizing DRPI, that each rod in Control Bank A moved 10-15 steps and signify this by initialing in space provided in column 3e.
- f. Utilizing the rod motion control switch, POSITION Control Bank A to original controlling position.
- g. RECORD in column 3g final group 1 and group 2 step counter readings.
- h. VERIFY, utilizing DRPI and group step counters, that all rods in Control Bank A are RESTORED to their original position and signify this by initialing in space provided in column 3h.

1. REPEAT SCEPS 3D CHIOUGH 3H LOF CONTION BARKS B, C, a		· FCE	PLAT S	ster i	SD	cnrougn	sn	IOL	Control	Banks	в,	C,	and
---------------------------------------------------------	--	-------	--------	--------	----	---------	----	-----	---------	-------	----	----	-----

Control Rod Bank	3a. Initi Cou Rea	ial Step unter inding	3d. Step Counter Readings After Movement		3e. Each Rod In Bank Moved 10-15 Steps		3g. Final Step Counter Readings		3h. All Rods At Original Position
	Group 1	Group 2	Group 1	Group 2			Group 1	Group 2	
Control Bank A	NIA	NIA	NIA	NA	e N	lA	NA	NA	NA
Control Bank B					¢				
Control Bank C	NA	NA	NA	NA	e n	/A	~/A	NA	NA
Control Bank D	NIA	NIA	NA	NA	e N	1A	NA	NA	N/A

-5-

1BOS 1.3.1.2-1 Revision 11

F. continued

**NOTE** Prior to performing P/A Converter and Bank Overlap Unit checks, ensure both CFD group 1 and group 2 demand step counters indicate the same number of steps withdrawn (even bank).

#### NOTE

During the performance of P/A Converter and Bank Overlap Unit checks, the CBD position will need to be maintained until the completion of these checks.

- 4. VERIFY P/A Converter and Bank Overlap Alagnment.
  - \_\_\_\_\_a. OBTAIN key 5061 or 5062 or equivalent for the Rod Drive Logic Cabinet 1RD07J.
  - b. OBTAIN key 5071 or 5072 or equivalent for the Rod Drive P/A Converter Cabinet 1RD08J
  - c. RECORD CBD Bank Height Position from 1PM05J Demand Step Counters.
    - \_\_\_\_ steps

d. ACCESS the Rod Drive P/A Converter in 1RD08J.

e. RECORD the following RCCA Bank Heights by rotating the Control Bank Select Switch in 1RD08J.

CBA steps CBB steps CBC steps CBD steps

COMPARE the values obtained from step F.4.e to those expected and step F.4.c. Adjust the P/A Converter as necessary or contact SED.

INDEPENDENT VERIFICATION

£.
#### APPROVED 09/05/97

Facsimile

1BOS 1.3.1.2-1 Revision 11

\*, 3.a

\*, 3.a

\*, 3.a

F.4. continued

g. RESTORE the P/A Converter Control Bank Select Switch in 1RD08J to the "Display Off" position.

INDEPENDENT VERIFICATION

- h. SECURE the P/A Converter Cabinet 1RD08J.
- i. ACCESS the Rod Drive Logic Cabinet 1RD07J.
- \* \_\_\_\_\_ j.

RECORD the "As Found" thumbwheel switch settings from the Bank Overlap Panel within the Logic Cabinet 1RD07J.



#### NOTE

Avoid control rod motion during execution of step F.4.k. If control rod motion is necessary then invoke Limitations and Actions E.3.

-----

\* 1.

\_\_\_\_k. EXERCISE the switch contacts for S1 through S6 by rotating each thumbwheel through approximately three revolutions.

VERIFY/RETURN the following to the "As Found" condition.

S1	S2	S3
s4	S5	S6

INDEPENDENT VERIFICATION

RECORD the Bank Overlap Counter Display value on the Bank Overlap Panel within the Logic Cabinet 1RD07J.

Bank Overlap Display

APPROVED 09/05/97	Facsimile	1BOS 1.3.1.2-1 Revision 11
F.4. continued		
n.	CALCULATE the expected Bank Overlap Dis the S5 Setting with the current CBD pos	play value by adding ition.
	S5 Setting + CBD Height Expected Dia (F.4 j) (F.4 c)	splay
0.	COMPARE the values obtained from step F recorded in step F.4.m. Adjust the Bank necessary or contact SED.	.4.n to those k Overlap Counter as
/	INDEPENDENT VERIFICATION	
_ p.	SECURE the Rod Drive Logic Cabinet 1RD0	7J.
5. REST	ORE rod control to automatic if plant cond	dition allows.
a.	VERIFY Low Power Interlock C-5 NOT LIT.	
	INDEPENDENT VERIFICATION	
b.	VERIFY TAVE-TREF deviation $\leq$ 1°F.	
	INDEPENDENT VERIFICATION	
c.	PLACE bank selector switch in AUTO.	
	INDEPENDENT VERIFICATION	
6. Noti clad Deter	fy Chemistry Department of rod movement to ding defect sampling should be obtained po rmination in an RCS Crud Sample.	o determine if RCCA er BCP 210-20, Silver
G. ACCEPTANCE	CRITERIA:	

 Each rod not fully inserted in the core shall be determined OPERABLE at least once each 92 days by movement of at least 10 steps in any one direction.

(Final)

-8-

# JOB PERFORMANCE MEASURE

# CANDIDATE CUE SHEET

# TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. A LOCA has occurred.
- 3. BEP ES-1.2 is in progress.

# INITIATING CUES:

1. The US directs you to depressurize the RCS starting at BEP ES-1.2 Step 9.

### NOTES FOR SETUP:

Desired conditions:

- 1. Break flow equal to injection flow with at least TWO CV pumps running in HHSI alignment.
- 2. MSIVs open (either block Steamiine SI, or reset if actuated, and open MSIVs)
- 3. RCS pressure between 1000 psig and 1450 psig
- 4. CNMT pressure is expected to be ADVERSE and should indicate that at some point 20 psig was exceeded
- 5. Pzr level about 40% but less than 50%
- 6. All RCPs stopped
- 7. SI reset, Phase A reset and air restored to CNMT, Phase B reset (if actuated)
- 8. Insert malfunctions TH11A and TH11B to 0 value to prevent operation of PZR Porvs.
- 9. Open CV8105 and CV8106.

The Pressurizer spray valves (and controllers, if required) are to be failed closed. The major steps of BEP-1 are complete through STEP 12. The steps of BEP ES-1.2 are complete through STEP 7. A cooldown should be set up as appropriate (20°F/hr to 50°F/hr). 1BEP ES-1.2 steps 9 & 10 are the evaluated actions for the JPM.

# JOB PERFORMANCE MEASURE

TASK TITLE:	Depressur Ccoldown	ize the RCS per and Depressuri	ES-1.2 zation	Post-LOCA	JPM No.: JPM-3
TPO No:		K&A No.:	OOWE	03A202	K&A IMP. 3.5/4.1
TRAINEE:					DATE:/_/
The Trainee:	PASSED	this	JPM	TIME	STARTED:
	FAILED_			TIME	FINIŞHED:
EVALUATION N	ETHOD:	PERFORM		SIMULATE	
LOCATION:		IN PLANT		SIMULATOR_	
MATERIALS:					

None

GENERAL REFERENCES:

1BEP ES-1.2, POST LOCA COOLDOWN AND DEPRESSURIZATION

TASK STANDARDS:

Depressurize the RCS per ES-1.2 Post-LOCA Cooldown and Depressurization

## TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. A LOCA has occurred.
- 3. BEP ES-1.2 is in progress.

### INITIATING CUES:

1. The US directs you to depressurize the RCS starting at BEP ES-1.2 Step 9.

### CRITICAL ELEMENTS: (\*)

2, 5 and 6

# APPROXIMATE COMPLETION TIME: 10 minutes

JPM-3

STANDARDS

RECORD START TIME

If this JPM is given on the simulator, only the cues <u>underlined</u> are required to be given to the <u>trainee</u>.

NOTE

- 1. Refer to ES-1.2, Post LOCA Cooldown And Depressurization
   Locate and open ES-1.2,
   I

   Post LOCA Cooldown And Depressurization
   Depressurization
- If asked: <u>All Prerequisites have been</u> met.

\*2. DEENERGIZE PZR HEATERS <u>DEENERGIZE PZR</u> <u>HEATERS:</u>

Cue: Heaters are OFF.

any time.

Group 1A

a. Place B/U heater

contactors in - OFF

Group 1B

Group 1D

Place variable heater control

Cue: Switch is in AFTER TRIP.

Group 1C

09/03/98 7:24 AM

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	<u>N/A</u>
Observes CAUTION	CAUTION Voiding may occur in the RCS during RCS depressurization. This will result in a rapidly increasing PZR level.			•
3. Depressurize RCS to Refill PZR NOTE: RCPs are OFF normal spray not available	<ul> <li>a. Use normal PZR spray:</li> <li>1RY455B</li> <li>1RY455C</li> </ul>			•
<ol> <li>Depressurize RCS using PZR PORV's</li> <li>Cue: 1RY455A and/or 1RY456 are closed</li> </ol>	Step 10 RNO a. use one PZR PORV: o 1RY455A o 1RY456			
* 5. Depressurize RCS using Aux Spray	<ul> <li>Step 10 RNO:</li> <li>Open PZR Aux Spray Valve 1CV8145</li> </ul>	•		0
Cue: 1CV8145 is open. 1CV8146 & 1CV8147 are closed.	<ul> <li>Verify/Close</li> <li>1CV8146</li> <li>1CV8147</li> </ul>			

\*6. Stop depressurization

Cue: Containment pressure is 20 psig

Cue: PZR level is 51%

When Pzr level – GREATER 
THAN 21% (50% FOR
ADVERSE CNMT)

 Stop RCS Depressurization by closing Aux Spray Valve, 1Cv8145

CUE: THIS COMPLETES JPM.

RECORD STOP TIME

COMMENTS:

#### Question No: 1

#### Reference Use: YES

Following operation of the Pressurizer PORV(s), the crew is preparing to drain the PRT. RCDT Drain pump RE01PB is out of service for motor replacement. If all systems are in normal alignment with RCDT level at 65%, what will occur when 1AOV-RY8031, PRT Drn Isol Vlv, is opened and why?

#### Expected Answer:

(RCDT Drain Pump RE01PA (50 gpm) will be running.) PRT volume will be pumped to the (Recycle) Hold Up Tanks due to the already running of the RCDT Drain Pump RE01PA (50 gpm).

Actual Answer:

Candidate's	response matched expected answer.
/A: 002000K105	3.2/3.4 Sat Unsat
eference(s):	BOP RY-4, DRAINING THE PRESSURIZER RELIEF TANK, Rev. 2.
	RY-4 PRT & RCDT, Rev. 2, Simplified MCR Circuit for RCDT Pumps.
	Chp 14. Pressurizer (RY), Rev. 3. IT.C.4. Page 64. LO 17.

#### JPM Questions

#### Question No: 2

#### Reference Use: NO

Sat

Unsat .

A Pressurizer Safety Relief valve has lifted. All ECCS components started and aligned as designed. RWST level is 84% and decreasing very slowly. RCS pressure has fallen to 1400 psig.

Describe how the pump cooling flowpaths change for the Centrifugal Charging and Safety Injection Pumps if the Pzr Safety Relief valve closes and pressurizer pressure returns to NOP?

#### Expected Answer:

CV: Initially flow from the pump discharge into the RCS provides the cooling. When pressure reaches approximately 1650 psig, the CV miniflow valves will reopen providing an additional flowpath to the seal return line.

SI: Initially flow from the pump discharge into the RCS and recirculation to the RWST provides pump cooling. At approximately 1700 psig, all flow will be recirculated to the RWST.

Actual Answer:

Candidate's response matched expected answer.

K/A: 000008AA213 RO/SRO 3.8/3.9

Reference(s): BAR 1-9-E1, Rev. 0

### OPERATOR QUESTION SHEET

## Question No: 1

#### Reference Use: YES

Following operation of the Pressurizer PORV(s), the crew is preparing to drain the PRT. RCDT Drain pump RE01PB is out of service for motor replacement. If all systems are in normal alignment with RCDT level at 65%, what will occur when 1AOV-RY8031, PRT Drn Isol Vlv, is opened and why?

Question No: 2

Reference Use: NO

A Pressurizer Safety Relief valve has lifted. All ECCS components started and aligned as designed. RWST level is 84% and decreasing very slowly. RCS pressure has fallen to 1400 psig.

Describe how the provide Sooling flowpaths change for the Centrifugal Charging and Safety Injection Pumps if the Pzr Safety Relief valve closes and pressurizer pressure returns to NOP?

# JOB PERFORMANCE MEASURE

# CANDIDATE CUE SHEET

# TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. A LOCA has occurred.
- 3. 1BEP-0 is in progress.

# INITIATING CUES:

1. The US directs you to continue 1BEP-0 at step 14.

### NOTES FOR SETUP:

Desired conditions:

- 1. Break flow equal to injection flow with at least TWO CV pumps running in HHSI alignment.
- 2. MSIVs open (either block Steamline SI, or reset if actuated, and open MSIVs)
- 3. RCS pressure between 1000 psig and 1450 psig
- 4. CNMT pressure is expected to be ADVERSE and should indicate that at some point 20 psig was exceeded
- 5. Pzr level about 40% but less than 50%
- 6. All RCPs stopped

CNMT Spray actuation failed, CS007 valves closed (NOT failed), CS019 valves closed (NOT failed), One CS pump running, if possible. The evaluated actions are those of ATTACHMENT B of BEP-0. Would like to have one CS pump running with associated CS007 valve closed. The other pump can be NOT running. This forces the RNO actions of step 1.b. CS019 valves should be close (if this does not affect CS pump in step 1.b). One CS pump is restarted per step 1.b, if possible, and the other (or both) is started in step 2.a.

Valve slaves for 1A CS pump - RF RP37 OUT

Valve slaves for 1B CS pump - RF RP63 OUT

Malfunction CS01B for 1B CS Pump

## JOB PERFORMANCE MEASURE

TASK TITLE:	Manual C	S Actuation		JPM No.: JPM-4
TPO No:		K&A No.: 00700	00K301	K&A IMP. 4.0/4.6
TRAINEE:				DATE://
The Trainee:	PASSED	this JPM	TIME	STARTED:
	FAILED		TIME	FINISHED:
EVALUATION	METHOD:	PERFORM	SIMULATE	
LOCATION:		IN PLANT	SIMULATOR_	
MATERIALS:				
N	one			

GENERAL REFERENCES:

1BEP, E-0, Reactor Trip or Safety Injection

TASK STANDARDS:

Manually Actuate Containment Spray

# TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. A LOCA has occurred.
- 3. 1BEP-0 is in progress.

### **INITIATING CUES:**

1. The US directs you to continue 1BEP-0 at step 14.

## CRITICAL ELEMENTS: (\*)

6, 7, 8 and 9 [ADD step 5 - hed to open CSOO7 A&B] APPROXIMATE COMPLETION TIME: 7 minutes APPROXIMATE COMPLETION TIME: 7 minutes PERFORMANCE CHECKLIST STANDARDS

\*

REC	RECORD START TIME						
lf gi	<u>NOTE</u> If this JPM is given on the simulator, only the cues <u>underlined</u> are required to be given to the Trainee.						
1. Note: If ask	Refer to BEP-0, Reactor Trip or Safety Injection This step may be performed at any time. Red: <u>All Prerequisites have been</u> <u>met.</u>	Locate and open BEP-0, Reactor Trip or Safety Injection					
2. Cue:	Check Containment Spray required. Cnmt pressure indicates >20 psig.	CHECK IF CONTAINMENT SPRAY IS REQUIRED: a. Comt pressure (1PR-937 or 1PI-CS934 thru 1PI-937) – HAS INCREASED TO GRE ATER THAN 20 PSIG					
3. Cue:	Check Group 6 monitor lights Lights are NOT LIT.	Group 6 CS momitor lights – LIT	•				

	PERFORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	N/A
	4. Perform RNO	RNO for Step 14.b.			•
	Cue: Group 6 monitor lights remain NOT LIT.	Manually actuate CS and Phase B Isolation.			
		IF group 6 CS monitor lights are <u>NOT</u> LIT, <u>THEN</u> GO to ATTACHMENT B, Step 1 (page 39).			
*	5. Perform Att. B – Check CS Valve alignment	CHECK CS VALVE ALIGNMENT:			
	Cue: Valves are OPEN.	<ul> <li>a. CS pump RWST suction valves – <u>OPEN:</u></li> </ul>			
A	0	• 1CS001A			
		• 1CS001B			
(*	Cue: Valve 1CS007A and B are CLOSED.	<ul> <li>b. CS pump header isolation valves – <u>OPEN</u></li> </ul>		•	
		• 1CS007A			
	Instructor Note:	• 1CS007B			
	If 1B pump is aligned first, Go To Step	o 10			
	*6. Perform I-NO for CS007A	RNO for Step 1.b	Q		
	Cue: "A" pump is running.	IF the associated CS pump is running, THEN perform the following to open the affected valve:			
	Pump switch is in PULL OUT.	Place 1A CS pump control switch in PULL OUT.			

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
*7. Continue with Step 1.b. RNO Cue: Switch is in NORMAL	Continue with Step 1.b. RNO Verify associated 1A CS pump test switch is in NORMAL			
*8. Continue with Step 1.b. RNO Cue: Valve 1CS007A is OPEN	Continue with Step 1.b. RNO Manually open valve 1CS007A after the 30 second time delay.			
*9. Continue with Step 1.b. RNO Cue: Pump is now running	Continue with Step 1.b. RNO Restart CS pump.			a
10. Continue with Step 1.b. RNO Cue: 1CS007B is OPEN	Continue with Step 1.b. RNO Open 1CS007B	•		
11. Continue with Step 1.c. Cue: 1CS019B is CLOSED	Continue with Step 1.c. CS eductor spray additive valves – <u>OPEN:</u> • 1CS019A • 1CS019B			

\*

STANDARDS

AD			
#12. Perform RNO for 1CS019B	RNO for 1CS019B		
Cue:	Perform the following for the affected train:		
1) Switch is in TEST	1) Place 1B CS pump test		
2) Valve is OPEN	switch in TEST		
3) Switch is in NORMAL	2) Manually open valve 1CS019B		
	<ol> <li>Place 1B CS pump Test switch in NORMAL</li> </ol>		
13. Continue with step 1 d.	Continue with step 1 d.		
Cue: Valves are OPEN	CS eductor inlet flow control valves – <u>OPEN:</u>		
	• 1CS010A		
	• 1CS010B		
14. Check CS pumps	CHECK CS PUMPS		
Cue: "B" pump us NOT running	RUNNING:		-
·····	CS pumps – BOTH NOT RUNNING		
15. Performs RNO	RNO for Step 2	D	
	(NOTE: Does NOT attempt local start of 1B CS Pump since 1A pump is running)		
	Return to main body Step 14.c.		
CUE: THIS COMPLETES JPM.			
RECORD STOP TIME			

COMMENTS:

.

.

### JPM Questions

Question No: 1 SRO ONLY Reference Use: YES (No Horse Notes)

Unit 1 is at 100% power with the following containment spray system conditions have just been reported:

- Spray Additive Tank NaOH Concentration 318
- Spray Additive Tank Level 78%

1A CS pump has been out of service for 91 hours for breaker repair. What is the maximum power level/mode that Unit 1 is allowed to be at, per ITS, 40 hours from now and why?

#### Expected Answer:

100% power/Mode 1. The action for the OOS pump is 7 days to repir before shutdown actions are directed. The LCO for the additive system is also 7 days. (The additive system being out does not render both trains inoperable)

Actual Answer:

Candidate's response matched expected answer.

#### Question No: 1

RO ONLY Reference Use: YES (No Horse Notes)

Immediately following a CS actuation due to a steam line break inside containment, the NSO, while verifying proper CS flow, notes a higher eductor flow rate on train B than on train A. Approximately TEN (10) minutes after the accident, the operator then notes that eductor flows on both trains have increased. Explain why Train B has more flow and why eductor flow increased during the event.

#### Expected Answer:

Because train B has more spray nozzles in its respective ring headers than does train A, train B delivers more total pump flow (253 vs. 219 nozzles). As containment pressure is reduced through the operation of the CS system, the back pressure as felt by the pumps is decreased and overall pump flow increases. Therfor, eductor flow will increase.

Actual Answer:

Candidate's response matched expected answer.

Sat \_\_\_\_ Unsat \_\_\_\_.

K/A: 026000A401 4.5/4.3

Reference(s): CS-1 Containment Spray, Rev. 3, Diagram.

## JPM Questions

#### Question No: 2

#### Reference Use: YES

Given the following conditions:

- Unit 1 is at 100% power.
- Testing of the Containment Spray Pump 1B is initiated.
- The pump failed to start when the control switch was place in the CLOSE position.
- PP 1B TEST switch is in the TEST position.

Using the electrical prints, show what conditions could have prevented the pump from starting if the electrical protection for the motor was found to be normal?

#### Expected Answer:

- 1. 1CS007B, Containment Spray Isolation valve, is OPEN (NOT CLOSED).
- 2. 1CS040B, U-1 CS Add Tk 1B Outlet Dwst Isol Vlv, is OPEN (NOT CLOSED).
- 3. 1SI001B, CS Pp 1B Dsch to RWST Test Line Isol Vlv, is CLOSED (NOT OPEN).

Actual Answer:

Candidate's response matched expected answer.

Sat Unsat .

K/A: 026000A401 4.5/4.3

Reference(s):

06-E-1-4030CS01/2

BOP CS-5, CONTAINMENT SPRAY SYSTEM RECIRCULATION TO THE RWST, Rev. 5.

Chp 59, Containment Spray System, Rev. 2, II.F.1, page 54, LO 7, 8, 11.c

# JPM Questions

Question No: 1

#### SRO ONLY Reference Use: YES (No Horse Notes)

Unit 1 is at 100% power with the following containment spray system conditions have just been reported:

- Spray Additive Tank NaOH Concentration 318
- Spray Additive Tank Level 78%

1A CS pump has been out of service for 91 hours for breaker repair. What is the maximum power level/mode that Unit 1 is allowed to be at, per ITS, 40 hours from now and why?

Question No: 2

Reference Use: YES

Given the following conditions:

- Unit 1 is at 100% power.
- Testing of the Containment Spray Pump 1B is initiated.
- The pump failed to start when the control switch was place in the CLOSE position.
- PP 1B TEST switch is in the TEST position.

Using the electrical prints, show what conditions could have prevented the pump from starting if the electrical protection for the motor was found to be normal?

### OPERATOR QUESTION SHEET

Question No: 1

RO ONLY Reference Use: YES (No Horse Notes)

Immediately following a CS actuation due to a steam line break inside containment, the NSO, while verifying proper CS flow, notes a higher eductor flow rate on train B than on train A. Approximately TEN (10) minutes after the accident, the operator then notes that eductor flows on both trains have increased. Explain why Train B has more flow and why eductor flow increased during the event.

Question No: 2

Reference Use: YES

Given the following conditions:

- Unit 1 is at 100% power.

- Testing of the Containment Spray Pump 1B is initiated.
- The pump failed to start when the control switch was place in the CLOSE position.
- PP 1B TEST switch is in the TEST position.

Using the electrical prints, show what conditions could have prevented the pump from starting if the electrical protection for the motor was found to be normal?

# JOB PERFORMANCE MEASURE

# CANDIDATE CUE SHEET

# TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. The Unit is in mode 1.
- 3. Normal Letdown is in service at 120 GPM.

# INITIATING CUES:

- 1. You have just been told by the US to establish maximum excess letdown to the RCDT due to a leak in the normal letdown line.
- 2. The US does not want normal Letdown secured at this time.

# JOB PERFORMANCE MEASURE

TASK TITLE:	Establish I	Excess Letdowr	נ		JPM No.: JPM-5
TPO No: IV.C.C	<u>CV-07</u>	K&A No.	004000	0G013	K&A IMP. 3.6/3.5
TRAINEE:					DATE:/_/_
The Trainee:	PASSED	thi	s JPM	TIME	STARTED:
	FAILED_			TIME	FINISHED:
EVALUATION N	IETHOD:	PERFORM		SIMULATE	
LOCATION:		IN PLANT		SIMULATOR_	

MATERIALS:

None

### **GENERAL REFERENCES:**

BOP CV-15, Excess Letdown Operations

TASK STANDARDS:

Perform the actions required to place Excess Letdown in service.

# TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. The Unit is in mode 1.
- Normal Letdown is in service at 75 GPM.

## INITIATING CUES:

- 1. You have just been told by the US to establish maximum excess letdown to the RCDT due to a leak in the normal letdown line.
- 2. The US does not want normal Letdown secured at this time.

# CRITICAL ELEMENTS: (\*)

2, 4, 5, 6, 7

### APPROXIMATE COMPLETION TIME: 10 minutes

JPM-5

STANDARDS

RECORD START TIME NOTE If this JPM is given on the simulator, only the cues underlined are required to be given to the Trainee. 1. Refer to BOP CV-15, Excess Locate and open Letdown Operations. BOP CV-15. Note: This step may be performed at any time. If asked: All Prerequisites have been met. \*2. Establish Initial Conditions. Perform the following at 1PM06J: Open: Cue: • CC9437A Open light is LIT. • 1CC9437A · CC9437B Open light is LIT. · 1CC9437B 3. Verify throttle valve position. Perform the following at 0 1PM05J: Verify/Take to 0% demand Cue: HCV-CV123 Indicates 0 %. on controller for 1CV123.

#### STANDARDS

- \*4. Align HX outlet flowpath.
- Cue: · CV8143 is in RCDT position.

Align Flow Path

\*5.

LIT.

° (If requested) **US DOES NOT desire flow** directed to VCT spray nozzle. (i.e. \_CV8482 & \_CV8484 do not require repositioning)

Perform the following at 1PM05J:

· Place 1CV8143 to RCDT position.

*5.	Align Flow Path.	Open:	Q	0
Cue:	• Selected loop drain 1RC8037A/B/C/D Open light is LIT.	ONE Loop Drain Valve     IRC8037A/B/C or D		
Note:	Only 1 loop drain is required to be opened. (all 4 can be opened)			
*6.	Align Heat Exchanger.	Open:		
Cue:	• 1CV8153A/B Open light is	1CV8153A and/or B		

Note: To maximize flowrate, the candidate may elect to use both Hx's.

\*7. Establish Flow.

Throttle/open 1CV123 to obtain flow.

Cue • 1HCV-CV123 Position Indicator IND!CATES DEMANDED position. to obtain now.

• 1TI-122A INDICATES 140°F.

Cue: (If requested) Seal leakoff flow recorders INDICATE 3 gpm.  Check excess letdown outlet temperature < 165°F on 1TI-122A, Exc Ltdwn Hx Temp.

CUE: THIS COMPLETES JPM.

RECORD STOP TIME

COMMENTS:

# JPM Questions

Question No: 1

Reference Use: YES

Given the following conditions:

Unit 1 is at 100% power Excess letdown to the VCT is in service with normal letdown isolated.

What effect would a SI signal have on excess letdown system without any operator action? Using prints, show sequence and affects of valve operations with no operator action.

#### Expected Answer:

The SI signal also generates a Containment Phase A Isolation. On Phase A, CNMT Isolation valves CV8112 and CV8100 close, isolating the excess letdown (and seal return) line. At 150 psig, the relief valve inside CNMT to the PRT will open allowing flow. In the long run, Instrument Air to CNMT Isolation valves close, and without air, control valves in excess letdown line (CV8153A/B and CV123) will fail closed stopping excess letdown flow.

Actual Answer:

Candidate's response matched expected answer.

K/A: 004000A212 4.1/4.3

Sat Unsat .

Reference(s): CV-1 CVCS, Rev. 2

4030 CV Prints

Chp 15a - Chemical and Volume Control System, Rev. 02, II.A.5.f.4), page 57, LO 8.

### Question No: 2

#### Reference Use: NO

With excess letdown in service to the VCT, a reduction in CC flow to the Excess Letdown HX results in a rise in outlet temperature and pressure.

What is the concern associated with the pressure rise?

Expected Answer:

High pressure on the excess letdown line may reduce RCP Seal Leakoff Flows below required values since they share the same return line to the VCT.

Actual Answer:

Candidate's response matched expected answer.

K/A: 004000K104 3.4/3.8

Reference(s): BOP CV-15 EXCESS LETDOWN OPERATIONS, Rev. 5, D.1, page 2.

Chp 15a - Chemical and Volume Control System, Rev. 02, I.C.2, page 10, LO 2.

Sat Unsat .

### OPERATOR QUESTION SHEET

Question No: 1

Reference Use: YES

Given the following conditions:

Unit 1 is at 100% power Excess letdown to the VCT is in service with normal letdown isolated.

What effect would a SI signal have on excess letdown system without any operator action?

Question No: 2

Reference Use: NO

With excess letdown in service to the VCT, a reduction in CC flow to the Excess Letdown HX results in a rise in outlet temperature and pressure.

What is the concern associated with the pressure rise?

#### TASK CONDITIONS:

- 1. You are the Unit 1 NSO.
- 2. The Unit is in mode 1.
- 3. The 1B DG was started and is suppling Bus 142 to perform the 18 month Crosstie Surveillance.

### INITIATING CUES:

The Unit Supervisor directs you to synchronize the SAT back to bus 142 to place the 1B DG in parallel to the grid per BOP AP-32.

Simulator Setup:

.4

1. Ensure Voltage and Frequency are set to require an adjustment to 60 hz and 4160 volts.

	JOB PERFORMANCE MEASURE		RE Rev. 4, 8/23/93
TASK TITLE:	Synchroniz Following S	e a SAT to a Bus being F surveillance.	Fed Ly a DG JPM No.: JPM-6
TPO No: IV.C.DG-04		K&A No.: 06400	00A203 K&A IMP. 3.1/3.1
TRAINEE:		NAME AND ADDRESS ADDRESS OF ADDRESS OF	DATE://
The Trainee: PASSEDFAILED		this JPM	TIME STARTED:
			TIME FINISHED:
EVALUATION ME	ETHOD:	PERFORM	SIMULATE
LOCATION:		IN PLANT	SIMULATOR
MATERIALS:			

None

### GENERAL REFERENCES:

BOP AP-32, Synchronizing a SAT to a Bus being Fed by a DG

### TASK STANDARDS:

Perform actions necessary to synchronize a SAT to a Bus being Fed by a DG.

## TASK CONDITIONS:

- 1. You are the Unit 1 NSO.
- 2. The Unit is in mode 1.
- 3. The 1B DG was started and is suppling Bus 142 to perform the 18 month Crosstie Surveillance.

INITIATING CUES:

The UNIT SUPERVISOR directs you to synchronize the SAT back to bus 142 to place the 1B DG in parallel to the grid per BOP AP-32.

CRITICAL ELEMENTS: (\*)

### 3, 4, 6, 8, 9

APPROXIMATE COMPLETION TIME: 10 Minutes

# PERFORMANCE CHECKLIST STANDARDS

.

.

NOTE         If this JPM is given on the simulator, only the cues <u>underlined</u> are required to be given to the Trainee.								
2. Cue:	Check if DG was started Manually DG was started MANUALLY	Verify/Check if DG was started Manually	۵	•	۵			
*3. Cue:	Verify DG operating properly • <i>DG Frequency is</i> 60 Hz • DG Voltage is 4160 Volts	Adjust: • DG Frequency-60 Hz • DG Voltage- 4160 V	٦		٥			
*4. Cue:	Tum Synchroscope ON SAT 142 -2 Feed to 4KV Bus 142 SYNC ACB 1422 Switch is ON	Place SAT 142-2 Feed to 4KV Bus 142 SYNC ACB 1422 Switch in On Position	٥		۵			
5.	Verify Incoming voltage ≥ 114 VAC	Verify Incoming Voltage ≥114 VAC • DIV 12 Incoming Volts	0	•	۵			
Cue:	Volts							

4
PERF	ORMANCE CHECKLIST	STANDARDS	SAT	UNSAT	N/A
*6.	Adjust DG voltage	Adjust DG voltage control so that Running Voltage is slightly higher than Incoming Voltage	۵	۵	٩
		DIV 12 Incoming Volts			
Cue:	• DIV 12 Incoming Voltage is 120 Volts	DIV 12 Running Volts			
	• DIV 12 Running Voltage is 121 Volts				
7.	Verify Phase Voltages are Equal	Verify DG Voltage Meter indicates the same voltage, 4160V, when DG Voltmeter Selector Switch is	a	۵	۵
		placed in the following positions			
Cue:	DG Voltmeter readings are:	• ØAB			
	•ØAB-4160V	• ØBC			
	• ØBC-4160V	• ØCA			
	• ØCA-4160V				
* 8.	Adjust DG Frequency	DIV 12 Synchroscope	a	a	a
		Place DG Governor Adjust in RAISE until DIV 12 Synchroscope is Rotating Slowly in the SLOW direction			
Cue:	• DN 12 Synchroscope is rotating Slow; in the FAST direction				
	When DG Governor Adjust is placed in RAISE,the DIV12 Synchroscope STOPS then reverses to rotate slowly in the SLOW direction				
Note:	If Governor adjusted in LOWER direction, rotation speed will be faster in the FAST direction.				

PERF	ORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	N/A
*9.	Close ACB 1422	When DIV 12 Synchroscope is within 5 minutes the 12 O-Clock position	۵	۵	۵
		Close ACB 1422			
Cue:	ACB 1422 CLOSE Light is LIT	· Check ACB 1422 CLOSE light - LIT , ADJUSTED KVARS to	< 1000	- 6000	l Practice
10.	Turn Synchroscope OFF	Place Synchroscope switch in OFF		a	a
Cue:	Synchoscope is in OFF				

Cue: This completes JPM

RECORD STOP TIME\_\_\_\_\_

COMMENTS:

.

.

## JPM Questions

Question No: 1	1 Reference Use: YES (electr	ical prints only)
What conditions m the control swite	must be met for Bus 143 UAT Feeder Breaker to ch ACB 1431 is in the AFTER-TRIP position?	AUTO close if
Expected Answer:		
<ol> <li>No lockouts of</li> <li>OCB 3-4 OR OC</li> <li>ACB 1411 (ESE</li> <li>Control switch</li> <li>ACB 1432 open</li> </ol>	on either UAT or SAT feed to bus CB 4-5 must be closed AND MT Disconnect must F Bus to Non-ESF Bus crosstie) must be OPEN ch for ACB 1432 in AFTER-CLOSE position ms	be closed
Actual Answer:		
Candidate's	response matched expected answer.	
<b>K/A:</b> 062000K403	2.8/3.1 Sat	Unsat
Reference(s):	4030-AP-041, AP42, AP26, MP24	
	BOP AP-85	
	Chp 4, A.C. Electrical Power Distribution St II.C.3.b.1).c), page 96, LO 11.e	ystem, Rev. 2,

### JPM Questions

#### Question No: 2

Reference Use: YES

The following plant conditions exist:

- Unit 1 is at 100% power
- Normal at power electrical line up
- · Diesel Gen 1B Start Switch on the MCB is inadvertantly placed in PTL

If the SAT feeder breaker to bus 142 (breaker 1422) were inadvertantly opened from the control room, what would be the 1B D/G and 1423 breaker response?

#### Expected Answer:

The 1B DG will start, breaker 1423 would cycle closed and open, then diesel will sart to shutdown and then restart due to the UV and restart cycle.

#### Actual Answer:

Candidate's response matched expected answer.

K/A: 064000K4.02 3.9/4.2

Sat Unsat .

Reference(s): 06E-1-4030DG02, DG40

Chp 9, DG & Aux. Systems, Rev. 1, LO 3e, 4.

### OPERATOR QUESTION SHEET

Question No: 1

Reference Use: YES (electrical prints only)

What conditions must be met for Bus 143 UAT Feeder Breaker to AUTO close if the control switch ACB 1431 is in the AFTER-TRIP position?

Question No: 2

Reference Use: YES

The following plant conditions exist:

- Unit 1 is at 100% power
- Normal at power electrical line up
- Diesel Gen 1B Start Switch on the MCB is inadvertantly placed in PTL

If the SAT feeder breaker to bus 142 (breaker 1422) were inadvertantly opened from the control room, what would be the 1B D/G and 1423 breaker response?

### JOB PERFORMANCE MEASURE

### CANDIDATE CUE SHEET

### TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. The Unit is in mode 5.
- 3. RCS conditions are 188°F and 360 psig.

### INITIATING CUES:

- 1. Reactor strartup is in progress and BGP 100-1 is being perfromed.
- 2. At Step F.28 a start of the first Reactor Coolant Pump is directed per BOP RC-1.
- 3. The US directs you to start the 1D RCP.

### NOTES FOR SETUP:

- 1. Reset to IC-3
- 2. Secure 1D RCP
- 3. Close 1RY455B
- 4. Operate Heaters as necessary
- 5. Shut 1CV8141D.

### JOB PERFORMANCE MEASURE

TASK TITLE:	Start a Re	actor Coolar	nt Pump		JPM No.: JPM-7
TPO No:		K&A I	No.: 00300	0G120	K&A IMP. 4.3/4.2
TRAINEE:					DATE:/_/_
The Trainee:	PASSED		this JPM	TIME	STARTED:
	FAILED			TIME	FINISHED:
EVALUATION N	METHOD:	PERFORM	L	SIMULATE	
LOCATION:		IN PLANT_		SIMULATOR_	
MATERIALS:					

None

### **GENERAL REFERENCES:**

BOP RC-1, STARTUP OF A REACTOR COOLANT PUMP

TASK STANDARDS:

Perform the actions required to start a Reactor Coolant Pump.

### TASK CONDITIONS:

- 1. You are the Unit NSO.
- 2. The Unit is in mode 5.

3. RCS conditions are 188°F and 360 psig.

### INITIATING CUES:

- 1. Reactor startup is in progress and BGP-100-1 is being performed.
- 2. At step F.28 a start of the first Reactor Coolant Pump is directed per BOP RC-1.
- 3. The US directs you to start the 1D RCP.

### CRITICAL ELEMENTS: (\*)

13, 15, 17, 23

### APPROXIMATE COMPLETION TIME: 14 minutes

JPM-7

STANDARDS

RECORD START TIME

### NOTE

If this JPM is given on the simulator, only the cues <u>underlined</u> are required to be given to the Trainee.

1.	Refer to BOP RC-1, Startup of a	Locate and open		
	Reactor Coolant Pump.	BOP RC-1.		

wote: This step may be performed at any time.

### If asked: <u>All Prerequisites have been</u> <u>met.</u>

 2.
 Dust Cover Removal
 VERIFY/REMOVE all dust
 I
 I
 I

 Cue:
 • Dust Covers are removed.
 RCPs.
 RCPs.

3. Loose Parts Monitoring System ENSURE that the Loose Parts Monitoring System is operating.

Cue: The LPMS is in operation.

PERFORMANCE CHECKLIST	STANDARDS	SAT	UNSAT
. Verify operable trip coils. Cue: <u>Lights are illuminated.</u>	Verify the Trip Coils are operable for each Reactor Coolant Pump to be started by ensuring the Reactor Coolant Pump under frequency Trip Lights are illuminated.		
	A RCP DS8025 PA11J DS8025 PA12J		
	B RCP DS8027 PA11J DS8027 PA12J		
	C RCP DS8028 PA11J DS8028 PA12J		
	D RCP DS8026 PA11J DS8026 PA12J		
5. Initiates Trending on the computer	VERIFY/INITIATE trending of RCP temperatures on the Unit		

Demonstrates the initiation of trending on the computer.

RCP D:

computer:

TO472 RCP 4 MTR STATOR WINDING T.

TO473 RCP 4 MTR UPPER RADIAL BRG T.

TO474 RCP 4 MTR UPPER THRUST BRG T.

TO475 RCP 4 MTR LOWER RADIAL BRG T.

TO476 RCP 4 MTR LOWER THRUST BRG T.

TO477 RCP 4 LOWER SEAL. WTR BRG T. N/A

PERFORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	LINSAT	<u>N/A</u>
6. Check VCT pressure. Cue: VCT Pressure is 33 psig.	ENSURE VCT pressure is at least 15 psig as indicated on PI-115, VCT Press, at 1PM05J.			
7. Check VCT temperature. Cue: VCT temperature is 115°F.	ENSURE VCT temperature is less than 135 F as indicated on TI-116, VCT Temp, at 1PM05J.			
8. Check VCT Level. Cue: VCT Level is 43 %.	ENSURE VCT level is between 37 -73% as indicated on LT-112, VCT Level, at 1PM05J.		ū	
9. Check VCT Annunciators Cue: VCT annunciators are clear.	<ul> <li>ENSURE the following annunciators are cleared:</li> <li>a. VCT LEVEL HIGH LOW (1-9-A2).</li> <li>b. VCT PRESS HIGH LOW (1-9-B2).</li> <li>c. VCT TEMP HIGH (1-9-C2).</li> </ul>			•
10. Check RCP Annunciators Cue: RCP Annunciators are clear.	<ul> <li>ENSURE the following annunciators for the applicable pump(s) are cleared.</li> <li>a. RCP THERM BARR CC WTR TEMP HIGH (1-7-E3).</li> <li>b. RCP THERM BARR CC WTR FLOW LOW (1-7- A4/B4/C4/D4).</li> <li>c. RCP BRNG CC WTR FLOW LOW (1-7-A5/B5/C5/D5).</li> <li>d. RCP BRNG CC WTR TEMP HIGH (1-7-E5).</li> </ul>			

#### STANDARDS

N/A

11. Check RCP Annunciators

Cue: RCP Annunciators are clear.

ENSURE the following annunciators for the applicable pump(s) are cleared.

a. RCP LOWER OIL RSRVR LVL HIGH LOW (1-13-A6/B6/C6/D6).

b. RCP UPPER OIL RSRVR LVL HIGH LOW (1 -13-A7/B7/C7/D7).

**Observes** Caution

### CAUTION

Do not open CV8141A/B/C/D or CV8142 unless there is a minimum of 100 psig RCS pressure. This prevents blowing stagnant unfiltered water into the seals.

12. Verify Open Seal Retrict line

Verify open 1Cv8100 and 1CV8112.

\*13. Establish seal leakoff flow. OPEN CV8141A/B/C/D, RCP A/B/C/D No. 1 Seal Leakoff Stop Valve. Cue: \_CV8141A/B/C/D, RCP A/B/C/D are open. 14. Check Seal leakoff flows normal. **ENSURE all RCP Seal Leakoff** 0 Flows are within the normal operating range per BOP RC-1A1, Cue: Seal leakoff flows are within RCP No 1 Seal Leakoff Normal normal range. Operating Range for A/B/C/D RCP.

\*15. Start oil lift pump. START the Oil Lift Pump for D RCP.

Cue: Oil lift pump has started.

09/03/98 7:18 AM

### STANDARDS

16. Check RCP annunciators

### Cue: RCP annunciators are clear.

ENSURE the following annunciators for the applicable pump are cleared:

a. RCP SEAL DP LOW (1 -7-A3).

**b. RCP STANDPIPE LEVEL HIGH** (1 -7-A6/B6/C6/D6).

c. RCP STANDPIPE LEVEL LOW (1-7-A7/B7/C7/D7).

d. RCP SEAL LEAKOFF FLOW HIGH (1 -7-B3).

### NOTE

RCP Seal Leakoff Flow Low alarm setpoint is 0.82 gpm. The minimum flow required is determined using BOP RC-1A1, RCP No 1 Seal Leakoff Normal Operating Range. This alarm does not have to be cleared as long as #1 seal leakoff flow is in the acceptable region.

### NOTE

If indicated RCP Seal Leakoff flow is less than the required flow per BOP RC-1A1, RCP No 1 Seal Leakoff Normal Operating Range, a bucket test may be performed, to measure the amount of leakoff actually returning from the RCP Seals.

\*17. Verify oil lift pump run for two minutes minimum.

Cue: Pump has been running for two minutes. Lights are illuminated. ENSURE the Oil Lift Purnp for D RCP has run for at least two minutes and is producing adequate pressure (OIL PRESS UP light On).

18. Check seal leakoff flow normal

Cue: Seal leakoff flows are within normal range.

**ENSURE Seal Leakoff flow is** within the normal operating range per BOP RC-1A1, RCP No 1 Seal Leakoff Normal Operating Range.

JPM-7

09/03/98 7:18 AM

STANDARDS

SAT UNSAT N/A

19. Check #1 seal DP.

Cue: Seal DP is > 400 psid.

20. Pump Start Announcement

ENSURE greater than 200 psid across #1 Seal for Reactor Coolant Pump A/B/C/D, as indicated on PI-153A/152A/151A/150A, RCP A/B/C/D No. 1 Seal DP, at PM05J.

ANNOUNCE the RCP to be started over the plant page system.

# . .

### NOTE

RCS pressure will drop ~100 psig when initially starting an RCP. RCS pressure will then increase as the RCP comes up to speed.

### NOTE

If an RCP is to be started with the RCS solid, then manually controlling CV131, Letdown line Press Cont VIv, will minimize any pressure transients in the RCS.

21. Take Manual control of 1CV131

Cue: another operator will monitor and contro! RCS pressure. PLACE 1CV131, Ltdwn Line Press Cont VIv, in MANUAL, if RCS is solid. (RCS is NOT solid)

22. Monitor RCS pressure.

MONITOR RCS pressure CLOSELY and ADJUST 1CV131, Ltdwn Line Press Cont VIv, as required to maintain pressure.

#### STANDARDS

### Notes CAUTION

### CAUTION

As the RCP comes up to speed, the differential pressure across its No. 1 seal is expected to decrease as the static pressure at the pump suction decreases. The RCP must be stopped if seal  $\Delta P$  cannot be maintained above 200 psid, or if seal leakoff flow is lost.

### NOTE

On the first start of each pump, the RCP should be stopped within approximately 35 seconds. On the second start, the RCP should be stopped after approximately 1 minute. An optional 5 minute run may be performed on each RCP. This pertains to filling and venting the RCS. If the RCS is already filled and pressurized, disregard this note.

### NOTE

It is preferred to start the RCPs in the following sequence D, C, B, A.

### CUE: RCS is filled and vented using vacuum refill system.

# An operator is standing by at the RCP to monitor rotation.

\*23. Starts Reactor Coolant Pump

START D RCP and ENSURE shaft rotation within 2 seconds, or TRIP the RCP, and NOTIFY the Shift Manager.

24. Checks RCP current.

Cue: RCP current behavior is as expected. ENSURE current drops to less than or equal to 650 amps within 35 seconds, or TRIP the RCP. 0

.

STANDARDS

25. Check RCP Annunciator.

Cue: RCP Annunciator is clear.

ENSURE "RC PUMP BREAKER OPEN OR FLOW LOW ALERT" annunciator cleared (Window -13-D3).

0 0 0

Cue: This completes JPM.

RECORD STOP TIME

COMMENTS:

### JPM Questions

Question No: 1

Reference Use: Yes

Unit 1 plant conditions:

- · Reactor power is 50%
- RCP SEAL LEAKOFF FLOW HIGH annunciator alarms (1-7-B3)
- RCP 1D No. 1 seal leakoff flow rate indicates 5.6 gpm
- · RCP 1D SEAL No. 2 LEAKOFF FLOW HIGH alarm is NOT printed
- RCP 1D No. 1 seal DP indicates > 400 psid
- RCP 1D #2 Seal Leakoff (1FIS-0191) indicates 0.5 gpm
- All RCP temperatures are normal and stable
- There are no instrument failures

What operator actions are required for the above conditions?

Expected Answer:

Maintain at least 9 gpm seal injection flow to RCP 1D; initiate a unit shutdown per BGP 100-4 (POWER DESCENSION); trip the 1D RCP within 8 hrs; Close 1CV8141D; and Close 1RY455B.

Actual Answer:

Candidate's response matched expected answer.

K/A: 003000A2.01 3.7/4.0

Sat Unsat .

Reference(s): BOA RCP-1 RCP SEAL FAILURE, Rev. 55C.

### JPM Questions

### Question No: 2

#### Reference Use: NO

The reactor is starting up and is at 35% power. A reactor coolant pump is accidentally tripped.

What is the origination of the reactor protection system signal that will trip the reactor?

#### Expected Answer:

A reactor trip will occur from Reactor Coolant Low Flow 2/3 channels < 90% loop flow on 1/4 loops (power above P-8).

### Actual Answer:

Candidate's response matched expected answer.

K/A: 012000A306	3.7/3.7
-----------------	---------

Sat Unsat \_\_\_\_.

Reference(s): EF-1 ESF Setpoints, Rev. 4, Reactor Trip BAR 1-11-C5, Rev. 51, Setpoint. Chapter 60b/Reactor Protection System, Rev. 2, II.B.c.5), page 22, LO 4.

### OPERATOR QUESTION SHEET

Question No: 1

Reference Use: YES

Unit 1 plant conditions:

- Reactor power is 50%
- RCP SEAL LEAKOFF FLOW HIGH annunciator alarms (1-7-B3)
- RCP 1D No. 1 seal leakoff flow rate indicates 5.6 gpm
- · RCP 1D SEAL No. 2 LEAKOFF FLOW HIGH alarm is NOT printed
- RCP 1D No. 1 seal DP indicates > 400 psid
- RCP 1D #2 Seal Leakoff (1FIS-0191) indicates 0.5 gpm
- All RCP temperatures are normal and stable
- There are no instrument failures

What operator actions are required for the above conditions?

Question No: 2

Reference Use: NO

The reactor is starting up and is at 35% power. A reactor coolant pump is accidentally tripped.

What is the origination of the reactor protection system signal that will trip the reactor?

### TASK CONDITIONS:

- 1. You are an extra NSO.
- The Unit has just tripped in conjunction with an electrical fire in the Unit's Remote Shutdown Panel.
- 3. The 1A AF Pump is OOS for maintenance and the 1B AF Pump did not auto start, and will NOT manually start with the MCR Switch.

### INITIATING CUES:

The Shift Manager has just directed you to initiate a Local Emergency Start of the 1B AF Pump using BOA ELEC-5, Attachment D.

		JOB PERFORM	A E !	MEASURE F	Rev. <u>3 9/4/97</u>		
TASK TITLE:	Local Eme	rgency Start of 1	B AFW	Pump	JPM No.:	JPM-8	
TPO No: IV.D.	OA-35	K&A No.:	01300	0G013	K&A IMP.	3.9/4	0
TRAINEE:			******		DATE:		
The Trainee:	PASSED	this	IPM	TIM	E STARTED:		
	FAILED			TIME	E FINISHED:		
EVALUATION N	ETHOD:	PERFORM		SIMULATE			
LOCATION:		IN PLANT					

MATERIALS:

1BOA ELEC-5, Attachment D, Diesel Driven AF Pump Local Start.

### GENERAL REFERENCES:

1BOA ELEC-5, Attachment D, Diesel Driven AF Pump Local Start.

TASK STANDARDS:

Correctly perform the actions required for 1B AF Pump Local Emergency Start.

### TASK CONDITIONS:

- 1. You are an extra NSO.
- The Unit has just tripped in conjunction with an electrical fire in the Unit's Remote Shutdown Panel.
- 3. The 1A AF Pump is OOS for maintenance and the 1B AF Pump did not auto start, and will not manually start with the MCR Switch.

INITIATING CUES:

The Shift Manager has just directed you to initiate a Local Emergency Start of the 1B AF Pump using BOA ELEC-5, Attachment D.

### CRITICAL ELEMENTS: (\*)

1, 4, 7, 8, 9, 10

### APPROXIMATE COMPLETION TIME: 12 minutes

JPM-8

PERF	ORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	N/A
RECO	ORD START TIME				
*1.	Locate the 1B AF pump.	Locate the 1B AF pump.	Q	a	a
Note:	Provide the Candidate with a copy of BOA ELEC-5, Attachment D.				
2.	Verify/Start associated Aux Lube Oil Pump.	Verify/Start 1B Aux Lube Oil Pump.	a	a	٩
Cue:	Aux Lube Oil Pump running.				
3.	Verify/Start Gearbox Lube Oil Pump.	Verify/Start Gearbox Lube Oil Pump.	۵	٩	Q
Cue:	Gearbox Lube Oil Pump running.				
*4.	Place ENGINE START Switch	Place ENGINE START	a	a	Q
Cue:	ENGINE START Switch is in "MAN".	Switch to MANUAL.			
5.	Verify Diesel Air Box Tripped reset.	Verify Diesel Air Box Tripped annunciator reset.	Q	Q	Q
Cue:	Air Box Tripped is reset.				
6.	Momentarily depress the RESET button.	Momentarily depress the RESET button.	٩	٩	٩
NOTE: Located on 1AF01J.					

PERFORMANCE CHECKLIST STANDARDS SAT UNSAT N/A

*7.	Start the 1B AF Pump.	Depress the START Button.	a	a	a
Cue:	The Engine does NOT crank. The ENGINE RUNNING Light is NOT LIT.	•Verify the ENGINE RUNNING Light is lit.			
NOTE	: If other battery bank is selected, the engine will still not start.				
*8.	Perform RNO.	RNO for Step 2.e	a	a	•
Cue:	Engine switch is in AUTO	Return Engine Switch to AUTO			
*9.	Start the 1B AF Pump at Emergency Control Panel	1) Proceed to 1AF03J (364 M16)	٩	٩	Q
Cue:	The ENGINE RUNNING Light is NOT LIT.	2) Place REMOTE EMERGENCY START switch to START			
*10.	Start the 1B AF Pump in START WITH BYPASS	Place REMOTE EMERGENCY START switch	a	٩	٩
Cue:	The engine STARTS w/ ENGINE RUNNING light LIT	IO START WITH BYPASS			

09/03/98 3:56 PM

### STANDARDS

- 11. Verify the SX Cooling Valves are Verify Of En using stem D D D position is carcation:
- NOTE: Provide copy of BOP AF-T1 DDAFP Operating Logs.

• 1SX173

• 1SX178

- NOTE: Identifying location of valves is sufficient.
- Cue: 1SX173 is OPEN.
  - 1SX178 is OPEN.

Cue: THIS COMPLETES JPM.

RECORD STOP TIME

COMMENTS:

09/03/98 3:56 PM

Question No: 1

Reference Use: NO

Given the following:

Unit 1 tripped due to a loss of feedwater AF Pump B auto started on the trip AF Pump A failed + start due to a failure of Train A SSPS to process any actuation signals d was manually started by the control room operator.

What are the expected AF system responses as CST level reaches an empty condition?

Expected Answer: (At 20.1 psia at the suction of either AF Pump, annunciator 1-3-A7 AF PUMP SUCT PRESS LOW will alarm.)

At 18.1 psia detected at the suction of the AF 1B Pump, SX supply valves AF017B and AF006B will open (CST recirc closes; SX recirc opens). This should ensure adequate pressure maintained to the AF 1B Pump.

At 16.5 psia detected at the suction of the AF 1A Pump, the pump will trip. (Swapover to SX will NOT occur since pump was manually started.)

#### Actual Answer:

Candidate's response matched expected answer.

Sat \_\_\_\_ Unsat \_\_\_\_.

K/A: 061000A104 3.9/3.9

Reference (s) :

AF-1, Auxiliary Feed System, Rev. 3, AF SUCTION PRESS SETPOINTS.

BAR 1-3-A7, Rev. 9.

Chp 26, Auxiliary Feedwater System (AF), Rev. 03, II.A.2, page 8-10, LO 10.

### JPM Questions

#### Question No: 2

#### Reference Use: NO

Following a reactor trip from 100% power due to a trip of a feedwater pump, only AF Pump 1B started. Following establishment of AFW flow to all SGs, the line downstream of AF005H ruptured and severed the main instrument air line. This resulted in a loss of instrument air at the Unit.

1. What is the minimum flow that will be provided to the SGs?

2. How would level in the SGs be controlled from the MCB?

#### Expected Answer:

- 1. The minimum flow to each SG other than SG D is 160 gpm; OR total flow to the SGs will be at least 480 gpm.
- 2. Flow to the 3 SGs may be controlled by throttling the (motor-driven) AF013 valves (AF013E, F, G) to SGs A B and C.

#### Actual Answer:

Candidate's response matched expected answer.

K/A: 061000K302 4.2/4.4

Sat Unsat ......

Reference(s): AF-1 Auxiliary Feed System, Rev. 3.

Chp 26, Auxil ary Feedwater System (AF), Rev. 03, II.A.6.c, page 35 and I.A.6.e, page 37-39, LO 12, 13.

### OPERATOR QUESTION SHEET

Question No: 1

Reference Use: NO

Given the following:

Unit 1 tripped due to a loss of feedwater AF Pump B auto started on the trip AF Pump A failed to start due to a failure of Train A SSPS to process any actuation signals and was manually started by the control room operator.

What are the expected AF system responses as CST level reaches an empty condition?

Question No: 2

Reference Use: NO

Following a reactor trip from 100% power due to a trip of a feedwater pump, only AF Pump 1B started. Following establishment of AFW flow to all SGs, the line downstream of AF005H ruptured and severed the main instrument air line. This resulted in a loss of instrument air at the Unit.

1. What is the minimum flow that will be provided to the SGs?

1. How would level in the SGs be controlled from the MCB?

-	-	\$ 1	1		-	-
- 14	pr.	v		- 54	1	24
- 1%	Sec.	-	٠	~	-	20

### LOCAL EMERGENCY CONTROL OF SAFE SHUTDOWN EQUIPMENT UNIT 1

1BOA ELEC-5

STEP ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
ATTACHMENT D (PG 1 OF ) DIESEL DRIVEN AUXILIARY FEEDWATER P	3) UMP LOCAL START
* NOTE * A start of the 1B AF pump for * either of the following loc * will bypass the lube oil pr * start permissives: * * o Local Control Panel (38) * o Emergency Control Panel ****	**************************************
1 START AUX LUBE OIL PUMPS: • Pump lube oil pump	
<ul> <li>1AF01PB-A (outside pump room</li> <li>333 L15)</li> </ul>	
· Gearbox lube oil pump	

• 1AF01PB-C (inside pump room 383 L16)

				-			
-	-				-	-	
-	<b>B</b> -1	.,		- 86	æ	ы.	
- 15	RC.	w	-	- 23	- 28	<b>1</b> 0	
	Sec.	-			-	1000	

.

# LOCAL EMERGENCY CONTROL OF SAFE SHUTDOWN EQUL

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
2 5	ATTACHMENT D (PG DIESEL DRIVEN AUXILIARY FEEDW	<u>2 OF 3)</u> MATER PUMP LOCAL START
e a	ANEL 1AF01J: . Place ENGINE START switch in - MAN	
b	. Check AIR BOX TRIPPED annunciator - NOT LIT	b. Reset diesel air box trip.
c	. Depress RESET pushbutton	
*d	. Depress START pushbutton	d. If engine fails to crank, <u>THEN</u> perform the following:
		1) Select otner battery bank.
		2) Depress RESET pushbutton.
		3) Depress START pushbutton.
e	. Verify engine starts - WITHIN	e. Perform the following:
	<u>60 SECONDS</u>	1) Return ENGINE START switch to AUTO.
		2) GOTO Step 3 (Next Page).
f	. GOTO Step 4 (Next Page)	

-	-		-	-
-	-			875
~			Ph 16	846
• • •	Б.,	υ.	00	5

.

.

### LOCAL EMERGENCY CONTROL OF SAFE SHUTDOWN EQUIPMENT UNIT 1

	DIESEL DRIVEN AUXILIARY FEEDWATE	R PUMP LOCAL START
	CAUTION The START WITH BYPASS po start the 1B AF pump wit Suction Pressure Trip Di	osition will th the Low ISABLED.
3	START 18 AF PUMP AT EMERGENCY CONTROL PANEL 1AF03J (364 M16):	
	a. Place REMOTE EMERGENCY START switch in - <u>START</u>	
	b. Verify RUN light - <u>LIT WITHIN</u> b. 60 SECONDS	<ul> <li>Perform the following:</li> <li>1) Place the REMOTE EMERGENCY START switch in START WITH BYPASS.</li> </ul>
		<ol> <li>Verify the RUN light lit within 60 seconds.</li> </ol>
		IF the pump fails to start contact the Shift Manager for guidance.
4	MONITOR 1B AF PUMP OPERATIONS:	
	a. Perform BOP AF-7T1, DIESEL DRIVEN AUXILIARY FEEDWATER PUMP OPERATING LOG	
5	RETURN TO PROCEDURE AND STEP IN EFFECT	
	-END-	
		4

#### Facsimile

### DIESEL DRIVEN AU TLIARY FEEDWATER PUMP OPI ATING LOG

NOTE
PERFORM the applicable steps of this Data Sheet after the start of the pump and every 30 minutes thereafter. Forward the completed BOP AF-7T1 to the AF System Engineer, SED
Notify the SM if Engine cranks more than 4 times upon starting.

					NUM	BER OF	CF	RANKS	
S	TART	DATE	 START	TIME	-	BEFO	RE	START	

EQUIPMENT

B AF Pump

EXPECTED VALUES

-	-	100	14	-	-	TAPPI	-	OBT
D	H.	55		ж	-1	PT		ON
-		~	~~	2.2	-	* *	-	224

TIME		N/A
INITIALS		N/A
DAY TANK LEVEL		<u>&gt;</u> 50%
SX COOLING VLVS _SX173 + _SX178		BOTH OPEN
CUBICLE COOLER SX FLOW		< 130 GPM
ENGINE RPM		1740-1840 U-1 1790-1875 U-2 RPM
MP SUCT PRESS		> 6#
PUMP RECIRC FLOW		80 - 110 GPM
OIL PUMP SHAFT BRG TEMP		< 185°F
PUMP OIL PRESS (FILTER OUT)		> 8#
OIL FILTER, DIFF PRESS		< 4#
TURN PUMP OIL FILTER		YES

APPROVED 10/09/97

.

### Facsimile

### BOP AF-7T1 Revision 7

### DIESEL DRIVEN AUXILIARY FEEDWATER PUMP OPERATING LOG

EQUIPMENT DESCRIPTION				EXPECTED VALUES
TIME			-	N/A
INITIALS				N/A
PP OIL COOLER OUTLET TEMP				65 - 128°F
TURN GEAR OIL FILTER				YES
GEAR COOLER, OIL OUTLET TEMP				65 - 130°F
GEAR OIL PRESS				> 13#
COOLER, SX OUTLET TEMP				< 150°F
ENGINE OIL PRESS				50 - 70#
ENGINE OIL TEMP				< 200°F
ENGINE WATER TEMP				< 180°F
TURN FAN GEAR OIL FILTER				YES

### JOB PERFORMANCE MEASURE

### CANDIDATE CUE SHEET

### TASK CONDITIONS:

- 1. You are an extra NSO.
- 2. Unit-2 is in Mode 3.
- 3. A fault on a 345KV line has caused the SAT's to trip.
- 4. Bus 241 is energized by D/G 2A.
- 5. Bus 242 BUS ALIVE light is NOT LIT.
- The UNIT NSO has placed the breakers identified in Step 1 of 2BOA ELEC-3 ATTACHMENT D in their appropriate positions and has check lockout alarms NOT lit.

INITIATING CUES:

The US directs you to perform a Local Start of the 2B D/G using 2BOA ELEC-3, ATTACHMENT D.

### JOB PERFORMANCE MEASURE

TASK TITLE: Local Abnormal Start of a D/G

TPO No: IV.D.OA-34 K&A No.: 064000A401

TRAINEE:

The Trainee: PASSED this JPM TIME STARTED: \_\_\_\_\_

FAILED

EVALUATION METHOD: PERFORM\_\_\_\_\_ SIMULATE\_\_\_\_\_

LOCATION: IN PLANT\_\_\_\_\_

MATERIALS:

2BOA ELEC-3, LOSS of 4KV ESF BUS

GENERAL REFERENCES:

2BOA ELEC-3, LOSS of 4KV ESF BUS

TASK STANDARDS:

Perform actions necessary to complete a Local Abnormal Start of a D/G.

TASK CONDITIONS:

- 1. You are an extra NSO.
- 2. Unit-2 is in Mode 3.
- 3. A fault on a 345KV line has caused the SAT's to trip.
- 4. Bus 241 is energized by D/G 2A.
- 5. Bus 242 BUS ALIVE light is NOT LIT.
- The UNIT NSO has placed the breakers identified in Step 1 of 2BOA ELEC-3 ATTACHMENT D in their appropriate positions and has check lockout alarms NOT lit.

INITIATING CUES:

The US directs you to perform a Local Start of the 2B D/G using 2BOA ELEC-3, ATTACHMENT D.

CRITICAL ELEMENTS: (\*)

7,9,10

APPROXIMATE COMPLETION TIME: 20 Minutes

JPM-9

09/03/98 4:07 PM

Rev.<u>0</u>, 4/6/94 JPM No.: <u>JPM-9</u> K&A IMP. <u>4.0 / 4.3</u> DATE: <u>/ /</u> ME STARTED: \_\_\_\_\_

TIME FINISHED:

STANDARDS

### RECORD START TIME

- NOTE: Completion of Step 1 is provided in task condition.
- 1. Refer to 2BOA ELEC-3, ATT. D, Locate and open 2BOA Local Start of a D/G ELEC-3, ATT. D.
- Note: This step may be performed at any time.
- Note: Provide the Candidate with a copy of 2BOA ELEC-3, ATTACHMENT 'D'.

Note: Simulate obtaining keys from Center Desk.									
2.	Get keys for local D/G operation.	Identify keys at center desk: • U2 PRI-5 keys	Q	۵	0				
Cue:	Keys have been obtained.	B-core masters							

Note:

For cueing steps 4,5,8 for DC control power, starting air receiver pressure, and support systems status, have candidate use actual values if D/G is operable. If D/G is inoperable or the actual parameter is out of spec, give the listed cues after the candidate locates the component.

PERFORMANCE CHECKLIST		STANDARDS	SAT	UNSAT	<u>N/A</u>				
*3. Cue:	Check 2B D/G Shutdown. oRunning Idle Light NOT Lit • Emergency Stop P/B is depressed and released	<ul> <li>o Verify Running Idle Light NOT Lit</li> <li>Depress Emergency Stop Pushbutton</li> </ul>	٩	L)	٩				
4. Cue:	Verify DC control power available •DC power on/bus #1 light is Green	Verify lights lit: • DC POWER ON/BUS #1 • DC POWER ON/BUS #2	٩	ū	a				
5.	<i>is Green</i> Verify starting air available.	Verify either air receiver >100 psig:	a	a	٩				
Cue:	*2Pi- DG097B = 240# *2Pi-DG096B = 240#	<sup>o</sup> Left bank 2PI-DG097B <sup>o</sup> Right bank 2PI-DG096B							
6. Cue:	Determine support system status. °2SA140B is CLOSED °2SA140D is CLOSED	Check air recvr valve position: * 2SA140B * 2SA140D	٩		0				
Note: Opening either valve in the next step would provide sufficient starting air for the D/G- however both are closed bullets in the procedure.									
*7. Cue:	Correct valve misalignment. *2SA140B is OPEN *2SA140D is OPEN	Open air receiver valves: * 2SA140B * 2SA140D	Q	ū	Q				

JPM-9

.
# PERFORMANCE CHECKLIST STANDARDS

.

SAT UNSAT N/A

3.	Verify all additional support systems status.	Verify :	a	a	a
Cue:	Fuel Head Tank upper Bull's Eye Full	<ul> <li>Fuel Head Tank upper Bull's Eye Full</li> </ul>			
	* Speed droop is 0	* Speed droop - 0			
	* Load limit is at MAX FUEL	* Load limit - max fuel			
	* Speed is per LOCAL PLACARD (9.70)	* Speed - per local placard			
	• Oil level is within sightglass	* Oil level within sightglass			
	• Output shaft is at MAX FUEL	* Output shaft - max fuel			
	<ul> <li>Overspeed Gov cil is within sightglass</li> </ul>	<ul> <li>Overspeed Gov Oil level - within sightglass.</li> </ul>			
	• The turning gear is DISENGAGED	Turning gear disengaged			
	<ul> <li>Fuel rack man. trip lever is LATCHED IN VERTICAL POSITION.</li> </ul>	<ul> <li>Fuel rack manual trip lever latched in vertical position</li> </ul>			
	• Control air Left Bank is ON • Non failsafe air is ON • Air drain is CLOSED	<ul> <li>Left bank control air lineup:</li> <li>Cranking air on</li> <li>Non failsafe air on</li> <li>Air drain closed</li> </ul>			
	• JW expansion tank level is WITHIN THE SIGHTGLASS.	<ul> <li>J.W. expansion tank level within sightglass</li> </ul>			
	<ul> <li>Overspeed butterfiy valve is OPEN.</li> </ul>	Overspeed butterfly valve     open			
	• Lube oil sump level is WITHIN THE SIGHTGLASS.	<ul> <li>Lube oil sump level within sightglass</li> </ul>			
	• Control air Right Bank is ON • Non failsafe air is ON • Air drain is CLOSED	<ul> <li>Right bank control air lineup:</li> <li>Cranking air on</li> <li>Non failsafe air on</li> <li>Air drain closed</li> </ul>			
JP	M-9	5	09/03/9	8 4:	07 PM

# PERFORMANCE CHECKLIST STANDARDS SAT UNSAT N/A

• •

۰.

*9.	Prepare for 2B D/G start.		Q	a	
Cue:	<ul> <li>Bus 242 is dead (Control Room report)</li> </ul>	°Check bus 242 is dead at 1PM01J			
	• D/G is CLEAR of personnel	Verify D/G clear of personnel			
	°U-2 has been NOTIFIED	°Request Unit 2 verify DG controls:			
	•2B D/G Control switch is in After Trip (A/T)	∘Asks if 2B D/G C/S at 2PM01J in A/T			
	• ACB 2423 switch is in After Trip (A/T)	∘Asks if ACB 2423 in A/T			
	<ul> <li>Annunciator and system reset switch has been placed in RESET and RELEASED.</li> </ul>	<ul> <li>Place annunciator &amp; system reset switch to RESET.</li> </ul>			
*10.	Start D/G 2B	Depress Emergency Stop     Reset P/B	a	٩	0
Cue:	•Emergency stop reset P/B has been DEPRESSED.				
	°Engine is CRANKING.	° Check: - Engine cranking - Speed > 590 rpm			
	°Speed is 600 rpm.				
	°2SX169B is OPEN.	° Check DG SX valve 2SX169B open.			
	°RUNNING LOADED light is LIT.	<sup>o</sup> Check bus 242 energized by RUNNING LOADED light.			

09/03/98 4:07 PM

# PERFORMANCE CHECKLIST

STANDARDS

0

11. Monitor DG per BOP DG-11T2.

Locates BOP DG-11T2 and indicates logging parameters.

Cue: This completes this JPM.

RECORD STOP TIME

COMMENTS:

Question No: 1

Reference Use: YES (Horse Notes Not Allowed)

Contrast the difference between a start of the D/G during normal testing per BOP DG-11 DIESEL GENERATOR STARTUP and a start of the D/G due to a SI signal as they relate to the operation of the D/G Air Compressor and Dryer.

#### Expected Answer:

On a normal start, the air dryer will start when the air receiver pressure falls to 240 psig. 90-180 seconds later the air compressor will start. On a safety injection, both the air dryer and the air compressor will start when the air receiver pressure falls to 240 psig.

Actual Answer:

			-
			_
			_
Candidate's	response matched expected answer.		
<b>K/A:</b> 064000K105	3.4/3.9	Sat	Unsat
Reference(s):	BOP DG-1, Diesel Generator Alignment Rev 5, Pages 5 & 6.	to Standby	Condition,
	6E-2-4030DG10, DG14, DG32, and EF11		
	DG-6, D/G Air Start / Pneu. Protect., DRYER/COMPRESSOR.	, Rev. 1,	
	Chp 9, Diesel Generators & Aux. Syste page 24-25, LO 2.e.	ems, Rev. 1	, II.E.1,

	the second of the other second	and the second	
The second se	Contraction of the Party of the	The second s	ACCREDING NO.
	Construction of the local states of the local		
INCOMPANY AND DESCRIPTION	And the state of the local distance of the l	Senate in the local division of the local di	ALC: NOT THE OWNER OF THE OWNER OWNER OF THE OWNER OWNER OF THE OWNER OWNE
			_

• .

۰.

-

.

TABLE FOR SLAVE RELAYS DEVELOPMENT SSPS PANEL 19409J

-

-

MASTER	OUTPUT RELAY NO.	COIL	S/D	L		CONTACT D	EVELOPMENT	& REFEREN	CE 3/0			
RELAY		RECULA	RUESUR	0-11-6	1011-8	10-11-8	10-1-19	10-1-6	RIFA	124HB	1241-8	FORCITOR
K501	UNKAON	EFS	EFO9	∆ 5₽	59	∆ 3₽	34	10.50	5.9	1 3p	630	FEED WATER VALVES (SAFETY INJECTIC
1521	(LATCH)			ACTUATE MAGT, SPOP	O-VAIA	END) EF36	0-VALS	1586	0-VA19	0-VAID	0-461	SAFETY INJECTION
K501	0.8483			CV15	\$106	\$111	- 8P	CVIO	CVII	AFOS	*6111	SAFETY INJECTION
¥521	aktes ?			AFCA	5.0	SI12	AFII	.0 60	# A514	B TENT	-6112	SAFETY INJECTION
K502	UNSA.			+CV19	EF63	SP	46121	+SI26	WERE.	Lanos	1 1000	CONTAINMENT ISOLATION-MA
×522	(LATCH)			ARY11	*RE04	-RED4	n:603	+0009	ØGII	4 PRO:	SP	CONTAINMENT ISOLATION-MA
K 502	11493			CVIS	*1404	0 2831	0 19551	*5P	•Phil01	+ PESE	-6503	CONTAINMENT ISOLATION-MA
K501	(1.K428)			EF01	EF01	59	*EF01	EFOI	+EF01	SP	*EF02	SAFETY INJECTION
K521	(141609)		11	AP30	56	50	BUX 3D	6.0	3.0	EFICO	50	SAFETY INJECTION
K501	KOTO (LATCH)			VIP01	VPOS	VPOZ	VPO6	*SX13	+5X15	*5X16	5.0	SAFETY INJECTION
K521	Kéll (LATCH)			0601	06.91	06.52	DGO	5.0	0- WAOI	0-1407	5.9	SAFETY INJECTION
K922	K612			*PS01	+#901	***	P502	0-46.09	80	9608	#809	CONTAINMENT ISOLATION-MA
KSUZ	K613 (LATCH)			*5005	*500.9	*\$007	*5007	*5004	*5004	-	*\$404	CONTAINMENT ISOLATION-MA
N 522	(5414)		TT	*9005	+\$005	*\$006	*5000	+6006		0-0618	-	CONTAINMENT ISOLATION-MA
K503	K615	EF36		SP	AMM (181.	# V907	SP	SP	SP	5.0	50	CONTAINMENT VENT I JLATION
× 904	KE16	EF35	TT	<b>HSO1</b>	14502	MS03	MEGA	SP	6.0	SP	152593	STEAM STOP VALVES
K906	×619	EF36	T	EF 36	8.0	8.P	SP	SP	1.00	50	5.9	CONTRINNENT ISOLATION-PE
×506	K619	EF36	TT		A SUPPLY STREET,	And a state of the	LPARE					CONTAINMENT ISOLATION-M
K 515	K620	PEF34	-	A 2003	# 8D03	∆ spo4	# 3004	Aspes	@ \$005	∆ \$006	A EFOS	AUX FW PUPPE 14 STEAM GEN.
K508	K621	2597		50	50	39	10	87100	SP.	SP	-4503	TEP FEED MATER PUMPS
K\$03	K622	EF36	TT	SP	8 Y908	SP	* 1011	• VQ07	90000		ovene	CONTA 1 124E NF YENT 1 SOLAT 1 JA
K90J	X623	EFSS		***	4606	+9807	***5077	5.0	SP	SP	50	STEAM STOP WALVES
K506	K677.41	EF36		50	SP	50	50	5.12	5.0	SP	8,19	CONTAINMENT ISOLATION-MB
K906	X424	EFSS		CC045	C097	0004	50	SP	50	50	*EFOS	COMPATINGENT ISOLATION-MB
K309	K627	EF28		RCD1	RCOR	RC05	RCD4	50	50	10	*EF09	RCP UNDERFREQUENCY
K510	K622	EF39	+++	4 SP	4 50	45011	45712	-	Provide State and Added		- DARY-	PRESSURIZER RELIEF BLOCK-P11
K911	K629	EF19	TT	SP	5.P	P	+48.04	30	5.0	5.0	50	SOURCE BANKE BLOCK
K912	X430	EF36	11	A SPARE	460	490	4 90	440		·A CED3	OPuse	SAFETY IN SECTION FEETMATER CONTROL
K513	K691	EF30		HSON	50	30	89	-		- Kar		LO-LO TAVE STEAN OURP INTERLOCK
K514	K652 0	6728		50	AFOS	A AFSS	ACILATE				5	ASTILLARY FOED LTD BLADDA (25)
K\$15	K633 0	EFSA		APUI	AP03	APOs	AF11	50		(a 5000 )	FEFOS	MILLI LARY FEED HTR PLAPS NO STH 66
K916	K634	EF34	++	50	# 5P	30	50			-	TEST	ANNUMARY FRED WYR PLOAPS THE STOR GE
K517	K695	6527	+++	1500	50	SP	19%					GENERATUR & TURAIME TRIP
K\$20	K696	EF37	++	A 50	30	440		A 60	-	A 40	A 58	STIMMETER VALVESTOFACTOR TRUE
K\$20	K637	EFST	+++		400	ASP	ASP	ASP		A 5570	D PHSA	FEEDWATER VALVES (REACTOR TIMP)
K907	K638	EF37	+		680	ASP	6 5P	682		A 5704	2 FML4	FEEDLATER VALVES ON -HI STRAN GENER
4336	K640	FF37		7004	5.0	SP	.50	4.0		-		LEVEL) ISOLATION
K556	K6d1	6537	++		50	SP	1.0			55		TIDRILE TRIP
1505	K643	EF36	+++	LENG	+	C506	0504	0007	(5/18		/19/16	SPRAY ACTUATION
4	KS44	EF36		CS01	ANDEI	50	(501	+ 4001	5,0		6.6800	
****	KAAS	E534		60	SP	50	40	C807			H KI C	SHEAV ACTUATION
K602	K647	65.84		3114	AP25	6510	CUIR					ANTRET ALTURITIET
\$924	(LATCH)	6530	+++	STIA	CYLE	SP	CTIN	37	34	30	8736	BUST (REFUELING WATER STORAGE TANK)
× 526	KA17	EE 17		CV37	SP	58	60	-			-	LO-LO LEVEL
K527	K624	EF 17	++-	ACV37	SP	50	50					LUCY NCS PRESSURE
	and an approximation of the second	6.F II	1				ər					AMPE
K6 32	s419 0	EF 2A	ERO?		4504	AFII	5.0	10		10	# EPOS	ANTELLARY FER WITH DURAN ( DOLLARS)
× 512	K646	65.20	1 FEOR	CURR	EEN	ACURA	A EFOR			50	TEST	AUAUUARY FLA HIC PLANS (ULAYLO)
ILTIES	(LATCH)	EF 36	Eros	CV37	Erny	40137	A TEST	SP	SP	SP	SP	SAPE IT INJECTION
FRIA	C \$47											FUTURE
			+									LR ROC STOP BLOCK
K5/3												

nichten anderen eine sind sind anderen eine seinen eine sind sind sind sind sind sind sind sind	FRY STARK	CONTROLLED DOCUMENT
6-6 (60-60)	1 N-G (NO-GO)	- RB
HE	i NONE	(INITIAL)
	HONE	DATE ISSUED
L THE USED CONTACTS (GG)	NOME	- INN 0 C 1997
1. THE USED CONTACTS (4-6)	NCHE	JANUO IJAK
1 THE USED CONTACTS (G-G)	NONE	TS GROUP - C'
L THE USED CONTACTS (G-G)	HONO CONTRACTOR	DEPT. TR JOB Sche
- 8, 9-10, 15-16	1-2 3-4 13-16	100 # 0 Set (
-4, 9-10,18-15	1+2 4-12	Sen Em_
1.9-10.18-16	NORE	ISSUED TO DATE VOID
L THE USED CONTACTS (G-G)	WONE	
8. 5-4. 7-8. 13-54. 18-16.54	R MONE	
. THE USED CONTACTS (C-C)	ANCHNE:	FRA REAM OF A CALL AND A
THE USED CONTACTS (G-G)	NONE	
. THE WOLD CONTACTS (G-6)	NONE	
9-4.7-8	NONE	
	1-2, 3-4, 7-4,9-0	PSCN P-118C
	NONE	10011 19/103
	HORE IT IN	DCP ALLED all
3-2.7-8.8-10.8-12 13-14 13-16	MONR	
12	NOONE	1
. THE LINES CONTACTS (DAD)	MCIE:	
. 8-4 7-8 9-00	NCMF	
E Constantine Constantine Constantine	MORAL	
******	5-2 5-6 7-8	· ·
CRY VINIORAL/CRIMINAL & COMPANY AND A COMPANY	1-2. 8-4.7-6.9-10	
3,0-0	MORE	
	NO TEST RED	
MC755 0-18	BY SHE	
1267 - 1-2	NC207	
-4. 7-8-	HOSHE 147 1 11	
. 8-4.7-8: 9-18.12-14 H-15	HOW	NO. NOTES
Research and the second s	BUNK	1. * FIELD TO CONVERT CONTACTS TO RORMALLY CLOSED.
The second	CONTRETS - 1-2	3. THIS CAG IS REDRAM FROM A PART OF & GAG, 1083492 SH. 27, REV.F
Additional and a sets decision of the set of	WINE CONTRACTOR	5. D- FIELD TO CONVERT CONTACTS TO NORMALY OPEN .
4673-1-18	STERNE	REFERENCE DRAGINGS
1072- 17-18	NORE .	E-1-4030EF19 5/0 - SOLID STATE PROTECTION SYSTEM TRAIN "A"
127 - 1-2	NONE	(AB. 19409.)
E.	MONE.	(minute and a final and a fina
	HONE	
3-6, 9-10, 11-12, 17-18	NOHS	TTEL VIE
1	NONE	
, 3-4,7-8,8-10	NONE -	FOURMENT IS SHOWN ON THIS DEAWARD
Bart	andere	DRAWING RELEASE MECORD DRAWN
Statistics of grant of grant of the second s	1-2	REX DATE DESCRIPTION ENGR. APPROVAL AN OUTPUT RELAYS DEVELOPMENT TR.A
The second s	1-2	DE D
All Charles and a light on the cores and second and	NAME OF TAXABLE PARTY OF TAXABLE PARTY OF TAXABLE PARTY OF TAXABLE PARTY.	PERSON AND AND AND AND AND AND AND AND AND AN
. 3-4, 7-8	NOME	TALando CHICAGO, ILLINOIS
8	1-2	S 8-10-3 The rate with the state of the same -Martin
12366 - Statement and a second se		THE AND
Balantin Rear (P) . And a local provide the second	analysis provide a second s	TARE LANGE BUT A LAND AND AND AND AND AND AND AND AND AND
"Real of the second sec	a nga 1965 ngang ngangang nga nga nga nga nga nga	W DE DE NEATES De Station and the second station of the second sta
1,8-4	NONE	1/4/ TRUELAND OFFIC

A. . . .







\*







Question Nc: 2

Reference Use: Diesel Generator Room

Following a diesel generator EMERGENCY start, it is required to trip the diesel locally. State three (3) methods that will trip the diesel?

Expected Answer: (any three of the following)

Depressing the "Emergency Stop" pushbutton. Manually closing the "Air Inlet Butterfly Valve". Manually positioning the "Fuel Rack" to "Off". Manually close Fuel Supply Isolation valve(s).

Actual Answer:

Candidate's response matched expected answer.

K/2: 064000A406 ..9/3.9

Sat Unsat .

Reference(s): Chp 9, Fiesel Generators & Aux. Systems, Rev. 1, II.D.1.b, II.G.4.c.1.c, II.B.5.a, LO 5

# OPERATOR QUESTION SHEET

Question No: 1

Reference Use: YES (Horse Notes Not Allowed)

Contrast the difference between a start of the D/G during normal testing per BOP DG-11 DIESEL GENERATOR STARTUP and a start of the D/G due to a SI signal is they relate to the operation of the D/G Air Compressor and Dryer.

Question No: 2

Reference Use: Diesel Generator Room

Following a diesel generator EMERGENCY start, it is required to trip the diesel locally. State three (3) methods that will trip the diesel?

				-	
1856	-				100
8.3	<b>G</b> .,	10		- 54	
105		w	-	- 23	23
	-			- 60	~

2BOA ELEC-3

STE	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
STEI	ACTION/EXPECTED RESPONSE ATTACHMENT D (PG 1 OF LOCAL START OF 2B AT 2PM01J CHECK IF BUS 242 CAN BE ENERGIZED BY DG 2B: a. Place DG 2B feed breaker control switch in - <u>PULL OUT</u> : a. ACB 2423 b. Place breaker control switches in - <u>PULL OUT</u> : a. Non-FSF bus tie (ACB 2421) b. SAT feed (ACB 2422) c. Check Bus 242 lockout alarms - c.	IE a fire has occurred,
	NOT LIT: <ul> <li>BUS 242 FD BRKR 2422 TRIP (2-22-A7)</li> <li>BRKR 2424 CROSS-TIE OVERCURRENT (2-22-B8)</li> <li>DG 2B OVERLOAD (2-22-B9)</li> <li>DG 2B GROUND (2-22-C9)</li> <li>DG 2B DIFF LOCKOUT/OVERSPEED (2-22-D8)</li> </ul>	<pre>THEN perform the following: 1) Locally check lockout relays NOT tripped: • ACB 2423 (Bus 242 cub 16) • ACB 2424 (Bus 242 cub 4) • ACB 2422 (Bus 242 cub 6) IF any relay is tripped, THEN GOTO *ATTACHMENT C, Step 6 (Page 29). 2) GOTO Step 2 (Next Page). TE a fire has NOT occurred</pre>
		THEN GOID ATTACHMENTC, Step 6 (Page 29).

Approved 04/10/98

Facsimile

D	F	V	5	5
2.5	See.			Υ.

STE	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
	ATTACHMENT D (PG	2 OF 12)
	HUCAN BIANI U	
	* NOT	*******************
	* The Shift Manager a	hould be informed *
	* can be prioritized.	*
	**********	****
2	OBTAIN KEYS FROM CENTER DESK:	Obtain keys from the SE's Office.
	• U2 PRI-5 keys	
	B-COIE MASCEIS	
3	CHECK DG ZE SHUTDOWN:	
	a. RUNNING IDLE light - NOT LIT	a. GOTO Step 12 (Page 41).
	b. Check Emergency Stop	b. Depress Emergency Stop
	pusibuccon - <u>DEFRESSED</u>	pusibuccon.

**REV. 55** 

LOSS OF 4KV ESF BUS



-	an .			-
80	Be 1	.,	- 84	
n.		w	- 22	23
	-	-	 -	-

STE	P	ACTION/EXPE	CTED RESPONSE	[	RESPONSE NOT OBTAINED
			ATTACHMENT D (PG	4 OF 1	2)
5	CHE	CK STARTING AIR A	VAILABLE:	Art. And And South	
	a.	At least one a pressure - <u>GRE</u> 100 PSIG:	ir receiver MATER THAN	a. P r s	Pressurize the selected receiver from the DG starting air cart:
		e Left Bank o Right Bank	(2PI-DG097B) (2PI-DG096B)	1	) Connect air hose to the air receiver drain valve:
					o 2SA147B o 2SA147D
				2	) Open the air receiver drain valve:
					o 2SA147B o 2SA147D
				3	) Open <u>THREE</u> air bottle outlet valves.
				4	) Set the regulator on th HP air cart to maintain 250 PSIG.
				5	Continue with Step 6 (Next Page), <u>WHEN</u> air receiver pressure is greater tha <u>100 PSIG OR</u> stops risin <u>THEN</u> perform the following:
					a) Close the air receiver drain valve
					o 2SA147B o 2SA147D
					<li>b) Close the air bottle outlet valves.</li>
					•

-	-		 	-
O	Sec. 1	u	- 64	5.
n.	8.	¥		3

STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
	ATTACHMENT D (PG 5 LOCAL START OF	<u>OF 12)</u> 2B DG
6 <u>Cł</u>	IECK SUPPORT SYSTEMS ALIGNED:	
a	Air receiver outlet valves - <u>OPEN</u> :	a. Open any closed valve.
	• 2SA140B • 2SA140D	
b.	Fuel head tank level - <u>UPPER</u> BULL'S-EYE FULL	b. RETURN TO "ATTACHMENT C, Step 6 (Page 29).
c.	Electro-hydraulic governor:	
	1) Settings:	1) Place governor
	• Speed droop - Q	position.
	<ul> <li>Load limit - MAX FUEL</li> </ul>	
	• Speed - <u>PER PLACARD ON</u> <u>2PL08J</u>	
	2) Oil level - WITHIN SIGHTGLASS	2) Add oil.
	3) Output shaft (on front of governor) - <u>MAX FUEL</u>	3) <b>RETURN TO</b> *ATTACHMENT C, Step 6 (Page 29).
đ.	Overspeed governor oil level - WITHIN SIGHTGLASS	d. Add oil.
e.	Turning gear - <u>DISENGAGED</u>	e. Disengage the turning gear.
£.	Fuel rack manual trip lever - LATCHED IN VERTICAL POSITION	f. Latch the fuel rack trip lever in the vertical position.
Step o	continued on next page	

D	C	11	1	6	E
K	ε.	¥		3	9



D	E	1	E	E
15.	κ.	w	9	9

TEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
	ATTACHMENT D (PG ) LOCAL START OF	7 OF 12) 2B DG
PR	EPARE FOR DG 2B START:	
a.	Check Bus 242 at 2PM01J - <u>DEAD</u>	a. Contact Shift Manager to determine if local emergency start is still desired.
		IF a emergency start is NOT desired, THEN <b>RETURN TO</b> procedure and step in effect.
b.	Verify DG clear of personnel	
c.	Request Unit 2 to verify DG 2B controls - <u>ALIGNED FOR AUTO</u> <u>START</u> :	
	1) DG 2B start switch in - AFTER TRIP	
	2) ACB 2423 control switch in - AFTER TRIP	
d.	Momentarily place Annunciator and System Reset switch in - <u>RESET</u>	

-	-			-		
R	Ł	٧	5	5		
	-	-	-	-		



			-	
	gers :	6.0		10
	Sec. 1	v	- 06	ъ.
20		w	- 22	
		-	-	-



D	C	V	12	£,
n	۶.,	w	2	J

	-' 1		No. Lottings Land and	
		ATTACHMENT D (PG 1 LOCAL START OF	0 01 2B 1	<u>F 12)</u> 2 <u>G</u>
		*****	* * * *	****
		* <u>NOTE</u> * The DG will start whe	n th	* * *
		* Stop Reset pushbutton	is ****	depressed. *
1	EMI	ERGENCY START DG 2B:		
	a.	Install jumpers at 2PL08J		
		(upper left hand side, rear wall):		
		<ul> <li>Terminals 7 to 8</li> <li>Terminals 43 to 44</li> </ul>		
	b.	Momentarily place Annunciator and System Reset switch in -		
		RESET		
	с.	Depress Emergency Stop Reset pushbutton		
	d.	Check engine speed - GREATER	d.	Perform the following:
		INAM 370 KEM		1) Depress the Emergency Stop pushbutton.
				2) <b>RETURN TO</b> *ATTACHMENT C, Step 6 (Page 29).
	e.	Check DG SX valve - OPEN:	e.	Open the valve.
		• 2SX169B		
	£.	Check Bus 242 - ENERGIZED:	£.	GO TO Step 12 (Next
		• RUNNING LOADED light - LIT		Page).
	q.	GO TO Step 13 (Page 42)		

**REV. 55** 

.

LOSS OF 4KV ESF BUS UNIT 2 2BOA ELEC-3

<ul> <li>ATTACHMENT D I PG 11 OF 121 IOCAL START OF 28 DS</li> <li>INCAL START OF 28 DS</li> <li>INCAL START OF 28 DS</li> <li>Check lockout relays - NOT TRIPPED: <ul> <li>ACB 2423 (Bus 242 cub 16)</li> <li>ACB 2422 (Bus 242 cub 6)</li> <li>ACB 2422 (Bus 242 cub 6)</li> <li>Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>I Verify fuses FU73 and FU74 at 2PL083 are NOT blowing:</li> <li>Verify breaker FF1-19 on DC Bus 212 is CLOSED.</li> <li>If DG voltage is still less that 400 VOLTS</li> <li>If DG voltage is still less that 400 VOLTS.</li> </ul> </li> <li>Perform the following: <ul> <li>Berres DG 28 Provide the perform the following:</li> <li>Step continued on next page</li> </ul> </li> </ul>	STEP	ACTION/EXPECTED RESPONSE	RESPONSE NOT OBTAINED
<ul> <li>ICCAL START OF 28 DG</li> &lt;</ul>	1	ATTACHMENT D (PG	11 OF 12)
<ul> <li>12 ENERGIZE BUS 242 FROM DG 2B:</li> <li>a. Check lockout relays - NOT TRIPPED:</li> <li>a. ACB 2423 (Bus 242 cub 16)</li> <li>b. ACB 2422 (Bus 242 cub 4)</li> <li>b. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>b. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>b. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>a. Perform the following:</li> <li>b. Check Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>a. Perform the following:</li> <li>b. Perform the following:</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> </ul>		LOCAL START OF	2B DG
<ul> <li>a. Check lockout relays - NOT <u>TRIPPED</u>:</li> <li>ACE 2423 (Bus 242 cub 16)</li> <li>ACE 2422 (Bus 242 cub 4)</li> <li>Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>b. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>a. Perform the following:</li> <li>a. Perform the following:</li> <li>b. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> </ul>	12 EN	ERGIZE BUS 242 FROM DG 2B:	
<ul> <li>ACB 2423 (Bus 242 cub 16)</li> <li>ACB 2424 (Bus 242 cub 6)</li> <li>ACB 2422 (Bus 242 cub 6)</li> <li>b. ACB 2422 (Bus 242 cub 6)</li> <li>c. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>b. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>b. IF DC POWER ON/FIELD FLASH light is NOT lit, THEN perform the following: <ol> <li>Verify fuses FU73 and FU74 at 2PL08J are NOT blown.</li> <li>Verify breaker EF1-19 on DC Bus 212 is CLOSED.</li> <li>IF DG voltage is still less than 4000 VOLTS. THEN perform the following: <ol> <li>Depress DG 28 Emergency Stop pushbutton.</li> </ol> </li> <li>RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> </ol></li></ul>	a.	Check lockout relays - NOT	a. Perform the following:
<ul> <li>ACB 2422 (Bus 242 Cub 4)</li> <li>ACB 2422 (Bus 242 Cub 6)</li> <li>2) RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> <li>b. Check DG voltage - GREATER THAN 4000 VOLTS</li> <li>b. IF DC POWER ON/FIELD FLASH light is NOT lit, THEN perform the following:</li> <li>1) Verify fuses FU73 and FU74 at 2PL08J are NOT blown.</li> <li>2) Verify breaker EF1-19 on DC Bus 212 is CLOSED.</li> <li>3) IF DG voltage is still less than 4000 VOLTS. THEN perform the following:</li> <li>a) Depress DG 2B Emergency Stop pushbutton.</li> <li>b) RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRLP</li> </ul>		• ACB 2423 (Bus 242 cub 16)	1) Depress DG 2B Emergency Stop pushbutton.
<ul> <li>b. Check DG voltage - <u>GREATER THAN</u></li> <li>b. IF DC POWER ON/FIELD FLASH light is NOT lit, THEN perform the following: <ol> <li>Verify fuses FU73 and FU74 at 2PL08J are NOT blown.</li> <li>Verify breaker EF1-19 on DC Bus 212 is CLOSED.</li> <li>IF DC voltage is still less than 4000 VOLTS, THEN perform the following: <ol> <li>Depress DG 2B Emergency Stop pushbutton.</li> </ol> </li> <li>RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> </ol> </li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - <u>AFTER</u> TRIP</li> <li>Step continued on next page</li> </ul>		<ul> <li>ACB 2424 (Bus 242 Cub 4)</li> <li>ACB 2422 (Bus 242 cub 6)</li> </ul>	2) <b>RETURN TO</b> *ATTACHMENT C, Step 6 (Page 29).
<ul> <li>1) Verify fuses FU73 and FU74 at 2PL08J are NOT blown.</li> <li>2) Verify breaker EF1-19 on DC Bus 212 is CLOSED.</li> <li>3) IF DG voltage is still less than 4000 VOLTS. THEN perform the following:</li> <li>a) Depress DG 2B Emergency Stop pushbutton.</li> <li>b) RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>Step continued on next page</li> </ul>	b.	Check DG voltage - <u>GREATER THAN</u> 4000 VOLTS	b. IF DC POWER ON/FIELD FLASH light is <u>NOT</u> lit, <u>THEN</u> perform the following:
<ul> <li>2) Verify breaker EF1-19 on DC Bus 212 is CLOSED.</li> <li>3) IF DG voltage is still less than 4000 VOLTS, THEN perform the following: <ul> <li>a) Depress DG 2B Emergency Stop pushbutton.</li> <li>b) RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> </ul> </li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRUP</li> <li>Step continued on next page</li> </ul>			<ol> <li>Verify fuses FU73 and FU74 at 2PL08J are <u>NOT</u> blown.</li> </ol>
<ul> <li>3) IF DG voltage is still less than <u>4000 VoLTS</u>, THEN perform the following:</li> <li>a) Depress DG 2B Emergency Stop pushbutton.</li> <li>b) <b>RETURN TO</b> *ATTACHMENT C, Step 6 (Page 29).</li> <li>Step continued on next page</li> </ul>			2) Verify breaker BF1-19 on DC Bus 212 is CLOSED.
<ul> <li>a) Depress DG 2B Emergency Stop pushbutton.</li> <li>b) RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRUP</li> <li>Step continued on next page</li> </ul>			3) IF DG voltage is still less than <u>4000 VOLTS</u> , <u>THEN</u> perform the following:
<ul> <li>b) RETURN TO *ATTACHMENT C, Step 6 (Page 29).</li> <li>c. Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP</li> <li>Step continued on next page</li> </ul>			a) Depress DG 2B Emergency Stop pushbutton.
<pre>c. Request Unit 2 to verify ACB     2423 control switch in - AFTER     TRIP Step continued on next page</pre>			b) <b>RETURN TO</b> *ATTACHMENT C, Step 6 (Page 29).
Step continued on next page	c.	Request Unit 2 to verify ACB 2423 control switch in - AFTER TRIP	
	Step c	continued on next page	

Facsimile

D	5	M	1	5	E
ĸ	С.	w		9	э

2BOA ELEC-3



Approved 04/10/98

Facsimile

#### JOB PERFORMANCE MEASURE

#### CANDIDATE CUE SHEET

#### TASK CONDITIONS:

.

- 1. You are extra licensed operator on shift.
- 2. The Unit 1 is in Post LOCA Conditions.
- 3. Unit 2 is in Mode 3, NOP, NOT.
- 4. Possible failures exist that could affect CC alignment.
- 5. BOP CC-8 has been completed.

## INITIATING CUES:

The US instructs you to separate the CC safety trains per BOP CC-14 Sect. F.2.

#### NOTES FOR SETUP:

1. JPM is local alignment of CCW for Post-LOCA alignment. The initial conditions are a LOCA on Unit 1 with possible failures that could affect CCW alignment. Actions provide for train separation (U-1) with B CC Pp available. The evaluated actions are those local actions of BOP CC-14, section 2. (The actions of BOP CC-8 (& CC-10 for aligning 0CC to Unit 1) are completed prior to this JPM.)

### JOB PERFORMANCE MEASURE

TASK TITLE:	Align U-1	CC System	for Post-LO	CA Conditions	JPM No.: JPM-10
TPO No:		K&A	No.: 00800	0G120	K&A IMP. 4.3/4.2
TRAINEE:					DATE:/_/
The Trainee:	PASSED		this JPM	TIME	STARTED:
	FAILED_			TIME	FINISHED:
EVALUATION N	IETHOD:	PERFORM	۸	SIMULATE	
LOCATION:		IN PLANT		SIMULATOR_	
MATERIALS:					

None

#### GENERAL REFERENCES:

BOP CC-14, POST LOCA ALIGNMENT OF THE CC SYSTEM

TASK STANDARDS:

Perform the actions required to separate CC safety trains with U-1 B CC Pump available for service.

### TASK CONDITIONS:

- 1. You are an extra licensed operator on shift.
- 2. Unit 1 is in Post LOCA Conditions.
- 3. Unit 2 is in Mode 3, NOP, NOT.
- 4. Possible failures exist that could affect CC alignment.
- 5. BOP CC-8 has been completed.

#### INITIATING CUES:

The US instructs you to separate the CC safety trains per BOP CC-14 Sect. F.2.

CRITICAL ELEMENTS: (\*)

5, 6, 7, 9, 12

APPROXIMATE COMPLETION TIME: 20 minutes

**JPM-10** 

09/03/98 4:38 PM

PERFORMANCE CHECKLIST STANDARDS

.

# RECORD START TIME

1.	Refer to BOP CC-14, POST LOCA ALIGNMENT OF THE CC SYSTEM.	Locate and open BOP CC-14, Sect. 2.		•
Note	: This step may be performed at any time.			
lf ask	ked: All Prerequisites have been met.			
2.	Open CC Pp Dsch Hdr Xtie VIv.	VERIFY OPEN 1CC9473B, CC Pp		
Cue:	Valve is OPEN.	Dsch Har Xtie VIV.		
Note	The valve is operated from the control room.			
З.	Open CC Pp Suct Hdr Xtie Isol	VERIFY OPEN 1CC9459B, CC Pp Sect Hdr Xtie Isol VIv.		
Cue:	Valve is OPEN.			
4.	Open CC HX Dsch Hdr Xtie Isol VIv.	VERIFY OPEN 1CC9467B, CC HX Dsch Hdr Xtie Isol VIv.		
Cue:	Valve is OPEN.			

PERF	ORMANCE CHECKLIST	STANDARDS	<u>SAT</u>	UNSAT	<u>N/A</u>
*5. NOTI	Close CC Pp Suct Hdr Xtie VIv. E: Valve is normally OPEN.	CLOSE SLOWLY 1CC9459A, CC Pp Suct Hdr Xtie VIv.	۵	٩	۵
Cue:	When operated, Valve is slowly closing & indicates CLOSED.				
*6. NOTI	Close CC Pp Dsch Hdr Isol VIv. E: Valve is normally OPEN.	CLOSE SLOW! Y 1CC9458, CC Pp Dsch Hdr Iso, VIv.			
Cue:	When operated, Valve is slowly closing & indicates CLOSED.				
*7.	Close CC Pp Dsch Hdr Xtie Isol VIv.	Contact Control Room to check 1CC9473A, CC Pp Dsch Hdi Xtie Isol VIv position			
Cue:	Valve is OPEN. Following CR contact report, Valve is CLOSED.	AND Direct closing 1CC9473A.			
NOTE	E: The valve is operated from the control room.				
8. Cue:	Verify flow from control room. Following CR contact report.	VERIFY component cooling flow indicated to 1B RH Heat Exchanger, (1FI-0689, 1PM06J).	۵	•	

Flow is 4700 gpm.

PERFORMANCE CHECKLIST

STANDARDS

Notes CAUTION.		CAUTION			
		When the next step is executed:			
		1. The 1A and/or U-0 CC pump(s) will provide service loads (via 1CC9415) and the 1A RH load. Ensure that flow demand meets pumping capability (<4800 gpm).			
		2. The 1B CC pump will be serving 'B' train RH load only.			
*9.	Close CC HX Dsch Hdr Xtie Isol VIv.	CLOSE 1CC9467A, CC HX Dsch Hdr Xtie Isol VIv.			
NOTE	E: Valve is normally OPEN.				
Cue:	When operated, Valve is closing & indicates CLOSED.				
Cue:	RCPs are off and CC to RCP's	NOTE			
	is NOT required.	Perform step 2.i based on plant conditions, i.e.: only if RCPs are tripped and CC cooling to RCPs is not required.	-	9	1
10. V	erity U-1 Service Loop Isol VIv is losed from control room.	U-1 Service Loop Isoi VIV.			
Cue:	Following CR contact report,				

Valve is CLOSED.

PERFORMANCE CHECKLIST

STANDARDS

Notes CAUTION. CAUTION To completely separate the U-1 CC Loop from U-2, CC Flow to the 2A RH HX, 2A RH Pp seal cooler, and U-2 PD charging Pp must be Isolated. If applicable, LCOAR 2BOS 7.3-1a must be initiated on U-2. 11. Notify US to initiate LCOAR 2BOS Notify Unit 2 US to initiate LCOAR 7.3-1a.

- 7.3-1a.
- Cue: When notified, US reports LCOAR entered.
- \*12. Isolate U-1 CC Loop from U-2
- Note: For 2CC9504A and 2CC9506B, \* applicant needs to identify where valves are located, but not simulate valve motion. •
- Cue: When operated, Valves are closing & indicate CLOSED.

- Close the following valves on U-2
  - 2CC9504A 2A RH HX CC Init Isol VIv. Is located at 364, S-19, AB2, +12 feet
- 2CC9506B 2A RH Pp Clg Wtr Init Isol VIv. Is located at 343, U23, RXB2, +2 feet
  - 2CC9482B PD Chg Pp Clg Wtr Init Isol VIv.

Cue: THIS COMPLETES JPM.

RECORD STOP TIME

COMMENTS:

**JPM-10** 

09/03/98 4:38 PM

.

#### Question No: 1

#### Reference Use: NO

The maximum CC heat exchanger outlet temperature is designed to be 105°F.

When is this outlet temperature allowed to increase to 120°F?

#### Expected Answer:

The temperature is allowed to reach 120°F for up to three hours during the initial phase of RHR cooldown.

#### Actual Answer:

Candidate's response matched expected answer. K/A: 008000A203 3.0/3.2 194001G132 3.4/3.8 Reference(s): CC-1 CC System, Rev.2, CC Design (CC-8, CC-14). BAR 1-2-C5, Rev. 1, CC HX OUTLET TEMP HIGH, B. NOTE. Chp 19, Component Cooling System (CC), Rev. 2, I.C.2, page 4; II.B.1.a.13), page 36, LO 9.

#### Question No: 2

#### Reference Use: YES

During the performance of 2BOS 7.3.2.a-1, Unit 2 CCW Pump Operability Monthly Surveillance, the following data was collected:

CC PUMPS	2CC01PA		2CC01PB	0CC01P		REQUIRED DATA
START TIME	0000		0900	0430	1	N/A
MOTOR CURRENT	42		49	43		$\leq$ 50 AMPS
PUMP DSCH PRESS	135		150	135		85 System 150 psig < Pressure < psig
HX OUTLET TEMP	101°F	¢	119°F ¢	100°F	¢	< 118°F
STOP TIME	0430			0900		N/A
RUN TIME	4.5 hours	¢	¢	4.5 hours	¢	≥ 4 HOURS

It is now 1330 and no other pump operations have occurred, what further actions, if any are required and why?

SRO ONLY: What additional actions are required per Technical Specifications?

#### Expected Answer:

Start the 2A or Common CC pump and secure the 2B CC pump. Take the 2B CC pump OOS due to HX Outlet Temperature not meeting acceptance criteria during the surveillance.

#### SRO ONLY:

Place the "O" CC pump racked in to BUS 242 and NOT in Pull-Out and 2B CC Pump in Pull-Out.

#### Actual Answer:

Candidate's response matched expected answer.

Sat Unsat .

K/A: 008000A303 3.0/3.1

Reference(s): 2BOS 7.3.2.a-1, Unit 2 CCW Pump Operability Monthly Surveillance, Rev 1. BOP CC-1 COMPONENT COOLING WATER SYSTEM STARTUP, Rev. 1, D.3, page 2. Chp 19, Component Cooling System (CC), Rev. 2, II.B.1.b, page 38, LO 3, 12.

#### OPERATOR QUESTION SHEET

Question No: 1

र स स स स स

\* E "#\*

Reference Use: NO

The maximum CC heat exchanger outlet temperature is designed to be 105°F. When is this outlet temperature allowed to increase to 120°F?

Question No: 2

Reference Use: YES

CC PUMPS	2CC01PA	Τ	2CC01PE	3	0CC01P	Т	REQUIRED DATA
START TIME	0000		0900		0430		N/A
MCTOR CURRENT	42		49		43		≤ 50 AMPS
PUMP DSCH PRESS	135		150		135		85 System 150 psig < Pressure < psig
HX OUTLET TEMP	101°F	*	119°F	¢	100°F	¢	< 118°F
STOP TIME	0430				0900		N/A
RUN TIME	4.5 hours	¢		¢	4.5 hours	*	≥ 4 HOURS

During the performance of 2BOS 7.3.2.a-1, Unit 2 CCW Pump Operability Monthly Surveillance, the following data was collected:

It is now 1330 and no other pump operations have occurred, what further actions, if any are required and why?

SRO ONLY: What additional actions are required per Technical Specifications?
\* POST LOCA ALIGNMENT OF THE CC SYSTEM

## A. STATEMENT OF APPLICABILITY:

This procedure outlines the steps necessary to align the Component Cooling System for Post-LOCA recovery.

### B. REFERENCES:

- 1. P & IDs:
  - a. M-66 Sheets 1-4, Component Cooling.
  - b. M-139 Sheets, 1 & 2, Component Cooling Unit 2.
- 2. Station Procedures:
  - a. BOP CC-1, Component Cooling System Startup and Operation.
  - b. BOP CC-8, Isolation of CC between U-1 and U-2.
  - c. BOP CC-10, Alignment of "0" CC PP to a Unit.
  - d. BOS 7.3-1a, LCOAR-CC Water System.
- Westinghouse Evaluation of CC Interunit Sharing November 28, 1988.
- Ltr: B. R. Shelton to PWR Station Managers Chron #PWR 127109, May 23, 1989.
- 5. UFSAR 9.2.2.3.5

# C. PREREQUISITES:

- The Component Cooling System is in operation in accordance with BOP CC-1.
- Essential Service Water is capable of supplying water to the U-O CC Heat Exchanger.

# D. PRECAUTIONS:

- The temperature of the cooling water supplied to the various components should not exceed <u>105°F</u> during normal operation. During initial operation of the RH System, the temperature may be permitted to increase to <u>120°F</u> for a maximum period of three hours.
- The Component Cooling Pumps should not be operated with less than 500 gpm flow through an operating pump as determined by a maximum pump discharge pressure of 150 psig on \_PI-CC673 locally, on PI-CC107 at \_PM06J, or Computer Point P0670.
- 3. Pump Start Limitations.
  - a. <u>2</u> Starts from ambient, and <u>45</u> minutes cooldown between additional starts.

**NOTE** Running start is defined as any start performed after a minimum run time of <u>45</u> minutes.

- b. <u>1</u> Start from running and <u>15</u> minute minimum cooldown between additional starts.
- E. LIMITATIONS AND ACTIONS:
  - 1. Two pumps, two heat exchangers, and one surge tank are normally provided for the unit undergoing Post-LOCA recovery. The U-O Pump is also available and aligned for the Post LOCA unit. Normal procedure is to operate Component Cooling Unit-Separate with Safeguard Trains shared. In this procedure unit separation is accomplished in Subsection F.1 for U-1 and F.4 for U-2. Limitations and Actions for the unit separation operation are included in BOP CC-8 and BOP CC-10.
  - 2. Subsections F.2, F.3, F.5, and F.6 are provided in the event that Separation of the Safeguard Trains is desired. These sections should be performed ONLY with the SE's permission. Limitations and Actions associated with separation of the Safeguard Trains are the following:

## **APPROVED 05/31/94**

C

#### Facsimile

#### 3. LIMITATIONS AND ACTIONS FOR TRAIN SEPARATION ONLY

- a. CC will be lost to the following components:
  - 1. Spent Fuel Cooling HX.
  - 2. Reactor Coolant Pumps.
  - 3. CV Letdown HX.
  - 4. RCS and Pressurizer Sample Coolers.
  - 5. Boron Recycle System.
  - 6. Waste Gas Compressors.
- b. The Spent Fuel Cooling System must be transferred to the unaffected unit.
  - If the U-0 CC Pump must be used instead of the \_B CC Pump (Alignments Specified in Steps F.3 and F.6) the following Limitations apply:
    - 1. The U-O CC Pump will be isolated from the Surge Tank.
    - 2. A CC Pump will be serving B Train loads and the U-0 CC Pump will be serving A Train loads. A loss of an ESF Eus will require the following realignments:
      - a). Loss of \_41 Bus will require aligning the flow of the U-O CC Pump for \_B Train RH service.
      - b): Loss of 42 Bus will require one of the following steps:
        - Realign the U-0 Pump Switchgear to the \_41 Bus.
        - Realign flow of the \_A CC Pump for \_A Train RH service.

(0231VV/WPF/050694)

## **APPROVED 05/31/94**

Facsimile

F. MAIN BODY:



1. To Align U-1 for Post LOCA Recovery, perform the following:

a. VERIFY/PERFORM BOP CC-8 to ensure that alignments are performed at the discretion of the Shift Engineer based on present heat loads, CC System Pressures, and anticipated unit cool down requirements. Two pumps, two HXs and one surge tank are normally provided for the unit undergoing Post LOCA recovery with the U-0 CC Pump aligned for added support.

Subsections 2 and 3 to be performed at the discretion of the Shift Engineer.

- This section separates Safety Trains with the U-1 'B' CC Pump available for service. Perform ONLY with SE's permission.
  - a. VERIFY/OPEN 1CC9473B, CC Pp Dsch Hdr Xtie Vlv.

- b. VERIFY/OPEN 1CC9459B, CC Pp Suct Hdr Xtie Isol Vlv.
- c. VERIFY/OPEN 1CC9467B, CC HX Dsch Hdr Xtie Isol Vlv.
- d. CLOSE SLOWLY 1CC9459A, CC Pp Suct Hdr Xtie Vlv.
- e. CLOSE SLOWLY 1CC9458, CC Pp Dsch Hdr Isol Vlv.
- f. VERIFY/CLOSE 1CC9473A, CC Pp Dsch Hdr Xtie Isol Vlv.
- g. VERIFY component cooling flow indicated to 1B RH Heat Exchanger, (1FI-0689, 1PM06J).

### CAUTION

When the next step is executed:

- The 1A and/or U-0 CC pump(s) will provide service loads (via 1CC9415) and the 1A RH load. Ensure that flow demand meets pumping capability (<4800 gpm).</li>
- 2. The 1B CC pump will be serving 'B' train RH load only.
  - h. VERIFY/CLOSE 1CC9467A, CC HX Dsch Hdr Xtie Isol Vlv.

#### NOTE

Perform step 2.i based on plant conditions ie: only if RCPs are tripped and CC cooling to RCPs is not required.

i. VERIFY/CLOSE 1CC9415, MOV U-1 Service Loop Isol Vlv.

#### CAUTION

To completely separate the U-1 CC Loop from U-2, CC Flow to the 2A RH HX, 2A RH Pp seal cooler, and U-2 PD charging Pp must be isolated. If applicable, LCOAR 2BOS 7.3-1a must be initiated on U-2.

- j. VERIFY/CLOSE 2CC9504A, 2A RH HX CC Inlt Isol Vlv.
- k. VERIFY/CLOSE 2CC9506B, 2A RH Pp Clg Wtr Inlt Isol Vlv.
- 1. VERIFY/CLOSE 2CC9482B, PD Chg Pp Clg Wtr Inlt Isol Vlv.
- This Section separates Safeguard Trains when the U-1 'B' CC Pump is <u>NOT</u> available for service. Perform ONLY with the SE's permission.
  - a. VERIFY/OPEN 1CC9458, CC Pp DSCH HDR ISOL VLV.

#### **APPROVED 05/31/94**

# Facsimile

- b. VERIFY/OPEN 1CC9459A, CC Pp Suct Hdr Xtie Isol Vlv.
- c. VERIFY/OPEN 1CC9467A, CC HX Dsch Hdr Xtie Isol Vlv.

#### CAUTION

Execution of following step will isolate the U-O CC pump from surge protection. See Limitations And Actions, Section E.3.c.

- d. CLOSE SLOWLY 1CC9459B, CC Pp Suct Hdr Xtie Isol Vlv.
- e. CLOSE MOV 1CC9473B, MOV CC Dsch Hdr Xtie Isol Vlv.
- f. CLOSE MOV 1CC9473A, MOV CC Dsch Hdr Xtie Isol Vlv.

### CAUTION

When the next step is executed:

- 1 The 1A CC pump will provide service loads (via 1CC9415) and 1B RH loads. Ensure that flow demand meets pumping capabilities (<4800 gpm).
- 2. The '0' CC pump will be serving 'A' Train RH. Ensure that a flow path is open to the 'A' Train RH HX.
  - \*\*See Limitations And Actions, Section E.3.c\*\*
  - g. CLOSE 1CC9467B, CC HX Dsch Hdr Xtie Isol Vlv.

#### LOTE

Perform step 3.h. based on plant conditions, ie: only if RCPs are tripped and CC cooling to RCPs is not required.

h. VERIFY/CLOSE 1CC9415, MOV U-1 Service Loop Isol Vlv.

#### CAUTION

To completely separate the U-1 CC loop from U-2, CC Flow to the 2A RH HX, 2A RH Pp seal cooler, and U-2 PD charging Pp must be isolated. If applicable, LCOAR 2BOS 7.3-1a must be initiated on U-2.

- i. VERIFY/CLOSE 2CC9504A, 2A RH HX CC Inlet Isol Vlv.
- j. VERIFY/CLOSE 2CC9506B, 2A RH Pp Clg Wtr Inlt Isol Vlv.
- k. VERIFY/CLOSE 2CC9482B, PD Chg Pp Clg Wtr Inlt Isol Vlv.

## **APPROVED 05/31/94**

#### Facsimile

- To Align U-2 for Post LOCA Recovery, perform the following:
  - a. VERIFY/PERFORM BOP CC-8 to ensure that alignments are performed at the discretion of the Shift Engineer based on present heat loads, CC System Pressures, and anticipated unit cool down requirements. Two pumps, two HXs and one surge tank are normally provided for the unit undergoing Post LOCA recovery.

Subsections 5.0 and 6.0 to be performed at the discretion of the Shift Engineer.

- 5. This section separates Safety Trains with the U-2 'B' CC Pump available for service. Perform ONLY with the SE's permission.
  - a. VERIFY/OPEN 2CC9473B, MOV CC Pp Dsch Hdr Xtie Vlv.
  - b. VERIFY/OPEN 2CC9459B, CC Pps Suct Hdr Xtie Isol Vlv.
  - c. VERIFY/OPEN 2CC9467B, CC HX Dsch Hdr Xtie Isol Vlv.
  - d. CLOSE SLOWLY 2CC9459A, CC Pps Suct Hdr Xtie Vlv.
  - e. CLOSE SLOWLY 2CC9458, CC Fp Dsch Hdr Isol Vlv.
  - f. VERIFY/CLOSE 2CC9473A, MOV CC Pp Dsch Hdr Xtie Isol Vlv.
  - g. VERIFY Component Cooling flow to 1B RH Heat Exchanger, (2FI-0689, 2PM06J).

## CAUTION

When the next step is executed:

- The 2A and/or U-0 CC pump(s) will provide service loads (via 2CC9415) and the 2A RH load. Ensure that flow demand meets pumping capability (<4800 gpm).</li>
- 2. The 2B CC pump will be serving 'B' Train RH load only.
  - h. VERIFY/CLOSE 2CC9467A, CC HX Dsch Hdr Xtie Isol Vlv.

**NOTE** Perform step 5.i. based on plant conditions ie: only if RCPs are tripped and CC cooling to RCPs is not required.

i. VERIFY/CLOSE 2CC9415, MOV U-2 Service Loop Isol Vlv.

#### CAUTION

To completely separate the U-2 CC loop from U-1, CC flow to the 1A RH HX, 1A RH Pp seal cooler, and U-1 PD charging Pp must be isolated. If applicable, LCOAR 1BOS 7.3-1a must be initiated on U-1.

- j. VERIFY/CLOSE 1CC9504A, RH HX 1A CC Inlt Isol Vlv.
- k. VERIFY/CLOSE 1CC9506B, 1A RH Pp CC Inlt Isol Vlv.
- 1. VERIFY/CLOSE 1CC9482B, PD Chg Pp CC Inlt Isol Vlv.
- This Section separates Safeguard Trains when the U-2 'B' CC Pump is NOT available for service. Perform ONLY with SE's permission.
  - a. VERIFY/OPEN 2CC9458, CC Pp Dsch Hdr Isol Vlv.
  - b. VERIFY/OPEN 2CC9459A, CC Pps Suct Hdr Xtie Vlv.
  - c. VERIFY/OPEN 2CC9467A, CC HX Dsch Hdr Xtie Isol Vlv.

#### CAUTION

Execution of following step will isolate the U-O CC pump from surge protection. See Limitations And Actions, Section E.3.c.

- d. CLOSE SLOWLY 2CC9459B, CC Pps Suct Hdr Xtie Isol Vlv.
- e. CLOSE MOV 2CC9473B, CC Pp Dsch Hdr Xtie Isol Vlv.
- f. CLOSE MOV 2CC9473A, MOV CC Pp Dsch Hdr Xtie Isol Vlv.

### CAUTION

When the next step is executed:

- The 2A pump will provide service loads (via 2CC9415) and 2B Train RH loads. Ensure that flow demand meets pumping capability (<4800 gpm).</li>
- 2. The '0' CC pump will be serving 'A' Train RH. Ensure that the flow path to the 2A Train RH is open.

\*\*See Limitations And Actions, Section E.3.c.\*\*

g. CLOSE 2CC9467B, CC HX Dsch Hdr Xtie Isol Vlv.

# NOTE

Perform step 6.h. based on plant conditions, ie: only if RCPs are tripped and CC cooling to RCPs is not required.

h. VERIFY/CLOSE 2CC9415, MOV U-2 Service Loop Isol Vlv.

#### CAUTION

To completely separate the U-2 CC loop from U-1, CC flow to the 1A RH HX, 1A RH Pp seal cooler, and U-1 PD charging Pp must be isolated. If applicable, LCOAR 1BOS 7.3-1a must be initiated on U-1.

- i. VERIFY/CLOSE 1CC9504A, RH HX 1A CC Inlt Isol Vlv.
- j. VERIFY/CLOSE 1CC9506B, 1A RH Pp CC Inlt Isol Vlv.
- k. VERIFY/CLOSE 1CC9482B, PD Chg Pp CC Inlt Isol Vlv.
- G. CHECKOFF LIST:

## VALVE #

## DESCRIPTION

LOCATION

1009458	CC	Pp Dsch Hdr Isol Vlv, +10	364'	L17	AB1
1CC9459A	CC	Pp Suct Hdr Xtie Isol Vlv, +8'	364'	L17	AB1
1CC9459B	CC	Pp Suct Hdr Xtie Isol Vlv, +8'	364'	L17	AB1
1CC9467A	CC	HX Dsch Hdr Xtie Isol Vlv, +9'	364'	N15	AB1
1CC9467B	CC	HX Dsch Hdr Xtie Isol Vlv, +9'	364'	M16	AB1
1CC9482B	PD	Charging Pp CC Inlt Isol Vlv	364'	S16	AB1
1CC9504A	Rh	HX 1A CC Inlt Isol Vlv, +3'	375 '	S16	AB1
1CC9506B	1A	RH Pp CC Inlt Isol Vlv, +3'	343'	U12	RXB1
2CC9467A	CC	HX Dsch Hdr Xtie Isol Vlv, +10'	364'	M19	AB2
2CC9467B	CC	HX Dsch Hdr Xtie Isol Vlv, +10'	364'	M18	AB2
2CC9482B	PD	Charging Pp Clg Wtr Inlt Isol, +1'	364'	S19	AB2
2CC9504A	2A	RH HX CC Inlt Vlv, +12'	364'	S19	RXB2
2СС9506В (	2B	RP Pp Clg Wtr Inlt Isol Vlv +2'	364 '	P18	AB2
2009458 7	CC	Pp Dsch Hdr Isol Vlv, +10'	364 '	L19	AB2
2CC9459A	CC	Pps Suct Hdr Xtie Vlv, +8'	364'	L19	AB2
2CC9459B	CC	Pps Suct Hdr Man Xtie Isol Vlv, +7'	364'	L18	AB2

incometly used in procedure - Askadd ke 2A RH Pup the

(0231VV/WPF/050694)

2BOS 7.3.2.a-1 Revision 1

# UNIT TWO COMPONENT COOLING WATER PUMP OPERABILITY MONTHLY SURVEILLANCE

# A. STATEMENT OF APPLICABILITY:

This procedure applies to the monthly verification of the operability of the component cooling pumps.

# B. <u>REFERENCES</u>:

- 1. Technical Specification
  - a. 4.7.3.2.a
- 2. Station Procedures
  - a. BOP CC-2, Component Cooling Water System Shutdown.
  - b. BOP CC-15, Switching Operating and Standby Component Cooling System Pumps.
  - c. BOP CC-E2, Component Cooling System Electrical Lineup (Unit 2).
  - d. BOP CC-M2, Component Cooling System Valve Lineup.
  - e. 2BOS 7.3-la, LCOAR Component Cooling Water System Tech Spec LCO #3.7.3.
- 3. Station Drawings
  - a. M-66, Component Cooling.

# C. PREREQUISITES:

1. Receive permission from the Shift Manager or designated SRO licensed assistant prior to performing this surveillance by having the Data Package Cover Sheet signed and dated.

# D. PRECAUTIONS:

- 1. Ensure the CC surge tank is within its normal operating level.
- Taking a control switch from the Pull-to-lock position can autostart the pumps due to low system pressure.

# **APPROVED 05/04/97**

# Facsimile

# E. LIMITATIONS AND ACTIONS:

- As stated in Technical Specifications Limiting Condition for Operation 3.7.3.
- In the event the Acceptance Criteria is not met during the performance of this procedure IMMEDIATELY notify the Shift Manager to initiate LCOAR 2BOS 7.3-1a, LCOAR Component Cooling Water System Tech Spec LCO #3.7.3.

# F. MAIN BODY:

### NOTE

Initial each step in the space provided adjacent to the Main Body step number <u>AFTER</u> the step has been <u>SUCCESSFULLY</u> completed. Persons performing INDEPFNDENT VERIFICATION should initial in the space provided below the step.

# NOTE

In order to verify the operability of a component/system the Shift Manager may elect to perform individual steps of this procedure provided all Prerequisites, Precautions and Limitations and Actions are observed.

#### NOTE

The start time for a running pump shall be the time when the surveillance is started.

- 1. VERIFY Operability of CC Pumps:
  - a. VERIFY/START the applicable CC Pump and record start time on CC Pump Data Chart.
  - b. ENTER data for the running pump(s) in the Data Chart after  $\geq 4$  hours from the time recorded in step F.1.a.

# NOTE

If necessary to swap pumps then refer to BOP CC-15, Switching Operating and Standby Component Cooling System Pumps.

c. Complete steps F.1.a and F.1.b for each non-operating pump.

# APPROVED 05/04/97

Facsimile

F.continued

CC PUMPS	2CC01PA	2CC01PB	0CC01P	REQUIRED DATA
START TIME				N/A
MOTOR CURRENT				≤ 50 AMPS
PUMP DSCH PRESS				85 System 150 psig <pressure <psig<="" td=""></pressure>
HX OUTLET TEMP	¢	¢	¢	< 118°F
STOP TIME				N/A
RUN TIME	¢	¢	¢	> 4 hours

2. VERIFY 2 CC pumps will auto-start on an ESF actuation:

a. Initial the OPERABLE CC pump on Division 21:

\_\_\_\_\_ 2A CC pump racked in to BUS 241 and NOT in Pull-out

INDEPENDENT VERIFICATION \_\_\_\_\_

-OR-

\_\_\_\_ 0 CC pump racked in to BUS 241 and <u>NOT</u> in Pull-out and 2A CC pump in Pull-out.

INDEPENDENT VERIFICATION

b. Initial the OPERABLE CC pump on Division 22:

\_\_\_\_\_ 2B CC pump racked in to BUS 242 and NOT in Pull-out.

INDEPENDENT VERIFICATION

-OR-

0 CC pump racked in to BUS 242 and <u>NOT</u> in Pull-out and 2B CC pump in Pull-out.

INDEPENDENT VERIFICATION

¢\_\_\_\_\_c.

c. VERIFY one CC pump OPERABLE on each Division in F.2.a and F.2.b above.

# APPROVED 05/04/97

Facsimile

# G. ACCEPTANCE CRITERIA:

 At least two component cooling water pumps shall be demonstrated operable by verifying that each pump starts upon actuation, operates for at least 4 hours, satisfies the cooling requirements for the routine operation of the component cooling water system, and is capable of auto-starting on an ESF actuation.

# NOTE

If a CC pump is running then it shall be implied that the pump has started upon actuation.

(Final)

FINAL AS-ADMINISTERED SCENARIOS FOR BYRON EXAMINATION - SEP 1998

\*

Simulation	Facil	ity Byron 1 & 2	Scenario No.:	1	Op Test No.: 1			
Examiners:				Operators:		SRO		
	_		-	-		RO		
1			_	_		BOP		
Objectives:	In	accordance with plant pr	ocedures:					
	1.	raise reactor power.						
	2.	respond to trip of Com	ponent Cooling wat	er Pump with failur	e of auto-start of standby p	ump due to		
		header pressure instrum	ent failure.					
	3.	respond to failure of co	ntrolling pressurizer	level channel				
	4.	respond to degraded op	eration of Charging	g Pump.				
	5.	respond to failure of the steam header pressure transmitter supplying feedwater pump speed control.						
	6.	respond to a faulted steam generator with failure of ESF signal for Steamline Isolation.						
	7.	respond to Pzr PORV failing open						
	8.	perform actions for a loss of heat sink.						
Initial Cond	lition	s: 1. IC-18, Reactor P	ower 75%, MOL, B	GP 100-3, step F.61	L.			
		2. PZR level contro	l is selected to 459/4	160.				
		3. 1B CV Pump run	ning; 1A CV Pump	in standby				
		4. SG 1B level LT-	557 is out of service					
		5. 1B AF pump OO	S, 1A HDP OOS.					
Turnover:	1.	Reactor power is 75%.						
	2.	Raise reactor power at 5	MW/hr after shift tu	irnover.				
	3.	1B CV Pump is currently	in service followin	g pump seal replace	ement testing. 1A CV Pum	p is in standby.		
	4.	Narrow range level trans per BOA INST-2 and the	mitter LT-557 on Se AR has been initia	G B is out of service ted.	e. All required actions have	e been performed		
	5.	The Diesel Driven Aux F OOS for 6 hours and is e	eedwater Pump is C xpected to be return	OOS for replacement ed to service by the	t of a fuel injector. The pu end of the shift.	mp has been		
	6.	1A Heater Drain Pump is	s out of service for n	notor bearing replac	cement.			

7. A thunderstorm warning is in effect for Stephenson, Winnebago and Ogle counties for the next 4 hours.

\*

Event	Malf.		Event	Event
No.	No.	-	Type*	Description
Preload	FW43 FW44			1A and 1B AFW Pumps fail to start
Preload	RX06H, 0 MRF - RX125 trip RX072 trip RX113 trip RX146 trip			Narrow Range Steam Generator level LT-557 out of service
Preload	RP-34, OUT RP-35, OUT RP-60, OUT RP-61, OUT			Failure of MSIV automatic closure signal
Preload	MS01A, 100%			1A MSIV Fails to Close
		R	RO SRO	Raise reactor power (5 MW/min)
1		N	BOP SRO	Set and raise turbine load
2	CC01B CC02B, 144	с	BOP SRO	1A CC Pump trips coincident with 1B CC Pump discharge pressure switch failing as-is.
3	RX13A, 0, 120	I	RO SRO	Controlling pressurizer level (1LT-459) fails downscale on a 120 second ramp. NOTE 1
4	CV29B,75%	С	RO SRO	Running charging pump 1B experiences impeller degradation of 75% over a 4 minute period causing reduction in flow and pressure
5	RX05, 0	1	BOP SRO	Steam Header Pressure Detector PT-507 fails low
6	MS09, 3.5 MLBH	M	RO SRO BOP	Main Steam Header Break with failure of MSIV auto closure
7	(MS01A)	с	RO SRO BOP	1A Steam Generator MSIV failure to close both automatic and manual
8	(FW43)	M	RO SRO BOP	1A MD AFW pump trip results in loss of feed.
9	TH01B, 100	С	FO SRO	Pzr PORV 456 fails open

\*(N)ormal,

(R)eactivity (I)nstrument,

(C)omponent, (M)ajor Transient

NOTE 1: When RO identifies failing channel or LOW PZR LEVEL alarm is actuated, immediately fail channel LOW to ensure letdown isolation.

EVENT 3: MRF RP20 - cabinet #1 (door) open

MRF RX029 - LB459A (bistable) trip

# SCENARIO #1-1

## SCENARIO SUMMARY:

Reactor power is 75%. The 1B AF pump is OOS due to injection pump replacement, and has been OOS for the past 6 hours. The AF pump is expected to be returned to service in the next 12 hours. SG 1B Narrow Range Steam Generator Level Transmitter LT-557 is out of service. All required actions have been performed and an AR has been initiated. 1A Heater Drain Pump is out of service for motor bearing replacement. Power is to be increased after shift turnover at 5MW/min.

After power has been increased approximately 5%, the 1A CC Pump will trip and the standby 1B CC Pump will NOT auto start due to failure of the associated discharge pressure instrument. BOA PRI-6 will be entered and the operator will be required to recognize failure of auto start of the standby pump, diagnose failed pressure instrument and start the 1B CC Pump. The SRO will address Technical Specification, Condition B.

Two minutes after the actions are determined for the inoperable CC pump, the controlling channel of pressurizer level (LT-459) will fail downscale on a 120 second ramp. BOA INST-2, ATTACHMENT C will be entered to restore pressurizer level and select an operable channel. Letdown will be placed back in service and heaters restored. Channel LT-459 will be taken OOS and Technical Specification 3.3.1 Table 3.3.1-1 Function 9 actions (Condition J) addressed.

Following Technical Specification actions, the 1B Charging Pump experiences impeller degradation (to 50%) resulting in reduction of charging flow and discharge pressure. Low charging line flow alarm actuates and pump amps will decrease. Operator response should include placing the 1A Charging Pump inservice and stopping the 1B Pump. The SRO addresses Technical Specifications 3.5.2 (Condition A) and 3.5.5 (Condition A) and TRM 3.1.d.

After addressing the failed Charging Pump actions, steam header pressure transmitter PT-507 will fail downscale causing feedwater pumps to go to minimum flow. Manual control will have to be taken of the feedpump speed controller to restore normal feed flow (FW header pressure).

A Main Steam header break occurs at the steam header crosstie with a failure of the Steamline Isolation automatic closure signal and a failure of the 1A MSIV to close. The 1A AFW pump will trip on overcurrent. Feed flow is lost to the SGs. BFR-H.1 will be entered and an alternate method of feedwater will be required. With 1A steam generator being faulted, the actions of BEP-2 will be required following transition from BFR-H.1. One Pzr PORV will fail open requiring the operator to close its associated Block valve to isolate the leak path to the PRT. The scenario ends following transition to BEP-1 after isolating the faulted SG in BEP-2.

# **ERG-Based** Critical Tasks

- EP-0 P: Manually actuate main steamline isolation before a severe challenge develops to either the Subcriticality or the Integrity CSF OR before transition to BCA-2.1, whichever occurs first.
- 2. EP-2 A: Isolate the faulted SG before transition out of EP-2.
- 3. FR-H.1 A: Establish feedwater flow into at least one SG before RCS bleed and feed is required.

Scenario No: 1-1		Event No. 1 Page <u>4-5 of 24</u>
Event De	scription:	Normal power increase at 5 MW/min
Time	Position	Applicant's Actions or Behavior
	US	Implement actions of 1BGP 100-3, Step F.61.
	US	Direct increase to 100% power at 5 MW/minute.
	CREW	Review applicable Precautions, and Limitations and Actions.
	RO	Verify rod position and boron concentration.
		<ul> <li>Initiate dilution, if required. (BOP CV-5)</li> <li>Place MU MODE CONT SWITCH to STOP position.</li> <li>Set MU MODE SELECT to DIL or ALT DIL position.</li> <li>Set 1FK-111 PW/Total Flow Cont to desired dilution rate.</li> <li>Verify 1CV111A in AUTO</li> <li>Set 1FY-0111 Primary Water Control Preset Counter to desired volume.</li> <li>Verify 1CV11B &amp; 1CV110B in AUTO</li> <li>Place MAKE-UP CONTROL Switch to START</li> <li>Verify proper operation of valves &amp; PW pump (CV111A &amp; 111B open, PW pump is running, CV110B opens [if ALT DIL])</li> <li>Verify PW flow on recorder</li> <li>Verify B/U Heaters ON and spray valves 1RY455B/C modulates OPEN.</li> </ul>
	BOP	<ul> <li>Initiate turbine load increase:</li> <li>DEPRESS the LOAD RATE MW/MIN Pushbutton</li> <li>VERIFY/ENTER the desired load rate of 5.0 MW/min</li> <li>DEPRESS the REF Pushbutton</li> <li>Using the number Pushbuttons, SET in 1050 MW on the REFERENCE DEMAND window</li> <li>When ready to begin load increase, depress GO</li> <li>Verify load increases.</li> </ul>

Scenario	No: 1-1	Event No. 1	Page 4 - 5 of 24
Event De	scription:	Normal power increase at 5 MW/min	
Time	Position	Applicant's Actions or Behavior	
	RO	<ul> <li>Monitor power increase:</li> <li>Monitor reactor power, Tave</li> <li>Verify rods move in AUTO to maintain Tave within ± 2.0°F of Tref.</li> <li>If diluting:</li> <li>Monitor VCT level</li> <li>Verify RCS concentration decreasing</li> <li>Monitor Primary Water Control counter countdown.</li> <li>Verify dilution auto stops at preset value.</li> <li>Return Reactor Makeup System to blended flow for current boron concentration.</li> </ul>	

Scenario No: 1-1	Event No. 2 Page 6-7 of 24
Event Description:	The 1A CC Pump trips. Normally the standby pump (1B CC Pp) would start on low CC header discharge pressure; however, the 1B CC Pump discharge header pressure instrument fails as-is
Time Position	Applicant's Actions or Behavior
CUE:	Annunciators (1-2-A4) CC PUMP TRIP (1-2-B5) CC PUMP DSCH PRESS LOW May also receive associated CC low flow alarms for cooled equipment • 1PI-CC107 indicates LOW
US/BOP	Identify/report trip of CC Pump 1A. Identify/report failure of 1B CC Pump to start on low header pressure.
US	Implement BOA PRI-6 "Component Cooling Malfunction" and direct operator action.
BOP/US	<ul> <li>Perform actions of BOA PRI-6 as directed:</li> <li>Check CC Surge Tank level &gt; 13% and stable</li> <li>Check CC Pumps and manually start standby CC Pump (1B)</li> <li>Check CC pumps and manually start standby CC Pump (1B)</li> <li>Check CC system pressure &gt; 85 psig.</li> <li>Check CC flow to RCP cooling. The following alarms NOT lit: <ul> <li>RCP</li></ul></li></ul>

.

Scenario No: 1-1 Event Description:		Event No. 2 Page <u>6-7 of 24</u>		
		The 1A CC Pump trips. Normally the standby pump (1B CC Pp) would start on low CC header discharge pressure; however, the 1B CC Pump discharge header pressure instrument fails as-is.		
Time	Position	Applicant's Actions or Behavior		
	US	<ul> <li>Check Technical Specifications:</li> <li>3.7.7</li> <li>CONDITION B - Restore required CC Pump to OPERABLE status within 7 days.</li> </ul>		
	US	Inform SM/Maint of trip of 1A CC Pump Inform SM/Maint of failure of 1B CC Pump to auto start.		
	US	Inform SM of unit status.		

Scenario	No: 1-1	Event No. 3 Page 8-9 of 24			
Event Description:		Selected controlling PZR level channel 1LT-459 fails LOW over a 120 second period. This results in isolation of CVCS letdown, rising charging flow, PZr heaters deepergized, and rising PZR level			
Time	Position	Applicant's Actions or Behavior			
	CUES:	<ul> <li>Annunciators (1-12-A4) PZR LVL LOW HTRS OFF LTDWN SECURED (1-12-B4) PZR LEVEL CONT DEV LOW</li> <li>PZR heaters tripped OFF</li> <li>Letdown Isolation Valve LCV-459 &amp; Orifice Isolation valves 1CV8149A/B/C CLOSE</li> <li>Charging flow control CV-121 throttles open to increase flow</li> </ul>			
	RO/US	Identify/report failed PZR level channel: • LT-459			
	US	Implement BOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment C "PRESSURIZER LEVEL CHANNEL FAILURE" and direct operator action.			
	RO/US	<ul> <li>Check PZR Level:</li> <li>Verify level normal (56% to 60%) <ul> <li>If NOT take manual control of either the master level controller (LK-459) OR CV121 valve (FK-121) and adjust charging flow to minimum while maintaining RCP seal injection flow within required limits.</li> </ul> </li> <li>Select Operable Channel on LEVEL CHANNEL SELECTOR by placing to 461/460 position.</li> <li>Verify Channel 460 or 461 selected on PZR level recorder</li> </ul>			
	RO	<ul> <li>Reestablish normal letdown per BOP CV-17:</li> <li>Place letdown pressure controller PCV-CV131 in MAN and raise de 200%</li> <li>Place letdown Hx Out temperature controller TCV-CC130A to MAN and raise demand to 60%.</li> <li>Open Letdown Line Isolation valve LCV-CV460</li> <li>Verify open inservice regen Hx isolation valves CV8324A/B &amp; CV8389A/B</li> <li>Verify open Letdown Line CNMT isolation valves CV8160 &amp; 8152</li> <li>When plant conditions are stable and PZR level at normal (58-60%), place FCV-121 in AUTO.</li> </ul>			

Scenario	No: 1-1	Event No. 3	Page 8 - 9 of 24
Event Description:		Selected controlling PZR level channel 1LT-459 fails LOW over isolation of CVCS letdown, rising charging flow, Pzr heaters dee	a 120 second period. This results in energized, and rising PZR level.
Time	Position	Applicant's Actions or Beh	havior
	RO (cont.)	<ul> <li>Adjust in MAN Cent Chg Pump Flow controller FK-121 to e 10 gpm seal injection flow.</li> <li>Open the selected letdown orifice isolation valve(s) CV8149</li> <li>Adjust PCV-CV131 to obtain 360-380 psig on PI-131 and pl</li> <li>Adjust TCV-CC130A to obtain 90-115°F on TK-130 and pla</li> <li>Restore Variable Heaters by taking Control Switch to CLOSI</li> </ul>	establish ≈ 100 gpm charging flow with 8- A/B/C to establish desired letdown flow lace in AUTO ace in AUTO E.
	US/RO	Trip bistables by placing in TEST: • LB459A C1-751 BS-1 PZR HI WTR LVL RX TRIP	
	RO/US	Place PZR level control in AUTO: Master PZR Level Controller ICV121 controller	
	US	<ul> <li>Check Technical Specifications:</li> <li>3.3.1 - Rx Trip Inst. Table 3.3.1-1 FU 9; Req Channels 3 - E channel in TRIP within 6 hours</li> <li>3.3.3 - Post Accident Monitoring. Table 3.3.3-1 Function 6;</li> <li>3.3.4 - Remote Shutdown System. CONDITION A - Restore 30 days</li> </ul>	Ensure only ONE channel inop; place inop Req Channels 2 - NO ACTION required Function to OPERABLE within
	US	Inform SM/Maint of PZR level channel LT-459 status.	
	US	Inform SM of unit status/potential GSEP event.	

Scenario	No: 1-1	Event No. 4 Page 10 - 11 of 24		
Event De	escription:	The running CVCS Charging Pump (1B) experiences impeller degradation of 75% over a 5-minute period. This condition results in decreasing charging flow and charging header pressure		
Time	Position	Applicant's Actions or Behavior		
	CUE:	<ul> <li>Annunciator (1-9-D3) CHG LINE FLOW HIGH LOW (1-7-B2) RCP SEAL WTR INJ FLOW LOW</li> <li>CV pump amp indication decreasing</li> <li>FI-121 flow lowering</li> <li>Possible indications of letdown line flashing (and associated alarms)</li> </ul>		
	RO/US	Identify/report lowering charging flow/ Charging Pump 1B degradation.		
	RO/US	<ul> <li>Response per AR 1-9-D3:</li> <li>Ensure PZR level is normal</li> <li>Check RCP seal injection flow, if NO flow go to BOA RCP-2 (See actions covered below on this page.)</li> <li>Check for flow control failure</li> <li>IF desired, start second Charging Pu p</li> <li>Check output of PZR Master Level Controller 1LK-459</li> </ul>		
	CREW	Dispatch operator to check Charging Pump 1B Dispatch operator to check Charging Pump 1A if started NOTE: BOA RCP-2 " Loss of Seal Cooling" may also be entered due to loss of RCP seal injection flow. If so. Actions are directed per step 1 of BOA RCP-2 below.		
	US	Implement BOA RCP-2 " Loss of Seal Cooling" and direct operator action.		
	RO/US	<ul> <li>Check seal cooling:         <ul> <li>RCP seal outlet temperatures less than 235°F (TI-173/171/169/167)</li> <li>RCP lower bearing temperatures less than 225°F (TI-172/170/168/166)</li> <li>CC flow to RCP thermal barrier FLOW LOW annunciators not lit (1-7-A4/B4/C4/D4)</li> </ul> </li> </ul>		

Scenario	No: 1-1	Event No. 4 Page 10 - 11 of 24
Event De	escription:	The running CVCS Charging Pump (1B) experiences impeller degradation of 75% over a 5-minute period. This condition results in decreasing charging flow and charging header pressure.
Time	Position	Applicant's Actions or Behavior
	RO/US (cont.)	<ul> <li>Restore seal injection:</li> <li>Start a CV pump</li> <li>Check seal injection isol valves open (CV8355A/B/C/D)</li> <li>RCP SEAL WTR INJ FILTER DP HIGH annunciator (1-7-A 2) not lit</li> <li>Establish seal injection flow between 8 gpm &amp; 13 gpm per RCP:</li> <li>Throttle CV121</li> <li>Throttle CV182</li> </ul>
	RO	When Charging Pump 1B stopped, place control switch in PULL TO LOCK.
	US	<ul> <li>Check Technical Specifications:</li> <li>3.5.2 - ECCS subsystems CONDITION A - Restore charging pump within 7 days.</li> <li>Check Technical Requirements Manual:</li> <li>3.1.b Boration Flow Paths - Operating (see below)</li> <li>3.1.d Charging Pumps - Operating, CONDITION A - Restore charging pump within 7 days.</li> </ul>
	US	Inform SM/Maint of 1B Charging Pump trip/problem
	US	Inform SM of unit status/potential GSEP event.

Scenario	No: 1-1	Event No. 5 Page 12 of 24
Event Description:		Steamline pressure sensor PT-MS507 fails LOW causing FW Pump speeds to decrease. Manual control of FW Pump master controller is expected. Steam Dumps are affected if operated in STM PRESS Mode; the dumps will NOT open in AUTO since measured pressure is ZERO.
Time	Position Applicant's Actions or Behavior	
	CUE	Annunciator (1-15-A9/B9/C9/D9) S/G 1_LEVEL DEVIATION HIGH LOW (1-15-A3/B3/C3/D3) S/G 1_FLOW MISMATCH STM FLOW LOW PI-507 indication at bottom of scale PI-507 computer input low Decrea. ing SG levels Decreasing feedwater flow FW pump(s) decrease speed
	BOP	Identify/report PT-507 failed low
	BOP/US	<ul> <li>Response per AR 1-15-A9/B9/C9/D9 and 1-15-A3/B3/C3/D3:</li> <li>Take MAN control of FW Pump speed controller (Feedwater Pumps Master Controller) and raise speed to increase FW flow</li> <li>If required, take MAN control of FW Reg valves (FW 510/520/530/540) and open to restore level</li> <li>Recover SG levels to 63% (± 5%)</li> <li>Monitor SG levels and FW flows, adjusting feed pump speed as necessary</li> <li>Return FW Reg valves to AUTO if required</li> </ul>
	US	Inform SM/Maint of PT-507 failure/status.

Scenario	No: 1-1	Event No. 6	Page 13 - 15 of 24
Event Description:		A steam break outside CNMT develops on steam header crosstie. MSIVs fail to close automatically on SGs low pressure. Manual operation of MSIVs (Control Room control switches) is available.	
Time	Position Applicant's Actions or Behavior		
	CUE	Increased steam flow indication on all SGs (until MSIVs close) SG pressures decreasing RCS temperature falling PZR level lowering PZR pressure lowering	
	US	Implement BEP-0 "REACTOR TRIP OR SI"	
	RO	<ul> <li>Perform immediate operator actions of BEP-0:</li> <li>Verify reactor trip <ul> <li>Rod bottom lights LIT</li> <li>Reactor trip &amp; Bypass breakers open</li> <li>Neutron flux lowering</li> </ul> </li> </ul>	
	BOP	<ul> <li>Verify Turbine Trip</li> <li>Turbine throttle valves closed</li> <li>Turbine governor valves closed</li> <li>Verify power to 4KV busses</li> <li>Bus 141 alive light lit</li> <li>Bus 142 alive light lit</li> </ul>	
	CREW	<ul> <li>Determine SI &amp;eeded/actuated</li> <li>If actuated</li> <li>SI First OUT annunciator lit (1-11-B1, 1-11-C1, 1-11-D1, 1-11-E1)</li> <li>SI ACTUATED lit (1-BP-4.1)</li> <li>SI Equipment actuated (SI pumps running, CV Cold leg injection SIX</li> </ul>	8801A/B open)

Scenario	No: 1-1	Event No. 6	Page <u>13 - 15</u> of <u>24</u>
Event De	escription:	A steam break outside CNMT develops on steam header crosstie. MSIVs fail to close automatically on SGs low pressure. Manual operation of MSIVs (Control Room control switches) is available.	
Time	Position	Applicant's Actions or Behavior	
	CREW (cont.)	<ul> <li>If SI NOT actuated</li> <li>Check</li> <li>PZR pressure &lt;1829 psig</li> <li>Steamline pressure &lt;460 µsig</li> <li>CNMT pressure &gt; 3.4 psig</li> <li>PZR level CANNOT be maintained &gt; 4%</li> <li>Manually actuate SI</li> </ul>	
	CREW	Identify/report failure of MSIV's to close on SG low(ering) pressure at	t 640 psig.
	BOP/US	<ul> <li>Verify FW isolated</li> <li>FW pumps tripped</li> <li>Isolation monitor lights lit</li> <li>FW pumps disch valves closed (FW002A-C)</li> </ul>	
	RO/US	<ul> <li>Verify ECCS pumps running</li> <li>CENT Chg pumps</li> <li>RH pumps</li> <li>SI pumps</li> </ul>	
	RO/US	<ul> <li>Monitor RCP trip criteria and trip RCPs</li> <li>RCS pressure &lt; 1370 psig AND HHSI flow &gt; 50 gpm OR SI florent CNMT Phase B actuated</li> <li>Loss of CC water to RCP</li> </ul>	low > 100 gpm

-

Comments:

•

3

. . .

Print and

7/13/98

Scenario	No: 1-1	Event No. 6	Page 13 - 15 of 24
Event Description:		A steam break outside CNMT develops on steam header crosstie. MSIVs fail to close automatically on SC low pressure. Manual operation of MSIVs (Control Room control switches) is available	
Time	Position	Applicant's Actions or	Behavior
	BOP/US	<ul> <li>Verify Phase A isolation - Group 3 Monitor lights lit</li> <li>Verify CNMT Ventilation isolation - Group 6 Monitor lights</li> </ul>	ghts lit
		SEE Event 7	

Scenario No: 1-1		Event No. 7,8 & 9	Page 16 - 24 of 24
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close duc to binding. With recognition for actions required for loss of feedwater flow, Pzr PORV 456 fails open and path to must be isolated	
Time	Position	Applicant's Actions or Behavior	
	BOP	Identifies/reports failure of AFW Pump 1A to start.	
	BOP/US	<ul> <li>Verify AF system:</li> <li>AF 1B pump OOS and NOT available</li> <li>AF 1A pump fails to start manually</li> <li>AF isolation valves open (AF13A-H)</li> </ul>	
		AF flow control valves throttled (AF005A-H)	
		<ul> <li>Verify RCFCs running in LOW SPEED</li> <li>Verify CC Pumps running</li> </ul>	
		Verify SX Pumps running	
	BOP/US	<ul> <li>Check Main Steamline Isolation</li> <li>Check SG pressure &lt; 640 psig</li> <li>Check CNMT pressure &gt;8.2</li> <li>Verify MSIV and MSIV Bypass valves closed</li> </ul>	
	BOP	If NOT performed previously, identify/report MSIV failure to auto close	

7/13/98

Scenario	No: 1-1	Event No. 7, 8 & 9	Page 16 - 24 of 24
Event D	escription:	The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr PORV 456 fails open and path to must be isolated	
Time	Position	Applicant's Actions or Behavior	
	BOP/US [CT] E-0P	<ul> <li>Manually actuate Main Steamline Isolation</li> <li>Verify MSIV and MSIV Bypass valves closed         <ul> <li>Identify/report 1A MSIV failed to close. SG 1A still steaming</li> </ul> </li> </ul>	
	BOP/US	<ul> <li>Check if CNMT Spray is required</li> <li>CNMT pressure &gt; 20 psig</li> <li>Determine/report CNMT Spray NOT required</li> </ul>	
	BOP/US	<ul> <li>Verify AF flows</li> <li>AF flow &gt; 500 gpm</li> <li>Determine/report AF flows ZERO</li> <li>Check SG levels &gt; 10%</li> <li>If level is NOT &gt; 10% in any SG (i.e. ≤ 10% in ALL SGs), then transition is "RESPONSE TO LOSS OF SECONDARY HEAT SINK" (Actions of 1BI)</li> </ul>	s made to 1BFR-H.1 FR-H.1 covered below)
		1BFR-H.1 ACTIONS	
	US	<ul> <li>Transition to 1BFR-H.1 "RESPONSE TO LOSS OF SECONDARY HEAT SIN</li> <li>Direct initiation of Critical Safety Function Status Tree monitoring.</li> </ul>	vK
	US	Direct action of BFR-H.1	

Scenario No: 1-1		Event No. 7,8&9	Page <u>16 - 24</u> of <u>2</u>
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr PORV 456 fails open and path to must be isolated	
Time	Position	Applicant's Actions or Behavi	ior
	CREW	Check secondary heat sink required	
		<ul> <li>RCS pressure &gt; non-faulted SG pressure</li> </ul>	
		<ul> <li>RCS temperature &gt; 350°F</li> </ul>	
	RO/US	Check at least ONE Cent Chg pump running	
	CREW	· Che 's if Feed and Bleed is required by either ONE of the follow	ving:
		Wide Range level in any THREE SGs < 27% OR	
		<ul> <li>PZR pressure &gt; 2335 psig due to loss of heat sink</li> </ul>	
		Determine/report Feed & Bleed is NOT required at this time.	
	BOP/US	Try to establish AF flow to ONE SG	
		<ul> <li>Verify SG blowdown valves closed (SD002A-H)</li> </ul>	
		• Verify SG sample isol valves closed (SD005A-D)	
		<ul> <li>Review feed flow guidelines (ATTACHMENT B):</li> </ul>	
		<ul> <li>Do NOT feed any DRY SGs (WR level &lt; 10%)</li> </ul>	
		<ul> <li>If SG feedlines are NOT voided (VOIDED - feed flow los non-dry SGs at rate to increase WR level</li> </ul>	st for > 75 min), feed at least TWO
		<ul> <li>If SG lines voided:</li> <li>Feed TWO non-dry SGS at sufficient rate to increase</li> </ul>	W/D local
		<ul> <li>Feed remaining non-dry SGs between 40 and 80 gpm feed rate.</li> </ul>	n for 15 min. prior to restoring desired
		Check AF PUMP SX VLVS ARMED (1-3-E7) NOT lit	
		Check AF Pumps both running	

•

Scenario No: 1-1		Event No. 7,8&9	Page 16 - 24 of 2
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow, Pzr PORV 456 fails open and path to must be isolated	
Time	Position	Applicant's Actions or Behavio	r
	BOP/US (cont.)	<ul> <li>Since neither pump starts, dispatch an operator to start one pu</li> <li>Verify AF test valves open (AF004A/B)</li> <li>Verify AF isol valves open (AF013B/C/D/F/G/H)</li> <li>Verify AF flow control valves throttled/open (AF005B/C/D/F/M)</li> </ul>	mp per 1BOA ELEC-5
	RO/US	Check RCP status     All stopped	
	BOP/US	<ul> <li>Prepare to restore FW:</li> <li>Check at least ONE CD/CB pump running</li> <li>Place FW Reg valves in MANUAL at ZERO demand (1FW510</li> <li>Place FW Bypass Reg valves in MANUAL at ZERO demand (</li> <li>Place tempering flow control valves in MANUAL at ZERO demand (</li> </ul>	0/520/530/540) 1FW510A/520A/530A/540A) mand (1FW034A-D)
	RO	Identify/report Pzr PORV RY456 open and will NOT close	
	RO	<ul> <li>Determine PORV NOT required to be open</li> <li>Attempt to close PORV RY456 by taking switch to CLOSE</li> <li>When PORV identified as NOT closing, take control switch for 1 valve, to CLOSE</li> </ul>	RY8000B, PORB RY456 Block
	BOP/US	<ul> <li>Reset FW Isol</li> <li>Check for FW isolation aux relay lights lit</li> <li>Check SI actuated</li> </ul>	

Comments: NOTE: SRO INTERPRETATION OF SUMMARY PAGE OF EOP BER-HI FOR "BLEED AND FEED "INITIATION" DETERMINED THAT IMMEDIATE BLEED AND FEED WAS REQUIRED DUG TO PER PORV CYCLING OPEN AFTER TERMINATION OF RCPS (NATURAL CIRC) AND THAT PER PRESSURE EQUAL TO 2335 PSIG. D. 19 7/13/98

Scenario No	): 1-1	Event No. 7,8	3&9	Page 16 - 24 of 24
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr POBV 456 fails open and path to must be isolated.		
Time	Position		Applicant's Actions or Behavior	
B ((	BOP/US cont.)	<ul> <li>Dispatch operator to pull FW</li> <li>1PA27J - FU-24 &amp; FU-27</li> <li>1PA28J - FU-24 &amp; FU-27</li> <li>Establish main FW flow</li> <li>Check either Startup FW Pum</li> <li>Open FW Tempering Isol valv</li> <li>Check at least TWO CD/CB p</li> </ul>	Isol Aux Relay fuses: 7 np OR FW Pump 1A available we for selected SGs, 1FW035B, C a pumps running	nd/or D
B	OP/US CTJ RH.1-A	<ul> <li>Start the Startup FW Pump <ul> <li>Check Bus 159 energized</li> <li>Check discharge valve 1F</li> <li>Place recirc valve 1FW07/</li> <li>Close Main FW Pump rec</li> <li>Take control switch for SI</li> </ul> </li> <li>Review feed flow guidelines (same <ul> <li>Throttle tempering flow control</li> <li>Maintain hotwell level &gt; 20 in</li> </ul> </li> <li>Check Narrow range level in at let</li> <li>If NOT, verify adequate feed <ul> <li>SG WIDE RANGE level</li> <li>Core Exit TCs decreasing</li> </ul> </li> </ul>	1 W059 open 6 in MODULATE and check open circ valves 1FW012A/B/C U Feed Pump to START as above) ol valves for selected SGs 1FW0341 iches east one SG > 10% flow to at least one SG l increasing g	B, C and/or D

Scenario	No: 1-1	Event No. 7, 8 & 9	Page 16 - 24 of 24
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for 1/G A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr PORV 456 fails open and path to must be isolated	
Time	Position	Applicant's Actions or Behavior	
	BOP/US (cont.)	<ul> <li>If adequate feed flow verified, restore level in at least ONE SG to procedure and step in effect</li> </ul>	>10% narrow range and return to
		BEP-0 ACTIONS (cont.)	
	RO/US	Verify ECCS valve alignment & flows	
		Group 2 CL Inj monitor lights lit	
		<ul> <li>HHSI flow &gt;50 gpm</li> </ul>	
		<ul> <li>SI flow &gt; 100gpm (if RCS pressure &lt;1590 psig)</li> </ul>	
	RO/US	<ul> <li>Check at least ONE PZR PORV relief path available:</li> <li>At least ONE PORV Isol valve energized.</li> </ul>	
		<ul> <li>PORV in AUTO</li> <li>Associated Isol valve open</li> </ul>	
	BOP/US	Verify generator trip     OCB 3-4 and 4-5 open      PMG output breaker open	
		<ul> <li>Verify both DGs running</li> <li>DG SX valves 1SX169A &amp; B open</li> <li>Dispatch operator to locally check DGs</li> </ul>	
		<ul> <li>Ventilation systems aligned for emergency</li> <li>Control Room <ul> <li>Control Room d/P on 0PDI-VC038 &gt; +0.125" H2O</li> <li>Aux Bldg</li> </ul> </li> </ul>	
		Fuel Handling Bldg	

Scenario	No: 1-1	Event No. 7,8&9 Page 16-24 of 24			
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr PORV 456 fails open and path to must be isolated.			
Time Position Applicant's Actions or Behavior		Applicant's Actions or Behavior			
	RO/US	<ul> <li>Check PZR sprays &amp; PORVs closed</li> <li>RCS temperature control <ul> <li>Check RCP status - any running OR none running</li> <li>Check RCS CL temps trending to or stable at 557°F</li> </ul> </li> </ul>			
	RO/US	<ul> <li>Check RCP status:</li> <li>If any RCP running and RCS pressure &lt; 1425 psig AND HHSI flow &gt; 50 gpm OR SI flow &gt; 100 gpm</li> <li>Stop all RCPs and place Steam Dumps in STM PRESS Mode (NOTE: Operator must control in MAN due to earlier PT-MS507 failure)</li> </ul>			
	BOP/US	<ul> <li>Check SG secondary boundary</li> <li>Identify/report 1A SG pressure lower and decreasing</li> </ul>			
	CREW	Diagnose faulted SG			
	US	Transition to 1BEP-2 "Faulted Steam Generator Isolation"			
		1BEP-2 ACTIONS			
	US	Direct operator actions of 1BEP-2.			
	BOP/US	<ul> <li>Check Main Steamline Isolated</li> <li>Identify report SG 1A MSIV NOT closed</li> <li>Check if any SG boundary intact <ul> <li>Identify/report 1B, 1C &amp; 1D SGs pressures higher (than 1A) and stable</li> </ul> </li> <li>Identify faulted SG <ul> <li>1A SG identified faulted</li> <li>Lowering pressure</li> <li>Indicated steam flow</li> <li>Complete depressurized</li> </ul> </li> </ul>			
			Page <u>16 - 24</u> of <u>24</u>		
--------------------	-------------------------	-----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	----------------------------------	--	--
Event Description:		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr POBV 456 fails open and path to must be isolated			
Time	Position	Applicant's Actions or Behavio	or		
	BOP/US [CT] E-2—A	<ul> <li>Isolate 1A SG</li> <li>Manually close AF valves (AF013A, AF013E)</li> <li>FW Isol valves 1FW009A closed</li> <li>FW tempering flow control valves 1FW034A closed</li> <li>FW tempering Isol valves 1FW035A closed</li> <li>Low flow FW Isol valve 1FW039A closed</li> <li>FW Reg valve1FW510 close</li> <li>IFW Reg Bypass valve1FW510A close</li> <li>Verify SG PORV closed (MS018A)</li> <li>Verify SG blowdown isol valves closed (SD002A, SD002B)</li> <li>Verify SG blowdown sample isol valve closed (SD005A)</li> <li>Check AF PUMP SX VLVS ARMED (1-3-E7) NOT 1it</li> </ul>			
	BOP/US	<ul> <li>Check secondary radiation</li> <li>NO group 12 rad monitors in alarm</li> <li>Reset CNMT Isol Phase A</li> <li>Request Chem to sample SGs and open sample isol valves 1SI</li> </ul>	D005A-D at Chem Dept request		
	US	Transition to BEP-1 "Loss Of Reactor or Secondary Coolant"			
		1BEP-1 ACTIONS			
	US	Direct actions of BEP-1, STEP 3.			

٤.

.

Scenario No: 1-1 Event Description:		Event No. 7,8 & 9 Page <u>16</u>	- 24 of 24
		The 1A AFW Pump fails to start resulting in a loss of feed flow to all SGs. The next event (addressed immediately following AF), with the AUTO MSIV failure the operator is required to manually close MSIVs. The MSIV for SG A fails to close due to binding. With recognition for actions required for loss of feedwater flow. Pzr PORV 456 fails open and path to must be isolated	
Time	Position	Applicant's Actions or Behavior	
	BOP /US	<ul> <li>Check intact SG levels</li> <li>Narrow range levels &gt;10%. If not flow is maintain &gt; 500 gpm (&amp; within feed Guideline ATTACHMENT B of BFR-H.1)</li> <li>Control feed flow to maintain intact SG levels between 10% and 50%</li> <li>Check narrow range levels NOT increasing in an uncontrolled manner.</li> </ul>	es of
		SCENARIO TERMINATED	

# SHIFT MANAGER'S TURNOVER

## **TODAY ONCOMING SHIFT**

UNIT 1 STATUS	UNIT 1 MAJOR OOS's
MODE	SG 1B level transmitter LT557 is OOS. 1B AF Pump is OOS for injection pump replacement on diesel. 1A HDP is OOS for motor bearing replacement.
LUUAN ENTRIES PREVIOUS 48 MRS	UNIT 1 MAJOR SURVEILLANCES
LCOARs have been entered for 1LT557 and 1B AF Pump.	
UNIT 1 IN PROGRESS	UNIT 1 AND COMMON PENDING
<ul> <li>1B CV pump is in service following pump seal replacement and post maintenance testing. iB CV pump is OPERABLE.</li> <li>The National Weather Service has declared a Thunderstorm Warning in effect for Stephenson, Winnebago and Ogle counties for the next 4 hours.</li> </ul>	Ready to increase power to 100%. The BPO has requested a power ascension to Full Power at 5MW/min.
SCHEDULED ACTIVITY CONFLICTS	
ann a sann ann a bhailtean ann an Sanna a' Banna a' Banna a' Bhanna an Sanna Banna ann an an an an ann an ann a	

BAP 335-1T1 Revision 7

# SHIFT MANAGER'S TURNOVER

UNIT 2 STATUS	UNIT 2 MAJOR OOS's
MODE 1	
%Pwr	
MWe 1178	
Max Load/Power 100%	
Min Load/Power 750 MW	
Max Ramp Rate 2 MW/Min	
Desired Delta I. Target	
Unit on EGC NA	
Boron @ 535	
Control Bank D @ 213	
LCOAR ENTRIES PREVIOUS 48 HRS	UNIT 2 MAJOR SURVEILLANCES
UNIT 2 IN PROGRESS	UNIT 2 PENDING
SCHEDULED ACTIVITY CONFLICTS	

## SHIFT MANAGER'S TURNOVER

ADMINISTRATIVE	
TEMPORARY PROCEDURES/ALTS	
DAILY ORDERS/SPECIAL OP. ORDERS	
DAILY MANNING SCHEDULE	
CONTROL ROOM ROUNDS	
(GSEP/LER/DVR/ENS)	
MATERIAL CONDITIONING	
RWP'S/RELEASES/PRECAUTIONS/ALARA	
INFREQUENT EVOLUTION ACTIVITIES	
SPSO/DIVISION LD	Alternate BPO Outside # 815-727-5902/5903 Tie # 8-565-5902/5903
UNIT 1 COMMENTS	UNIT COMMON COMMENTS
S/G B/D returning to Condenser per SPP	CW Blowdown Lineup IL-2
	FC Cleanup U-1
	FC Cooling U-1
	50K DO Tank Certified
	125K DO Tank Certified
	Aux Steam U-1
	U-0 CC HX U-1
UNIT 2 COMMENTS	GENERAL COMMENTS
SO BD returning to Condenser per SPP	
Caution Cards	Abnormal Positioned Components
CCNUM EPN	CCNUM EPN Abnormal Position

SHIFT: LAST TO PRESENT TIME: NOW DATE: TODAY OFFGOING ONCOMING

...

Simulation	Facili	ty Byron 1 & 2	Scenario No.:	2	Op Test No.: 1	
Examiners:				Operators:		SRO
	-		_	-		RO
			_	-		BOP
Objectives:	In	accordance with plant j	procedures:			
	1.	reduce reactor power	(for shutdown).			
	2.	respond to Pressurize	r Pressure Master con	troller failure with	a failure of the PORV to c	lose.
	3.	respond to a loss of in	strument air to the co	ontainment.		
	4.	respond to a steam ge	nerator tube leak.			
	5.	respond to failure of f	eedwater isolation on	reactor trip and SI.		
	6.	respond to a loss of C	ontrol Room dP.			
	7.	perform emergency as	ctions for a SGTR wit	h out Pressurizer P	ressure control.	
Initial Cond	litions	1. IC-21, Reactor	Power 100%, Steady	state BOL, BGP 10	00-3, step F.61.	
		2. PZR pressure c	ontrol selected to 455	/456.		
		3. Pressurizer pre	ssure channel PT-458	is OOS with bistal	bles tripped.	
		4. PORV RY456	control switch is in C	LOSE and Block V	alve RY-8000B is closed	and deenergized
		5. 1A HDP OOS				
		6. 250' Meteorol	ogical Tower OOS.			
Turnover:	1.	Reactor Power is 100%	, Steady state power a	at BOL. BGP 100-:	3 is in effect.	
	2.	Unit 2 is at 100% powe	er.			
	3.	The block valve (RY-8 When the block valve v is investigating. Valve	000B) for PCV-456 is was shut it tripped aft has been OOS for 62	s closed and deener er the closed indica hours.	gized. A leak had develop tion was observed. Electr	ed on PCV-456 ical Maintenanc
	4.	Pressurizer pressure in been completed. PT-14 service.	strument 1PT-458 is t for channel has been	failed. All actions on initiated. Current	of BOA INST-2, ATTACI tly no report of expected ti	IMENT B have me for release to
	5.	Heater Drain Pump 1A	is out of service to m	neggar motor leads.		
	6.	The 250 foot Meteorolo	ogical Tower is out of	service and actions	s of TRM 3.3.c being track	ed. (LCOAR)

7. High wind warnings have been issued for Stephenson, Winnebago and Ogle counties for the next 2 hours.

Event	Malf.	Even	t	Event
Preload	NO. RF RP-78 & RP-79 , RF FW-150 & FW-151 , REMOVED	I B(	OP.	EWI valves fail to close (EWI signal failure)
Preload	OR ZAOOUREMO OR ZAOOUREMO OR ZAOOUREMO	002P2, 0 012P1, 0 012P2, 0		250' Met Tower OOS
Preload	RX22B, 2500 RF RX044 TRIP RF RX045 TRIP RF RX046 TRIP RF RX025 TRIP RF RX141 TRIP			Pressurizer pressure instrument 458 is OOS bistables tripped
Preload	RF ED065D OPEN			Block Valve MOV-RY8000B (PCV 456) was closed to cycle the valve. When the operators attempted to open valve, the motor operator tripped on overload.
1	RX15, 2500	I SF	20	Pressurizer Pressure Master Controller failure to maximum output.
2	TH11A, 25%	C SR	20	PORV 455A fails to close requiring the block valve RY8000A to be closed.
		R RC	20	Lowering reactor power during shutdown due to inoperable PORVs
3		N BC	NO DP	Set and lower turbine load
4	TH03D, 25	C BC	D RO DP	Steam Generator 1D Tube Leak – 25 gpm.
5	IA03, 5000	RC BC C SR	D DP RO	Loss of instrument air to the containment.
6	TH03D, 500	RC BC M SR	) )P (O	Steam Generator 1D Tube Rupture – Increases requiring a reactor trip and SI.
7	(Preload)	I BC	OP	FWI signal fails requiring manual operation of FW components
7	OR ZAOOPDIVC038 C SE:PN0530 ON	BC I SR	OP tO	Main Control Room differential pressure failure with decreasing pressure.
8	RF ED058C OPEN	RC BC C SR	) )P (O	Power is lost to the power supply for the Block Valve MOV-RY8000A (PORV 455A) while valve is closed (control switch taken to OPEN).

\*(N)ormal,

(R)eactivity (I)nstrument,

(C)omponent, (M)ajor Transient

#### SCENARIO #1-2

#### SCENARIO SUMMARY:

The scenario will begin at 100% power. Pressure transmitter 1PT-53 is out of service. An AR has been initiated and all required actions have been taken per BOA INST-2. The block valve for PO.  $\sqrt{456}$  is closed and deenergized due to thermal overloads tripping on the valve operator. The 250' elevation Meteorological Tower Instrumentation has failed and action of TRM 3.3.c is being tracked (LCOAR).

A failure of the Pressurizer Pressure Controller will cause PORV PCV-455A and the spray valves to open. PORV 455A fails open since the PORV enabling pressure channel PT-458 is failed HIGH. Failure of PORV 455A to close will require closure of its block valve MOV-RY8000A. The spray valves will close after manual control is taken of the pressurizer pressure controller. SRO will address Technical Specification 3.4.11 (Condition E) and TRM 3.3.k and 3.4.d.

Unit shutdown and cooldown to less than 500°F within 6 hours is initiated due to the inoperability of TWO PORVs.

After pressurizer pressure is returned to the normal band using manual control, a tube leak will occur in SG 1D. The crew will have to diagnose the tube leak and perform actions per the BOA PRI-1 and BOA SEC-8. This will include determination of leak size (~ 25 gpm) and SRO will address Technical Specification 3.4.13 (Condition A).

After initial actions have been performed for the SG tube leak, instrument air will be lost to the containment. Actions will be performed in accordance with the BOA SEC-4 for loss of instrument air to the containment. The loss of instrument air will prevent operation of the pressurizer normal spray valves or the auxiliary spray valve. The crew may decide to continue with the unit shutdown or may decide to trip the reactor since the ability to control Pzr pressure is severely impacted.

The reactor trip will cause Steam Generator Tube Rupture to increase requiring a SI. EOP actions of BEP-0 and BEP-3 will be performed. In BEP-0, the feedwater system will not isolate due to a failure of the feedwater isolation signal requiring manual action to isolate feedwater, and at step 21, the operator will recognize failure to maintain positive Control Room pressure and will perform actions of BOP VC-14. PORV Block valve (RY8000A) electrical power feed will trip if the valve is taken to open. Without pressurizer PORVs, pressurizer normal spray valves and Aux. Spray valves, pressurizer pressure control is lost. This will require that BCA-3.3, "SGTR Without Pressurizer Pressure Control", be performed during actions for the SGTR. The scenario ends with the establishment of RCS cooldown either in BCA-3.3 or BCA-3.1, as appropriate.

### ERG Based Critical Tasks:

- 1. EP-3 A: Isolate feedwater flow into and steam flow from the ruptured SG before a transition to ECA-3.1 occurs.
- EP-3 B: Establish/maintain and RCS temperature so that transition from EP-3 does not occur because RCS temperature is in either of the following conditions.
  - Too high to maintain minimum required subcooling
  - OR
  - Below the RCS temperature that causes an extreme (red-path) or a severe (orange path) challenge to the subcriticality and/or integrity CSF.
- 3. ECA-3.3-A Terminate SI before a water release occurs through the SG PORV or SG Safeties.

Scenario	No: 1-2	Event No. 1 & 2 Page _ 4 - 5 of
Event De	escription:	Master PZR Pressure Master Controller PK-455A fails HIGH. This results in normal Pzr Spray valves opening, Pzr PORV PCV-455A opening. Following opening of PORV PCV-455A, the PORV fails to close when demanded (Manual or Auto). The operator is required to close the Block valve associated with PORV-455A (MOV RY-800A). The PORV failure results in BOTH PORVs being inoperable.
Time	Position	Applicant's Actions or Behavior
	CUES:	Annunciators (1-12-D2) PZR PESS CONT DEV HIGH (1-12-C6) PZR PORV DSCH TEMP HIGH
		<ul> <li>Pzr Spray valves OPEN</li> <li>Pzr heaters tripped OFF</li> <li>Pzr PORV PCV-455A OPEN</li> </ul>
	RO/US	Identify/report failed Master PZR Pressure Controller (AUTO).
	RO/US	<ul> <li>Perform actions of 1BAR 1-12-D2:</li> <li>Place Master PZR Pressure Controller to MANUAL OR spray s to MANUAL</li> <li>Restore PZR pressure to normal</li> </ul>
		Monitor PZR pressure and level
	RO/US	Identify/report failure of PCV-455A to close (either AUTO or when C/S taken to CLOSE) Close MOV RY8000A Pzr PORV Block valve
	US	May chose to implement BOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment B "PRESSURIZER PRESSURE CHANNEL FAILURE" and direct operator action.
	RO/US	<ul> <li>Check PZR pressure:</li> <li>Take manual control to restore Pzr pressure</li> <li>Determine all channels of Pzr pressure operable except PT-458 which was OOS prior to event</li> <li>Check PORVs closed, then if PZR pressure &lt; 2315 psig, Manually close PORV <ul> <li>If PORV will NOT close, manually close PORV Isol valve IRY8000A</li> </ul> </li> <li>Check spray valves IRY455B &amp; 455C closed, then manually close if open</li> <li>Manually operate PZR heaters</li> </ul>

Scenario	No: 1-2	Event No. 1 & 2 Page _4 - 5 of _32	
Event Description:		Master PZR Pressure Master Controller PK-455A fails HIGH. This results in normal Pzr Spray valves opening, Pzr PORV PCV-455A opening. Following opening of PORV PCV-455A, the PORV fails to close when demanded (Manual or Auto). The operator is required to close the Block valve associated with PORV-455A (MOV RY-800A). The PORV failure results in BOTH PORVs being inoperable.	
Time	Position	Applicant's Actions or Behavior	
	US	<ul> <li>Check Technical Specifications:</li> <li>3.4.1 - RCS Pressure, Temp, and Flow DNB Limits. If PZR pressure &lt;2219 psig, the CONDITION A applies with ACTION to restore above limit within TWO hours.</li> <li>3.4.11 - PZR PORVs; CONDITION E (TWO PORVs inop) with ACTION to immediate initiate actions to restore ONE, CLOSE Block Valves within ONE hour, Remove Block Valve power within ONK hour, and be in MODE 3 with RCS Tavg &lt; 500°F in 6 hours.</li> <li><i>E HP</i></li> <li>Check TRM:</li> <li>3.4.d - PORVs; CONDITION A – BOTH PORVs unable to automatically perform a pressure relief actuation, restore the automatic pressure relief function to at least ONE PORV in 72 hours.</li> </ul>	
	US	Inform SM/Maint of PZR Master Pressure Controller failure. Inform SM/Maint of PZR PORV PCV-455A failure to close	
	US	Inform SM of unit status/potential GSEP event (TWO PORVs inoperable).	

-

5

Scenario	No: 1-2	Event No. 3 Page 6 - 7 of 32
Event De	scription:	Power decrease for plant shutdown due to inoperable PORVs.
Time	Position	Applicant's Actions or Behavior
	US	Identify Technical Specification REQUIRED ACTION requiring plant shutdown due to inoperable PORVs.
	US	<ul> <li>Implement actions of 1BGP 100-4, Step F.1:</li> <li>Implement flowpath 1BGP 100-4T1, Power Descension Flowchart.</li> <li>Direct initiation of Reference Reactivity Data as per 1BGP 100-7.</li> </ul>
	US	Direct decrease from 100% power at 5 MW/minute.
	CREW	Review applicable Precautions, and Limitations and Actions.
	BOP	<ul> <li>Initiate turbine load decrease to 580 MW:</li> <li>DEPRESS the LOAD RATE MW/MIN Pushbutton</li> <li>VERIFY/ENTER the desired load rate of 5.0</li> <li>DEPRESS the REF Pushbutton</li> <li>Using the number Pushbuttons, SET in 580 MW on the REFERENCE DEMAND window</li> <li>When ready to begin load decrease, depress GO</li> <li>Verify load decreases.</li> </ul>
	RO	<ul> <li>Initiate boration: (BOP CV-6)</li> <li>Place MU MODE CONT SWITCH to STOP position.</li> <li>Set MU MODE SELECT to BOR position.</li> <li>Set 1FK-110 BA Flow Cort to desired boration rate.</li> <li>Fill out Boration/Dilution/Rod Motion Log</li> </ul>

Scenario	No: 1-2	Event No. 3 Page 6 - 7 of 32
Event De	escription:	Power decrease for plant shutdown due to inoperable PORVs.
Time	Position	Applicant's Actions or Behavior
	RO	<ul> <li>Verify 1CV110A in AUTO</li> <li>Set 1FY-0110 BA Blender Preset Counter to desired volume.</li> <li>Verify 1CV110B in AUTO</li> <li>Verify BA Transfer Pump in START or AUTO</li> <li>Place MAKE-UP CONTROL Switch to START</li> <li>Verify proper operation of valves &amp; BA transfer pump (CV110B open, BA pump is running, CV110A throttles open)</li> <li>Verify BA flow on recorder</li> <li>Verify B/U Heaters ON and spray valves 1RY455B/C modulates OPEN.</li> </ul>
	CREW	<ul> <li>Monitor power decrease:</li> <li>Monitor reactor power, Tave</li> <li>Verify rods move in AUTO to maintain Tave within ± 2.0°F of Tref.</li> <li>if borating:</li> <li>Monitor VCT level</li> <li>Verify RCS concentration increasing</li> <li>Monitor B/A Control counter countdown.</li> <li>Verify boration auto stops at preset value.</li> <li>Return Reactor Makeup System to blended flow for current boron concentration.</li> </ul>

Scenario	No: 1-2	Event No. 4 Page 8 - 12 of 32
Event De	escription:	25 gpm S/G tube leak occurs in 1D S/G.
Time	Position	Applicant's Actions or Behavior
	CUE:	Annunciator (1-12-B4) PZR LEVEL CONT DEV LOW (1-12-C1) PZR PRESS CONT DEV LOW HTRS ON SG blowdown radiation monitor 1PR08 increasing SJAE/Gland Steam Exhauster radiation monitor 1PR027 increasing Steamline radiation monitors 1RE-AR022, AR023 N-16 monitor increasing when aligned Increased charging flow PZR level dropping PZR pressure dropping
	CREW	<ul> <li>Identify/ report RCS leak rate increasing</li> <li>Identify/report secondary radiation increasing/SG leakage</li> </ul>
		NOTE: BOA SEC-8 (see page 9) may be entered directly on symptoms of tube leak OR may be entered on transition from BOA PRI-1. PRI-1 actions are provided but are NOT required to be performed. BOA PRI-1 ACTIONS
	US	Implement BOA PRI-1 "EXCESSIVE PRIMARY PLANT LEAKAGE" and direct operator action.
	RO/US	<ul> <li>Attempt to maintain PZR level         <ul> <li>Check Cent Chg pump running</li> <li>Throttle Charging header valves to maintain PZR level                 <ul></ul></li></ul></li></ul>
		<ul> <li>PZR PORVs closed (NOTE: PORV 455A indicates open; Block valves are closed)</li> <li>RY455A</li> <li>RY456</li> </ul>

Scenario	No: 1-2	Event No. 4 Page 8 - 12 of 32
Event De	escription:	25 gpm S/G tube leak occurs in 1D S/G.
Time	Position	Applicant's Actions or Behavior
RO/US		<ul> <li>PZR spray valves closed (NOTE: Valves are failed close due to loss of LA)</li> <li>RY455B</li> <li>RY455C</li> <li>CV8145 Aux spray</li> <li>Check all PZR heaters energized</li> <li>PZR pressure stable or increasing</li> <li>Monitor PZR level stable or increasing</li> <li>If not start second Cent Chg pump</li> <li>Check letdown isolated</li> <li>Isolate portions of charging, if desired, to determine leak location and determine leak NOT isolable</li> <li>Check SG Tube intact:</li> <li>Check secondary rad monitors <ul> <li>SJAE GS exhaust IPR27J Grid 1 IPS027</li> <li>SG Blowdown IPR08J Grid 1 IPS108</li> <li>Main Steam: IRT-AR022 &amp; IRRT-AR023 for each SG, Grid 1 4AA122/123, 4AB222/223, 4AC322/223, 4AD422/423</li> <li>Main Steam Penetration IA/ID IRT-AR024 Grid 4 4AA124</li> <li>Main Steam Penetration IB/IC IRT-AR024 Grid 4 4AB124</li> </ul> </li> </ul>
		BOA SEC-8 ACTIONS
	US	Implement BOA SEC-8 "STEAM GENERATOR TUBE LEAK" and direct operator action.
	RO/US	<ul> <li>Attempt to maintain PZR level</li> <li>Throttle Charging header valves to maintain PZR level         <ul> <li>CV121</li> <li>CV182</li> </ul> </li> </ul>
	RO/US	<ul> <li>Check PZR level stable or increasing</li> <li>If not establish 75 gpm letdown flow</li> </ul>

Comments: \_

Scenario	No: 1-2	Event No. 4 Page 8-12 of 32
Event De	escription:	25 gpm S/G tube leak occurs in 1D S/G.
Time	Position	Applicant's Actions or Behavior
	RO/US	Monitor VCT level
	BOP/US	<ul> <li>Minimize secondary contamination</li> <li>Perform BOP MS-11 (NOTE: Actions covered below on page 11.)</li> <li>Notify Rad Pro</li> <li>Monitor secondary systems</li> <li>Monitor condensate polisher area</li> <li>Initiate 0BCS 11.2.4.1-1</li> </ul>
	CREW	<ul> <li>Estimate SG tube leak rate         <ul> <li>Observe difference between charging flow and seal leakoff</li> <li>Change in VCT level</li> <li>Chemistry estimated primary to secondary leak rate</li> </ul> </li> <li>Determine leak rate &gt; 10 gpm</li> </ul>
	US	<ul> <li>Initiate Unit shutdown</li> <li>Review Technical Specifications         <ul> <li>3.4.13 RCS Operational LEAKAGE - LCO d. &amp; e., CONDITION A &amp; B, Required ACTION reduce leakage with 4 hours or be in MODE 3 in 6 hours</li> </ul> </li> <li>Continue shutdown of Unit</li> </ul>

Scenario N	No: 1-2	Event No. 4	Page 8 - 12	_ of <u>32</u>
Event Des	cription:	25 gpm S/G tube leak occurs in 1D S/G.		
Time	Position	Applicant's Actions or Behavior		
	CREW	<ul> <li>Identify leaking SG</li> <li>Decreasing feed flow with stable level</li> <li>Unexpected rise in SG NR level</li> <li>High activity sample</li> <li>Increasing trend on any Main Steamline Rad Group 12</li> <li>ID SG RT-AR022 Grid 1 4AD422</li> <li>ID SG RT-AR023 Grid 1 4AD423</li> </ul>		
		ACTIONS OF BOP MS-11		
	CREW	<ul> <li>IDENTIFY leaking steam generator(s):</li> </ul>		
		<ul> <li>REQUEST Chemistry to take sample(s) on the suspected leaking SG(s).</li> <li>PERFORM a quick count (approximately 10 minutes).</li> <li>REQUEST that the Shift Manager be notified of any activity that is found in the IDENTIFY contaminated systems:</li> <li>NOTIFY Chemistry Supervision to establish activity sampling per BCP 300-A9, St Tube Leak System Check Requirements.</li> <li>If contamination is suspected, then REQUEST Chemistry sample the following for</li> <li>Affected unit's condensate pump discharge header.</li> <li>Affected unit's radwaste sumps:</li> <li>Condenser floor drain sump.</li> <li>Turbine Building Equipment Drain sump.</li> </ul>	he sample(s) eam Genera activity:	tor
Comment	ts:			

Scenario	No: 1-2	Event No. 4 Page 8 - 12 of 3
Event De	escription:	25 gpm S/G tube leak occurs in 1D S/G.
Time	Position	Applicant's Actions or Behavior
	CREW (cont.)	<ul> <li>MINIMIZE input to the affected unit's secondary systems: <ul> <li>If Aux Feed is being used to feed steam generators, use of the Startup Feedwater Pump should be considered.</li> </ul> </li> <li>If Aux Steam is being used for the unaffected unit's Gland Steam, then TRANSFER Aux Steam to an unaffected source per BOP AS-5, Transferring Aux Steam Loads.</li> <li>TRANSFER GS to unaffected unit's AS per BOP GS-6 if either of the following occur: <ul> <li>Cooldown rate must be reduced.</li> <li>Insufficient Main Steam header pressure to maintain Gland Seal pressure develops during cooldown.</li> </ul> </li> <li>VERIFY Aux Steam returns aligned:: <ul> <li>If Aux Steam is being supplied from the affected unit, then VERIFY CLOSED unaffected unit's AS103, Hig Sys HX Chds Rtrn to U- HD Tk Cont Viv Dwst Isol Viv.</li> <li>If Aux Steam is being supplied from the unaffected unit, then VERIFY CLOSED affected unit's AS103, Hig Sys HX Chds Rtrn to U- HD Tk Cont Viv Dwst Isol Viv.</li> <li>If Aux Steam is being supplied from the unaffected unit, then VERIFY CLOSED affected unit's AS103, Hig Sys HX Chds Rtrn to U- HD Tk Cont Viv Dwst Isol Viv.</li> <li>ALIGN condensate collection tank pressure control to non-affected unit.</li> <li>OPEN AS246, AS Collection Vent to U- MS Flash Tank, on affected unit.</li> <li>OPEN AS246, AS Collection Vent to U- MS Flash Tank, on non-affected unit.</li> </ul> </li> <li>Notify Radwaste Supervisor of any sample results indicating a contaminated secondary system or radwaste sump so action can be initiated to minimize the spread of contamination.</li> <li>CONTACT System Engineering Thermal Group Leader to have N-16 monitors placed.</li> <li>INITLATE plant walkdowns by Operations ,</li> <li>REQUEST Rad Protection initiate surveys to monitor for contaminated areas in the Turbine Building, Main Steam Tunnel, and TR.</li> </ul>
	US	Inform SM of SG Tube Leak and continuation of planned shutdown.
	US	Inform SM of unit status/potential GSEP event.

Scenario No: 1-2		Even	t No. 5	Page 13 - 16 of 32
Event Des	scription:	Instrument air to containment is lost due to rupture of IA line inside CNMT.		ie CNMT.
Time	Position	tion Applicant's Actions or Beha		vior
	CUES:	<ul> <li>Various Instrument Air Id</li> <li>Air operated controls</li> <li>Specific CNMT valve</li> <li>RY455A-456</li> <li>RY455 B-C</li> <li>RC8037 A-D</li> <li>CV459-CV460</li> <li>CV8389 A-B</li> <li>CV8149 A-C</li> <li>CV816</li> </ul>	ow pressure annunciators may alarm. and valves begin to go to FAIL position es fail; Pzr PORV's (have accumulators) Pzr sprays Loop Drains Letdown Isolation Valves Regen Hx Letdown inlet isol Orifice Isolations Letdown cnmt isol.	Closed Closed Closed Closed Closed Closed Closed
		<ul> <li>CV8324 A-B</li> <li>CV8146-8147</li> <li>CV8145</li> <li>CV123</li> <li>CV8143</li> <li>CV8143</li> <li>CV8141 A-D</li> <li>CV8142</li> <li>CC9437 A/B</li> <li>Leak may be isolated</li> </ul>	Regen Hx Charging inlet isol Charging to loops A-B Aux Spray Excess Letdown Flow Control Excess Letdown Divert #1 seal leakoff isolation #1 seal bypass isolation Excess Letdown Hx isol if IA CNMT Isol valves IA065/066 close	Closed Open Closed Closed To Seal Water Hx Open Closed Closed closed t (FAIL CLOSE on loss of air)
	RO/US	Identify/report decreasing NOTE: Crew initiate ac	Instrument Air pressure tions of 1BOA SEC-4 OR may select to	o enter and perform 0BOA SEC-4
	US	either initially or as folio Implement 1BOA SEC-4	"Loss Of Instrument Air" and direct oper	w on page 15). ator action.
	BOP/US	<ul> <li>Direct Unit 2 NSO to</li> <li>Evaluate plant condit</li> <li>Refer to TABLE</li> </ul>	initiate 2BOA SEC-4. ions A for potential actuations (See above for	r expected failures)
	RO/US	<ul> <li>Control RCP seal inje</li> <li>Check CV121 fai</li> <li>o If valve is fai</li> <li>locally close</li> </ul>	ection iled open, if NOT continue with VCT lev iled open, Direct operator to locally throu 1CV121 Isol valve 12CV8483A/B	el tle open Bypass valve 1CV8387A/Band

Scenario	No: 1-2	Event No. 5 Page <u>13 - 16 of 32</u>
Event De	escription:	Instrument air to containment is lost due to rupture of IA line inside CNMT.
Time	Position	Applicant's Actions or Behavior
	RO/US (cont.)	Check VCT level     Check that VCT level is NOT <10%
		<ul> <li>Maintain Pzr level</li> <li>Maintain Pzr level between 25% and 60%</li> <li>Control charging</li> <li>Reduce turbine load</li> <li>Cooldown RCS at &lt; 100°F/hr</li> </ul>
		<ul> <li>Check RCS pressure         <ul> <li>RCS pressure &lt; 2335 psig</li> <li>If NOT, open one PORV to reduce pressure to 2235 psig (NOTE: PORVs are NOT available)</li> <li>Cycle Pzr heaters to maintain pressure stable</li> </ul> </li> </ul>
	BOP/US	<ul> <li>Minimize secondary plant effects:</li> <li>Check GS supply header &lt; 120 psig on 1PI-GS001</li> <li>Check HP turbine gland seal pressure 1psig to 3 psig on 1PI-GS002</li> <li>Direct operator to locally check <ul> <li>LP turbine gland seal regulators operating at 1 psig to 3 psig</li> <li>MS flash tank vent NOT blowing</li> </ul> </li> <li>Check FW PUMP SEAL WTR TANK LEVEL HIGH LOW (1-16-B5) NOT lit</li> </ul>
	CREW	<ul> <li>Restore control &amp; System alignments: <ul> <li>Determine components isolated by recovery actions (See above for affected components)</li> </ul> </li> <li>Determine air leak is in CNMT and if NOT already isolated, close 1IA065 and/or 1IA066 (NOTE: valves fail closed on loss of 1A).</li> <li>Check IA pressure &gt; 95 psig and stable or increasing</li> <li>Maintain RCP seal injection between 8 gpm &amp; 13 gpm</li> </ul>

Scenario No: 1-2		Event No. 5	Page <u>13 - 16 of 32</u>
Event De	escription:	Instrument air to containment is lost due to rupture of IA line inside CNMT.	
Time	Position	Applicant's Actions or Behavior	
	CREW (cont.)	Restore at SM direction     O Control Systems     O System alignments Minimize charging flow to RCS	
		ACTIONS OF 0BOA SEC-4	
	US	Implement 0BOA SEC-4 "Loss Of Instrument Air" and direct operator action.	
	BOP/US	Direct Unit 2 NSO to initiate 2BOA SEC-4. (If NOT done prior)	
		<ul> <li>Check SAC control air available         <ul> <li>Check minimum SAC control pressure</li> <li>IA header pressure &gt; 28 psig</li> <li>Direct operator locally check SAC control cabinet supply pressure</li> </ul> </li> <li>Check at least one SAC running loaded         <ul> <li>Check SA pressure &gt; 105 psig</li> </ul> </li> </ul>	
		<ul> <li>Check IA status</li> <li>IA pressure &gt; 90psig and stable or increasing</li> </ul>	
	CREW	Locate and isolate air leak     Determine leak is inside CNMT	
		Determine leak is isolated by CNMT IA isolation valves IA065 and IA066	
	BOP/US	<ul> <li>Restore control &amp; System alignments:</li> <li>Check IA pressure &gt; 95 psig and stable or increasing</li> </ul>	

200

•

.....

Scenario	No: 1-2	Event No. 5	Page 3 - 16 of 32
Event De	escription:	Instrument air to containment is lost due to rupture of IA line inside CNMT.	
Time Position		Applicant's Action	as or Behavior
	CREW (cont.)	<ul> <li>Direct local check SAC alignment (ONE SAC b standby)</li> <li>Direct local check IA dryer alignment (TWO on</li> </ul>	base loaded, ONE loaded in AUTO & ONE in
	US	Inform SM/Maint of loss of IA to CNMT Inform SM of loss of PZR pressure control components (1 letdown. Decide to either continue unit shutdown monitoring Pzr p limited capability for Pzr pressure control	Normal sprays, Aux Spray, & PORVs) and RCS pressure control OR initiate a reactor trip due to
	US	NOTE: When the crew makes a decision to trip reactor Inform SM of unit status/potential GSEP event.	or, EVENT 6 (SGTR) will be activated

a

-

ч.

Scenario	No: 1-2	Event No. 6 & 7	Page 17 - 20 of 32
Event Description:		The SG Tube leak will increase in size to a SGTR. This will require a manual reactor trip and SI. The FWI signal will fail to actuate and operator action is required to trip the feed pump(s) and isolate FW flow to the SGs.	
Time	Position	Applicant's Actions or Behavior	
	CUE:	Annunciator (1-12-B4) PZR LEVEL CONT DEV LOW (1-12-C1) PZR PRESS CONT DEV LOW HTRS ON SG blowdown radiation monitor 1PR08J increasing SJAE/Gland Steam Exhauster radiation monitor 1PR 27J increasing Increased charging flow PZR level dropping PZR pressure dropping FW flow/Steam flow mismatch for 1D SG	
		Feed Reg Valves and FW Isol valves will remain open Main FW Pumps continue to run (fail to trip)	
	CREW	Identify increase in RCS leakage	
	RO	Report inability to maintain PZR level > 17%	
	US	Direct reactor trip and SI initiation	
	RO	Manually trips reactor     Manually actuates SI	
	US	Implement BEP-0 "REACTOR TRIP OR SI"	
	RO	<ul> <li>Perform immediate operator actions of BEP-0:</li> <li>Verify reactor trip</li> <li>Rod bottom lights LIT except TWO</li> <li>Reactor trip &amp; Bypass breakers open</li> <li>Neutron flux lowering</li> </ul>	
	BOP	<ul> <li>Verify Turbine Trip</li> <li>Turbine throttle valves closed</li> <li>Turbine governor valves closed</li> </ul>	

Scenario	No: 1-2	Event No. 6 & 7	Page <u>17 - 20</u> of <u>32</u>
Event Description:		The SG Tube leak will increase in size to a SGTR. This will require a manual reactor trip and SI. The FWI signal will fail to actuate and operator action is required to trip the feed pump(s) and isolate FW flow to the SGs.	
Time Position		Applicant's Actions or Behavior	
	BOP (cont.)	<ul> <li>Verify power to 4KV busses</li> <li>Bus 141 alive light lit</li> <li>Bus 142 alive light lit</li> </ul>	
	CREW	<ul> <li>Determine SI actuated</li> <li>5.1 First OUT annunciator lit (1-11-C1)</li> <li>SI ACTUATED lit (1-BP-6.1)</li> <li>SI Equipment actuated (SI pumps running,</li> <li>Actuate SI by taking either SI switch to ACTUA</li> </ul>	CV Cold leg injection SI8801A/B open) TE (1PM05J or 1PM06J)
	BOP/US	<ul> <li>Verify FW isolated</li> <li>FW pumps tripped</li> <li>FW PUMPS TRIPPED alarms NOT lit :</li> </ul> Determine/report failure of FWI signal <ul> <li>Manually trip pumps</li> <li>Manually close FW Reg valves 1FW510/520</li> <li>FW pumps disch valves closed (FW002A-C)</li> </ul>	and/or FW Isolation Monitor lights NOT lit /530/540 and/or FW shutoff valves 1FW006A-D
	RO/US	<ul> <li>Verify ECCS pumps running</li> <li>CENT Chg pumps</li> <li>RH pumps</li> <li>SI pumps</li> </ul>	
	BOP/US	<ul> <li>Verify Phase A isolation - Group 3 Monitor light</li> <li>Verify CNMT Ventilation isolation - Group 6 Monitor 1</li> </ul>	nts lit Monitor lights lit

.

Scenario	No: 1-2	Event No. 6 & 7	Page <u>17 - 20</u> of <u>32</u>
Event Description:		The SG Tube leak will increase in size to a SGTR. This will require a manual reactor trip and SI. The FWI signal will fail to actuate and operator action is required to trip the feed pump(s) and isolate FW flow to the SGs.	
Time Position		Applicant's Actions or Behavior	
	BOP/US (cont.)	<ul> <li>Verify AF system:</li> <li>BOTH AF pumps running</li> <li>AF isolation valves open (AF13A-H)</li> <li>AF flow control valves throttled (AF005A-H)</li> <li>Verify RCFCs running in LOW SPEED</li> <li>Verify CC Pumps running {1B and 0 (common)}</li> <li>Verify SX Pumps running</li> <li>Check Main Steamline Isolation NOT required <ul> <li>Check SG pressure &gt; 640 psig</li> <li>Check SG pressure &lt;8.2</li> </ul> </li> <li>Check if CNMT Spray is required</li> <li>CNMT pressure &gt; 20 psig</li> <li>Determine/report CNMT Spray NOT required</li> <li>Verify AF flows <ul> <li>AF flow &gt; 500 gpm available</li> <li>SG levels maintained between 10% and 50%</li> </ul> </li> </ul>	
	BOP/US [CT] E-3A	<ul> <li>Check for NR level NOT increasing in uncontrolled manner</li> <li>If ruptured SG suspected, isolate AF Isol valves:</li> <li>AF013D</li> <li>AF013H</li> </ul>	
	RO/US	<ul> <li>Verify ECCS valve alignment &amp; flows</li> <li>Group 2 CL Inj monitor lights lit (except 1A CC pump)</li> <li>HHSI flow &gt;50 gpm</li> <li>SI flow &gt; 100 gpm (if RCS pressure &lt;1590 psig)</li> </ul>	

Scenario No: 1-2 Event Description:		Event No. 6 & 7	Page <u>17 - 20</u> of <u>32</u>
		The SG Tube leak will increase in size to a SGTR. This will require a manual reactor trip and SI. The FWI signal will fail to actuate and operator action is required to trip the feed pump(s) and isolate FW flow to the SGs.	
Time	Position	Applicant's Actions or Behavior	
	RO/US	<ul> <li>Check at least ONE Pzr PORV relief path available:</li> <li>PORV Isol valves at least one energized</li> <li>Determine NO PORV Isol valve energized (assuming action take)</li> </ul>	en per Tech Specs)
	BOP/US	Verify Generator trip	
	BOP/US	<ul> <li>Verify DG running</li> <li>SX valves open (SX169A/B)</li> <li>Dispatch operator locally to check operation</li> </ul>	
		CONTINUED IN EVENT 8	

Scenario	No: 1-2	Event No. 8 Page 21 - 28 of 32	
Event De	scription:	Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pressure to drop with respect to Turbine Building and Aux Building. Continue with actions of BEP-0.	
Time Position Applicant's Actions of		Applicant's Actions or Behavior	
	CUE Annunciator (0-33-C7) MCR PRESSURE LOW MCR/TB BLDG DP indication reading below 0.125 "H2O (GREEN band)		
	BOP/US	<ul> <li>Ventilation systems aligned for emergency</li> <li>Control Room         <ul> <li>Control Room pressure &gt; +0.125" H2O on 0PDI-VC038</li> </ul> </li> <li>Determine/report control d/P inadequate</li> <li>Determine BOP VC-14 needs to be performed (See actions below on page 23.)</li> </ul>	
	BOP/US	<ul> <li>Ventilation systems aligned for emergency</li> <li>Aux Bldg</li> <li>Fuel Handling Bldg</li> </ul>	
	RO/US	<ul> <li>Check PZR sprays &amp; PORVs closed</li> <li>Pzr Spray valves 1RY455B &amp; 455C closed (NOTE: valves are failed closed due to loss of IA)</li> <li>PORVS 1RY455A and 1RY456 closed (NOTE: PORVs isolated due to faults earliet)</li> <li>RCS temperature control</li> <li>Check RCP status</li> <li>If RCP running, check RCS Tave trending to 557°F, OR if NO RCP running, check RCS CL temperatures stable at or trending to 557°F.</li> <li>Check status of RCPs</li> <li>If any running, apply trip criteria <ul> <li>HHSI flow &gt;50 gpm on 1FI-917</li> <li>SI flow &gt; 100 gpm on 1FI-918/922</li> <li>RCS pressure &lt; 1425 psig</li> </ul> </li> </ul>	

Scenario	No: 1-2	Event No. 8	Page 21 - 28 of _ 32	
Event De	escription:	Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pressure to drop with respect to Turbine Building and Aux Building. Continue with actions of BEP-0		
Time	Position	Applicant's Actions or	Behavior	
	BOP/°JS	If RCPs stopped, place steam dumps in STEAM PRESSU	STEAM PRESSURE Mode	
	BOP/US	<ul> <li>Check if SGs secondary pressure boundaries are intact</li> <li>NO SG pressure decreasing in an uncontrolled mannel</li> <li>NO SG completely depressurized</li> <li>Determine secondary boundary intact</li> </ul>	er	
	CREW	<ul> <li>Check if SG Tubes intact</li> <li>SJAE GS exhaust 1PR27J Grid 1 1PS027 &lt; ALERT</li> <li>SG Blowdown 1PR08J Grid 1 1PS108 &lt; ALERT AL</li> <li>Main Steam: 1RT-AR022 &amp; 1RRT-AR023 for each 4AC322/323, 4AD422/423 &lt; ALERT ALARM</li> <li>Main Steam Penetration 1A/1D 1RT-AR024 Grid 4</li> <li>Main Steam Penetration 1B/1C 1RT-AR024 Grid 4</li> </ul>	ALARM .ARM SG, Grid 1 4AA122/123, 4AB222/223, 4AA124 < ALERT ALARM 4AB124 < ALERT ALARM	
	CREW	<ul> <li>Diagnose SGTR</li> <li>Secondary area rad monitors levels increasing or in A</li> </ul>	LERT	
	US	<ul> <li>Transition to BEP-3 "STEAM GENERATOR TUBE RUP</li> <li>Direct initiation of Critical Safety Function Status Trees n</li> </ul>	PTURE" (Sec page 24.) nonitoring.	

Scenario	No: 1-2	Event No. 8		Page 21 - 28 of 3
Event Description:		Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pressure to drop with respect to Turbine Building and Aux Building. Continue with actions of BEP-0.		
Time	Position	Applicant's Actions or Behavior		
		BOP VC-14 ACTIONS. NOTE: U	US/BOP may direct that a dir	fferent operator perform actions.
and a second second second	BOP	Restore pressure by performing action	ons of BOP VC-14	
	BOP	<ul> <li>BOP VC-14 ACTIONS. NOTE: C</li> <li>Restore pressure by performing action</li> <li>CHECK position indication of the system:</li> <li>0A/0B TRAIN</li> <li>DAMPER #</li> <li>0VC17Y/0VC01Y</li> <li>0VC19Y/0VC03Y</li> <li>0VC20Y/0VC04Y</li> <li>0VC18Y/0VC02Y</li> <li>0VC24Y/0VC08Y</li> <li>0VC281Y/0VC282Y</li> <li>0VC312Y/0VC16Y</li> <li>0VC312Y/0VC16Y</li> <li>0VC25Y/0VC09Y</li> <li>0VC23Y/0VC172Y</li> <li>0VC43Y/0VC44Y</li> <li>0VC21Y/0VC05Y</li> <li>0VC22Y/0VC06Y</li> </ul> Determine/report 0VC24Y/0VC08Y Take differential controller to MAND	JS/BOP may direct that a dif ons of BOP VC-14 the operating train dampers at NORMAL POSITION OPEN CLOSED CLOSED CLOSED OPEN CLOSED OPEN CLOSED OPEN OPEN CLOSED OPEN CLOSED OPEN CLOSED CLOSED OPEN OPEN CLOSED CLOSED	fferent operator perform actions. OPM02J for abnormal alignment of the MAKEUP POSITION OPEN OPEN CLOSED CLOSED CLOSED CLOSED CLOSED CLOSED CLOSED CLOSED OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN OPEN O

Scenario	No: 1-2		Event No. 8		Page 21 - 28 of 32
Event De	escription:	Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pressure to drop with respect to Turbine Building and Aux Building. Continue with actions of BEB 0			
Time	Position	Applicant's Actions or Behavior		ons of DEP-0.	
BOP (cont.)		<ul> <li>CHECK the :</li> <li>0A Train</li> <li>0B Train</li> </ul>	shutdown train isolati 1: Return fan 0VC17 1: Return fan 0VC013	ion dampers indicate CLOSED at 0PM02. Y, Supply fan 0VC33Y Y, Supply fan 0VC172Y	J.
		CHECK the area problems:	differential pressure i	indicators to determine which area or area	as have the low pressure
		LOCATION • 0PM02J • 0PM02J • 0VC01JA • 0VC01JA • 0VC01JB • 0VC01JB • 0VC01JB • 0VC01JB • 0VC01JB	INDICATOR OPDI-VC037 OPDI-VC038 OPDI-VC037A OPDI-VC037C OPDI-VC037D OPDI-VC038A OPDI-VC038B OPDI-VC038D	AREA WP INDICATED Control Room - Aux Bldg Control Room - Turbine Bldg Control Room - Turbine Bldg Control Room - #1 Computer Room 0A VC HVAC Rm - Div 11 Misc. Elect. Equip. Rm Control Room - #2 Computer Room Control Room - Lower Cable Spreading Rm. 0B VC HVAC Rm - Div 21 Misc. Elect. Equip. Rm	NORMAL READING > +0.125" > +0.125" > +0.125" > +0.125" > +0.125" > +0.125" > +0.125" > +0.125" > +0.125"
		REP-3 ACTION	controller to MANUA	AL and adjust dampers open to restore d/P	? > +0.125" H2O
	US	Direct operator ac	tions of BEP-3.		
	RO/US	Check status     If any ru     O HHS     O SI fl     O RCS	of RCPs nning, apply trip crite If flow >50 gpm on 1 ow > 100 gpm on 1F pressure < 1425 psig	eria FI-917 FI-918/922 g	

Scenario No: 1-2		Event No. 8	Page 21 - 28 of 32
Event De	scription:	Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pressure to drop with respect to Turbine Building and Aux Building. Continue with actions of BEP-0	
Time	Position	Applicant's Actions or	Behavior
	BOP/US	<ul> <li>If RCPs stopped, place steam dumps in STEAM PRESSU</li> </ul>	JRE Mode
	CREW	<ul> <li>Identify ruptured SG <ul> <li>Unexpected rise in NR level</li> </ul> </li> <li>Main steamline rad monitor <ul> <li>RT-AR022 Grid 1 4AD422</li> <li>RT-AR023 Grid 1 4AD423</li> </ul> </li> <li>Main Steam Penetration 1A/1D 1RT-AR024 Grid 4 4</li> <li>High activity for any SG sample <ul> <li>Reset CNMT isol Phase A</li> <li>Notify Chem to locally sample</li> <li>Open SG blowdown sample valves at Chem request</li> </ul> </li> </ul>	AA124 < ALERT ALARM
	CREW	Identify/report 1D SG as ruptured	
	BOP/US	<ul> <li>Isolate flow from rupture SG</li> <li>SG PORV MS018D in AUTO</li> <li>Check SG PORV MS018D closed</li> <li>Verify closed when SG pressure &lt; 1115 psig</li> <li>Verify SG blowdown valves closed unless open for sam</li> <li>SD002C</li> <li>SD002D</li> <li>Close MSIV and MSIV bypass valves for 1D SG</li> </ul>	pling

Scenario	No: 1-2	Event No. 8	Page 21 - 28 of 32
Event De	escription:	Main Control Room (MCP.) differential pressure controller fails caus to drop with respect to Turbine Building and Aux Building. Continu	sing MCR envelope differential pressure
Time	Position	Applicant's Actions or Behavi	or
	BOP/US [CT] E-3A	<ul> <li>Check ruptured SG level</li> <li>&gt; 10%</li> <li>Close AF isol valves</li> <li>AF013D</li> <li>AF013H</li> </ul>	
	RO/US	<ul> <li>Check PZR PORVs</li> <li>Power to PORV Isol valves available</li> <li>US may direct reenergizing PORV Block valve IRY800 10CFR50.54(x) ) by closing breaker MCC 131X2B</li> <li>PORVs closed <ul> <li>RY455A</li> <li>RY456</li> </ul> </li> <li>Reports IRY455 A is open; Ensures Block valve is closed.</li> <li>At least ONE PORV Block valve OPEN <ul> <li>RY8000A</li> <li>RY8000B</li> </ul> </li> <li>Determines PORV Isol valve should NOT be opened.</li> </ul>	0A (US may choose implement A5
	BOP/US	<ul> <li>Check SG secondary boundaries intact</li> <li>Check intact SG levels <ul> <li>NR level ~ 10%</li> <li>Maintain level between 18% and 50%</li> <li>Check NR level NOT increasing in uncontrolled manner.</li> </ul> </li> </ul>	

7/13/98

Scenario	No: 1-2	Event No. 8	Page <u>21 - 28</u> of <u>32</u>
Event De	scription:	Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pressure to drop with respect to Turbine Building and Aux Building. Continue with actions of BEP-0	
Time	Position	Applicant's Actions or Beha	ivior
	RO/US	<ul> <li>Reset SI</li> <li>Reset CNMT isolation</li> <li>Restore Instrument Air to CNMT</li> <li>Determine air CANNOT be restored to CNMT due to IA leak</li> </ul>	
	BOP/US	Verify all AC buses powered from offsite	
	RO/US	<ul> <li>Check if RH stopped</li> <li>RCS pressure &gt;300 psig</li> <li>Stop RH pumps and place in standby</li> </ul>	
	BOP/US	Check 1D SG pressure > 640 psig	
	CREW [CT] E-3B	<ul> <li>Initiate RCS cooldown</li> <li>Determine target temperature based on 1D SG pressure (No</li> <li>Check PZR pressure &lt; 1930 psig</li> <li>If so, block Steamline SI</li> </ul>	ormal CNMT)
	BOP/US	<ul> <li>Dump steam from intact SGs at maximum rate         <ul> <li>Steam dumps in STEAM PI/ESSURE Mode</li> <li>If steam dumps NOT avail: ble, use SGA, B, C PORVs</li> </ul> </li> <li>Check average CETC temperatures &lt; value determined at Check suptured SG processors stells as increasing.</li> </ul>	bove
		<ul> <li>Check ruptured SG pressure stable or increasing.</li> </ul>	

Scenario	No: 1-2	Event No. 8	Page 21 - 28 of 32
Event Description:		Main Control Room (MCR) differential pressure controller fails causing MCR envelope differential pr to drop with respect to Turbine Building and Aux Building. Continue with actions of BEP-0.	
Time Position Applicant's Actions or Behavior		avior	
	CREW	Check RCS subcooling acceptable per ATTACHMENT A &	1BEP 3-2
		SEE Event 9	

Scenario	No: 1-2	Event No. 9	Page 29 - 32 of 32
Event D	escription:	Power is lost to PORV Block valve 1RY8000A while valve is closed. This results in a loss of ALL Pzr pressure control for depressurization, except for MANUAL control of Pzr heaters.	
Time	Position	Applicant's Actions or Behavior	
	CUE	1RY8000A control/position lights extinguish 1RY8000A remains closed	NUMBER OF THE OTHER PROPERTY OF THE
	RO/US	<ul> <li>Depressurize RCS <ul> <li>Use PZR sprays</li> </ul> </li> <li>Determines normal sprays NOT available due to loss of IA</li> <li>Depressurize RCS <ul> <li>PZR PORV at least ONE available</li> </ul> </li> <li>Determine either PORVs NOT available OR PORV open and Block Valve a <ul> <li>Attempt to open PORV Block Valve IRY8000A, if directed</li> </ul> </li> <li>Determine/report Block Valve is NOT OPEN and NOT available</li> </ul>	wailable
	US	Transition to 1BCA-3.3 "SGTR WITHOUT PRESSURIZER PRESSURE CO	ONTROL"
	1	BCA-3.3 ACTIONS	
	US	Direct operator actions of BCA-3.3.	
	BOP/US	<ul> <li>Check ruptured SG NR level &lt; 88%</li> <li>If level &gt; 88% go to step 7 (NOTE: Marked + below on page 31.)</li> </ul>	
	RO /US	<ul> <li>Try to establish normal Pzr Spray         <ul> <li>Check RCP status running in either loop D or loop C</li> </ul> </li> <li>Determine normal spray NOT available</li> <li>Try to establish PZR PORV         <ul> <li>Manually open or locally open one PORV isol valve</li> <li>Determine PORV CANNOT be operated</li> </ul> </li> </ul>	

Scenario No: 1-2		Event No. 9 Page 29 - 32 of	
Event De	escription:	Power is lost to PORV Block valve 1RY8000A while valve is closed. This results in a loss of ALL Pzr pressure control for depressurization, except for MANUAL control of Pzr heaters.	
Time	e Position Applicant's Actions or Behavior		
	RO/US (cont.)	<ul> <li>Try to establish Aux Spray</li> <li>Both SI pumps running</li> <li>At least one CENT CHG pump running</li> <li>Reset SI recirc sump isol valves 1SI8811A/1CV8110, 1SI881B/1CV8111</li> <li>Reset SI CENT CHG pump miniflow isol valves 1CV8114, 1CV8116</li> <li>Establish 70 gpm charging flow <ul> <li>Verify CENT CHG miniflow valves open 1CV8810, 1CV8111, 1CV8114, 1CV8116</li> <li>Throttle CENT CHG pumps flow control 1CV121 to 5% open</li> <li>Open charging line CNMT isol valves 1CV8105, 1CV8106</li> <li>Close CENT CHG pumps to CL injection isol valves 1SI8801A/B</li> <li>Throttle 1CV182 to maintain seal injection flow between 8 gpm &amp; 13 gpm per RCP</li> <li>Throttle 1CV121 to establish 70 gpm charging flow</li> </ul> </li> <li>Establish aux spray flow <ul> <li>Open PZR Aux Spray flow 1CV8145</li> </ul> </li> </ul>	
	BOP/US	<ul> <li>Check intact SG levels</li> <li>NR level &gt;10%</li> <li>Maintain level between 18% and 50%</li> <li>Check NR leve! NOT increasing in uncontrolled manner.</li> </ul>	
	RO /US	Check PZR level > 4%	

Scenario	No: 1-2	Event No. 9	Page 29 - 32 of 32
Event De	escription:	Power is lost to PORV Block valve 1RY8000A while valve is closed. This results in a loss of ALL Pzr pressure control for depressurization, except for MANUAL control of Pzr heaters.	
Time	Position	Applicant's Actions or Behavi	ior
	CREW	<ul> <li>Check if ECCS flow can be terminated</li> <li>RCS Subcooling acceptable         <ul> <li>Iconic Display</li> <li>OR</li> <li>ATTACHMENT A, FIGURE 1BCA 3.3-1</li> </ul> </li> </ul>	
		<ul> <li>Secondary heat sink</li> <li>Total feed flow to SGs &gt; 500 gpm available</li> <li>OR</li> <li>OR level in at least ONE intact SG &gt; 10%</li> </ul>	
		<ul> <li>Check RCPs running</li> <li>If NONE running, check Plenum region of RVLIS indi</li> <li>If &lt; 15%, DO NOT stop ECCS Pumps and go to 1BCA</li> <li>Check ruptured SG level NR level increasing in uncontrolle</li> <li>If NOT, DO NOT stop ECCS pumps and return to step control capabilities for depressurization.</li> </ul>	cates > 15% A-3.1 ed manner OR offscale high as to attempt to establish PZR pressure
	CREV [CT] ECA-3.3 -A	<ul> <li>Stop ECCS Pumps and place in standby</li> <li>SI Pumps</li> <li>All but ONE CENT CHG pump</li> </ul>	
	RO/US	<ul> <li>Establish 70 gpm charging flow</li> <li>Reset SI recirc sump isol valves 1SI8811A/1CV8110, 1SI88</li> <li>Reset SI CENT CHG pump miniflow isol valves 1CV8114,</li> <li>Verify CENT CHG miniflow valves open 1CV8810, 1CV81</li> </ul>	B1B/1CV8111 1CV8116 111, 1CV8114, 1CV8116
Scenario	No: 1-2	Event No. 9	Page 29 - 32 of 32
----------	------------------	-------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	-----------------------------------------------------------------------------
Event De	escription:	Power is lost to PORV Block valve 1RY8000A while valve pressure control for depressurization, except for MANUAL	e is closed. This results in a loss of ALL Pzr control of Pzr heaters.
Time	Position	Applicant's Actions	or Behavior
	RO/US (cont.)	<ul> <li>Throttle CENT CHG pumps flow control 1CV121</li> <li>Open charging line CNMT isol valves 1CV8105,</li> <li>Close CENT CHG pumps to CL injection isol valves</li> <li>Throttle 1CV182 to maintain seal injection flow b</li> <li>Throttle 1CV121 to establish 70 gpm charging flow</li> </ul>	l to 5% open 1CV8106 ves 1SI8801A/B between 8 gpm & 13 gpm per RCP
	CREW	<ul> <li>Verify ECCS flow NOT required</li> <li>RCS Subcooling acceptable         <ul> <li>Iconic Display</li> <li>OR</li> <li>ATTACHMENT A, FIGURE 1BCA 3.3-1</li> </ul> </li> <li>Check RCPs running         <ul> <li>If NONE running, check Plenum region of RV</li> <li>If &lt; 15%, manually operate ECCS equipment</li> </ul> </li> </ul>	VLIS indicates > 15% as necessary and go to 1BCA-3.1
		SCENARIO TERMINATED	

# SHIFT MANAGER'S TURNOVER

### **TODAY ONCOMING SHIFT**

UNIT 1 STATUS	UNIT 1 MAJOR OOS's
MODE	<ul> <li>PZR pressure channel PT-458</li> <li>PORV 1RY456 with PORV Block Valve 1RY8000B closed and deenergized.</li> <li>Heater Drain Pump 1A is out of service to meggar motor leads.</li> <li>250' Meteorological Tower instruments are OOS.</li> </ul>
LCOAR ENTRIES PREVIOUS 48 HRS	UNIT 1 MAJOR SURVEILLANCES
LCOARs have been entered for 1PT458 and PORV 1RY456. LCOAR has been entered for 250' Met Tower.	
UNIT 1 IN PROGRESS	UNIT 1 AND COMMON PENDING
The National Weather Service has declared a high wind warnings in effect for Stephenson, Winnebago and Ogle counties for the next 2 hours.	
SCHEDULED ACTIVITY CONFLICTS	

BAP 335-1T1 Revision 7

## SHIFT MANAGER'S TURNOVER

UNIT 2 STATUS	UNIT 2 MAJOR OOS's
MODE 1	
%Pwr	
MWe 1178	
Max Load/Power 100%	
Min Load/Power 750 MW	
Max Ramp Rate 2 MW/Min	
Desired Delta I. Target	
Unit on EGC NA	
Boron @ 535	
Control Bank D @ 213	
LCOAR ENTRIES PREVIOUS 48 HRS	UNIT 2 MAJOR SURVEILLANCES
LINIT 2 IN PROCRESS	UNIT 2 DENDING
ONT 2 IN PROGRESS	ONIT 2 PENDING
SCHEDULED ACTIVITY CONFLICTS	
SCHEDOLED ACTIVITY CONTLICTS	

## SHIFT MANAGER'S TURNOVER

ADMINISTRATIVE			
TEMPORARY PROCEDURES/ALTS	1	nte en transmission de la seconda de contrado de la decidade de contra de polício esta de la decidade seconde e	
DAILY ORDERS/SPECIAL OP. ORDERS	1	and a second	
DAILY MANNING SCHEDULE	1	and a second	
CONTROL ROOM ROUNDS			
(GSEP/LER/DVR/ENS)			
MATERIAL CONDITIONING		menten ar entre rescuelle menter entre arrente arrente arrente arrente arrente arrente arrente arrente arrente	
RWP'S/RELEASES/PRECAUTIONS/ALARA		an a	
INFREQUENT EVOLUTION ACTIVITIES		ren minister and a state of the second state of the second state of the second state of the second state of the	
SPSO/DIVISION LD	Alternate	BPO Outside # 815-727-59	02/5903 Tie # 8-565-5902/5903
UNIT 1 COMMENTS		UNIT COMMON C	OMMENTS
S/G B/D returning to Condenser per SPP	Non-realized to the second period second second	CW Blowdown Lineup	U-2
		FC Cleanup	U-1
·		FC Cooling	U-1
		50K DO Tank	Certified
		125K DO Tank	Certified
		Aux Steam	U-1
		U-0 CC HX	U-1
	Call Million Prototoly Name and an and so of	NAMES AND ADDRESS OF ADDRESS A	
UNIT 2 COMMENTS		GENERAL COMM	ENTS
Caution Cards		Abnormal Position	ned Components
CCNUM EPN		CCNUM EPN	Abnormal Position

SHIFT: LAST TO PRESENT TIME: NOW DATE: TODAY OFFGOING ONCOMING

Simulation	Facil	ty Byron 1 & 2	Scenario No.:	3	Op Test No.: 1	
Examiners:			-	Operators:		SRO
			_	-		RO
			_	_	NAMES AND ADDRESS ADDR	BOP
Objectives:	In	accordance with plant pr	ocedures:			
	1.	increase reactor power.				
	2.	respond to a trip of one	feedpump.			
	3.	respond to a failed prin	hary RTD			
	4.	respond to failure of dig	gital rod position ind	dication channel.		
	5.	respond to failed steam	flow channel.			
	6.	respond to TWO dropp	ed control rods with	failure of the react	or to trip.	
	7.	respond to failure of ru	nning Charging Pun	np.		
Initial Cond	8. lition	cS pump trips. 1. IC-190, Reactor	rge break LOCA wł Power 67%, MOL, I	BGP 100-3, step F.	Lase B actuation fails to ope	rate and running
		2. 1B CV Pump run	nning; 1A CV Pump	in standby.		
		3. 1A Containment	Spray pump OOS.			
		4. 1A Motor driven	Feedwater Pump O	OS		
		5. 250' Meteorologi	cal Tower OOS.			
Turnover:	1.	Reactor power is 67% w	ith power increase to	o continue followin	g turnover at 5MW/hr.	
	2.	Unit 2 is operating at 10	0% power.			
	3.	1B CV Pump is currently	y in service checking	g for post-test leaka	ge. 1A CV Pump is in stan	dby.
	4.	1A Containment Spray p the pump is expected to	oump is OOS due to be release to service	high vibrations due in 24 hours.	ring testing. An AR has been	en initiated and
	5.	1A Feedwater Pump is C NOT be ready to return t	OS with electrical s o service this week.	upply cleared due t	o electrical wiring problem	Pump will
	6.	The 250 foot Meteorolog	ical Tower is out of	service.		
	7.	Thunderstorm warning i	s in effect for Stephe	enson, Winnebago	and Ogie counties for the ne	ext 6 hours.

-

No	Malf.		Event	Event
140.	INU.		Typer	Description
Preload	RP01	С	RO SRO	Reactor protection system failure of automatic trip
Preload	CS01A			1A Containment Spray pump OOS.
Preload	OR ZAOOUREM OR ZAOOUREM OR ZAOOUREM	002P2, 012P1, 012P2,	0 0 0	250' Met Tower OOS
	OR ZDUCSOIPB,			Allared - NOT NOT DED He on High High Containment
Preload	TRIP (NOTE 1)			Pressure
		R	SRO RO	Raise Reactor Power (Fringmen) to
1		N	BOP	Raise reactor power (5 MW/min) of Set and Raise Turbine Load,
2	FW02A	c	BOP SRO	1B (turbine driven) Main FW Pump trips.
3	RX18A, 630	1	RO SRO	Tcold RTD fails high resulting in higher Tavg input
4	RD13AK10	С	RO SRO	A DATA A failure occurs for rod K10 when rod motion occurs.
9	RX03B, 4.8 MLBH	I	BOP	Steam Picked Net NEEDED the SGWLC fails unscale
6	RD02K10 RD02F06 (RP01)	м	RO BOP SRO	TWO dropped control rod – Failure of the reactor to trip on negative rate trip
7	CV01B	С	RO SRO	Running Charging Pump trip (to occur on reactor trip).
8	TH06, 50,000 to 400,000	М	RO SRO BOP	Large break LOCA inside containment. (Put on a 5 min. ramp for containment pressure to rise above HI HI setpoint.)
	(OR)		RO BOP	Failure of Phase B And Containment spray system to actuate automatically.
9	CSOIB	C	SRO	1B CS Pump trips after starting (approx. 30 sec).

\*(N)ormal,

(R)eactivity (I)nstrument,

(C)omponent, (M)ajor Transient

NOTE 1: Trigger is set up on ZDI1CS01PB using - 2DICIPBA1, 2DICIPBA2, 2DICIPBA3, 2DICIPBA4

7/13/98

### SCENARIO #1-3

#### SCENARIO SUMMARY:

The scenario begins with power at 67% with the 1A Containment Spray pump out of service due to high vibration during the last run. The 250' elevation Meteorological Tower Instrumentation has failed and action of TRM 3.3.c is being tracked. Power is to be raised at 5 MW/hr.

After reactor power is increased at least 5%, the 1B Main Feedwater will trip. The crew should respond per BOA SEC-1 and reduce power to within the capacity of one feedpump (540 to 600 MWe or ~ 60% power).

Prior to power stabilization following the FW Pump trip, a loop Tcold RTD will fail high resulting in increased auctioneered high Tave. This will result in demand inward motion of the control rods. The crew will perform actions of BOA ROD-1 due to the rod motion, and will be directed to BOA INST-2, ATTACHMENT A. Coincident with the RTD failure, a DATA A failure (DRPI coil fails open) will occur on CBD rod K10. Alarm Response procedures and/or BOA ROD-3 will be entered. SRO will review Technical Specification 3.3.1, Table 3.3.1-1, Function 6 & 7 (Condition D) and 3.1.7 (Condition A).

Following completion of actions for taking the failed RTD instrument out of service, the 1A SG selected flow channel instrument fails high. This results in indication of increased steam flow and initial opening of the 1A SG Feed Reg Valve to attempt to match feed flow to steam flow An equilibrium level should be reached if manual control is not taken expediently. The operator will perform the actions of BOA INST-2, Attachment H.

Following stabilization of SG levels after control is returned to auto, TWO rods trip into the core. The reactor fails to automatically trip on the PR Negative Rate trip and the operator will have to manually trip the reactor (also required on drop of more than one rod). The running Charging Pump trips coincident with the reactor trip, and the operator must start the 1A CV Pump to provide charging flow. After performing the first FOUR steps of BEP-0, transition will be made to BEP ES-0.1.

After Step 10 is performed in BEP ES-0.1, a large break LOCA will occur requiring BEP-0 to be re-entered and actions of BEP-0 and BEP-1 to be performed. Phase B will fail to occur and containment spray will fail to initiate (i.e., the CS pumps will NOT start) requiring the crew to manually actuate CS and Phase B Isolation. Following auto alignment and start of 1B CS pump, that pump will trip approximately 30 seconds later. The scenario ends with completion of alignment of the ECCS and CS for cold leg recirculation in BEP ES-1.3.

#### **ERG-Based Critical Tasks:**

- 1. EP-0 A: Manually trip the reactor from the Control Room before transition to ES-0.1.
- EP-0 E: Manually actuate at least the minimum required complement of containment cooling equipment before an extreme (red path) challenge develops to the containment CSF.
- ES-1.3 A: Transfer to cold leg recirculation and establish ECCS recirculation flow that at least meets ' ussumptions of the LOCA analysis (one train).

Scenario	No: 1-3	Event No. 1 Page 4 - 5 of 33				
Event Description:		Normal power increase at 5 MW/min				
Time	Position	Applicant's Actions or Behavior				
	US	Implement actions of 1BGP 100-3, Step F.61:				
	US	Direct increase to 100% power at 5 MW/minute.				
	CREW	Review applicable Precautions, and Limitations and Actions.				
	RO	Verify rod position and boron concentration.				
		<ul> <li>Initiate dilution, if required. (BOP CV-5)</li> <li>Place MU MODE CONT SWITCH to STOP position.</li> <li>Set MU MODE SELECT to DIL or ALT DIL position.</li> <li>Set 1FK-111 PW/Total Flow Cont to desired dilution rate.</li> <li>Verify 1CV111A in AUTO</li> <li>Set 1FY-0111 Primary Water Control Preset Counter to desired volume.</li> <li>Verify 1CV11B &amp; 1CV110B in AUTO</li> <li>Place MAKE-UP CONTROL Switch to START</li> <li>Verify proper operation of valves &amp; PW pump (CV111A &amp; 111B open, PW pump is running, CV110B opens [if ALT DIL])</li> <li>Verify PW flow on recorder</li> <li>Verify B/U Heaters ON and spray valves 1RY455B/C modulates OPEN.</li> </ul>				
	BOP	<ul> <li>Initiate turbine load increase:</li> <li>DEPRESS the LOAD RATE MW/MIN Pushbutton</li> <li>VERIFY/ENTER the desired load rate of 5.0</li> <li>DEPRESS the REF Pushbutton</li> <li>Using the number Pushbuttons, SET in 1050 MW on the REFERENCE DEMAND window</li> <li>When ready to begin load increase, depress GO</li> <li>Verify load increases.</li> </ul>				

Scenario	No: 1-3	Event No. 1	Page 4 - 5 of 33
Event De	scription:	Normal power increase at 5 MW/min	an manada da manana ana ana ana ana ana ana ana ana
Time	Position	Applicant's Actions or Behavior	a na manana manana ana ana ana ana ana a
	RO	<ul> <li>Monitor power increase:</li> <li>Monitor reactor power, Tave</li> <li>Verify rods move in AUTO to maintain Tave within ± 2.0°F of Tref.</li> <li>If diluting:</li> <li>Monitor VCT level</li> <li>Verify RCS concentration decreasing</li> <li>Monitor Primary Water Control counter countdown.</li> <li>Verify dilution auto stops at preset value.</li> <li>Return Reactor Makeup System to blended flow for current boron concentration.</li> </ul>	

Scenario	No: 1-3	Event No. 2 Page <u>6-10</u> of	33
Event De	escription:	Main Fed Pump 1B trips. Load must be reduced to approximately 60% (700 MWe) in order to ensure feed flow requirements are within capacity of ONE pump.	1
Time	Position	Applicant's Actions or Behavior	
	CUE:	Annunciators (1-16-B1) FW PUMP 1B TRIP (1-15-A4/B4/C4/D4) S/G 1_ FLOW MISMATCH FW FLOW LOW Trip of 1B FW Pump Lowering FW flow FW Pump 1C speed increase in AUTO	EPCONS.
	US/BOP	Identify/report trip of FW Pump 1B.	
	US	Implement BOA SEC-1 "Secondary Pump Trip", ATTACHMENT A and direct operator action.	
	BOP/US	<ul> <li>Perform actions of BOA SEC-1 as directed:</li> <li>Close recirc valve 1FW012B</li> <li>Check Turbine load &gt; 700MWE</li> <li>Check at least ONE FW Pump running</li> <li>Determine/report 1C FW Pump running</li> <li>Reduce turbine load <ul> <li>Depress TURBINE RUNBACK pushbutton</li> <li>Check turbine load decreasing</li> </ul> </li> </ul>	
	RO/US	<ul> <li>Verify rod control in AUTO</li> <li>Initiate boration as necessary</li> </ul>	
	BOP/US	<ul> <li>Raise FW Pump Suction Pressure</li> <li>(NOTE: Annunciator alarm 1-16-E1 may NOT be lit</li> <li>If FW PUMP NPSH LOW (1-16-E1) alarm lit</li> <li>Verify open CP bypass valves 1CD210A/B</li> <li>Start standby CD/CB Pump</li> </ul>	

-

\*

Scenario	No: 1-3	Event No. 2 Page 6-10 of 3		
Event De	escription:	Main Fed Pump 1B trips. Load must be reduced to approximately 60% (700 MWe) in order to ensure feed flow requirements are within capacity of ONE pump		
Time	Position	Applicant's Actions or Behavior		
	BOP/US (cont.)	<ul> <li>Verify HDP discharge valve 1HD046B responding as necessary</li> <li>Verify CB pump recirc valves 1CB113A-D closed</li> <li>Close CD Pump recirc valve 1CD152</li> <li>Open GS condenser bypass valves 1CD157A/B</li> <li>Restore Feed flow</li> <li>Determine FW Pump 1A NOT available</li> <li>Check feed flow restored <ul> <li>Feed flow &gt; Steam flow</li> <li>Stop turbine runback</li> <li>Depress TURBINE RUNBACK pushbutton</li> <li>Depress turbine HOLD pushbutton</li> </ul> </li> <li>Check feed flow stable <ul> <li>Check feed flow stable</li> <li>SG levels stable at or trending to NORMAL</li> <li>FW PUMP DSCH FLOW HIGH alarm (1-16-D2) NOT lit</li> </ul> </li> </ul>		
	CREW	<ul> <li>Evaluate Plant Status         <ul> <li>Check control rods &gt; RIL</li> <li>Check ΔI within TARGET BAND</li> <li>Check TURBINE RUNBACK pushbutton NOT lit                 <ul> <li>If it is lit, US may direct reset, depressing TURBINE RUNBACK button</li> </ul> </li> <li>Check LOSS OF TURBINE LOAD INTLK C7 Bypass Permissive light (1-BP-4.6) NOT lit</li> </ul> </li> </ul>		

Scenario	No: 1-3	Event No. 2 Page <u>6-10</u> of
Event De	escription:	Main Fed Pump 1B trips. Load must be reduced to approximately 60% (700 MWe) in order to ensure feed flow requirements are within capacity of ONE pump.
Time	Position	Applicant's Actions or Behavior
	BOP/US	<ul> <li>Restore Plant conditions</li> <li>Verify recirc valve 1FW012C in MODULATE</li> <li>Verify valve controls in AUTO for running eqpt</li> <li>HD Pump disch</li> <li>CB Pump recircs</li> <li>CD Pumps recirc</li> <li>GS condenser bypass</li> </ul>
		<ul> <li>Complete shutdown of PW Pump IB per BOP PW-2a (See below on this page)</li> <li>Shutdown unnecessary CD/CB pump per BOP CD/CB-2 (See below on page 9)</li> <li>Adjust SG blowdown flows and calorimetric inputs</li> <li>Place DEHC feedback loop in service <ul> <li>Impulse</li> <li>MW</li> </ul> </li> <li>Notify Chemistry to monitor secondary chemistry</li> <li>Complete applicable sections of 1BGP 100-4</li> <li>Check power change&gt; 15% in one hour</li> </ul> <li>Determine change was &lt; 15%</li>
		ACTIONS OF 1BOP FW-2a
	BOP	<ul> <li>ENSURE/OPEN the following valves:</li> <li>1GS046A, Stop Vlv Drain Valve, at 1PM04J.</li> <li>1GS047A, Stop Vlv Drain Valve, at 1PM04J.</li> <li>1MS070A, 1B FW PP Hot Reheat Stm Sup Line Drn Vlv. (local)</li> <li>1MS071A, 1B FW PP Hot Reheat Stm Sup Line Drn Vlv. (local)</li> <li>1MS073A, 1B FW PP Hot Reheat Stm Sup AOV Check Vlv Drn Vlv. (local)</li> <li>1MS074A, 1B FW PP Hot Reheat Stm Sup AOV Check Vlv Drn Vlv. (local)</li> </ul>

a

9

4

0

Scenario	No: 1-3	Event No. 2 Page <u>6 - 10 of 33</u>		
Event Description:		Main Fed Pump 1B trips. Load must be reduced to approximately 60% (700 MWe) in order to ensure feed flow requirements are within capacity of ONE pump.		
Time	Position	Applicant's Actions or Behavior		
	BOP (cont.)	<ul> <li>IGS075A, 1B FW PP Chest Drn Vlv. (local)</li> <li>IGS076A, 1B FW PP HP Stop/Gov Vlv Stm Leakoff Vlv. (local)</li> <li>IMS201A, 1B FW Pp Turb MS S/U Sup Hdr Drn Vlv. (local)</li> <li>VERIFY/CLOSE 1FW012B, FW Pump 1B Recirc Valve, at 1PM04J when Turbine speed decreases to 1500 RPM.</li> <li>ENSURE that the Turbine Tripped Indicating Backlight ILLUMINATES.</li> <li>ENSURE the following: <ul> <li>High Pressure Stop Valve Closed Indicating Backlight ILLUMINATED.</li> <li>Low Pressure Stop Valve Closed Indicating Backlight ILLUMINATED.</li> </ul> </li> <li>High Pressure Gov. Valve Closed Indicating Backlight ILLUMINATED.</li> </ul>		
		<ul> <li>Low Press Gov. Valve Closed Indicating Backlight ILLUMINATED.</li> <li>If necessary, ISOLATE IMS072A, FW Pp 1B Hot RHT Stm Sup Isol Vlv, to ensure steam isolation.</li> <li>If necessary, ISOLATE IMS079A, FW Pp 1B MS Supply Isol Vlv, to ensure steam isolation to the FW Pp.</li> <li>ENSURE that FW Pump 1B Turning Gear AUTOMATICALLY ENGAGES when zero speed is indicated.</li> </ul>		
	DOD	ACTIONS OF BOP CD/CB-2		
	BOL	<ul> <li>VERIFY/START the Aux Lube Oil Pump at PM03J for the selected CD/CB Pump.</li> <li>VERIFY/PLACE the CD/CB STBY PUMP SELECT Switch in the OFF position at PM03J.</li> <li>PLACE CD113A/B/C/D, CB Pump Recirc VIv, in the OPEN position for the pump being stopped.</li> <li>STOP CD/CB Pump from panel PM03J.</li> </ul>		

· Carl

Comments:

Street, street

7/13/98

4

Scenario No: 1-3 Event Description:		Event No. 2 Page <u>6 - 10 of 33</u>		
		Main Fed Pump 1B trips. Load must be reduced to approximately 60% (700 MWe) in order to ensure feed flow requirements are within capacity of ONE pump.		
Time	Position	a Applicant's Actions or Behavior		
	BOP	<ul> <li>PLACE CB113A/B/C/D, CB Pump Recirc VIv in the CLOSED position for the pump being stopped.</li> <li>PLACE the STBY PUMP SELECT Switch at PM03J to the desired position, if it is desired to select a Stby Pump.</li> <li>STOP the Lube Oil Pump 5 minutes following the shutdown of the affected CD/CB Pump.</li> </ul>		
	US	Inform SM/Maint of trip of 1B FW Pump		
	US	Inform SM of unit status.		

•

7/13/98

Scenario	No: 1-3	Event No. 3 & 4 Page _11 - 13 of _33		
Event Description:		Tcold RTD fails HIGH on loop A (TE-411B). This results in high Tavg for loop A with a low $\Delta T$ on the same loop. Auctioneered HIGH Tavg is associated with this loop and rods will begin to insert in AUTO to match Tavg with Tref. Coincident with RTD failure, a DATA A failure occurs tor rod K10 on DRPI		
Time	Position	Applicant's Actions or Behavior		
	CUES:	<ul> <li>Annunciators (1-14-A5) LOOP 1A ΔT DEV LOW (1-14-B/C/D3) Loop 1B/C/D TAVE DEV LOW (1-14-D1) TAVE CONT DEV HIGH (1-12-B4) PZR LEVEL CONT DEV LOW</li> <li>Loop 1 Tave indication at top of scale and Loop1 ΔT indication at bottom of scale</li> <li>Rods begin to move inward in AUTO</li> <li>PZR level begins to rise</li> <li>Charging flow control CV-121 throttles open to increase flow</li> <li>Annunciators (1-10-D6) ROD CONT NON-URGENT FAILURE</li> <li>DATA A FAIL LEDs flashing</li> <li>GW LED flashing for rod K10</li> </ul>		
	RO/US	Identify/report failed RTD input/TAVE channel. Diagnose NR Cold RTD failure		
	US	Implement BOA INST-2 "OPERATION WITH A FAILED INSTRUMENT CHANNEL", Attachment A "RCS NARROW RANGE RTD CHANNEL FAILURE" and direct operator action.		
	RO/US	<ul> <li>Place ROD BANK SELECT switch in MANUAL</li> <li>Manually defeat failed RTD channel: <ul> <li>Select LOOP A on TAVE DEFEAT switch</li> <li>Select LOOP A on ΔT DEFEAT switch</li> </ul> </li> <li>Select LOOP B, C or D on ΔT recorder</li> <li>Check Tave-Tref stable and within 1°F <ul> <li>If NOT,</li> <li>Adjust rods</li> <li>Adjust turbine load</li> <li>Adjust RCS boron concentration</li> </ul> </li> </ul>		

.

Scenario	No: 1-3	Event No. 3 & 4 Page 11 - 13 of		
Event Description:		Tcold RTD fails HIGH on loop A (TE-411B). This results in high Tavg for loop A with a low $\Delta T$ on the same loop. Auctioneered HIGH Tavg is associated with this loop and rods will begin to insert in AUTO to match Tavg with Tref.		
Time	Position	Applicant's Actions or Behavior		
	RO/US (cont.)	<ul> <li>Check Pzr level normal &amp; stable</li> <li>If NOT, manually restore to program level</li> </ul>		
	US/RO	<ul> <li>Trip bistables by placing in TEST:</li> <li>TB411G C1-124 BS-1 OPΔT TRIP</li> <li>TB411H C1-124 BS-2 OPΔT RUNBACK</li> <li>TB411C C1-124 BS-3 OTΔT TRIP</li> <li>TB411D C1-124 BS-4 OTΔT RUNBACK</li> <li>TB412G C1-121 BS-2 LOW TAVE</li> <li>TB412D C1-121 BS-1 LO-LO TAVE</li> </ul>		
	RO/US	<ul> <li>Check if rod control can be placed in AUTO:</li> <li>TURBINE LOW POWER INTLK C5 (1BP-5.7) NOT lit</li> <li>Tave-Tref deviation stable and within 1°F</li> <li>If desired, place ROD BANK SELECT switch to AUTO</li> <li>Check P12 Interlock, LO-2 TAVE STM DUMP INTLK P12 (1-BP-5.4) NOT lit</li> </ul>		
	US	<ul> <li>Check Technical Specifications:</li> <li>3.3.1 - Rx Trip Inst. Table 3.3.1</li> <li>FU 6(ΟΤΔΤ): Req Channels 4 - CONDITION D, Ensure only ONE channel inop or restore to on one inop within 1 hour, place inop channel in TRIP within 6 hours</li> <li>FU 7(OPΔT): Req Channels 4 - CONDITION D, Ensure only ONE channel inop or restore to on one inop within 1 hour, place inop channel in TRIP within 6 hours</li> <li>3.3.2 - ESFAS Inst. Table 3.3.2-1; FU 8.c TaveLow-2 P-12: Required channels 3, satisfied. NO ACTION</li> </ul>		

Scenario	No: 1-3	Event No. 3 & 4	Page _11 - 13 of _33
Event Description:		Tcold RTD fails HIGH on loop A (TE-411B). This results in high Tavg for loop A with a low $\Delta T$ on the same loop. Auctioneered HIGH Tavg is associated with this loop and rods will begin to insert in AUTO to match Tavg with Tref. Coincident with RTD failure, a DATA A failure occurs for rod K10 on DRPI	
Time	Position	Applicant's Actions or Behavior	
	US/RO	Determine/report failure of DRPI DATA A for	control rod K10
	RO/US	<ul> <li>Perform actions of BAR 1-10-D6:</li> <li>Check SER Printout for Point 2150; If in a</li> <li>CHECK the front of the DRPI system FAILURE" LED</li> <li>PLACE the "ACCURACY MODE" switch position</li> <li>(NOTE: Window 1-10-D6 will remain in alarr</li> </ul>	llarm display panel for a "Data A FAILURE" or "Data B (S106) on the back of the DRPI display panel to B ONLY n until the system is returned to the "A + B" accuracy mode.)
	US	Inform SM/Maint of Loop A Cold Leg RTD fai Inform SM/Maint of DRPI DATA A failure for	lure. rod K10.
	US	Inform SM of unit status/potential GSEP event.	

Scenario	No: 1-3	Event No. 5
Event De	NO. 1-5	Event No. 5 Page 14 of 33
crem ossenption.		Fed Reg valve, 1FW510. The Feed Reg valve will open due to the steam flow/feed flow mismatch.
Time	Position	Applicant's Actions or Behavior
	CUE:	<ul> <li>Annunciator (1-15-A4) S/G 1A FLOW MISMATCH FW FLOW LOW</li> <li>FT-513 indication reading high (4.8 x 10<sup>6</sup>)</li> <li>1FW510 throttling open</li> <li>FW flow increasing</li> <li>SG level increasing above program</li> </ul>
	BOP/US	<ul> <li>Identify/report steam flow channel FT-513 failure</li> <li>Take MANUAL control of 1FW510 and balance Feed flow with Steam flow to stabilize SG level, as necessary.</li> </ul>
	US	Implement BOA INST-2 "OPER ATION WITH A FAILED INSTRUMENT CHANNEL", Attachment H "STEAN FLOW CHANNEL FAILURE" and direct operator action.
	BOP/US	<ul> <li>Check affected SG levels normal.</li> <li>If NOT,</li> <li>Place reed reg value in manual</li> <li>Vorify adequate feedwater ΔP</li> <li>Restore SG level to a stable condition A</li> <li>Select operable steam flow channel FT-512</li> <li>Establish AUTO level control</li> <li>Verify steam pressure channels PT-514 and PT-515 normal</li> </ul>
/	US	Inform SM/Maint of failure of SG. A steam flow channel FT-513
/	US	Inform SM of unit status/potential GSEP event.

Scenario	No: 1-3	Event No. 6 & 7 Page 15 - 18 of 33
Event De	scription:	TWO control rods, K10 and F6, drop into the core. A negative rate on at least TWO channels of Power Range NIs which should generate a reactor trip. AUTOMATIC trip will NOT occur and operator will be required to manually trip the reactor. Coincident with the reactor trip, the running CENT CHG pump trips. The operator will be required to manually start the standby CENT CHG pump (1A)
Time	Position	Applicant's Actions or Behavior
	CUE	<ul> <li>Annunciator (1-10-±6) ROD AT BOTTOM (1-10-C3) PRW RNG FLUX RATE RX TRIP ALERT (1-11-E2) PWR RNG FLUX RATE HIGH RX TRIP</li> <li>PR NI indication lowering</li> <li>Decreasing Tave</li> <li>K10 and F6 ROD BOTTOM LEDs lit on DRPI</li> <li>Annunciator (1-9-A3) CHG PUMP TRIP (1-9-D3) CHG LINE FLOW HIGH LOW (1-7-B2) RCP SEAL WTR INJ FLOW LOW</li> <li>Trip indication for CENT CHG pump 1B NO charging flow indicated FI-121 Flashing indicated by pressure swings in letdown line PI-131</li> </ul>
	CREW	Identify/report failure of reactor to trip on TWO channels PR NI negative rate trip Identify need to manually trip reactor/manually trip reactor
	US	Direct trip of reactor Implement BEP-0 "REACTOR TRIP OR SI"
	RO [CT] EP-0-A	<ul> <li>Perform immediate operator actions of BEP-0:</li> <li>Manually trip the reactor with switch at 1PM05J OR 1PM06J</li> <li>Check PR channels &lt; 5%</li> <li>Check IR SUR less negative than -0.2 DPM</li> </ul>

Scenario N	lo: 1-3	Event No. 6 & 7 Page 15 - 18 of 3
Event Desc	cription:	TWO control rods, K10 and F6, drop into the core. A negative rate on at least TWO channels of Power Range NIs which should generate a reactor trip. AUTOMATIC trip will NOT occur and operator will be required to manually trip the reactor. Coincident with the reactor trip, the running CENT CHG pump trips. The operator will be required to manually start the standby CENT CHG pump (1A)
Time	Position	Applicant's Actions or Behavior
	BOP	<ul> <li>Verify Turbine Trip</li> <li>Turbine throttle valves closed</li> <li>Turbine governor valves closed</li> <li>Verify power to 4KV busses</li> <li>Bus 141 alive light lit</li> <li>Bus 142 alive light lit</li> </ul>
	CREW	<ul> <li>Determine SI NOT actuated/required</li> <li>SI First OUT annunciator NOT lit (1-11-B1, 1-11-C1, 1-11-D1, 1-11-E1)</li> <li>SI ACTUATED NOT lit (1-BP-4.1)</li> <li>SI Equipment NOT actuated (SI pumps NOT running, CV Cold leg injection SI8801A/B open for emergency boration)</li> <li>PZR pressure &gt; 1829 psig</li> <li>Steamline pressure &gt; 640 psig</li> <li>CNMT pressure &lt;3.4 psig</li> <li>PZR level &gt; 4%</li> </ul>
1	US	<ul> <li>Review immediate operator actions and determine SI not required</li> <li>Transition to BEP ES-0.1 "Reactor Trip Response"</li> <li>Direct initiation of Critical Safety Function Status Trees monitoring.</li> </ul>
]	RO/US	Determine/report trip of running CENT CHG pump 1A

Scenario	No: 1-3	Event No. 6 & 7 Page 15 - 18 of 33	
Event Description:		TWO control rods, K10 and F6, drop into the core. A negative rate on at least TWO channels of Power Range NIs which should generate a reactor trip. AUTOMATIC trip will NOT occur and operator will be required to manually trip the reactor. Coincident with the reactor trip, the running CENT CHG pump trips. The operator will be required to manually start the standby CENT CHG pump (1A)	
Time	Position	Applicant's Actions or Behavior	
	RO/US	<ul> <li>Perform action of BAR 1-9-A3</li> <li>ENSURE suction source to standby Charging Pump.</li> <li>VERIFY/CLOSE 1CV121 Cent Chg Pumps Flow Cont Vlv.</li> <li>START an alternate Charging Pump 1A.</li> <li>PLACE 1CV121, Cent Chg Pumps Flow Cont Vlv, in AUTO.</li> <li>OPEN 1CVLCV459 and 460, Ltdwn Line Isol Vlvs, when PZR level has increased to 17%.</li> <li>OPEN 1CV8149A/B/C, Ltdwn Orif Isol Vlvs, as appropriate.</li> <li>DETERMINE cause of trip; Dispatch operator to locally check CENT CHG pump 1B and electric breaker Bus 142 cubicle 10</li> </ul>	
		BEP ES-0.1 ACTIONS	
	US	Direct operator actions of BEP ES-0.1.	
	CODEW		
	CREW	Announce reactor trip on page.	
	BOP/US	<ul> <li>Verify generator tripped</li> <li>Output breakers open</li> <li>OCB 3-4</li> <li>OCB 4-5</li> <li>PMG output breaker open</li> </ul>	
	RO/US	<ul> <li>Check RCP Status and with RCP(s) running check RCS average temperature stable or trending to 557°F.</li> </ul>	

17

Scenario	No: 1-3	Event No. 6 & 7 Page <u>15 - 18 of 3</u>		
Event Description:		TWO control rods, K10 and F6, drop into the core. A negative rate on at least TWO channels of Power Range NIs which should generate a reactor trip. AUTOMATIC trip will NOT occur and operator will be required to manually trip the reactor. Coincident with the reactor trip, the running CENT CHG pump trips. The operator will be required to manually start the start be stard by CENT CHG pump (1A)		
Time	Position	Applicant's Actions or Behavior		
	BOP/US	<ul> <li>Check FW isolation</li> <li>FW Isolation monitor lights LIT</li> <li>Trip HD Pumps</li> <li>Check total feed flow to SGs &gt; 500 gpm available</li> <li>Check SG blowdown valves SD002 A-H closed</li> </ul>		
	RO/US	<ul> <li>Verify all control rods fully inserted <ul> <li>Checks all rod bottom lights lit</li> </ul> </li> <li>Check Pzr level control <ul> <li>Level &gt; 17%</li> <li>Check charging and letdown in service</li> <li>Check level trending to 25%</li> </ul> </li> <li>Check Pzr pressure control <ul> <li>Press ure &gt; 1829 psig</li> <li>Pressure stable at or trending to 2235 psig</li> </ul> </li> </ul>		
	BOP/US	<ul> <li>Check SG levels <ul> <li>Narrow range levels &gt; 10% in any SG</li> <li>If level in all SG NOT &gt; 10% NR, maintain feed flow &gt; 500 gpm</li> <li>When level is at least one SG &gt; 10% NR, feed flow may be throttled</li> </ul> </li> <li>Control feed flow to maintain SG NR levels between 10% and 50%</li> <li>Verify all AC busses energized by offsite power</li> <li>Transfer Steam Dumps to Steam Pressure Mode <ul> <li>(NOTE: Steam lines may be isolated and if so dumps are unavailable)</li> </ul> </li> </ul>		
		SEE Event 9		
		SEE ENTIR O		

Scenario	No: 1-3	Event No. 8	Page 19 - 21 of 33
Event De	escription:	A LOCA occurs inside CNMT.	
Time	Position	Applicant's Actions or Behavior	
	CUE	<ul> <li>RCS temperature falling</li> <li>PZR level lowering</li> <li>PZR pressure lowering</li> <li>CNMT pressure, temperature &amp; humidity rapidly rising</li> </ul>	
	CREW	Recognize/report indications of LOCA	
		BEF-0 ACTIONS	
	US	Transition to/Implement BEP-0 "REACTOR TRIP OR SI"	
	RO	<ul> <li>Perform immediate operator actions of BEP-0:</li> <li>Verify reactor trip (Previously performed)</li> <li>Rod bottom lights LIT</li> <li>Reactor trip &amp; Bypass breakers open</li> <li>Neutron flux lowering</li> </ul>	
	BOP	<ul> <li>Verify Turbine Trip</li> <li>Turbine throttle valves closed</li> <li>Turbine governor valves closed</li> <li>Verify power to 4KV busses</li> <li>Bus 141 alive light lit</li> <li>Bus 142 alive light lit</li> </ul>	
	CREW	<ul> <li>Determine SI needed/actuated</li> <li>If actuated</li> <li>SI First OUT annunciator lit (1-11-B1, 1-11-C1, 1-11-D1, 1-11-E1)</li> <li>SI ACTUATED lit (1-BP-4.1)</li> <li>SI Equipment actuated (SI pumps running, CV Cold leg injection SI8801A/E</li> <li>Manually actuate SI</li> </ul>	3 open)

Scenario	No: 1-3	Event No. 8	Page 19 - 21 of 33
Event De	escription:	A LOCA occurs inside CNMT.	and a second
Time	Position	Applicant's Actions or Behavior	n en mennen i den mente mente di norman del de la falle e denne la mente e contra de la falle i normania
	CREW	<ul> <li>Recognize ADVERSE CNMT conditions when</li> <li>CNMT pressure &gt; 5psig</li> <li>CNMT rad level &gt; 10<sup>5</sup> R/hr (Grid 4 4AS120 or 4AS121)</li> </ul>	
	RO/US	<ul> <li>Trip RCPs per Operator Action Summary         <ul> <li>CC Water lost to RCP</li> <li>CNMT Phase B actuated</li> <li>ALL of the following exist</li> <li>Controlled RCS cooldown NOT in progress</li> <li>RCS pressure &lt; 1425.psig</li> <li>HHSI flow &gt; 50 gpm OR SI pump discharge flow &gt; 100 gpm</li> </ul> </li> <li>Trip all RCPs when parameters indicate (RCS pressure &amp; SI flow)</li> </ul>	
	BOP/US	<ul> <li>Verify FW isolated</li> <li>FW pumps tripped</li> <li>Isolation monitor lights lit</li> <li>FW pumps disch valves closed (FW002A-C)</li> </ul>	
	RO/US	<ul> <li>Verify ECCS pumps running</li> <li>CENT Chg pumps</li> <li>RH pumps</li> <li>SI pumps</li> </ul>	
	BOP/US	<ul> <li>Verify Phase A isolation - Group 3 Monitor lights lit</li> <li>Verify CNMT Ventilation isolation - Group 6 Monitor lights lit</li> </ul>	

Scenario	No: 1-3	Event No. 8	Page 19 - 21 of 33
Event De	scription:	A LOCA occurs inside CNMT.	Annual Constant Constant and Constant Constant Constant Constant Constant Constant Constant Constant Constant C
Time	Position	Applicant's Actions or Pehavior	Hard Concerning and the submit of the State of the submit of
	BOP/US (cont.)	<ul> <li>Verify AF system:</li> <li>AF 1B pumps running</li> <li>AF isolation valves open (AF13A-H)</li> <li>AF flow control valves throttled (AF005A-H)</li> <li>Verify RCFCs running in LOW SPEED</li> <li>Verify CC Pump 1B running</li> <li>Verify SX Pumps running</li> <li>Check Main Steamline Isolation <ul> <li>Check SG pressure &gt; 640 psig</li> <li>Check CNMT pressure on 1PR-937 OR 1PI-CS934-937 is &gt;8.2 psig</li> </ul> </li> <li>Verify MSIV and MSIV E:pass valves closed</li> </ul>	
		SEE Event 9	

		Not LOUDED			
Scenario	No: 1-3	Event No. 9 Deleved HP - Page 22 - 33 of 33			
Event De	scription:	Phase D isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation CNMT Spray Pump 14 is OOS			
Time	Position	Applicant's Actions or Behavior			
	CUE	<ul> <li>CNMT pressure &gt; 20 psig</li> <li>CS Pump 1B NOT running</li> <li>CS valves position NOT in actuation position</li> <li>Phase B valves position NOT in actuation position</li> </ul>			
	BOP/US [CT] EP-0-E	<ul> <li>Check if CNMT Spray is required</li> <li>CNMT pressure &gt; 20 psig <ul> <li>Check Group 6 monitor lights lit</li> <li>Check Group 6 monitor Phase B lights lit</li> </ul> </li> <li>Identifies/reports failure of CS Pump 1B to start.</li> <li>Identifies/reports failure of PHASE B actuation/positioning of PHASE B valves</li> <li>Manually actuate BOTH switches CS &amp; \u03c6 B ISOL switches <ul> <li>Check Group 6 CS monitor lights LIT</li> <li>Check Group 6 Phase B Isol monitor lights LIT</li> <li>Check Group 6 Phase B Isol monitor lights LIT</li> <li>Stop ALL RCPs</li> <li>Check CS eductor suction flow &gt;15 gpm on 1FI-CS014</li> <li>Check CS eductor additive flow &gt; 5 gpm on 1FI-CS016</li> </ul> </li> <li>Identify/report start of 1B CS pump and 1A CS pump NOT running</li> <li>Identify/report trip of 1B CS Pump.</li> </ul>			
		NOTE: At some time CNMT pressure is expected to rise to an ORANGE Path condition (without CS pumps running). If so performance of 1BFR-Z.1 "Response To High Containment Pressure" is required. Actions are covered below on page 25.			

Scenario No: 1-3		Event No. 9	Page 22 - 33 of 33	
Event Description:		Phase B Isc. and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS.		
Time	Position	Applicant's Actions or Behavior	an and an and an	
	BOP/US	<ul> <li>Align SX Cooling Towers</li> <li>All EIGHT riser valve 0SX163A-H open</li> <li>All FOUR Hot water Basin Bypass valves 0SX162A-D open</li> </ul>		
		<ul> <li>All EIGHT SX cooling tower fans running in HIGH Speed</li> <li>Verify AF flows</li> <li>AF flow &gt; 500 gpm</li> </ul>		
		Check SG NR level > 10%		
		<ul> <li>SG levels maintained between 31% and 50%</li> <li>NR levels NOT increasing in an uncontrolled manner</li> </ul>		
	POUS			
	KU/US	<ul> <li>Verify ECCS valve alignment &amp; flows</li> <li>Group 2 CL Inj monitor lights lit</li> <li>HHSI flow &gt;50 gpm</li> <li>SI flow &gt; 100gpm (if RCS pressure &lt;1590 µsig)</li> <li>Check RCS pressure &lt; 300 psig</li> </ul>		
		<ul> <li>If so, check RH pump discharge flow &gt; 100 gpm</li> <li>Check at least ONE PZR PORV relief path available: <ul> <li>At least ONE PORV Isol valve energized.</li> </ul> </li> <li>PORV in AUTO <ul> <li>Associated Isol valve open</li> </ul> </li> </ul>		
	BOP/US	<ul> <li>Verify generator trip</li> <li>OCB 3-4 and 4-5 open</li> <li>PMG output breaker open</li> </ul>		

Scenario No: 1-3 Event Description:		Event No. 9	Page 22 - 33 of 33		
		Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS			
Time Position		Applicant's Actions or Behavior			
	BOP/US (cont.)	<ul> <li>Verify both DGs running</li> <li>DG SX valves 1SX169A &amp; B open</li> <li>Dispatch operator to locally check DGs</li> <li>Ventilation systems aligned for emergency</li> <li>Control Room <ul> <li>Control Room d/P on 0PDI-VC038 &gt; +0.125" H2O</li> <li>Aux Bidg</li> <li>Fuel Handling Bldg</li> </ul> </li> </ul>			
	RO/US	<ul> <li>Check PZR sprays &amp; PORVs closed</li> <li>RCS temperature control <ul> <li>Check RCP status – none running</li> <li>Check RCS CL temps trending to or stable at 557°F</li> </ul> </li> </ul>			
	RO/US	<ul> <li>Check RCP status:</li> <li>If any RCP running and RCS pressure &lt; 1425 psig AND HHSI flow &gt; 3</li> <li>Stop all RCPs and place Steam Dumps in STM PRESS Mode</li> </ul>	50 gpm OR SI flow > 100 gpm		
	BOP/US	<ul> <li>Check SG secondary boundary</li> <li>All SG pressure stable</li> <li>Check SG tubes intact</li> <li>All secondary rad monitors &lt; ALERT setpoint</li> </ul>			
	CREW	<ul> <li>Diagnose LOCA</li> <li>CNMT are rad monitors levels increasing or in ALERT</li> <li>Grid 4 AS101, 4AS202, 4AS303 (1RT-AR014)</li> <li>Grid 4 AS111 (1RT-AR011)</li> <li>Grid 4 AS112 (1RT-AR012)</li> <li>Grid 4 AS120 (1RT-AR020)</li> <li>Grid 4 AS121 (1RT-AR021)</li> <li>CNMT pressure &gt; 3.4 psig</li> <li>CNMT sump level 1A &amp; 1B lights lit</li> </ul>			

Section 140. 1-5	Event No. 9	Page <u>22 - 33</u> of <u>33</u>
Event Description:	Phase B Isol and CNMT Spray Actuation signal will fail resulting in a start and align CNMT Spray Train B for operation. CNMT Spray Put	manual action to actuate Phase B, and mp 1A is OOS.
Time Position	Applicant's Actions or Behavior	r
US	Transition to BEP-1 "LOSS OF REACTOR OR SECONDARY COOL	LANT" (See page 27.)
	NOTE: With cooldown an ORANGE path may exist for the INTE of 1BFR-P.1 "Response To Imminent Pressurized Thermal Shock	GRITY CSFST. If so performance condition" is required.
	1BFR-P.1 ACTIONS	
US	Direct action of BFR-P.1	
RO/US	<ul> <li>Check RCS pressure &gt; 300 psig</li> <li>I RCS pressure &lt; 300 psig, check RH flow &gt; 1000 gpm</li> </ul>	
US	Transition to procedure & step in effect	
	NOTE: At some time CNMT pressure is expected to rise to an OR pumps running). If so performance of 1BFR-Z.1 "Response To H required.	ANGE Path condition (without CS ligh Containment Pressure" is
	1BFR-Z.1 ACTIONS	
US	Direct action of BFR-Z.1	
BOP/US	<ul> <li>Verify Phase A isolation - Group 3 Monitor lights lit</li> <li>Verify CNMT Ventilation isolation - Group 6 CNMT Vent Moni</li> <li>Check if CNMT Spray is required</li> <li>CNMT pressure &gt; 20 psig</li> <li>Verify CS Pump run lights LIT <ul> <li>If NOT lit, Manually initiate CS &amp; \u03c6B</li> </ul> </li> <li>With CS pumps NOT running <ul> <li>Place 1B CS pump Test Switch in TEST</li> <li>Verify 1CS019B open</li> <li>Place 1B CS pump Test Switch in NORMAL</li> <li>Verify 1CS007B open</li> <li>Attempt to manually start 1B CS pump</li> </ul> </li> <li>Identify/report failure of HB CS pump to start (NOTE: Since 1B CS pump had 'r iped, Green may decide NOT to attempt to preaser bus 142 cub 8 is racked in a</li> </ul>	tor lights lit

Event No. 9	Page <u>22 - 33</u> of <u>33</u>	
Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS		
Applicant's Actions or Be	havior	
<ul> <li>Verify CS System valves in EMERGENCY alignment         <ul> <li>RWST suction valve 1CS001B open</li> <li>Sump suction 1CS009B open</li> <li>CS pump header isol valve 1CS007B open</li> <li>CS eductor spray additive valve 1CS019B open</li> <li>CS eductor inlet flow control valve 1CS010B open</li> <li>CS eductor inlet flow control valve 1CS010B open</li> <li>CS eductor inlet flow control valve 1CS010B open</li> <li>Check Group 6 Phase B Isol monitor lights LIT</li> </ul> </li> <li>Stop ALL RCPs</li> <li>Check CS flow indication on scale         <ul> <li>CS eductor suction flow on 1FI-CS012</li> <li>CS eductor additive flow on 1FI-CS014</li> <li>CS eductor additive flow on 1FI-CS016</li> </ul> </li> <li>(NOTE: No flow will be indicated, but RNO does NOT provide flow solution to the indicated, but RNO does NOT provide flow on SPRAY ADDITVE TANK LO-2 level lights LIT, 1CS019A/B</li> <li>Verify RCFCs LOW SPEED run lights LIT</li> <li>Verify Main Steamline Isolation by ALL MSIV and MSIV E</li> <li>Check if feed flow should be isolated to any SG</li> <li>Check pressure in all SGs             <ul> <li>ANY SG pressure decreasing in an uncontrolled mator OR</li> <li>Any SG completely depressurized</li> </ul> </li> </ul>	for NO CS pumps running) close CS eductor spray additive valves Bypass valves closed	
	Event No. 9 Phase B Isol and CNMT Spray Actuation signal will fail resultin start and align CNMT Spray Train B for operation. CNMT Spr Applicant's Actions or Be • Verify CS System valves in EMERGENCY alignment • RWST suction valve 1CS001B open • RWST suction 1CS009B open • CS pump header isol valve 1CS017B open • CS eductor spray additive valve 1CS019B open • CS eductor inlet flow control valve 1CS010B open • CS eductor inlet flow control valve 1CS010B open • Check Group 6 Phase B Isol monitor lights LIT • Stop ALL RCPs • Check CS flow indication on scale • CS eductor suction flow on 1FI-CS012 • CS eductor suction flow on 1FI-CS014 • CS eductor additive flow on 1FI-CS016 (NOTE: No flow will be indicated, but RNO does NOT provide f • Reset CNMT Spray signal • When SPRAY ADDITVE TANK LO-2 level lights LIT, ICS019A/B • Verify Main Steamline Isolation by ALL MSIV and MSIV F • Check if feed flow should be isolated to any SG • Check pressure in all SGs • ANY SG pressure decreasing in an uncontrolled ma OR • Any SG completely depressurized	

Scenario No: 1-3		Event No. 9 Page <u>22 - 33</u> of <u>33</u>			
Event Description:		Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS.			
Time Position BOP/US (cont.)		Applicant's Actions or Behavior			
		<ul> <li>Obtain hydrogen concentration measurement per BOP PS-9 <ul> <li>Verify open or open valves - 1PS228A, 1PS230A, 1PS228B, 1PS229A, 1PS229B, and 1PS230B on PM12J</li> <li>Direct local operator to open valves - 1PS232A, 1PS233A, 1PS232B and 1PS233B</li> <li>Direct local operator to verify LOCAL SET/NORMAL switch for alarms on H2 units are set to NORMAL</li> <li>Place ON/OFF switch on H2 panels (1HSU-PS345/346) to ON position on PM12J</li> <li>After 4 minutes verify H2 and System Status alarm lights OFF (PM12J)</li> <li>Verify LO RANGE lights are ON for 1EL-PS343 and PS344 on PM06J (CS section)</li> </ul> </li> <li>Check Hydrogen concentration &lt; 5.0% in dry air and &lt; 0.5% in dry air</li> <li>Notify TSC of Hydrogen concentration</li> <li>Periodically obtain a hydrogen concentration measurement</li> <li>Return to procedure &amp; step in effect</li> </ul>			
		BEP-1 ACTIONS			
	US	Direct actions of BEP-1			
	CREW	<ul> <li>Check Status of RCPs <ul> <li>If any RCP is running check if RCPs should be stopped:</li> <li>Check RCS pressure &lt; 1425 psig</li> <li>AND</li> <li>Check HHSI flow &gt; 50 gpm OR SI flow &gt; 100 gpm</li> </ul> </li> <li>If so, stop all RCPs <ul> <li>AND</li> <li>Place Steam Dumps in STM PRESS Mode (NOTE: Operator must control in MAN due to earlier PT-MS507 failure)</li> </ul> </li> </ul>			
	BOP/US	<ul> <li>Check SG secondary boundaries intact</li> <li>Check pressure in all SGs</li> <li>No SG pressure decreasing in uncontrolled manner</li> <li>No SG completely depressurized</li> </ul>			

Scenario No: 1-3 Event Description:		Event No. 9 Page 22 - 33 of 33				
		Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS				
Time Position		Applicant's Actions or Behavior				
	BOP/US (cont.)	<ul> <li>Check intact SG levels</li> <li>Narrow range levels &gt;31%. If not flow is maintain &gt; 500 gpm</li> <li>Control feed flow to maintain intact SG levels between 31% and 50%</li> <li>Check narrow range levels NOT increasing in an uncontrolled manner.</li> </ul>				
	CREW	<ul> <li>Check secondary radiation normal</li> <li>SJAE GS exhaust 1PR27J Grid 1 1PS027</li> <li>SG Blowdown 1PR08J Grid 1 1PS108</li> <li>Main Steam: 1RT-AR022 &amp; 1RRT-AR023 for each SG, Grid 1 4AA122/123, 4AB222/223, 4AC322/323, 4AD422/423</li> <li>Main Steam Penetration 1A/1D 1RT-AR024 Grid 4 4AA124</li> <li>Main Steam Penetration 1B/1C 1RT-AR024 Grid 4 4AB124</li> </ul>				
	RO/US	<ul> <li>Check PZR PORVs</li> <li>Power to PORV Isol valves 1RY8000A/B available</li> <li>PORVs RY455A &amp; RY456 CLOSED</li> <li>At least ONE PORV Block valve RY8000A OR RY8000B OPEN</li> </ul>				
	CREW	<ul> <li>Check if ECCS flow should be reduced</li> <li>RCS Subcooling acceptable <ul> <li>Iconic Display</li> <li>OR</li> <li>ATTACHMENT A, FIGURE 1BEP 1-1</li> </ul> </li> <li>Secondary heat sink <ul> <li>Total feed flow to SGs &gt; 500 gpm available</li> <li>OR</li> <li>NR level in at least ONE intact SG &gt; 10%</li> </ul> </li> <li>RCS Pressure stable or increasing</li> <li>PZR level &gt;38%</li> </ul> <li>Determine ECCS reduction criteria NOT met (subcooling likely)</li>				

Scenario No: 1-3 Event Description:		Event No. 9 Page 22 - 33 of 33			
		Phase B Isol and CNMT Spray . Tuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS			
Time Position		Applicant's Actions or Behavior			
	CREW	<ul> <li>Check if CNMT Spray should be stopped</li> <li>CS Pump 1B run light LIT</li> <li>Reset CS signal</li> <li>When Spray Additive tank LO-2 level lights LIT, close eductor spray additive valves 1CS019A/B</li> <li>When CNMT pressure is &lt; 15 psig AND CS has operated for at least 2 hours, continue with steps to secure CS</li> </ul>			
	RO/US	<ul> <li>Check if RH Pumps should be stopped</li> <li>Reset SI <ul> <li>Depress BOTH SI RESET pushbuttons</li> <li>Verify SI ACTUATED permissive light NOT lit</li> <li>Verify AUTO SI BLOCK permissive light LIT</li> </ul> </li> <li>Check RCS pressure &gt; 300 psig <ul> <li>If NOT, DO NOT stop RH pumps</li> </ul> </li> <li>If &lt; 300 psig AND pressure stable or increasing <ul> <li>Stop RH pumps and place in standby</li> </ul> </li> </ul>			
	CREW	<ul> <li>Check RCS and SG pressures</li> <li>Check pressure in ALL SGs stable or increasing</li> <li>Check RCS pressure stable or decreasing</li> </ul>			
	BOP/US	<ul> <li>Check if DG should be stopped</li> <li>SAT 142-1 &amp; 142-2 BUS ALIVE lights lit</li> <li>ACB 1412 &amp; 1422 closed</li> <li>ACB 1432 &amp; 1442 closed</li> <li>Stop 1A &amp; 1B DG per BOP DG-12</li> </ul>			

Scenario No: 1-3 Event Description:		Event No. 9	Page 22 - 33 of 33
		Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS.	
Time	Position	Applicant's Actions or Behavior	
	CREW	<ul> <li>Evaluate plant status</li> <li>CL recirc <ul> <li>Power available to RH pump 1A OR 1B</li> <li>CNMT sump isol valve position light lit for SI8811A/B</li> </ul> </li> </ul>	
	BOP/US	Check various Aux Bldg radiation monitors	
		Reset CNMT ISOL Phase A	
		<ul> <li>Place Hydrogen monitors in service per BOP PS-9</li> </ul>	
		<ul> <li>Verify open or open valves – 1PS228A, 1PS230A, 1PS228B, 1F 1PS230B on PM12J</li> </ul>	PS229A, 1PS229B, and
		<ul> <li>Direct local operator to open valves - 1PS232A, 1PS233A, 1PS</li> <li>Direct local operator to verify LOCAL SET/NORMAL switch for NORMAL</li> <li>Place ON/OFF switch on H2 panels (1HSU-PS345/346) to ON</li> <li>After 4 minutes verify H2 and System Status alarm lights OFF (</li> <li>Verify LO RANGE lights are ON for 1EL-PS343 and PS344 on</li> </ul>	232B and 1PS233B for alarms on H2 units are set to position on PM12J (PM12J) a PM06J (CS section)
		<ul> <li>Obtain samples by contacting Chem</li> <li>RCS activity</li> <li>RCS boron</li> </ul>	
		CNMT atmosphere	
		Prepare both hydrogen recombiners per BOP OG-10. Dispatch oper	ators
		<ul> <li>Align SX MDCT for long-term cooling per BOP SX-T2</li> <li>Place SX tower makeup in AUTO</li> <li>CLOSE SXCT B/D to Flume Isol valves SX161A/B</li> </ul>	
		Shutdown unnecessary equipment	

Scenario No: 1-3 Event Description:		Event No. 9	Page 22 - 33 of 33		
		Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS.			
Time	Position	Applicant's Actions or Behavior			
	BOP/US (cont.)	<ul> <li>Align NDCT for temperature &amp; level control</li> <li>Place NDCT riser valves CS for Unit 1 BYPASS OPEN position</li> <li>Verify NDCT TURBINE INTERLOCK switch in OVERRIDE position</li> <li>Verify flume level within seasonal band</li> <li>Dispatch operator to locally check Basin water levels acceptable</li> <li>Align NDCT per BOP CW-25a</li> </ul>			
	RO/US	<ul> <li>Check if RCS cooldown and depressurization required</li> <li>RCS pressure &gt; 300 psig</li> <li>If NOT check RHR flow &gt; 1000 gpm</li> <li>If NOT, go to BEP ES-1.2</li> <li>If SO, when RWST level &lt; 46% for transition to BEP ES-1.3</li> </ul> (NOTE: While waiting for RWST level to fall below 46%, the crew should reverify t indicated with (on page 30.)	he steps above		
	US	Transition to BEP ES-1.3 "TRANSFER TO COLD LEG RECIRCULATION"			
		BEP ES-1.3 ACTIONS			
	US	Direct actions of BEP ES-1.3			
	CREW	<ul> <li>Establish CC flow to RH HX</li> <li>OPEN CC to RH HX isol valves <ul> <li>1CC9412B</li> <li>1CC9412A</li> </ul> </li> <li>Check CC to RH HX flows &gt; 5000 gpm on 1FI0689/0688</li> </ul> <li>Verify adequate CNMT sump level <ul> <li>Check CNMT sump BOTTOM 4 LIGHTS lit on CNMT SUMP 1A or 1B LV</li> </ul> </li> <li>Align RH pumps suction to CNMT sumps <ul> <li>Verify both RH pumps running</li> <li>Check CNMT sump isol valves 1SI881A and 1SI 8811B open</li> <li>Close RH pump suction from RWST 1SI8812B (AND 8812 A)</li> </ul> </li>	Л.		

Scenario No: 1-3 Event Description:		enalika kanalar waka kata kata kata kata kata kata kata	Event No. 9	Page 22 - 33 of 33
		Phase B Isol an MT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align C. Spray Train B for operation. CNMT Spray Pump 1A is OOS		
Time Position		The owners of the owners of	Applicant's	Actions or Behavior
	Crew • Check if S (cont.) • Check if S o Any S OR o Any C		CENT CHG pumps are in ECC mp running T CHG pumps to cold legs injec	S injection mode tion isol valves 1SI8801A/B
		<ul> <li>Dispatch c</li> <li>1SI88</li> <li>1SI88</li> </ul>	perators to energize 13 (MCC 132X4A L3) 06 (MCC 131X1A P3)	
		Verity CE. CLOSED     Close SI p	NT CHG pump miniflow isol va ump miniflow isol valves 1SI88	alves ICV8111, ICV8114, ICV8110 and ICV8116 814, 1SI8920 and ISI8813
CR [C ES	CREW [CT] ES-1.3-A	<ul> <li>Close RH I</li> <li>OPEN SI &amp;</li> <li>Check RH</li> <li>Open RH I</li> <li>Check RH</li> <li>Open RH I</li> <li>Open RH I</li> <li>Start SI and CE</li> </ul>	HX discharge crosstie valves 1F & CENT CHG pumps suction h pump 1A running HX to CENT CHG pumps isol v pump 1B running HX to SI pumps isol valve 1SI8 ENT CHG pumps as necessary	RH8716A and IRH8716B eader crosstie valves ISI8807A, ISI8807B and ISI8924 valve 1CV8804A 804B
	CREW	<ul> <li>Reset SI</li> <li>depress both</li> <li>Verify SI A</li> <li>Verify AU</li> </ul>	th SI RESET pushbuttons ACTUATED permissive light N TO SI BLOCKED permissive li	IOT lit ight LIT
Scenario No: 1-3		Event No. 9 Page 22 - 33 of 33		
--------------------	-----------------------------	----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------	--	--
Event Description:		Phase B Isol and CNMT Spray Actuation signal will fail resulting in manual action to actuate Phase B, and start and align CNMT Spray Train B for operation. CNMT Spray Pump 1A is OOS		
Time	Position	Applicant's Actions or Behavior		
Time	Position CREW (cont.)	<ul> <li>Applicatu's Actions or Behavior</li> <li>Isolate RWST from SI and CENT CHG pumps</li> <li>Close SI pump suction from RWST isol valve 1SI8806</li> <li>Close RWST to CENT CHG pumps suction valves 1CV112D and 1CV112E</li> <li>Dispatch operator to deenergize RWST to CENT CHG pumps valves <ul> <li>1CV112D - MCC 131X1 K4</li> <li>1CV112E - MCC 132X4 C2</li> </ul> </li> <li>Align CNMT Spray system for recirculation <ul> <li>Check RWST level &lt; 12% - RWST LEVEL LO-3 status lights LIT</li> <li>When LO-3 level is reached (NOTE: Next MAJOR step below will be performed if level&gt; LO-3)</li> <li>Open CS pump sump suction valves 1CS009B</li> <li>Close CS pump RWST suction valves 1CS001B</li> <li>Verify both CS pumps running</li> </ul> </li> <li>Identify/ report 1A CS pump is NOT available</li> <li>Align CC System for Post LOCA recovery</li> <li>Establish SX flow to Unit 0 CC HX <ul> <li>Open CC HX 0 outlet valve 0SX146</li> <li>Open CC HX 0 inlet valve 1SX005</li> </ul> </li> <li>Dispatch operator to check SX to CC HX flows &gt; 6000 gpm <ul> <li>If flow is NOT &gt; 6000 gpm, direct throttling of following as necessary</li> <li>0SX007</li> <li>1SX007</li> </ul> </li> </ul>		
		SCENARIO TERMINATED		

Comments:

BAP 335-1T1 Revision 7

## SHIFT MANAGER'S TURNOVER

## **TODAY ONCOMING SHIFT**

UNIT 1 STATUS	UNIT 1 MAJOR OOS's		
MODE	<ul><li>1A CS Pump is OOS.</li><li>1A FW Pump is OOS.</li><li>250' Meteorological Tower instruments are OOS.</li></ul>		
LCOAR ENTRIES PREVIOUS 48 HRS	UNIT 1 MAJOR SURVEILLANCES		
LCOARs has been entered for 1A CS Pump. LCOAR has been entered for 250' Met Tower.			
UNIT 1 IN PROGRESS	UNIT 1 AND COMMON PENDING		
The National Weather Service has declared a Thunderstorm Warning in effect for Stephenson, Winnebago and Ogle counties for the next 6 hours.	Ready to increase power to 100%. Electrical Operations has requested a power ascension to Full Power at 5MW/min.		
SCHEDULED ACTIVITY CONFLICTS			

BAP 335-1T1 Revision 7

## SHIFT MANAGER'S TURNOVER

UNIT 2 STATUS	UNIT 2 MAJOR OOS's			
MODE 1				
%Pwr				
MWe 1178				
Max Load/Power. 100%				
Min Load/Power 750 MW				
May Ramp Pate 2 Mu/Min				
Desired Dolto T. Margat				
Unit on ECC				
Dance of EGC NA				
Boron @ 535				
Control Bank D @ 213				
LCOAR ENTRIES PREVIOUS 48 HRS	UNIT 2 MAJOR SURVEILLANCES			
UNIT 2 IN PROGRESS	UNIT 2 PENDING			
SCHEDULED ACTIVITY CONFLICTS				

.

.

## SHIFT MANAGER'S TURNOVER

ADMINISTRATIVE	
TEMPORARY PROCEDURES/ALTS	
DAILY ORDERS/SPECIAL OP. ORDERS	
DAILY MANNING SCHEDULE	
CONTROL ROOM ROUNDS	
(GSEP/LER/DVR/ENS)	
MATERIAL CONDITIONING	
RWP'S/RELEASES/PRECAUTIONS/ALARA	
INFREQUENT EVOLUTION ACTIVITIES	
SPSO/DIVISION LD	Alternate BPO Outside # 815-727-5902/5903 Tie # 8-565-5902/5903
UNIT 1 COMMENTS	UNIT COMMON COMMENTS
S/G B/D returning to Condenser per SPP	CW Blowdown LineupU-2FC CleanupU-1FC CoolingU-150K DO TankCertified125K DO TankCertifiedAux SteamU-1U-0 CC HXU-1
UNIT 2 COMMENTS	GENERAL COMMENTS
Caution Cards	Abnormal Positioned Components
CCNUM EPN	CCNUM EPN Abnormal Position

SHIFT: LAST TO PRESENT TIME: NOW DATE: TODAY OFFGOING ONCOMING

.

4

•••

.