

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

JUN 13 1988

TVA-SQN-TS-88-10

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket Nos. 50-327
50-328

SEQUOYAH NUCLEAR PLANT (SQN) - TECHNICAL SPECIFICATION CHANGE 88-10 -
TURBINE-DRIVEN AUXILIARY FEEDWATER PUMP (TDAFWP) RESPONSE TIME AND ACTUATION
SIGNAL TESTING

In accordance with 10 CFR 50.90, we are enclosing a requested amendment to licenses DPR-77 and DPR-79 to change the technical specifications of SQN units 1 and 2. The proposed change will allow entry into mode 3 before performance of the response time and actuation signal testing for the TDAFWP. TVA believes that this change should be approved before restart of SQN unit 1 to avoid any possible misinterpretation of the testing requirements for the TDAFWP.

The proposed technical specification change is identified in enclosure 1. The justification for the proposed technical specification change is provided in enclosure 2. A proposed determination of no significant hazards consideration performed pursuant to 10 CFR 50.92 is provided in enclosure 3.

Enclosed is a check for the \$150 amendment application fee required by 10 CFR 170.12.

App 1
w/check \$150
#43296


JUN 13 1988

U.S. Nuclear Regulatory Commission


Please direct questions you may have concerning this issue to
Russell R. Thompson at (615) 870-7470.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


R. Gridley, Director
Nuclear Licensing and
Regulatory Affairs

Sworn to and subscribed before me
this 13th day of June 1988


Notary Public
My Commission Expires 8-24-88

Enclosures

cc: See page 2

cc (Enclosures):

Mr. K. P. Barr, Acting Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. Michael H. Mobley, Director (w/o enclosures)
Division of Radiological Health
T.E.R.R.A. Building
150 9th Avenue, N
Nashville, Tennessee 37203

Mr. G. G. Zech, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Sequoyah Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION CHANGE

SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2

DOCKET NOS. 50-327 AND 50-328

(TVA-SQN-TS-88-10)

]

LIST OF AFFECTED PAGES

Unit 1

3/4 3-29
3/4 3-30
3/4 3-31
3/4 3-32
3/4 3-33a
3/4 7-6

Unit 2

3/4 3-29
3/4 3-30
3/4 3-31
3/4 3-32
3/4 3-33a
3/4 7-6