



Southern California Edison Company

SAN ONOFRE NUCLEAR GENERATING STATION

P. O. BOX 128

SAN CLEMENTE, CALIFORNIA 92672

H. E. MORGAN
STATION MANAGER

TELEPHONE
(714) 368-6241

April 7, 1986

U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Region V
1450 Maria Lane, Suite 210
Walnut Creek, California 94596-5368

RECEIVED
APR 11 1986
NRC

Attention: Mr. J. B. Martin, Regional Administrator

Dear Sir:

Subject: Docket Nos. 50-361 and 50-362
Follow-up Report, Inoperable Fire Doors - March 1986
San Onofre Nuclear Generating Station, Units 2 and 3

Reference: Letter, H. E. Morgan (SCE) to J. B. Martin (NRC),
dated March 14, 1986.

In accordance with our referenced letter, this submittal provides the follow-up report of fire-rated assemblies (specifically fire doors) found inoperable during routine surveillances in March 1986.

Fire doors found inoperable during the March routine surveillances are identified in the Attachment and include: 7 latching mechanism failures; 12 closure mechanism failures; and 1 door blocked open for maintenance activities. As each of these deficiencies was identified, compensatory fire watches, pursuant to Technical Specification 3.7.9, Action Statement 'a', were established. Door mechanism failures are being corrected on an "as found" basis.

8604220322 860407
PDR ADOCK 05000361
S PDR

IE01


Mr. J. B. Martin

-2-

This monthly follow-up report and those sent previously provide updated information associated with an ongoing condition initially reported in 1983. The follow-up report covering inoperable fire doors identified in April 1986 will be submitted by May 15, 1986.

If you require any additional information, please so advise.

Sincerely,

A handwritten signature in black ink, appearing to read "H. E. Mays", with a horizontal line extending to the right.

Enclosure

cc: F. R. Huey (USNRC Senior Resident Inspector, Units 1, 2 and 3)

U. S. Nuclear Regulatory Commission
Document Control Desk

Institute of Nuclear Power Operations (INPO)

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MARCH 1986
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362

I. Latching Mechanism Failures:

Number of doors inoperable - 7, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-301	10/24/85	03/26/86
AC-332	01/23/86	03/06/86
AR-305	02/22/86	-----
AC-442	03/06/86	03/30/86
AC-416	03/06/86	-----
AC-417	03/07/86	-----
AC-455	03/08/86	-----

ATTACHMENT
 SOUTHERN CALIFORNIA EDISON COMPANY
 INOPERABLE FIRE DOORS FOR THE MONTH OF MARCH 1986
 SAN ONOFRE NUCLEAR GENERATING STATION
 UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
 (Continued)

II. Closure Mechanism Failures:

Number of doors inoperable - 12, as follows:

<u>Door Number</u>	<u>Inoperable</u>	<u>Operable</u>
AR-502	02/01/86	-----
FH3-103	02/07/86	03/22/86
FH3-207	02/28/86	03/02/86
AC-127	03/03/86	03/05/86
FH3-304	03/09/86	03/10/86
FH3-304	03/23/86	03/29/86
FH3-103	03/23/86	03/31/86
FH3-207	03/23/86	03/31/86
FH3-404	03/25/86	-----
AC-415	03/26/86	03/27/86
AR-301	03/27/86	03/28/86
AR-301	03/30/86	-----

ATTACHMENT
SOUTHERN CALIFORNIA EDISON COMPANY
INOPERABLE FIRE DOORS FOR THE MONTH OF MARCH 1986
SAN ONOFRE NUCLEAR GENERATING STATION
UNITS 2 AND 3, DOCKET NOS. 50-361 and 50-362
(Continued)

III. Doors Blocked Open:

Number of doors blocked open - 1, as follows:

<u>Door Number</u>	<u>Date Found Blocked Open*</u>
S2-018	3/13/86

*(fire watch established within one hour)