



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-373

LASALLE COUNTY STATION, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 57
License No. NPF-11

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by the Commonwealth Edison Company (the licensee), dated March 9, 1988 complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-11 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 57, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective on the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Leif J. Norrholm, Acting Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: May 24, 1988

ENCLOSURE TO LICENSE AMENDMENT NO. 57

FACILITY OPERATING LICENSE NO. NPF-11

DOCKET NO. 50-373

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE

3/4 8-4

INSERT

3/4 8-4

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- d. At least once per 18 months* during shutdown by:
1. Subjecting the diesel to an inspection in accordance with procedures prepared in conjunction with its manufacturer's recommendations for this class of standby service.
 2. Verifying the diesel generator capability to reject a load of greater than or equal to 1190 kw for diesel generator 0, greater than or equal to 638 kw for diesel generators 1A and 2A, and greater than or equal to 2381 kw for diesel generator 1B while maintaining engine speed less than or equal to 75% of the difference between nominal speed and the overspeed trip setpoint or 15% above nominal, whichever is less.
 3. Verifying the diesel generator capability to reject a load of 2600 kw without tripping. The generator voltage shall not exceed 5000 volts during and following the load rejection.
 4. Simulating a loss of offsite power by itself, and:
 - a) For Divisions 1 and 2 and for Unit 2 Division 2:
 - 1) Verifying de-energization of the emergency busses and load shedding from the emergency busses.
 - 2) Verifying the diesel generator starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 13 seconds, energizes the auto-connected loads and operates for greater than or equal to 5 minutes while its generator is so loaded. After energization, the steady state voltage and frequency of the emergency busses shall be maintained at 4160 ± 150 volts and 60 ± 1.2 Hz during this test.
 - b) For Division 3:
 - 1) Verifying de-energization of the emergency bus.
 - 2) Verifying the diesel generator starts on the auto-start signal, energizes the emergency bus with its loads within 13 seconds and operates for greater than or equal to 5 minutes while its generator is so loaded. After energization, the steady state voltage and frequency of the emergency bus shall be maintained at 4160 ± 150 volts and 60 ± 1.2 Hz during this test.
 5. Verifying that on an ECCS actuation test signal, without loss of offsite power, diesel generators 0, 1A and 1B start on the auto-start signal and operate on standby for greater than or equal to 5 minutes. The generator voltage and frequency shall be $4160 + 416, -150$ volts and $60 + 3.0, -1.2$ Hz within 13 seconds after the auto-start signal; the steady state generator voltage and frequency shall be maintained within these limits during this test.

*The specified 18 month interval may be waived for Unit 2 Division 2 provided the surveillance is performed during Unit 2 Refuel 2.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

COMMONWEALTH EDISON COMPANY

DOCKET NO. 50-374

LASALLE COUNTY STATION, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 38
License No. NPF-18


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment filed by the Commonwealth Edison Company (the licensee), dated March 9, 1988, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the regulations of the Commission;
 - C. There is reasonable assurance: (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations set forth in 10 CFR Chapter I;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the enclosure to this license amendment and paragraph 2.C.(2) of the Facility Operating License No. NPF-18 is hereby amended to read as follows:

(2) Technical Specifications and Environmental Protection Plan

The Technical Specifications contained in Appendix A, as revised through Amendment No. 38, and the Environmental Protection Plan contained in Appendix B, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications and the Environmental Protection Plan.

3. This amendment is effective on the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION

A handwritten signature in black ink, appearing to read "Leif J. Norrholm", written over the typed name below.

Leif J. Norrholm, Acting Director
Project Directorate III-2
Division of Reactor Projects - III,
IV, V and Special Projects

Enclosure:
Changes to the Technical
Specifications

Date of Issuance: May 24, 1988

ENCLOSURE TO LICENSE AMENDMENT NO. 38

FACILITY OPERATING LICENSE NO. NPF-18

DOCKET NO. 50-374

Replace the following page of the Appendix "A" Technical Specifications with the enclosed page. The revised page is identified by Amendment number and contains a vertical line indicating the area of change.

REMOVE

3/4 0-2

INSERT

3/4 0-2

APPLICABILITY

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be met during the OPERATIONAL CONDITIONS or other conditions specified for individual Limiting Conditions for Operation unless otherwise stated in an individual Surveillance Requirements.

4.0.2 Each Surveillance Requirement shall be performed within the specified time interval with:

- a. A maximum allowable extension not to exceed 25% of the surveillance interval, but
- b. The combined time interval for any 3 consecutive surveillance intervals shall not exceed 3.25 times the specified surveillance interval.*

4.0.3 Failure to perform a Surveillance Requirement within the specified time interval shall constitute a failure to meet the OPERABILITY requirements for a Limiting Condition for Operation. Exceptions to these requirements are stated in the individual Specifications. Surveillance requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL CONDITION or other specified condition shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the stated surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, & 3 components shall be applicable as follows:

- a. Inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g) (6) (i).
- b. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice inspection and testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these Technical Specifications:

<u>ASME Boiler and Pressure Vessel Code and applicable Addenda terminology for inservice inspection and testing activities</u>	<u>Required frequencies for performing inservice inspection and testing activities</u>
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days

*Not applicable to 18 month surveillances required for Unit 2 Cycle 2 operation.