

June 1, 1988

Docket No. 50-460

Mr. D. W. Mazur, Managing Director
Washington Public Power Supply System
3000 George Washington Way
P.O. Box 968
Richland, Washington 99352-0968

Dear Mr. Mazur:

SUBJECT: EMERGENCY RESPONSE CAPABILITY - CONFORMANCE TO REGULATORY
GUIDE 1.97, REVISION 3 FOR WASHINGTON PUBLIC POWER SUPPLY
SYSTEM NUCLEAR PROJECT NO. 1 (WNP-1)

We have reviewed your responses of April 15, 1983 and February 6, 1986 to Generic Letter 82-33 concerning how WNP-1 meets the guidelines of Regulatory Guide R. G. 1.97 as applied to emergency response facilities. We have determined that the instrumentation provided for WNP-1 for meeting the recommendations of R. G. 1.97, Revision 3, for each post-accident monitoring variable are acceptable except for pressurizer heater status, emergency ventilation damper position, condenser air removal system exhaust and gland steam exhaust. R.G. 1.97 recommends Category 2 instrumentation to monitor the status of these systems. Therefore, we request your commitment within 60 days of the date of this letter to install Category 2 instrumentation to monitor the status of pressurizer heater status, emergency ventilation damper position, condenser air removal system exhaust and gland steam exhaust. Since WNP-1 is currently in deferred status, we request a commitment to provide a schedule and any subsequent changes in the schedule for installing such instrumentation when construction is restarted.

Our associated Safety Evaluation Report is enclosed.

Sincerely,
original signed by
Lester S. Rubenstein, Acting Director
Standardization and Non-Power
Reactor Project Directorate
Division of Reactor Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

8806170128 880601
PDR ADOCK 05000460
P PDR

Enclosure:
Safety Evaluation Report

cc: See next page

Distribution:

Docket File	OGC-Rockville
NRC & Local PDRs	EJordan
PDSNP Reading	JPartlow
DCrutchfield	ACRS (10)
EHylton	S. Newberry
GVising	B. Marcus

PDSNP
GVising
05/24/88

PDSNP
LRubenstein
05/11/88



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

June 1, 1988

Docket No. 50-460

Mr. D. W. Mazur, Managing Director
Washington Public Power Supply System
3000 George Washington Way
P.O. Box 968
Richland, Washington 99352-0968

Dear Mr. Mazur:

SUBJECT: EMERGENCY RESPONSE CAPABILITY - CONFORMANCE TO REGULATORY
GUIDE 1.97, REVISION 3 FOR WASHINGTON PUBLIC POWER SUPPLY
SYSTEM NUCLEAR PROJECT NO. 1 (WNP-1)

We have reviewed your responses of April 15, 1983 and February 6, 1986 to Generic Letter 82-33 concerning how WNP-1 meets the guidelines of Regulatory Guide R. G. 1.97 as applied to emergency response facilities. We have determined that the instrumentation provided for WNP-1 for meeting the recommendations of R. G. 1.97, Revision 3, for each post-accident monitoring variable are acceptable except for pressurizer heater status, emergency ventilation damper position, condenser air removal system exhaust and gland steam exhaust. R.G. 1.97 recommends Category 2 instrumentation to monitor the status of these systems. Therefore, we request your commitment within 60 days of the date of this letter to install Category 2 instrumentation to monitor the status of pressurizer heater status, emergency ventilation damper position, condenser air removal system exhaust and gland steam exhaust. Since WNP-1 is currently in deferred status, we request a commitment to provide a schedule and any subsequent changes in the schedule for installing such instrumentation when construction is restarted.

Our associated Safety Evaluation Report is enclosed.

Sincerely,

A handwritten signature in dark ink, appearing to read "L. S. Rubenstein", with a long, sweeping horizontal line extending to the right.

Lester S. Rubenstein, Acting Director
Standardization and Non-Power
Reactor Project Directorate
Division of Reactor Projects III,
IV, V and Special Projects
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation Report

cc: See next page

Mr. D. W. Mazur
Washington Public Power Supply System

WPPSS Nuclear Project No. 1
(WNP-1) Docket No. STN 50-460

cc:

Mr. Charles B. Brinkman
Washington Nuclear Operations
Combustion Engineering, Inc.
7010 Woodmont Avenue, Suite 1310
Bethesda, Maryland 20814

Mr. G. C. Sorensen, Manager
Regulatory Programs
Washington Public Power Supply
System
Post Office Box 968
Richland, Washington 99352

Nicholas S. Reynolds, Esq.
Bishop, Cook, Furcell & Reynolds
Law Offices
1400 L. Street, N.W.
Washington, DC 20005-3502

G. E. Doupe, Esq.
Washington Public Power Supply System
3000 George Washington Way
Richland, Washington 99352

Mr. Curtis Eschels, Chairman
Energy Facility Site Evaluation Council
Mail Stop PY-11
Olympia, Washington 98505

Mr. Douglas Coleman
Washington Public Power Supply System
P. O. box 1223
Elma, Washington 98541

Mr. William Ang
Region Inspector/WPPSS 3/5
U.S. Nuclear Regulatory Commission
1450 Maria Lane - Suite 210
Walnut Creek, California 94596

Mr. Eugene Rosolie, Director
Coalition for Safe Power
408 Southwest Second Avenue
Portland, Oregon 97204