



CHARLES CENTER · P. O. BOX 1475 · BALTIMORE, MARYLAND 21203

JOSEPH A. TIERNAN  
VICE PRESIDENT  
NUCLEAR ENERGY

June 9, 1988

U. S. Nuclear Regulatory Commission  
Washington, DC 20555

ATTENTION: Document Control Desk

SUBJECT: Calvert Cliffs Nuclear Power Plant  
Unit Nos. 1 & 2; Docket Nos. 50-317 & 50-318  
Request for Additional Information Concerning BG&E Responses to  
Generic Letter 83-28, Item 2.2.2

REFERENCE: (a) Letter from Mr. S. A. McNeil (NRC) to Mr. J. A. Tiernan (BG&E),  
dated April 25, 1988, same subject

Gentlemen:

This is in response to Reference (a). Enclosure (1) addresses the additional information you requested regarding Item 2.2.2 of Generic Letter 83-28, "Required Actions Based on Generic Implications of Salem ATWS Events."

Should you have any further questions regarding this matter, we will be pleased to discuss them with you.

Very truly yours,

JAT/DLS/dlm

Enclosure

cc: D. A. Brune, Esquire  
J. E. Silberg, Esquire  
R. A. Capra, NRC  
S. A. McNeil, NRC  
W. T. Russell, NRC  
D. C. Trimble, NRC

A055  
11

ENCLOSURE (1)

ADDITIONAL INFORMATION CONCERNING ITEM 2.2.2  
OF GENERIC LETTER 83-28

1. NRC Request

Please provide a description of the additional vendor interface programs that you determined would be appropriate and practicable.

BG&E Response

We have identified and contacted nine vendors that we determined would be desirable to establish an interface program with. A list of these vendors and the equipment they supply us is provided below. We are experiencing difficulties obtaining timely vendor response and support, and have thus far received initial responses from only six vendors. We are proceeding with defining individual programs for some vendors and we are continuing to follow-up our communications with the others. The interface programs will be individually tailored to the equipment and the vendor.

| <u>Vendor</u>           | <u>Equipment</u>                  |
|-------------------------|-----------------------------------|
| * ARMCO                 | Charging Pumps                    |
| * BINGHAM INTERNATIONAL | HPSI Pumps                        |
| * BYRON JACKSON         | Reactor Coolant Pumps             |
|                         | Auxiliary Feed Pumps              |
| * DRESSER RAND          | Auxiliary Feed Pump Turbines      |
| EXIDE                   | Vital AC System (Inverters)       |
| FAIRBANKS - MORSE       | Emergency Diesel Generators       |
|                         | Drip-Proof Synchronous Alternator |
| * GENERAL ELECTRIC      | Reactor Trip Switchgear           |
| * INGERSOLL - RAND      | LPSI Pumps                        |
| WESTINGHOUSE            | 480 Volt Circuit Breakers         |
| * = Response Received   |                                   |

2. NRC Request

Please provide a commitment to establishing and maintaining these additional vendor interface programs by a certain date.

BG&E Response

Due to the aforementioned difficulties in getting timely responses from vendors, these interface programs are still in the early stages of development. These vendors are not under our control and have little incentive to proceed aggressively in establishing these programs. We have set a target date for ourselves to have these programs established by December 31, 1988. We cannot consider this a commitment, though, because of this vendor dependence.