

Yellow

APR 21 1986

Carolina Power and Light Company
ATTN: Mr. E. E. Utley
Senior Executive Vice President
Power Supply and Engineering
and Construction
P. O. Box 1551
Raleigh, NC 27602

Gentlemen:

SUBJECT: NOTICE OF VIOLATION
(NRC INSPECTION REPORT NOS. 50-325/85-26 AND 50-324/85-26)

This refers to the special team inspection of Environmental Qualification conducted by the NRC August 12 - 16, 1985, of activities authorized by Operating License Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric plant. The results of this inspection were previously sent to you by our letter of November 12, 1985. The inspection team identified four deficiencies classified as Potential Enforcement/Unresolved Items. We have determined from a further review of these matters that two of the four Potential Enforcement/Unresolved Items were in violation of NRC requirements. These two are identified in the inspection report as items 50-325, 324/85-26-10, "Inclusion of Rockbestos Coaxial Cable on EQ List," and 50-325, 324/85-26-11, "Qualification of Rockbestos Fire-wall III Cable." The violations, references to pertinent requirements, and elements to be included in your response are presented in the enclosed Notice of Violation.

Potential Enforcement/Unresolved Items 50-325/324:85-26-04, "Procurement of Replacement Parts," and 50-325/324:85-26-05, "Qualified Status of Installed Equipment/Establishment of EQ Maintenance Requirements in Plant Procedures," are regarded as Unresolved Items.

In accordance with Section 2.790 of the NRC's "Rules of Practice," Part 2, Title 10, Code of Federal Regulations, a copy of this letter, its enclosure, and your reply will be placed in the NRC's Public Document Room upon completion of our evaluation of the reply.

The responses directed by this letter and the enclosed Notice are not subject to the clearance procedures of the Office of Management and Budget as required by the Paperwork Reduction Act of 1980, PL 86-511.

8605050385 860421
PDR ADOCK 05000324
Q PDR

1/1
TE01

APR 21 1986

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,

Original Signed by
Luis A. Reyes /for

Roger D. Walker, Director
Division of Reactor Projects

Enclosure:
Notice of Violation

cc w/encl:

- ✓ P. W. Howe, Vice President
Brunswick Nuclear Project
- ✓ C. R. Dietz, Plant General Manager

bcc w/encl:

- ✓ NRC Resident Inspector
Document Control Desk
State of North Carolina
- ✓ B. K. Grimes, OIE
- ✓ J. Axelrad, OIE

RIL *[Signature]*
ARuff:jw
03/26/86

RIL *[Signature]*
TConlon
03/26/86

RIL *[Signature]*
AHerdt
04/2/86

RIL *[Signature]*
AFGibson
03/1/86
4/17/86

RIL *[Signature]*
PFredrickson
04/8/86

[Signature]
JEMONS
4/17/86

4/17/86 : Discussed this action
w/ B. Beale, IE Eng. : he
agreed w/ issuing the NOV. *[Signature]*