

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

JUN 13 1988

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of) Docket Nos. 50-327
Tennessee Valley Authority) 50-328

SEQUOYAH NUCLEAR PLANT (SQN) - WASTE DISPOSAL SYSTEM PHYSICAL PIPING
DRAWINGS

- References:
1. TVA Letter to NRC dated April 22, 1987, "Sequoyah Nuclear Plant - NRC Inspection and Enforcement Report Numbers 50-327/86-55 and 50-328/86-55"
 2. TVA letter to NRC dated January 21, 1987, "Sequoyah Nuclear Plant Unit 2 - Long-Term Drawing Control Program"

In response to Inspection Reports 50-327/86-55 and 50-328/86-55, TVA committed to generate configuration control drawings (CCDs) for the waste disposal physical drawings (47W560 series) as stated in reference 1. The current commitment completion date was April 1, 1988.

To date, a walkdown of the waste disposal system has been completed; and CCDs will be generated for the flow drawings. The other waste disposal system drawings will be completed in accordance with TVA's commitment to generate CCDs as stated in reference 2.

Safety evaluations and other safety-related reviews utilize the primary drawings in performing reviews. Physical drawings are normally used in performing design changes. Design changes that affect these drawings will result in a detailed walkdown of the portion of the system that is being affected. This is to ensure essential information needed for the modification is not overlooked. Therefore, TVA has determined that generation of CCDs for the waste disposal system physical drawings is not essential. In accordance with TVA's drawing commitment, however, the waste disposal system physical drawings will be updated to include known drawing deficiencies as changes are made to the waste disposal system.

D030
1/1

JUN 13 1988


U.S. Nuclear Regulatory Commission

With completion of field verification of the waste disposal system, the generation of CCDs for the primary drawings, and TVA's overall drawing commitment, this commitment should be closed.

If you have any questions, please telephone M. R. Harding at (615) 870-6422.

Very truly yours,

TENNESSEE VALLEY AUTHORITY


R. Gridley, Director
Nuclear Licensing and
Regulatory Affairs

cc: Mr. K. P. Barr, Acting Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Sequoyah Resident Inspector
Sequoyah Nuclear Plant
2600 Igou Ferry Road
Soddy Daisy, Tennessee 37379