


Commonwealth Edison Company  
Braidwood Generating Station  
Route #1, Box 84  
Braceville, IL 60407-9619  
Tel 815-458-2801



November 3, 1998

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, D.C. 20555


The enclosed Licensee Event Report (LER) from Braidwood Generating Station is being transmitted in accordance with 10 CFR 50.73(a)(2)(i)(B), which requires a 30-day report.

The following commitment was made in this LER:

- Procedure BwHS TRM 3.8 a.3-1, "Surveillance for Inspection and Testing of 480 Volt Motor Control Center (MCC) Draw-Out Units," will be enhanced to include a visual inspection of the motor starter.

This report is number 98-005-00, Docket Number 50-456.

If your staff has any questions or comments concerning this LER, please refer them to Terrence Simpkin, Braidwood Regulatory Assurance Supervisor, at (815) 458-2801, extension 2980.

  
Timothy J. Tulon  
Site Vice President  
Braidwood Nuclear Generating Station

Enclosure: Licensee Event Report No. 456-98-005-00

cc: Regional Administrator-USNRC, Region III  
NRC Senior Resident Inspector-Braidwood Station

nrc/98072tjt.doc

9811090149 981103  
PDR ADOCK 05000456  
S PDR