



Commonwealth Edison
One First National Plaza, Chicago, Illinois
Address Reply to: Post Office Box 767
Chicago, Illinois 60690

May 6, 1986

Mr. James G. Keppler
Regional Administrator
Region III
U.S. Nuclear Regulatory Commission
799 Roosevelt Road
Glen Ellyn, IL 60137

SUBJECT: Braidwood Station Units 1 and 2
Open Items 50-456/84-03-04 and 50-457/84-03-04
NRC Docket Nos. 50-456 and 50-457

REFERENCE: (a) C. J. Paperiello letter to C. Reed
dated March 16, 1984

Dear Mr. Keppler:

This letter is in response to an inspection conducted by Dr. M. J. Oestmann and Mr. R. B. Holzman on April 21, 1986 through April 25, 1986 at Braidwood Station.

Per discussions at the April 25, 1986 exit meeting, this letter is being sent to confirm that charcoal filter cartridges have been installed on the six fixed air sampler units at Braidwood and all six units are fully operational as of the date of this letter. It is our understanding that the completion of this activity allows closure of open items 50-456/84-03-04 and 50-457/84-03-04 identified in reference (a).

If you have any further questions on this matter, please direct them to this office.

Very truly yours,

8605130204 860506
PDR ADOCK 05000456
G PDR

Anthony Miosi
for D. L. Farrar
Director of Nuclear Licensing

DLF/JKJ/jab

cc: NRC Resident Inspector - Braidwood
Dr. M. J. Oestmann - USNRC RIII

*IE06 1/0
delete
RIII*

1666K

MAY 8 1986