



FISHER QUALIFICATION REPORT
Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation

FQP-11AB-7
Revision B
October 31, 1985
Page 1 of 12

©Fisher Controls

QUALIFICATION REPORT FQP-11AB-7

Group VII Control Valves

for

ALVIN W. VOGTLE NUCLEAR PLANT
UNITS 1 & 2
GEORGIA POWER

IMPORTANT NOTE

THE REVISION LEVEL OF THIS DOCUMENT IS SHOWN AT THE TOP OF EACH PAGE OF THE DOCUMENT. PLEASE SPECIFY THIS REVISION LEVEL WHEN REFERRING TO THIS DOCUMENT.

THIS REVISION LEVEL WILL BE INCREASED WHEN ANY PAGE OF THE DOCUMENT IS REVISED.

PROPRIETARY


This document is property of Georgia Power Company and is not to be reproduced, copied, transferred or used by anyone else without written permission from Georgia Power Company.

N29-24/ 1

8605130349 860507
PDR ADDOCK 05000424
E PDR

FISHER QUALIFICATION REPORT

FQP-11AB-7
Revision B
October 31, 1985



Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation

Page 2

©Fisher Controls

Control Valve Assemblies per FQP-11AB

Alvin W. Vogtle Nuclear Power Plant, Units 1 & 2
Georgia Power Company
Bechtel Power Corp. Purchase Order No.: PAV-206, PAV 2-34
Design Specification No.: X5AC03, Rev. 11, App. EA, Rev. 3, & App. QG, Rev. 0
Seismic Category/Class: Seismic Category I, Nuclear Class 2
Fisher Representative Order No.: 22B-X5AC03-N1T, N2T, N1U, & N2U
Qualification Group: VII
Environmental Designators: IB-R-111, V-R-117, V-R-125
Order Items: see table page 5
Serial Numbers: see table page 5
Tag Numbers: see table page 5
Bechtel Data Sheets: CX5DL-98, 110, 148, 150



This is to certify that, to the best of my knowledge and belief, the qualification information listed in the Table of Contents (Page 3) or referenced in the following qualification summary is complete and accurate. The information meets the requirements and intent of the above design specification, as interpreted by the applicable Fisher Qualification Plan, FQP-11AB.

Dave Stanze

Dave Stanze
Senior Engineer

I certify that I accept responsibility for the adequacy of this document, which was prepared by others, to the same degree that I would if I had prepared it, and that I am a duly Registered Professional Engineer under the laws of the State of Iowa.

John Dresser


John Dresser Reg. No: 7547
Registered Professional Engineer

Date: 10-31-85



Certified and Approved by:

Floyd D. Jury
Floyd D. Jury, Manager
Engineering Qualification and Analysis



Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation


TABLE OF CONTENTS

	PAGE
Title/Change Page.....	1
Certificate of Compliance.....	2
Table of Contents.....	3
List of Attachments.....	4
1.0 Purpose and Scope.....	5
2.0 Valve Assembly Description.....	5
3.0 Requirements.....	5
4.0 Results.....	6
5.0 Supplementary Qualification.....	10
6.0 Maintenance and Qualified Life.....	11
7.0 Statement of Qualification.....	12



PROPRIETARY

This document is property of Georgia Power Company and is not to be reproduced, copied, loaned, lent, or used by anyone else without written permission from Georgia Power Company.



Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation

LIST OF ATTACHMENTS

1. Resonant Frequency Test Report - Fisher Lab Problem 1667, Report 192
2. ES 117, Rev. F Seismic Analysis, dated 9-24-84 and Certification, dated 12-4-84
3. Pressure Retaining Parts Stress Calculation: NA-140, Rev. A
4. Static Side Load Test of Vogtle Item 149, 14" 9280 Butterfly Valves with Bettis Actuator Model No. NT316B-SR2-M3, Fisher Lab Problem 1662, Report 70
5. Certificates of Compliance and Related Documentation - Bettis Actuators for Group VII Valves
6. Arrhenius Rate Equation Calculation
7. Effects of Gamma Radiation Exposure to 200 Mrads on 20" Type 9220 Valve With Bettis Actuator, Fisher Lab Problem 1685-3, Report 8
8. Valve Closure Test of a 6" Prototype Snupps Butterfly Valve; Wyle Report Number 44503-0
9. Combined Loads Shaft Analysis, dated December 5, 1984
10. ES 199, Rev. A, Verification of Rotary Valve Shaft Stress Analysis Program
11. ANSYS Program Q.A. Statement (Swanson Analysis System letter dated 8/27/85)
12. ES 121, Rev. D, Control and Maintenance Procedures for FCS Engineering Analytical Computer Programs and Data Bases
13. Operability Qualification Data

Note: Report FQP-11A, a separate related volume entitled "Vogtle Environmental Qualification Report for Type 9200 Butterfly Control Valve Assembly" has been previously furnished under separate cover.



1.0 PURPOSE AND SCOPE

- 1.1 This Qualification Summary is submitted to verify qualification of the following Nuclear Code Class 2 active control valve assemblies for Seismic Category I service. Information presented and referenced in this report is in accordance with the specification listed above, as interpreted by Fisher Qualification Plan: FQP-11AB.
- 1.2 The valves covered by this report are designated active valves, Nuclear Safety Class 2, Nuclear Code Class 2, and Seismic Category I (Bechtel Project Class 212). These on-off service containment isolation valves are located in the sprayed vapor region of the containment building or in the equipment building.

2.0 VALVE ASSEMBLY DESCRIPTION

The valves shown to be qualified by this report are 14" ANSI Class 150, Type 9280, butterfly valve assemblies. Actuators are Bettis NT316B-SR2-M3 pneumatic piston actuators. Specific production valves covered by this report are as follows:

<u>Item No.</u>	<u>Unit 1 Serial No.</u>	<u>Unit 1 Tag No.</u>	<u>Item No.</u>	<u>Unit 2 Serial No.</u>	<u>Unit 2 Tag No.</u>
179	8669191	1-HV-2626B	147	8670354	2-HV-2626B
180	8672366	1-HV-2627B	148	8672368	2-HV-2627B
181	8672365	1-HV-2628B	149	8670355	2-HV-2628B
182	8672367	1-HV-2629B	150	8672369	2-HV-2629B

3.0 REQUIREMENTS

The requirements for Group VII valves are as follows:

- 3.1 Rigid Valve Requirement - The lowest resonant frequency of these valves must be shown to be greater than or equal to 33 Hz (see FQP-11AB, Paragraph 2.3.2.).
- 3.2 Structural Integrity Requirements - It must be shown that extended structure stress levels meet the acceptance criteria of Fisher Engineering Standard ES 117 (Attachment 3, FQP-11AB), when the assemblies are loaded with a 4.5 g triaxial load (see FQP-11AB Paragraphs 2.2 and 3.3.1; also see Paragraph 3.5 of FQP-11AB for pressure-retaining part stress calculation procedure, per SAG 1034).
- 3.3 Environmental Requirements - It must be shown that the environmental conditions listed in Appendices EA-1 Rev. 3 and EA-5 Rev. 3 of Bechtel Specification for Environmental Designators IB-R-111,

FISHER QUALIFICATION REPORT

FQP-11AB-7
Revision B
October 31, 1985Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation

Page 6

©Fisher Controls


V-R-117, and V-R-125 can be met by the subject valves without affecting the pressure retaining integrity of the valve assemblies or interfering with the safety-related function. (see FQP-11AB, Paragraph 6.3).

- 3.4 Operability requirements - Capability of the subject "active" valves to perform the designated safety-related function must be shown in keeping with the FQP-11AB, Paragraph 5.1, requirements. The safety-related function of these Bettis actuator valve assemblies is to provide a "fail-closed" disc position upon loss of air pressure to the cylinder.

4.0 RESULTS

The ability of the subject valves to satisfy the requirements listed in Section 3 above is demonstrated in the following manner:

- 4.1 The lowest resonant frequency of these valves has been determined by impulsive excitation test and by analysis. The testing was done in the Fisher Laboratory as reported in Lab Problem 1667, Report 192. The analysis was done (9-24-84) according to Fisher Engineering Standard, ES 117, Rev. F (Attachment 3, FQP-11AB). ES 136, Rev. D is an algorithm verification of ES 117, Rev. F and is included as Attachment 4, FQP-11AB. The lowest resonant frequency as determined by test is 43.5 Hz, and the calculated lowest resonant frequency for the test unit is 37 Hz. The resonant frequency test report and ES 117, Rev. F analysis are included as Attachments 1 and 2 to this final report. The lowest resonant frequency is above 33 Hz as required and is within 20% of the calculated lowest resonant frequency value.
- 4.2 The seismic analysis (done at 9.5 g triaxial) and certification are included as Attachment 2 to this report. The analysis printout provided is for a horizontal shaft orientation in a vertical pipeline. This orientation has been determined to be the most highly stressed orientation possible and therefore verifies that this valve assembly is qualified for any orientation, with respect to seismic extended structure stresses. This is provided per Paragraph 4.1.1, Part 5 of the X5AC03 Specification. Supplementary stress calculations for pressure retaining valve parts are included as Attachment 3 to this report (see FQP-11AB, Paragraph 3.5). All stress levels are shown to be acceptable. Actuators are being qualified by Bettis in accordance with Section 2.6 of FQP-11AB.



FISHER QUALIFICATION REPORT

Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation

FQP-11AB-7
Revision B
October 31, 1985

Page 7

©Fisher Controls

- 4.3 The environmental requirements (per Attachments EA-1 Rev. 3 and EA-5 Rev. 3) for Normal/Abnormal conditions are as follows:

Temperature: 135/35°F
Pressure: 11.7 psia to 60 Psig
Radiation: 5×10^5 Rads
Relative Humidity: 90%

These levels are within the conditions considered during valve design and can be met without exception. Valve design is in accordance with Section III of the ASME Boiler and Pressure Vessel Code and body pipeline connections mate with standard ANSI Class 150 flanges.

The maximum DBA/Post-DBA temperature/pressure conditions are listed in Paragraphs 4.4.2 and 4.4.3 of this report, and it is explained there how the levels can be met. The maximum DBA/Post-DBA radiation level is 2×10^8 rads, and Laboratory Report 1685-3, Report 8 shows how a similar valve with a T-ring of identical EPDM material performed at this radiation dosage. Lab Report 1685-3, Report 8 is included as Attachment 7 to this report. Also, the maximum DBA/Post-DBA relative humidity is 100%, and the valve-assemblies are in the sprayed vapor region. However, there would be no detrimental effect to the safety mode (fail-closed position) performance of the valve-assemblies by exposure to 100% humidity, vapor, or spray.

- 4.3.1 Similarity between the Vogtle production valves, covered in this report, and the environmental test valve discussed in FQP-11A, permits applying the elastomer test results to the valves of this Vogtle group. Attachment A-3 of FQP-11A discusses modifications and exceptions to the environmental test program that adapt it to the Vogtle project.
- 4.3.2 The elastomer T-ring disc seal in these Vogtle valves is made of EPDM (ethylene propylene) suitable for a design temperature range of 0°F to +300°F. EPDM T-ring seals are satisfactory without significant loss of function for radiation dosages up to 1×10^7 rads, but should be replaced, along with any other elastomeric parts, at intervals of four years or less, depending upon continuous service temperatures experienced, or when cumulative radiation exposure exceeds 1×10^7 rads.
- 4.3.3 The shaft packing used in these production valves consists of Grafoil ribbon and filament rings. The packing is suitable for the maximum design pressures and temperatures involved (60 psig, 300°F) and for the environmental conditions specified for Environmental Designators IB-R-111, V-R-117, and V-R-125.

FISHERAlvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power CorporationFQP-11AB-7
Revision B
October 31, 1985

Page 8

©Fisher Controls

4.4 Margin allowances are addressed as follows.

- 4.4.1 Normal/Abnormal Temperature -- The maximum external Normal/Abnormal environmental temperature for this valve group is 135°F. The maximum internal temperature is 120°F. Since the lowest valve design temperature is 300°F, the margin provided for Normal/ Abnormal conditions is 165°F, well in excess of the 15°F margin suggested in IEEE 323-1974.
- 4.4.2 DBA/Post-DBA Temperature - The maximum external DBA/Post-DBA environmental temperature is 400°F for slightly less than 15 minutes per Figure 9 (Attachment EA-84 Rev. 3) to Specification Number X5AC03. The T-ring seal is the only elastomeric component in the Group VII valve-assemblies exclusive of the Bettis Actuator. Its capability to withstand these temperatures has been demonstrated by testing done by Wyle Laboratories using a test valve of similar T-ring seal design. The temperature level results achieved in the Wyle test program (per Report Number 45390-1) to show the capability to withstand air temperatures of 400°F for 15 minutes are provided in Attachment 4 to Attachment 9 (NA-42) of Qualification Plan FQP-11AB. Also, see Paragraphs 1.2 and 5.5 of FQP-11A* for a description of the extension of these environmental test results in meeting the Vogtle requirements. Since the tested time duration at high temperature levels meets or exceeds the Vogtle time duration requirements, margin has been provided for these short-term, one-time temperature conditions.
- 4.4.3 Pressure - The maximum external Normal/Abnormal/DBA/Post-DBA environmental pressure is 60 psig, and the maximum internal pressure is 0.18 psig. These pressures are either equal to or below the valve design pressure rating of 60 psig.
- 4.4.4 Frequency - Reference is made to Paragraph 4.1, the margin regarding resonant frequency is 4.0 Hz above the required 33 Hz.
- 4.4.5 Vibration - The level of seismic loading included in the static side load test was 10.0 g uniaxial (5.8 g triaxial equivalent), furnishing a margin of 1.3 g seismic excitation over the required 4.5 g triaxial.

* FQP-11A, a separate volume titled "Vogtle Environmental Qualification Report for Type 9200 Butterfly Control Valve Assembly", was furnished previously under separate cover.



4.5 Bettis Actuator data for the pneumatic piston actuators associated with the Group VII valve assemblies is maintained in the Fisher QA files, and copies will be furnished to Bechtel under separate cover, according to the submittal schedule. However, copies of the specific Bettis Certifications and Valve Assembly Test Reports are included in Attachment 5 of this report, showing the results of production test, including bi-directional seat leakage tests and stroking time tests.

4.6 Operability Results

4.6.1 Operability tests were performed before, during, and after each application of side load force to evaluate performance of the valve under simulated seismic conditions, in accordance with the requirements of test procedure FTP-33, Rev. D (Attachment 11 to FQP-11AB).

4.6.2 Functional tests consisted of packing leakage tests, bi-directional seat leakage tests, stroking time tests, and verification of the "fail-closed position" safety-related function. Complete procedures followed during all tests are presented in Fisher Lab Problem 1662, Report 70 included as Attachment 4 of this report.

4.6.3 Side load applied at the center-of-gravity of the extended structure was the equivalent of a 10.0 g uniaxial load (2446 lbs) applied in the weakest direction. This load level corresponds to a 5.8 g triaxial load, which is more than 1.0 g above the required 4.5 g triaxial; therefore, the operability test qualifies the valve assembly for any orientation.

4.6.4 No packing leakage was noted during any of the functional testing. Packing leakage tests were run at 180 psig.

4.6.5 Seat Leakage was not detected in either flow direction during the functional tests. A 60 psig pressure drop was maintained during the seat leakage testing.


4.6.6 The test unit showed no structural damage after the tests and maintained the required "fail-safe" position without deviation (fail-closed position).


FISHERAlvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation

Page 10

©Fisher Controls

5.0 SUPPLEMENTARY QUALIFICATION

The ability of these valves to meet the additional functional tests required as set forth in Paragraphs 5.3.3.4 and 5.3.3.5 of Bechtel Specification X5AC03 Rev. 11 are addressed as follows: 

- 5.1 A combined loads shaft analysis considering dynamic (flow-induced) loads, shutoff loads, and seismic loads from the disc is provided in Attachment 9. The most critical stress concentration is at the shaft pin location. The stress due to shear is 21703 psi which is less than the allowable of 25725 psi and therefore demonstrates the adequacy of the most critical component (the valve shaft) under the most severe conditions. (See FQP-11AB, Paragraph 5.3.1)
- 5.1.1 Verification of the Corapolis Shaft Program (printout included in Attachment 9) is provided in ES 199 (Attachment 10), using applicable analysis examples. The reason for the examples used in the program is presented, followed by manual calculations and a comparison of the manual and computer calculations.
- 5.1.2 A statement from Swanson Analysis Systems, Inc. is included as Attachment 11, assuring that an independent Quality Assurance (Q.A.) Department at Swanson has responsibility for verification of all ANSYS versions, with a Q.A. manual issued and in force. 
- 5.1.3 Fisher has a standard in effect defining computer program documentation and Q.A. procedures for Fisher FCS engineering analytical applications. This engineering standard (ES 121) is included as Attachment 12 to this report and applies to Fisher originated programs as well as to purchased or leased programs such as ANSYS.
- 5.2 A 60 psid bi-directional shut-off test on each of the eight production valves was conducted. (See Assembly Test Reports, Attachment 5). The results (0 leakage) demonstrate the seat leakage integrity of the closed valves. (Reference FQP-11AB, Paragraph 5.3.2)

FISHER QUALIFICATION REPORT

FISHERAlvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power CorporationFQP-11AB-7
Revision B
October 31, 1985


Page 11

©Fisher Controls

- 5.3 No-flow valve closure data as presented in the Assembly Test Reports (Attachment 5) does not consider the effect of full-flow conditions. Based upon the provisions set forth in FQP-11AB, Paragraph 5.3.3, the no-flow closure times will be corrected to account for full-flow effects. Table I of the Valve Closure Test of a 6" Prototype Snupps Butterfly Valve (Wyle Report No. 44503-0) indicates that the worst test case yields a factor of 1.24 (1.25 / 1.01). (See Attachment 8). Applying this factor (1.24) to the worst no-flow closure time (3.5 sec) results in a full-flow closure time value of 4.34 sec. This is still less than the specified 5 sec maximum closure time allowed and is therefore adequate.
- 5.4 Bechtel Power Corporation has assembled a document relating to the subject valve assemblies entitled "Operability Qualification of Purge and Vent Valves", based on Fisher-furnished data, documentation, and calculations. A copy is furnished in Attachment 13, together with related correspondence. This was issued to satisfy the requirements of NUREG-0737 for containment purge and vent valves, i.e. demonstrate valve closure from an open position during a DBA. △

6.0 MAINTENANCE AND QUALIFIED LIFE


- 6.1 Qualified Life of these Vogtle project valves is limited by the elastomeric parts. To address this, Fisher has conducted an activation energy testing program as reported in Attachment A-7 of Report FQP-11A. That data covers common elastomeric materials, including those used for O-rings, T-ring seals, packing components, and gaskets for the valves in this qualification group. These elastomeric parts, gaskets, and packing components are all identified as recommended spare parts on the valve-assembly Bill-of-Material Drawings for the Group VII Valves (48A9881, 48A9882, 48A9883, and 48A9884).
- 6.2 The lowest activation energy for any of the elastomeric materials was found to be 0.79 eV. Based on the results of a prior environmental test program, it is recommended that all elastomeric parts be replaced on a regular four-year cycle, assuming a maximum continuous normal service temperature of 131°F or less. (See calculation in Attachment 6 of this report). However, if the service temperature is maintained continuously at 135°F, the qualified life becomes 3 years, 120 days and the replacement cycle should be modified accordingly. (See calculation in Attachment 6 of this report). Elastomers should also be replaced if the cumulative radiation exposure exceeds 1×10^7 rads.


Alvin W. Vogtle Nuclear Plant
Georgia Power
Bechtel Power Corporation


©Fisher Controls

- 6.3 The normal service qualified life for Fisher equipment can be renewed for another service period by replacement of all elastomeric components listed in Paragraph 6.1 above, in accordance with the procedures provided in Fisher instruction manuals. Successive renewals of qualified life can be attained in increments up to the intended life of the plant or to 41 years, whichever is less.
- 6.3.1 Each time the valve assembly is disassembled, new packing and gaskets should be used upon re-assembly.
- 6.3.2 Replacement of the elastomeric parts in the Bettis actuator should comply with the specified Bettis procedures and schedules furnished from Bettis.
- 6.4 Even though the specified orientation (pipeline vertical, shaft horizontal) has been primarily considered in the qualification documentation provided in this report, there are no qualification restrictions for any orientation as far as the Fisher supplied comments are concerned.
- 6.5 Additional calculations and further qualification rationale are provided in FQP-11A.

7.0 STATEMENT OF QUALIFICATION

The qualification data presented herein for the Group VII valves meet the requirements and intent of Bechtel Power Corp., Specification No. X5AC03, Rev. 11, including Appendices EA, Rev. 3, and QG, Rev. 0, as interpreted by Fisher Qualification Plan FQP-11AB. 


John Dresser
Engineering Reviewer


Dave Stanze
Senior Engineer

ATTACHMENT 1

FQP-11AB-7

Resonant Frequency Test Report
Fisher Lab Problem 1667, Report 192

Fisher Controls

FISHER**Laboratory Report**

Problem	1667
Report	192
Page	1
Date	9-25-84

©Fisher Controls 1984

**DISTRIBUTION
RESTRICTED**By *Jon Milliken*

PRODUCTION
RESONANT FREQUENCY TEST
OF VOGTLE ITEM 149

PROJECT NUMBER: 78EC07
PROJECT NAME: Vogtle
PROJECT ENGINEER: Don Winnike
TEST ENGINEER: Jon Milliken
ITEM: 149
ORDER NUMBER: 22B-X5AC03-N2T
SERIAL NUMBER: 8670355
EM/FS NUMBER:
BILL OF MATERIALS DWG.: 39A2460
DIMENSIONED ASSEMBLY DWG.: 48A9882

ACTUATOR TYPE: 5ettis	ACTUATOR SIZE: NT316-SR-2-M3
BONNET STYLE:	BONNET SIZE: BONNET CLASS:
BODY DESIGN: 9280	BODY SIZE: 14" BODY CLASS: 150

APPURTENANCES: 2 NAMCO Limit Switches 180-31302/32302, ASCO Solenoid NPK8316A74E, Type 262C Air Filter, Type 95H Regulator, Type H120 Relief Valve, Ashcroft Pressure Gage

OTHER SPECIAL IDENTIFICATION: Actuator S/N 83-9045-4

PURPOSE: Model Verification

LOWEST CALCULATED RESONANT FREQUENCY OF TEST ITEM: 37.1 Hz/X-Axis

TEST PROCEDURE: Production Testing Per FTP-5

RESULTS: X-Axis - 43.95 Hz
Y-Axis - 72.75 Hz
Z-Axis - 43.46 Hz

CONCLUSIONS AND RECOMMENDATIONS: The calculated lowest resonant frequency of 37.1 Hz in the X-axis is 18.5% lower than the measured resonant frequency of 43.95 Hz in the X-axis. This is acceptable.

Note: The GenRad test data results yielded a frequency of 43.5 Hz for the Z-axis and 43.0 Hz for the X-axis. The resolution limit for both the Zonic FFT and the GenRad is 0.5 Hz. This indicates that the X and Z axis frequencies could be the same and the Y-axis rotation is the appropriate mode.

Jon Milliken
J.B. Milliken
Evaluation & Analysis Department

REP24/23

INSTRUMENTATION EQUIPMENT SHEET

9510-ARG003-1151-2

PAGE NO. 2

PROBLEM NO. 1667
REPORT NO. 192

DATE 9-14-84 PROBLEM NO. 1667 REPORT NO. 192 TEST AREA Seismic
 TECHNICIAN Bob Roe TEST ENGINEER Jon Milliken TEST DESCRIPTION Resonant Frequency

NO.	INSTRUMENT	MANUFACTURER	MODEL NO.	SERIAL NO.	FISHER CONTROL NO.	USEABLE RANGE	ACCURACY	CALIBRATION	
								ON	DUE
1	Data Memory Sys	Zonics	5003	465	7006-1			1-83	1-85
2	Hammer & Force Tr	PCB	205M08	175	9401-1	±5000 Lb		11-82	11-84
3	Accelerometer	PCB	308B	3535	9701-7	3KHz/50G	<+3.5%	1-83	1-85




Figure 1

X-Axis - 43.95 Hz.
Y-Axis - 72.75 Hz.
Z-Axis - 43.46 Hz.

Tape Data Location	Reel No. 78EC07D
	X Data Begins 1540-1600
	Y Data Begins 1600-1640
	Z Data Begins 1640-1700
	Recorder - HP3964A

ATTACHMENT 2

FQP-11AB-7

ES 117 Analysis and Seismic Certification

- a) Seismic Certification Letter for Group VII Vogtle Valves dated December 4, 1984
- b) Analysis Model Drawings for Group VII Valves Extended Structure
- c) Assembly Drawings 48A9881, 48A9882, 48A9883, and 48A9884
- d) ES 117, Rev. F Computer Printout for Group IIV Vogtle Valves dated September 24, 1984

FISHER**Fisher Controls**


December 4, 1984


Seismic Certification for:
 Representative Order: 22B-X5AC03-N1T, N2T
 Customer Order: PAV-206, Pav-2-34
 Georgia Power Company
 Vogtle Nuclear Plant - Units 1 & 2
 Active Butterfly Valve Assemblies per FQP-11AB

<u>Item Number</u>	<u>Tag Number</u>	<u>Serial Number</u>	<u>Description</u>
179	1-HV-2626B	8669191	14" Type 9280 Valve Body
180	1-HV-2627B	8672366	NT316B-SR2-M3
181	1-HV-2628B	8672365	Bettis Actuator
182	1-HV-2629B	8672367	
147	2-HV-2626B	8670354	
148	2-HV-2627B	8672368	
149	2-HV-2628B	8670355	
150	2-HV-2629B	8672369	

Enclosed are the stresses and resonant frequency calculations for the above items. In accordance with Bechtel Specification X5AC03, Fisher Qualification Plan (FQP-11AB), and Paragraph VIII of Fisher Engineering Standard 117, the items are considered capable of maintaining their structural integrity when submitted to a triaxial load of 9.5 g's. Acceptable stress limits for materials are considered to be allowable stresses found in ASME Boiler and Pressure Vessel Code, Section III, for Code Class 2, per the Winter 75 Addenda.

The calculated resonant frequencies are well above the acceptable limit (33 Hz), and verified by test (see Report FQP-11AB-7).





 Jon Whitesell
 Qualification Analyst


 Don Winnike
 Qualification Engineer


FISHER CONTROLS COMPANY
SEISMIC-4
SEISMIC ANALYSIS
OF
CONTROL VALVE ASSEMBLIES
(REV F)

9510-AX5AC03-5151-2 020

39A2459



DISC CHORDAL SWING Ø AT THE VALVE FACE IS 11.81
 TOTAL VALVE WEIGHT: 925 LBS ±10%







UNLESS OTHERWISE SPECIFIED
 UNIT OF MEASURE: INCHES
 ENVELOPE DIMENSIONS ARE ±.25

DIMENSIONS CERTIFIED CORRECT		BY <i>Ken A. Leggett</i> DATE 7-22-83	
VALVE PRESS/TEMP RATING ANSI B16.34-1977 CLASS 150			
CUST GEORGIA POWER COMPANY		14" BODY	
P.O. NO: PAV-206 VOGTLE UNIT 1		NT316-SR2-M3-9280	
ORDER NO: 22B-X5AC03-NIT		BETTIS ACTUATED	
TAG NO: 1HV-2626B, 1HV-2628B		CONTROL VALVE	
SERIAL NO: 8669191, 8672365		CW TO CLOSE VALVE	
		SHAFT ROTATION	
		HORIZ PIPE, VERT SHAFT	
DATE	REVISIONS	OWN	WUR
7-9-83	A	7-B-B3	7-22-83
11-08-83	B	REVISE FLOW	
12-13-83	C	REVISED ACCESS	
REVISE FLOW			
REVISED ACCESS			
DATE	REVISIONS	OWN	WUR
7-9-83	A	7-B-B3	7-22-83
11-08-83	B	REVISE FLOW	
12-13-83	C	REVISED ACCESS	
REVISE FLOW			
REVISED ACCESS			
FISHER		ITEM 179, 181	
Fisher Controls		DWG NO	
Manufactured in USA		39A2459	
© Fisher Controls 1983		SCALE NONE	


9410-AX5AC03-S151-2 021

39A2460



DISC CHORDAL SWING ϕ AT THE VALVE FACE IS 11.81
 TOTAL VALVE WEIGHT: 925 LBS $\pm 10\%$




UNLESS OTHERWISE SPECIFIED
 UNIT OF MEASURE: INCHES
 ENVELOPE DIMENSIONS ARE $\pm .25$



DIMENSIONS CERTIFIED CORRECT	BY <i>Kevin A. Loggins</i> DATE 7-22-83	
	VALVE PRESS/TEMP RATING ANSI B16.34-1977 CLASS 150	
	CUST GEORGIA POWER COMPANY P.O. NO. PAV 2-34 VOGTLE UNIT II ORDER NO. 22B-X5AC03-N2T TAG NO. 2HV-2626B, 2HV-2628B SERIAL NO. 8670354, 8670355	
	14" BODY NT316-SR2-M3-9280 BETTIS ACTUATED CONTROL VALVE CW TO CLOSE VALVE SHAFT ROTATION HORIZ PIPE VERT SHAFT	
REVISIONS	DATE	REVISIONS
	7-8-83	A FIRST U.S. MAN
	11-11-83	B REVISE FLOW ORIENTATION
12-13-83 C REVISED ACCESSORY ORIENTATION		
FISHER		ITEM 147, 149
Fisher Controls 1983		39A2460 C

9510-AX5AC03-5151-2 027

39A2461




ACCESSORIES WILL BE PIPED PER THIS INSTALLATION SCHEMATIC

← IHV-2629B
→ IHV-2627B

DISC CHORDAL SWING ϕ AT THE VALVE FACE IS 11.81
TOTAL VALVE WEIGHT: 925 LBS ± 10%

UNLESS OTHERWISE SPECIFIED
UNIT OF MEASURE: INCHES
ENVELOPE DIMENSIONS ARE ± .25







14 SCHED STD BUTT
WELD END PER BECTEL
DWG CX4DG02

12/3/83 C REVISED ACCES- SORY ORIENTATION 11/11/83 B REVISE FLOW 7-8-83 A FIRST U.S. WIN DATE	DIMENSIONS CERTIFIED CORRECT		BY <i>Kevin A. Loggins</i>	DATE 7-22-83
	VALVE PRESS/TEMP RATING ANSI B16.34-1977 CLASS 150			
	CUST. GEORGIA POWER COMPANY P.O. NO. PAV-206 VOGTLE UNIT 1 ORDER NO. 22B-X5AC03-NIU TAG NO. IHV-2627B, IHV-2629B		14" BODY NT316-SR2-M3-9280 BETTIS ACTUATED CONTROL VALVE CW TO CLOSE VALVE SHAFT ROTATION HORIZ PIPE, VERT SHAFT	
	SERIAL NO. 8672366, 8672367			
C AMAS 12-13-83 B WGR 11-11-83 © Fisher Controls 1983		FISHER Fisher Controls March 1981 Issue USA		ITEM 180, 182 DWG NO. 39A2461 SCALE NONE


9510-AXSAC03-5151-2 0223

39A2462



DISC CHORDAL SWING ϕ AT THE VALVE FACE IS 11.81
TOTAL VALVE WEIGHT: 925 LBS $\pm 10\%$

UNLESS OTHERWISE SPECIFIED:
UNIT OF MEASURE: INCHES
ENVELOPE DIMENSIONS ARE $\pm .25$






14 SCHED STD BUTT
WELD END PER BECHTEL
DWG CX4DGO2

DIMENSIONS CERTIFIED CORRECT VALVE PRESS/TEMP RATING ANSI B16.34-1977 CLASS 150 CUST GEORGIA POWER COMPANY P.O. NO: PAV 2-34 VOGTLE UNIT II ORDER NO: 22B-XSAC03-N2U TAG NO: 2HV-2627B, 2HV-2629B SERIAL NO: 8672368, 8672369	DATE	7-8-83	BY	W. A. Laguarda	DATE	7-22-83
	ORIENTATION	11-11-83	REVISE	A	FIRST	U. W. N.
	SOFT ORIENTATION	12-13-83	REVISED	C	ACCES	
FISHER Fisher Controls MADE IN U.S.A.		ITEM 148, 150 39A2462		NONE		

48A982

48A982

QTY	PART NUMBER	DESCRIPTION	UNIT OF MEASURE
1	51840010022	VALVE BODY	EA
1	51840010023	VALVE BODY ASSEMBLY	EA
1	51840010024	VALVE BODY	EA
1	51840010025	VALVE BODY	EA
1	51840010026	VALVE BODY	EA
1	51840010027	VALVE BODY	EA
1	51840010028	VALVE BODY	EA
1	51840010029	VALVE BODY	EA
1	51840010030	VALVE BODY	EA
1	51840010031	VALVE BODY	EA
1	51840010032	VALVE BODY	EA
1	51840010033	VALVE BODY	EA
1	51840010034	VALVE BODY	EA
1	51840010035	VALVE BODY	EA
1	51840010036	VALVE BODY	EA
1	51840010037	VALVE BODY	EA
1	51840010038	VALVE BODY	EA
1	51840010039	VALVE BODY	EA
1	51840010040	VALVE BODY	EA
1	51840010041	VALVE BODY	EA
1	51840010042	VALVE BODY	EA
1	51840010043	VALVE BODY	EA
1	51840010044	VALVE BODY	EA
1	51840010045	VALVE BODY	EA
1	51840010046	VALVE BODY	EA
1	51840010047	VALVE BODY	EA
1	51840010048	VALVE BODY	EA
1	51840010049	VALVE BODY	EA
1	51840010050	VALVE BODY	EA
1	51840010051	VALVE BODY	EA
1	51840010052	VALVE BODY	EA
1	51840010053	VALVE BODY	EA
1	51840010054	VALVE BODY	EA
1	51840010055	VALVE BODY	EA
1	51840010056	VALVE BODY	EA
1	51840010057	VALVE BODY	EA
1	51840010058	VALVE BODY	EA
1	51840010059	VALVE BODY	EA
1	51840010060	VALVE BODY	EA
1	51840010061	VALVE BODY	EA
1	51840010062	VALVE BODY	EA
1	51840010063	VALVE BODY	EA
1	51840010064	VALVE BODY	EA
1	51840010065	VALVE BODY	EA
1	51840010066	VALVE BODY	EA
1	51840010067	VALVE BODY	EA
1	51840010068	VALVE BODY	EA
1	51840010069	VALVE BODY	EA
1	51840010070	VALVE BODY	EA
1	51840010071	VALVE BODY	EA
1	51840010072	VALVE BODY	EA
1	51840010073	VALVE BODY	EA
1	51840010074	VALVE BODY	EA
1	51840010075	VALVE BODY	EA
1	51840010076	VALVE BODY	EA
1	51840010077	VALVE BODY	EA
1	51840010078	VALVE BODY	EA
1	51840010079	VALVE BODY	EA
1	51840010080	VALVE BODY	EA
1	51840010081	VALVE BODY	EA
1	51840010082	VALVE BODY	EA
1	51840010083	VALVE BODY	EA
1	51840010084	VALVE BODY	EA
1	51840010085	VALVE BODY	EA
1	51840010086	VALVE BODY	EA
1	51840010087	VALVE BODY	EA
1	51840010088	VALVE BODY	EA
1	51840010089	VALVE BODY	EA
1	51840010090	VALVE BODY	EA
1	51840010091	VALVE BODY	EA
1	51840010092	VALVE BODY	EA
1	51840010093	VALVE BODY	EA
1	51840010094	VALVE BODY	EA
1	51840010095	VALVE BODY	EA
1	51840010096	VALVE BODY	EA
1	51840010097	VALVE BODY	EA
1	51840010098	VALVE BODY	EA
1	51840010099	VALVE BODY	EA
1	51840010100	VALVE BODY	EA



NOTE: THIS DRAWING IS FOR USE IN PART IDENTIFICATION ONLY.



DATE	REVISIONS
1-1-59	FIRST DRAWN
1-1-59	SW T.C.H.E.D.
1-1-59	17 28
1-1-59	37 28

DIMENSIONS CERTIFIED CORRECT BY: *[Signature]* DATE: 7-22-59
 VALVE PRESS. TEMP. RATING: ANSI B16.34-1957 CLASS 150
 BODY: 14
 BODY: 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, 34, 35, 36, 37, 38, 39, 40, 41, 42, 43, 44, 45, 46, 47, 48, 49, 50
 TAG NO. 2 HV-2626B, 2 HV-2626B
 SERIAL NO. B670354, B670355

48A982

40A9883

ITEM NO.	QTY	PART NO.	DESCRIPTION	MATERIAL SPEC.
1	1	5146010027	VALVE BODY ASSEMBLY	517600 AOM SA-564, 51075 31-306
2	1	5146010028	VALVE BODY ASSEMBLY	517600 AOM SA-564, 51075 31-306
3	1	2766410022	TABLE PIN	318 537 AOM SA-351-078M
4	1	4786410022	WALVE DISK	517600 AOM SA-564, 51075 31-306
5	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
6	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
7	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
8	1	2766410022	TABLE PIN	318 537 AOM SA-351-078M
9	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
10	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
11	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
12	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
13	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
14	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
15	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
16	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
17	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
18	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
19	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
20	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
21	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
22	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
23	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
24	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
25	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
26	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
27	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
28	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
29	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
30	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
31	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
32	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
33	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
34	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
35	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
36	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
37	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
38	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
39	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
40	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
41	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
42	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
43	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
44	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
45	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
46	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
47	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
48	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
49	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306
50	1	1647100022	VALVE DISK	517600 AOM SA-564, 51075 31-306
51	1	1927810022	VALVE DISK	517600 AOM SA-564, 51075 31-306
52	1	5111010022	VALVE DISK	517600 AOM SA-564, 51075 31-306



NOTE: THIS DRAWING IS FOR USE IN PART IDENTIFICATION ONLY.

UNLESS OTHERWISE SPECIFIED:
 UNIT OF MEASURE: INCHES
 ENVELOPE DIMENSIONS: DIM 8 28

DATE: 7-22-63
 BY: [Signature]
 CLASS: 150

VALVE PRESS: [Signature]
 POWER COMPANY
 P.O. BOX 206, MOBILE UNIT 1
 CROOKING 228-154033-NU
 TAG NO. 141-26478, 141-26208
 SERIAL NO. P-273566, B-672367

REVISIONS:
 1-11-63 FIRST DRAWN
 1-11-63 SWITCHED

PART NO. 57,38


ITEM NO. 40A9883

40A9883

48A9BB4

9510
KXAC03-5151-2
027

NATIONAL BOARD
YEAR 1963
FISHER CONTROLS CO.
MARSHALLTOWN, IOWA, USA
SERIAL E
CLASSIFICATION PRT 557 50 1P51AT 0007



FIND NO.	PART NO.	DESCRIPTION	MATERIAL SPECS
1	5746014022	VALVE BODY	S31600 ASME SA-182
2	3746011022	DISC & SHMT ASSEMBLY	S31600 ASME SA-564, HD75 31-30MC
3	6172835362	TAPER PIN	S31600 ASME SA-564, HD75 31-30MC
4	2746010402	SHMT	316 SST ASME SA-351-47BM
5	4746010402	VALVE DISC	DOW CORNING COMPOUND 111
6	19570306992	SILICONE LUB. ANT.	EPDM TO DURO (FMS DNAC)
7	11302705552	O-RING	ETHYLENE/PROPYLENE
8	1647204022	O-RING	
9	2746010402	RETAINING RING ASSEMBLY	S31600 ASME SA-479, FMS 20R20 BHM 145-195
10	11774460022	DISC STOP	316 SST ASME SA-351-47BM
11	3746011022	RETAINING RING	18-8 SST
12	3940660002	CAP SCREW	STEEL, NON WELD, FMS 20R13/20 PL
13	16341540622	SALT SCREW	STEEL ASME SA-194-2H/2H PL
14	22490804012	PACKING FLANGE	STEEL ALLOY ASME SA-193-B7/2H PL
15	14381224112	HEX NUT	S31600 ASME SA-479, FMS 20R20 BHM 145-195
16	12480264012	STUD	S31600 ASME SA-479, FMS 20R20 BHM 145-195
17	12490104012	PACKING FOLLOVER	GRAPHITE W/COU FIBROUS LOW CHLORIDE FMS 17014
18	12490104022	PACKING RING	S31600 ASME SA-479, FMS 20R20 BHM 145-195
19	16472794012	PACKING BOX F.W.	STEEL ALLOY ASTM A304-HB4000
20	11302705552	WIGGURIFT KEY	BRONZE GRAPHITE
21	11302705552	BUSHING	STEEL SA-516-70 PL
22	14485724052	CAP SCREW	STEEL ASME SA-214-42B
23	46472374012	SEALING BRACKET	ZINC ASTM B69 TYPE 1
24	14485724052	DRIVE SCREW	18-8 SST
25	12491384032	PACKING RING	GRAPHITE FILAMENT YARN-FMS 17014-17014 LOW CHLORIDE
26	18181379982	LOCKWASHER	BRONZE ASTM B504-C93200
27	11302705552	LOCKWASHER	SST
28	11302705552	SPRING PIN	18-8 SST
29	11302705552	COMPRESSION F.W.	18-8 SST
30	12492304012	SALT SCREW	18-8 SST
31	14306309982	FLOW ARROW	18-8 SST
32	11302705552	CAPLE ASST	18-8 SST
33	16442444012	NAME PLATE	18-8 SST
34	12490474012	NUCLEAR NAME PLATE	18-8 SST
35	18181379982	DRIVE SCREW	18-8 SST
36	1746014112	NETTLE ACTUATOR	ASSEMBLY
37	4747180012	ACTUATOR BRACKET	ST11 W/LOADABLE FMS 20R14
38	3729274052	CAP SCREW	STEEL SA-516-70 PL
39	18181379982	CAP SCREW	STEEL SA-516-70 PL
40	18181379982	CAP SCREW	STEEL SA-516-70 PL
41	18181379982	LOCKWASHER	CARBON STEEL PLATED
42	18181379982	LOCKWASHER	CARBON STEEL PLATED
43	14375729982	NASHER	CARBON STEEL
44	1647242012	NUJTING B.O.Z.	STEEL NON WELD/FMS 20R13
45	1647242012	ANTI-RUPTURE RING	STEEL W/LOADABLE FMS 20R14
46	274724012	SUPPORT BRACKET	STEEL W/LOADABLE FMS 20R14
47	274724012	SUPPORT BRACKET	STEEL W/LOADABLE FMS 20R14
48	1545450022	NAME LIMIT SW. TCR.	ASSEMBLY
49	1545450022	NAME LIMIT SW. TCR.	ASSEMBLY
50	1545450022	NAME LIMIT SW. TCR.	ASSEMBLY
51	1545450022	NAME LIMIT SW. TCR.	ASSEMBLY
52	1545450022	NAME LIMIT SW. TCR.	ASSEMBLY

* - RECOMMENDED SPARE PART
 - APPLY LUBRICANT PER INSTRUCTION MANUAL
 F - FUNCTIONAL PART
 - COMMERCIAL QUALITY PART


NOTE THIS DRAWING IS FOR USE IN PART IDENTIFICATION ONLY.

UNLESS OTHERWISE SPECIFIED
 UNIT OF MEASURE INCHES
 ENVELOPE DIMENS. DIMS ARE X 25

DATE	BY	REVISION
11/10/53	W. J. B. / J. S. B.	1
11/10/53	W. J. B. / J. S. B.	2
11/10/53	W. J. B. / J. S. B.	3
11/10/53	W. J. B. / J. S. B.	4
11/10/53	W. J. B. / J. S. B.	5
11/10/53	W. J. B. / J. S. B.	6
11/10/53	W. J. B. / J. S. B.	7
11/10/53	W. J. B. / J. S. B.	8
11/10/53	W. J. B. / J. S. B.	9
11/10/53	W. J. B. / J. S. B.	10
11/10/53	W. J. B. / J. S. B.	11
11/10/53	W. J. B. / J. S. B.	12
11/10/53	W. J. B. / J. S. B.	13
11/10/53	W. J. B. / J. S. B.	14
11/10/53	W. J. B. / J. S. B.	15
11/10/53	W. J. B. / J. S. B.	16
11/10/53	W. J. B. / J. S. B.	17
11/10/53	W. J. B. / J. S. B.	18
11/10/53	W. J. B. / J. S. B.	19
11/10/53	W. J. B. / J. S. B.	20
11/10/53	W. J. B. / J. S. B.	21
11/10/53	W. J. B. / J. S. B.	22
11/10/53	W. J. B. / J. S. B.	23
11/10/53	W. J. B. / J. S. B.	24
11/10/53	W. J. B. / J. S. B.	25
11/10/53	W. J. B. / J. S. B.	26
11/10/53	W. J. B. / J. S. B.	27
11/10/53	W. J. B. / J. S. B.	28
11/10/53	W. J. B. / J. S. B.	29
11/10/53	W. J. B. / J. S. B.	30
11/10/53	W. J. B. / J. S. B.	31
11/10/53	W. J. B. / J. S. B.	32
11/10/53	W. J. B. / J. S. B.	33
11/10/53	W. J. B. / J. S. B.	34
11/10/53	W. J. B. / J. S. B.	35
11/10/53	W. J. B. / J. S. B.	36
11/10/53	W. J. B. / J. S. B.	37
11/10/53	W. J. B. / J. S. B.	38
11/10/53	W. J. B. / J. S. B.	39
11/10/53	W. J. B. / J. S. B.	40
11/10/53	W. J. B. / J. S. B.	41
11/10/53	W. J. B. / J. S. B.	42
11/10/53	W. J. B. / J. S. B.	43
11/10/53	W. J. B. / J. S. B.	44
11/10/53	W. J. B. / J. S. B.	45
11/10/53	W. J. B. / J. S. B.	46
11/10/53	W. J. B. / J. S. B.	47
11/10/53	W. J. B. / J. S. B.	48
11/10/53	W. J. B. / J. S. B.	49
11/10/53	W. J. B. / J. S. B.	50
11/10/53	W. J. B. / J. S. B.	51
11/10/53	W. J. B. / J. S. B.	52

18A/185A

BETTIS T-316B-SR2-M3-1/L



BY DATE SUBJECT
 CHKD BY DATE
 SHEET NO. OF
 JOB NO.

QUAL GROUP VII

PAGE 1

** FISHER CONTROLS COMPANY **

GEORGIA POWER COMPANY

ASSEMBLY 48A9861, 48A9882

48A9863, 48A9884

ORIENTATION 39A2459, 39A2460

39A2461, 39A2462

REP ORDER 22B-X5AC03-N1T,N2T,N1U,N2U CODE CLASS 2

CUSTOMER ORDER PAV-206, FAV-2-34

SERIAL NO.

TAG NO.

ITEM NO.

8670354	2HV-2626B	147
8670355	2HV-2628B	149
8669191	1HV-2626B	179
8672365	1HV-2628B	181
8672368	2HV-2627B	148
8672369	2HV-2629B	150
8672366	1HV-2627B	180
8672367	1HV-2629B	182

** VALVE DESCRIPTION **

14" NT316B-SR2-M3-12-9280

CODE CLASS 2

BRACKET 47A7168

BETTIS ACTUATOR

ACCESSORIES: ASCO SOLENOID NPK8316A74E

TYPE 95H REGULATOR

DESIGN CONDITIONS: 60 PSIG AT 300 DEG F

ACTUATOR TORQUE: 9800 IN-LBS

REQUIRED FREQUENCY: 33 HERTZ

MAX ALLOWABLE TRI-AXIAL G-LOADING

DATE OF THIS REPORT / SEPT. 24, 1964

CONTROL INPUT DATA

MANUAL INPUT GENERATION FOR VALVE ANALYSIS

SEISMIC STRESSES ARE SUPERIMPOSED BY SQUARE ROOT OF SUM OF SQUARES

STRESS ALLOWABLES ARE COMPARED TO MAXIMUM PRINCIPAL STRESS

MASS, STIFFNESS, LOAD AND STRESS MATRICES ARE NOT PRINTED

STATIC SEISMIC ANALYSIS TO BE PERFORMED

OPERATIONAL LOAD ANALYSIS TO BE PERFORMED

DYNAMIC MODAL ANALYSIS TO BE PERFORMED

CROSS-SECTION DATA

EL. CROSS-SECTION

NO. DESCRIPTION

PARAMETERS

1 TUBE

A = 16.00

, T = .2100

2 SAME AS LAST

QUAL GROUP VII

3	MANUAL DATA				
4	SAME AS LAST				
5	SAME AS LAST				
6	SAME AS LAST				
7	SOLID CIRCLE	A = .8750	,		
8	SAME AS LAST				
9	MANUAL DATA				
10	SAME AS LAST				
11	SAME AS LAST				
12	SAME AS LAST				
13	RECTANG.BOX	A = 4.250 T1= 1.312	,	T = 1.312 R1= .2500	, B = 4.250
14	CHANNEL	A = 8.125 T1= .3120	,	T = .3120 R1= .3120	, B = 1.312
15	SAME AS LAST				
16	CHANNEL	A = 10.13 T1= .3120	,	T = .3120 R1= .3120	, B = 1.312
17	MANUAL DATA				
18	SAME AS LAST				
19	SAME AS LAST				
20	SAME AS LAST				
21	SAME AS LAST				
22	RECTANG.BOX	A = 4.250 T1= 1.312	,	T = 1.312 R1= .2500	, B = 4.250
23	MANUAL DATA				
24	SAME AS LAST				
25	SOLID CIRCLE	A = .8750	,		
26	SAME AS LAST				
27	TUBE	A = 10.00	,	T = .2500	,
28	SAME AS LAST				
29	MANUAL DATA				
30	SAME AS LAST				
31	RECTANGULAR	A = 11.00	,	T = 1.125	,
32	SAME AS LAST				
33	CHANNEL	A = 10.00 T1= .5750	,	T = .7940 R1= .0	, B = 4.375
34	SAME AS LAST				
35	CHANNEL	A = 10.00 T1= .5750	,	T = .7940 R1= .0	, B = 4.375
36	SAME AS LAST				
37	RECTANGULAR	A = 11.00	,	T = 1.875	,
38	RECTANGULAR	A = 11.00	,	T = 1.875	,
39	RECTANGULAR	A = 11.00	,	T = 1.875	,
40	SAME AS LAST				
41	RECTANGULAR	A = 2.875	,	T = 1.875	,
42	SAME AS LAST				
43	SOLID CIRCLE	A = 2.000	,		
44	SOLID CIRCLE	A = 2.000	,		
45	RECTANG.BOX	A = 5.000 T1= 1.375	,	T = 4.875 R1= 1.125	, B = 12.00
46	RECTANG.BOX	A = 5.000 T1= .2500	,	T = .2500 R1= .2500	, B = 3.000
47	SAME AS LAST				
48	RECTANGULAR	A = 5.000	,	T = .7500	,
49	RECTANGULAR	A = .7500	,	T = 4.500	,
50	SAME AS LAST				

QUAL GROUP VII

PAGE 3

JOINT COORDINATE DATA

JOINT NO.	X	Y	Z
1	4.401000	2.812000	-20.906006
2	4.501000	2.812000	-7.312000
3	4.501000	2.812000	-7.312000
4	7.939000	2.812000	-20.906006
5	1.064000	2.812000	-20.906006
6	4.501000	2.812000	-18.906006
7	1.064000	2.812000	-7.312000
8	7.939000	2.812000	-7.312000
9	3.064000	2.812000	-20.906006
10	4.501000	2.812000	-5.000000
11	7.730000	0.0	-2.250000
12	7.730000	0.0	2.250000
13	1.345000	0.0	-2.250000
14	1.345000	0.0	2.250000
15	4.501000	2.812000	5.000000
16	4.501000	2.812000	35.188004
17	4.501000	2.812000	7.250000
18	0.0	0.0	0.0
19	4.501000	2.812000	7.250000
20	4.501000	2.812000	22.625000
21	3.064000	2.812000	35.188004
22	0.0	7.265000	0.0
23	0.0	-7.265000	0.0
24	-7.000000	7.265000	0.0
25	-7.000000	-7.265000	0.0
26	-7.000000	4.750000	0.0
27	-7.000000	-4.750000	0.0
28	-7.000000	2.625000	0.0
29	-7.000000	-2.625000	0.0
30	-7.936000	0.0	0.0
31	-10.000000	0.0	0.0
32	-3.562500	7.265000	5.000000
33	-3.562500	-7.265000	5.000000
34	-3.562500	6.500000	20.375000
35	-3.562500	-6.500000	20.375000
36	12.396000	2.812000	-20.906006
37	-3.394000	2.812000	-20.906006
38	5.939000	2.812000	-20.906006
39	12.396000	2.812000	-7.312000
40	-3.394000	2.812000	-7.312000
41	5.939000	2.812000	-7.312000
42	3.064000	2.812000	-7.312000
43	7.730000	0.0	-5.000000
44	1.345000	0.0	-5.000000
45	1.345000	0.0	-3.462000
46	1.345000	0.0	3.462000
47	7.730000	0.0	5.000000
48	1.345000	0.0	5.000000

JOINT RELEASE DATA

		SPRING CONSTANTS FOR ELEMENT FORCES & MOMENTS					
		(K= 0., NO RELEASE)			(K=-1., FULL RELEASE)		
ELM. NO.	END	K(F1)	K(F2)	K(F3)	K(M1)	K(M2)	K(M3)
30	2	0.	0.	0.	-1.	0.	0.
29	1	0.	0.	0.	-1.	0.	0.
24	2	0.	0.	0.	-1.	0.	0.
23	1	0.	0.	0.	-1.	0.	0.
6	1	0.	0.	0.	-1.	0.	0.
5	2	0.	0.	0.	-1.	0.	0.
4	1	0.	0.	0.	-1.	0.	0.
3	1	0.	0.	0.	-1.	0.	0.

ELEMENT INPUT DATA

EL. NO.	JOINTS		LENGTH /RADIUS	ANGLE	AREA	MOMENTS OF INERTIA			MATERIAL DESCRIPTION
	I-11	I-22				I-33			
1	1	6	2.002		10.4	324.7	649.4	324.7	STEEL
2	6	2	11.594		10.4	324.7	649.4	324.7	STEEL
3	38	4	2.000		18.8	2.5	24.7	354.9	STEEL
4	9	5	2.000		18.8	2.5	24.7	354.9	STEEL
5	7	42	2.000		18.8	2.5	24.7	354.9	STEEL
6	41	8	2.000		18.8	2.5	24.7	354.9	STEEL
7	38	41	13.594		0.6013	0.0288	0.0575	0.0288	STEEL
8	9	42	13.594		0.6013	0.0288	0.0575	0.0288	STEEL
9	4	36	4.457		19.6	2.7	24.1	384.3	STEEL
10	37	5	4.458		19.6	2.7	24.1	384.3	STEEL
11	40	7	4.458		19.6	2.7	24.1	384.3	STEEL
12	8	39	4.457		19.6	2.7	24.1	384.3	STEEL
13	3	10	2.312		15.4186	26.6053	35.6168	26.6053	DUCTILE IRON
14	43	11	2.750		3.1590	23.4735	0.1111	0.2880	DUCTILE IRON
15	12	47	2.750		3.1590	23.4735	0.1111	0.2880	DUCTILE IRON
16	11	12	4.500		3.7830	42.0143	0.1313	0.3019	DUCTILE IRON
17	46	48	1.538		13.0	126.4	7.5	22.1	DUCTILE IRON
18	14	46	1.212		13.0	126.4	7.5	22.1	DUCTILE IRON
19	45	13	1.212		13.0	126.4	7.5	22.1	DUCTILE IRON
20	44	45	1.538		13.0	126.4	7.5	22.1	DUCTILE IRON
21	13	14	4.500		13.0	126.4	7.5	22.1	DUCTILE IRON
22	15	19	2.250		15.4186	26.6053	35.6168	26.6053	DUCTILE IRON
23	49	51	3.812		10.8	0.8	1.6	116.1	STEEL
24	52	50	3.813		10.8	0.8	1.6	116.1	STEEL
25	50	21	27.938		0.6013	0.0288	0.0575	0.0288	STEEL
26	49	53	27.938		0.6013	0.0288	0.0575	0.0288	STEEL
27	17	20	15.375		7.7	91.1	182.1	91.1	STEEL
28	20	16	12.563		7.7	91.1	182.1	91.1	STEEL
29	53	54	3.812		8.6610	0.2510	2.6500	75.0200	STEEL
30	55	21	3.813		8.6610	0.2510	2.6500	75.0200	STEEL
31	22	18	7.265		12.4	1.3	4.9	124.8	STEEL
32	18	23	7.265		12.4	1.3	4.9	124.8	STEEL
33	22	56	3.563		12.1	157.7	2.0	17.8	STEEL
34	56	24	3.438		12.1	157.7	2.0	17.8	STEEL
35	23	57	3.563		12.1	157.7	2.0	17.8	STEEL
36	57	25	3.438		12.1	157.7	2.0	17.8	STEEL
37	24	26	2.515		20.6	6.0	21.6	208.0	STEEL
38	26	28	2.125		20.6	6.0	21.6	208.0	STEEL
39	29	27	2.125		20.6	6.0	21.6	208.0	STEEL
40	27	25	2.515		20.6	6.0	21.6	208.0	STEEL
41	58	60	5.250		5.3906	1.5793	3.7607	3.7131	STEEL
42	59	61	5.250		5.3906	1.5793	3.7607	3.7131	STEEL
43	26	62	0.938		3.1416	0.7854	1.5708	0.7854	STIFF ELEMENT
44	27	63	0.938		3.1416	0.7854	1.5708	0.7854	STIFF ELEMENT
45	30	31	2.062		54.9	122.9	281.0	717.9	STEEL
46	64	66	14.875		3.7500	12.2656	11.3873	5.3906	STEEL
47	65	67	24.875		3.7500	12.2656	11.3873	5.3906	STEEL
48	66	67	13.000		3.7500	0.1758	0.6367	7.8125	STEEL

QUAL GROUP VII

PAGE 7

49	34	68	8.372	3.3750	5.6953	0.5664	0.1582	STEEL
50	35	69	8.372	3.3750	5.6953	0.5664	0.1582	STEEL
	36	1		RIGID	LINK			
	37	1		RIGID	LINK			
	38	9		RIGID	LINK			
	39	2		RIGID	LINK			
	40	2		RIGID	LINK			
	41	3		RIGID	LINK			
	42	3		RIGID	LINK			
	43	10		RIGID	LINK			
	44	10		RIGID	LINK			
	45	18		RIGID	LINK			
	46	18		RIGID	LINK			
	47	15		RIGID	LINK			
	48	15		RIGID	LINK			
	49	19		RIGID	LINK			
	50	19		RIGID	LINK			
	51	17		RIGID	LINK			
	52	17		RIGID	LINK			
	54	16		RIGID	LINK			
	55	16		RIGID	LINK			
	53	21		RIGID	LINK			
	56	32		RIGID	LINK			
	57	33		RIGID	LINK			
	64	32		RIGID	LINK			
	65	33		RIGID	LINK			
	58	28		RIGID	LINK			
	59	28		RIGID	LINK			
	60	29		RIGID	LINK			
	61	29		RIGID	LINK			
	62	30		RIGID	LINK			
	63	30		RIGID	LINK			
	66	34		RIGID	LINK			
	67	35		RIGID	LINK			
	68	20		RIGID	LINK			
	69	20		RIGID	LINK			

S T A T I C A N A L Y S I S

DEFORMATION RESPONSE TO 1 G GRAVITATIONAL LOAD IN VALVE SYSTEM X DIR.

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	0.004834	-0.000338	-0.000223	-0.000015	-0.000318	-0.000012
2	0.000483	-0.000130	-0.000191	-0.000015	-0.000318	-0.000012
3	0.000483	-0.000130	-0.000191	-0.000015	-0.000063	-0.000012
4	0.004834	-0.000380	0.000792	-0.000015	-0.000359	-0.000012
5	0.004834	-0.000299	-0.001174	-0.000015	-0.000359	-0.000012
6	0.004196	-0.000309	-0.000191	-0.000015	-0.000318	-0.000012
7	0.000483	-0.000089	-0.001082	-0.000015	-0.000393	-0.000012
8	0.000483	-0.000171	0.000700	-0.000015	-0.000393	-0.000012
9	0.004834	-0.000322	-0.000447	-0.000015	-0.000178	-0.000012
10	0.000338	-0.000094	-0.000191	-0.000015	-0.000056	-0.000012
11	0.000157	-0.000085	0.000025	-0.000016	-0.000053	-0.000012
12	-0.000081	-0.000009	0.000015	-0.000016	-0.000053	-0.000006
13	0.000152	-0.000039	-0.000323	-0.000015	-0.000053	-0.000002
14	-0.000086	0.000029	-0.000323	-0.000015	-0.000053	-0.000001
15	-0.000208	0.000061	-0.000203	-0.000015	-0.000052	-0.000007
16	0.002425	0.000065	-0.000255	0.000001	0.000093	-0.000004
17	-0.000317	0.000095	-0.000249	0.000000	0.000095	-0.000006
18	0.000033	-0.000004	-0.000394	-0.000015	-0.000053	-0.000001
19	-0.000317	0.000095	-0.000204	-0.000015	-0.000048	-0.000006
20	0.001174	0.000081	-0.000256	0.000001	0.000096	-0.000004
21	0.002425	0.000071	-0.000209	0.000001	0.000010	-0.000004
22	0.000017	-0.000004	-0.000274	0.000029	0.000030	0.000000
23	0.000009	-0.000005	-0.000155	-0.000037	0.000011	-0.000002
24	0.000010	-0.000001	-0.000005	-0.000000	0.000028	-0.000001
25	0.000004	-0.000000	-0.000003	-0.000000	0.000010	0.000000
26	0.000002	-0.000000	-0.000004	-0.000000	0.000003	-0.000001
27	0.000000	-0.000000	-0.000004	-0.000000	0.000002	0.000000
28	0.000001	-0.000000	-0.000004	-0.000000	0.000003	-0.000001
29	0.000000	-0.000000	-0.000004	-0.000000	0.000002	0.000000
30	0.000001	-0.000000	-0.000002	-0.000000	0.000002	-0.000000
31	0.0	0.0	0.0	0.0	0.0	0.0
32	0.000166	0.000024	-0.000095	-0.000005	0.000030	-0.000000
33	0.000062	0.000033	-0.000053	-0.000007	0.000011	-0.000001
34	0.001129	0.000109	-0.000079	-0.000005	0.000068	-0.000004
35	0.001069	0.000110	-0.000047	-0.000005	0.000054	-0.000004
36	0.004834	-0.000433	0.002321	-0.000015	-0.000318	-0.000012
37	0.004834	-0.000246	-0.002704	-0.000015	-0.000318	-0.000012
38	0.004834	-0.000357	0.000065	-0.000015	-0.000178	-0.000012
39	0.000483	-0.000223	0.002320	-0.000015	-0.000318	-0.000012
40	0.000483	-0.000036	-0.002703	-0.000015	-0.000318	-0.000012
41	0.000483	-0.000147	-0.000100	-0.000015	-0.000063	-0.000012
42	0.000483	-0.000113	-0.000282	-0.000015	-0.000063	-0.000012
43	0.000305	-0.000132	0.000033	-0.000015	-0.000056	-0.000012
44	0.000305	-0.000057	-0.000325	-0.000015	-0.000056	-0.000012
45	0.000215	-0.000059	-0.000323	-0.000015	-0.000053	-0.000001

QUAL GROUP VII

PAGE 9

46	-0.000150	0.000047	-0.000323	-0.000015	-0.000053	-0.000001
47	-0.000227	0.000039	0.000007	-0.000015	-0.000052	-0.000007
48	-0.000227	0.000083	-0.000323	-0.000015	-0.000052	-0.000007
49	-0.000317	0.000087	-0.000136	-0.000015	-0.000048	-0.000006
50	-0.000317	0.000103	-0.000273	-0.000015	-0.000048	-0.000006
51	-0.000317	0.000066	-0.000745	0.000000	0.000095	-0.000006
52	-0.000317	0.000124	0.000248	0.000000	0.000095	-0.000006
53	0.002425	0.000059	-0.000238	0.000001	0.000010	-0.000004
54	0.002425	0.000043	-0.000743	0.000001	0.000093	-0.000004
55	0.002425	0.000087	0.000233	0.000001	0.000093	-0.000004
56	0.000014	-0.000003	-0.000095	-0.000005	0.000030	-0.000000
57	0.000007	-0.000000	-0.000053	-0.000007	0.000011	-0.000001
58	-0.000010	-0.000001	-0.000004	-0.000000	0.000003	-0.000001
59	0.000012	-0.000000	-0.000004	-0.000000	0.000003	-0.000001
60	-0.000010	-0.000000	-0.000004	-0.000000	0.000002	0.000000
61	0.000010	-0.000000	-0.000004	-0.000000	0.000002	0.000000
62	0.000002	-0.000000	-0.000002	-0.000000	0.000002	-0.000000
63	0.000000	-0.000000	-0.000002	-0.000000	0.000002	-0.000000
64	0.000166	0.000024	-0.000091	-0.000005	0.000030	-0.000000
65	-0.000047	-0.000034	-0.000058	-0.000007	0.000011	-0.000001
66	0.001095	0.000107	-0.000079	-0.000005	0.000068	-0.000004
67	0.001042	0.000107	-0.000047	-0.000005	0.000054	-0.000004
68	0.001190	0.000081	-0.000251	0.000001	0.000096	-0.000004
69	0.001135	0.000081	-0.000268	0.000001	0.000096	-0.000004

QUAL GROUP VII

PAGE 10

DEFORMATION RESPONSE TO 1 G GRAVITATIONAL LOAD IN VALVE SYSTEM Y DIR.

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	-0.000254	0.000815	-0.000041	0.000041	0.000011	0.000006
2	-0.000098	0.000239	-0.000042	0.000040	0.000011	0.000006
3	-0.000098	0.000236	-0.000042	0.000021	0.000011	0.000006
4	-0.000254	0.000838	-0.000082	0.000041	0.000012	0.000006
5	-0.000254	0.000794	-0.000003	0.000041	0.000012	0.000006
6	-0.000231	0.000732	-0.000042	0.000041	0.000011	0.000006
7	-0.000098	0.000215	-0.000003	0.000027	0.000012	0.000006
8	-0.000098	0.000259	-0.000082	0.000027	0.000012	0.000006
9	-0.000254	0.000807	-0.000026	0.000041	0.000011	0.000006
10	-0.000072	0.000190	-0.000042	0.000014	0.000011	0.000006
11	-0.000024	0.000171	-0.000117	0.000014	0.000011	0.000004
12	0.000025	0.000109	-0.000117	0.000013	0.000011	-0.000001
13	-0.000024	0.000135	-0.000046	0.000013	0.000011	0.000004
14	0.000025	0.000077	-0.000046	0.000013	0.000011	0.000004
15	0.000047	0.000062	-0.000049	0.000012	0.000011	0.000003
16	-0.000008	0.003852	-0.000066	-0.000129	-0.000003	-0.000003
17	0.000072	0.000051	-0.000064	-0.000131	-0.000003	0.000000
18	0.000000	0.000098	-0.000032	0.000013	0.000011	0.000005
19	0.000072	0.000048	-0.000049	0.000006	0.000011	0.000000
20	0.000031	0.002148	-0.000067	-0.000132	-0.000003	-0.000003
21	-0.000008	0.003857	-0.000049	-0.000129	0.000005	-0.000003
22	-0.000018	0.000093	-0.000032	-0.000019	-0.000000	0.000005
23	0.000018	0.000092	0.000014	-0.000020	0.000001	0.000005
24	-0.000013	0.000008	-0.000036	-0.000015	-0.000000	0.000002
25	0.000013	0.000008	0.000031	-0.000011	0.000000	0.000002
26	-0.000004	0.000007	-0.000010	-0.000003	0.000000	0.000002
27	0.000004	0.000007	0.000010	-0.000002	-0.000000	0.000002
28	-0.000001	0.000007	-0.000005	-0.000002	0.000000	0.000002
29	0.000001	0.000007	0.000005	-0.000002	0.000000	0.000002
30	-0.000000	0.000005	-0.000000	-0.000002	0.000000	0.000001
31	0.0	0.0	0.0	0.0	0.0	0.0
32	-0.000019	0.000402	0.000072	-0.000070	-0.000001	0.000008
33	0.000019	0.000194	-0.000000	-0.000029	0.000001	0.000008
34	-0.000132	0.001785	0.000108	-0.000087	-0.000006	0.000028
35	0.000314	0.001782	0.000018	-0.000080	0.000008	0.000030
36	-0.000254	0.000866	-0.000133	0.000041	0.000011	0.000006
37	-0.000254	0.000765	0.000048	0.000041	0.000011	0.000006
38	-0.000254	0.000825	-0.000059	0.000041	0.000011	0.000006
39	-0.000098	0.000290	-0.000133	0.000040	0.000011	0.000006
40	-0.000098	0.000189	0.000048	0.000040	0.000011	0.000006
41	-0.000098	0.000245	-0.000058	0.000021	0.000011	0.000006
42	-0.000098	0.000227	-0.000027	0.000021	0.000011	0.000006
43	-0.000054	0.000210	-0.000117	0.000014	0.000011	0.000006
44	-0.000054	0.000170	-0.000046	0.000014	0.000011	0.000006
45	-0.000037	0.000148	-0.000046	0.000013	0.000011	0.000005
46	0.000038	0.000061	-0.000046	0.000013	0.000011	0.000005
47	0.000055	0.000070	-0.000117	0.000012	0.000011	0.000003
48	0.000055	0.000053	-0.000047	0.000012	0.000011	0.000003

QUAL GROUP VII

PAGE 11

49	0.000072	0.000048	-0.000064	0.000006	0.000011	0.000000
50	0.000072	0.000047	-0.000034	0.000006	0.000011	0.000000
51	0.000072	0.000052	-0.000051	-0.000131	-0.000003	0.000000
52	0.000072	0.000051	-0.000077	-0.000131	-0.000003	0.000000
53	-0.000008	0.003849	-0.000062	-0.000129	0.000005	-0.000003
54	-0.000008	0.003838	-0.000050	-0.000129	-0.000003	-0.000003
55	-0.000008	0.003867	-0.000022	-0.000129	-0.000003	-0.000003
56	-0.000016	0.000051	0.000072	-0.000070	-0.000001	0.000008
57	0.000016	0.000050	-0.000000	-0.000029	0.000001	0.000008
58	-0.000001	-0.000003	-0.000005	-0.000002	0.000000	0.000002
59	-0.000001	0.000016	-0.000005	-0.000002	0.000000	0.000002
60	0.000001	-0.000003	0.000005	-0.000002	0.000000	0.000002
61	0.000001	0.000016	0.000005	-0.000002	0.000000	0.000002
62	-0.000004	0.000005	-0.000010	-0.000002	0.000000	0.000001
63	0.000004	0.000005	0.000010	-0.000002	0.000000	0.000001
64	-0.000013	0.000402	0.000126	-0.000070	-0.000001	0.000008
65	0.000007	-0.000095	-0.000022	-0.000029	0.000001	0.000008
66	-0.000129	0.001741	0.000108	-0.000087	-0.000006	0.000028
67	0.000310	0.001742	0.000018	-0.000080	0.000008	0.000030
68	0.000041	0.002148	-0.000554	-0.000132	-0.000003	-0.000003
69	0.000006	0.002148	0.001164	-0.000132	-0.000003	-0.000003

DEFORMATION RESPONSE TO 1 G GRAVITATIONAL LOAD IN VALVE SYSTEM Z DIR.

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	0.002376	0.000576	0.001932	0.000028	-0.000115	-0.000002
2	0.000814	0.000200	0.001942	0.000028	-0.000115	-0.000002
3	0.000814	0.000200	0.001880	0.000028	-0.000111	-0.000002
4	0.002376	0.000570	0.002320	0.000028	-0.000122	-0.000002
5	0.002376	0.000581	0.001534	0.000028	-0.000109	-0.000002
6	0.002146	0.000520	0.001944	0.000028	-0.000115	-0.000002
7	0.000814	0.000205	0.001517	0.000028	-0.000103	-0.000002
8	0.000814	0.000194	0.002301	0.000028	-0.000129	-0.000002
9	0.002376	0.000578	0.001750	0.000028	-0.000113	-0.000002
10	0.000557	0.000136	0.001879	0.000028	-0.000111	-0.000002
11	0.000250	0.000053	0.002158	0.000028	-0.000110	-0.000001
12	-0.000242	-0.000074	0.002156	0.000028	-0.000109	-0.000004
13	0.000250	0.000062	0.001450	0.000027	-0.000110	-0.000000
14	-0.000243	-0.000061	0.001450	0.000027	-0.000110	-0.000000
15	-0.000532	-0.000138	0.001875	0.000027	-0.000110	-0.000004
16	-0.002716	-0.000560	0.001910	0.000014	-0.000071	-0.000005
17	-0.000776	-0.000198	0.001899	0.000013	-0.000069	-0.000005
18	0.000004	0.000001	0.001302	0.000027	-0.000110	-0.000000
19	-0.000777	-0.000198	0.001876	0.000027	-0.000109	-0.000005
20	-0.001824	-0.000388	0.001901	0.000014	-0.000071	-0.000005
21	-0.002716	-0.000553	0.001762	0.000014	-0.000092	-0.000005
22	0.000000	0.000000	0.000731	-0.000121	-0.000053	0.000000
23	0.000000	0.000001	0.000592	0.000126	-0.000040	-0.000000
24	0.000000	-0.000000	0.000057	0.000020	-0.000049	-0.000000
25	0.000000	0.000000	0.000026	-0.000008	-0.000037	0.000000
26	0.000000	-0.000000	0.000021	0.000002	-0.000007	-0.000000
27	-0.000000	0.000000	0.000012	0.000001	-0.000006	0.000000
28	-0.000000	-0.000000	0.000019	0.000001	-0.000007	-0.000000
29	-0.000000	0.000000	0.000014	0.000001	-0.000007	0.000000
30	0.000000	-0.000000	0.000011	0.000001	-0.000005	-0.000000
31	0.0	0.0	0.0	0.0	0.0	0.0
32	-0.000259	0.000027	0.000300	-0.000006	-0.000052	-0.000000
33	-0.000196	-0.000248	0.000289	0.000050	-0.000039	-0.000000
34	-0.001349	-0.000289	0.000320	0.000024	-0.000082	-0.000007
35	-0.001474	-0.000287	0.000347	0.000010	-0.000083	-0.000010
36	0.002376	0.000563	0.002851	0.000028	-0.000115	-0.000002
37	0.002376	0.000588	0.001037	0.000026	-0.000115	-0.000002
38	0.002376	0.000573	0.002074	0.000028	-0.000113	-0.000002
39	0.000814	0.000187	0.002849	0.000028	-0.000115	-0.000002
40	0.000814	0.000212	0.001035	0.000028	-0.000115	-0.000002
41	0.000814	0.000197	0.002040	0.000028	-0.000111	-0.000002
42	0.000814	0.000202	0.001721	0.000028	-0.000111	-0.000002
43	0.000553	0.000131	0.002159	0.000028	-0.000111	-0.000002
44	0.000553	0.000141	0.001451	0.000028	-0.000111	-0.000002
45	0.000383	0.000095	0.001450	0.000027	-0.000110	-0.000000
46	-0.000376	-0.000094	0.001450	0.000027	-0.000110	-0.000000
47	-0.000543	-0.000151	0.002154	0.000027	-0.000110	-0.000004
48	-0.000543	-0.000126	0.001451	0.000027	-0.000110	-0.000004

QUAL GROUP VII

PAGE 13

49	-0.000777	-0.000205	0.002032	0.000027	-0.000109	-0.000005
50	-0.000777	-0.000192	0.001719	0.000027	-0.000109	-0.000005
51	-0.000776	-0.000222	0.002263	0.000013	-0.000069	-0.000005
52	-0.000776	-0.000173	0.001536	0.000013	-0.000069	-0.000005
53	-0.002716	-0.000568	0.002027	0.000014	-0.000092	-0.000005
54	-0.002716	-0.000588	0.002283	0.000014	-0.000071	-0.000005
55	-0.002716	-0.000533	0.001537	0.000014	-0.000071	-0.000005
56	0.000000	-0.000002	0.000300	-0.000006	-0.000052	-0.000000
57	0.000000	0.000001	0.000289	0.000050	-0.000039	-0.000000
58	0.000027	0.000004	0.000019	0.000001	-0.000007	-0.000000
59	-0.000027	-0.000004	0.000019	0.000001	-0.000007	-0.000000
60	0.000026	0.000004	0.000014	0.000001	-0.000007	0.000000
61	-0.000027	-0.000004	0.000014	0.000001	-0.000007	0.000000
62	0.000000	-0.000000	0.000016	0.000001	-0.000005	-0.000000
63	-0.000000	-0.000000	0.000007	0.000001	-0.000005	-0.000000
64	-0.000259	0.000027	0.000304	-0.000006	-0.000052	-0.000000
65	0.000196	0.000251	0.000327	0.000050	-0.000039	-0.000000
66	-0.001308	-0.000277	0.000320	0.000024	-0.000082	-0.000007
67	-0.001432	-0.000282	0.000347	0.000010	-0.000083	-0.000010
68	-0.001805	-0.000388	0.001952	0.000014	-0.000071	-0.000005
69	-0.001873	-0.000388	0.001773	0.000014	-0.000071	-0.000005

QUAL GROUP VII

PAGE 14

DEFORMATION RESPONSE TO OPERATIONAL LOADS (NOT INCLUDING DEADWEIGHT)

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	-0.000034	0.005611	0.000572	0.000268	0.000002	-0.000001
2	-0.000010	0.001970	0.000572	0.000268	0.000002	-0.000001
3	-0.000010	0.001970	0.000572	0.000268	0.000002	-0.000001
4	-0.000034	0.005608	0.000566	0.000268	0.000002	-0.000001
5	-0.000034	0.005614	0.000578	0.000268	0.000002	-0.000001
6	-0.000031	0.005075	0.000572	0.000268	0.000002	-0.000001
7	-0.000010	0.001972	0.000578	0.000268	0.000002	-0.000001
8	-0.000010	0.001967	0.000566	0.000268	0.000002	-0.000001
9	-0.000034	0.005612	0.000575	0.000268	0.000002	-0.000001
10	-0.000007	0.001350	0.000572	0.000268	0.000002	-0.000001
11	-0.000004	0.000609	-0.000187	0.000268	0.000002	-0.000000
12	0.000004	-0.000597	-0.000187	0.000267	0.000002	-0.000002
13	-0.000004	0.000613	-0.000176	0.000268	0.000002	0.000000
14	0.000004	-0.000594	-0.000176	0.000268	0.000002	0.000000
15	0.000014	-0.001327	0.000568	0.000267	0.000002	-0.000002
16	-0.000915	-0.003063	0.000547	0.000042	-0.000033	-0.000006
17	0.000017	-0.001911	0.000550	0.000048	-0.000033	-0.000004
18	0.000000	0.000009	-0.000174	0.000268	0.000002	0.000000
19	0.000017	-0.001914	0.000568	0.000258	0.000001	-0.000004
20	-0.000493	-0.002535	0.000547	0.000042	-0.000034	-0.000006
21	-0.000915	-0.003054	0.000539	0.000040	-0.000014	-0.000006
22	-0.000000	0.000007	0.000388	-0.000018	-0.000022	0.000000
23	0.000000	0.000008	-0.000487	-0.000073	0.000022	0.000000
24	0.000000	-0.000000	0.000093	0.000035	-0.000021	0.000000
25	-0.000000	0.000000	-0.000087	0.000031	0.000021	0.000000
26	0.000000	-0.000000	0.000030	0.000007	-0.000001	0.000000
27	-0.000000	-0.000000	-0.000030	0.000007	0.000001	0.000000
28	0.000000	-0.000000	0.000015	0.000006	-0.000000	0.000000
29	-0.000000	-0.000000	-0.000016	0.000006	0.000000	0.000000
30	0.000000	-0.000000	-0.000000	0.000006	0.000000	-0.000000
31	0.0	0.0	0.0	0.0	0.0	0.0
32	-0.000109	-0.000438	0.000079	0.000088	-0.000022	0.000001
33	0.000109	-0.000181	-0.000168	0.000036	0.000022	0.000001
34	-0.000292	-0.002263	0.000026	0.000116	-0.000012	-0.000008
35	-0.000456	-0.002261	-0.000152	0.000108	-0.000029	-0.000010
36	-0.000034	0.005605	0.000558	0.000268	0.000002	-0.000001
37	-0.000034	0.005617	0.000586	0.000268	0.000002	-0.000001
38	-0.000034	0.005610	0.000570	0.000268	0.000002	-0.000001
39	-0.000010	0.001964	0.000558	0.000268	0.000002	-0.000001
40	-0.000010	0.001976	0.000586	0.000268	0.000002	-0.000001
41	-0.000010	0.001969	0.000570	0.000268	0.000002	-0.000001
42	-0.000010	0.001971	0.000575	0.000268	0.000002	-0.000001
43	-0.000009	0.001347	-0.000187	0.000268	0.000002	-0.000001
44	-0.000009	0.001352	-0.000176	0.000268	0.000002	-0.000001
45	-0.000006	0.000438	-0.000176	0.000268	0.000002	0.000000
46	0.000006	-0.000919	-0.000176	0.000268	0.000002	0.000000
47	0.000009	-0.001333	-0.000187	0.000267	0.000002	-0.000002
48	0.000009	-0.001321	-0.000177	0.000267	0.000002	-0.000002

QUAL GROUP VII

PAGE 15

49	0.000017	-0.001919	0.000567	0.000258	0.000001	-0.000004
50	0.000017	-0.001908	0.000569	0.000258	0.000001	-0.000004
51	0.000017	-0.001932	0.000721	0.000048	-0.000033	-0.000004
52	0.000017	-0.001890	0.000378	0.000048	-0.000033	-0.000004
53	-0.000915	-0.003071	0.000581	0.000040	-0.000014	-0.000006
54	-0.000915	-0.003094	0.000723	0.000042	-0.000033	-0.000006
55	-0.000915	-0.003031	0.000371	0.000042	-0.000033	-0.000006
56	0.000000	0.000000	0.000079	0.000088	-0.000022	0.000001
57	-0.000000	0.000001	-0.000168	0.000036	0.000022	0.000001
58	0.000001	0.000026	0.000015	0.000006	-0.000000	0.000000
59	-0.000001	-0.000026	0.000015	0.000006	-0.000000	0.000000
60	-0.000001	0.000026	-0.000016	0.000006	0.000000	0.000000
61	0.000001	-0.000026	-0.000016	0.000006	0.000000	0.000000
62	0.000000	-0.000000	0.000029	0.000006	0.000000	-0.000000
63	-0.000000	-0.000000	-0.000029	0.000006	0.000000	-0.000000
64	-0.000108	-0.000438	0.000012	0.000088	-0.000022	0.000001
65	-0.000110	0.000184	-0.000140	0.000036	0.000022	0.000001
66	-0.000285	-0.002205	0.000026	0.000116	-0.000012	-0.000008
67	-0.000441	-0.002207	-0.000152	0.000108	-0.000029	-0.000010
68	-0.000471	-0.002535	0.000701	0.000042	-0.000034	-0.000006
69	-0.000549	-0.002535	0.000156	0.000042	-0.000034	-0.000006

D Y N A M I C A N A L Y S I S

RESONANT FREQUENCY = 37.0 HERTZ (IN X-DIRECTION OR Y-ROTATION)

* * * * NORMALIZED EIGENVECTOR * * * *

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	0.999983	0.044365	0.138987	0.002238	-0.061543	-0.001100
2	0.160372	0.013709	0.145119	0.002231	-0.061509	-0.001099
3	0.160284	0.013694	0.143900	0.002113	-0.022364	-0.001099
4	1.000000	0.040475	0.339425	0.002240	-0.067931	-0.001100
5	0.999999	0.048040	-0.049743	0.002240	-0.067668	-0.001100
6	0.876630	0.039764	0.145154	0.002238	-0.061554	-0.001100
7	0.160313	0.017477	-0.035871	0.002149	-0.072700	-0.001099
8	0.160313	0.009920	0.324835	0.002149	-0.073211	-0.001099
9	0.999998	0.045840	0.086819	0.002241	-0.040156	-0.001100
10	0.109292	0.008835	0.143871	0.002068	-0.021279	-0.001090
11	0.048363	-0.000025	0.205856	0.002025	-0.020882	-0.001136
12	-0.044829	-0.008912	0.204608	0.002025	-0.020656	-0.000741
13	0.048295	0.004157	0.070999	0.002075	-0.020719	-0.000095
14	-0.044942	-0.005189	0.070998	0.002075	-0.020719	-0.000091
15	-0.099511	-0.011778	0.142468	0.002070	-0.020763	-0.000769
16	-0.268285	-0.095575	0.142029	0.002816	-0.004512	-0.000659
17	-0.145407	-0.016454	0.141956	0.002784	-0.004495	-0.000716
18	0.001675	-0.000401	0.043131	0.002075	-0.020718	-0.000090
19	-0.145470	-0.016459	0.142462	0.002096	-0.020333	-0.000719
20	-0.209550	-0.059487	0.141827	0.002837	-0.004514	-0.000659
21	-0.268291	-0.094632	0.123477	0.002812	-0.013172	-0.000659
22	0.000476	-0.000405	0.043905	-0.000644	-0.005604	0.000027
23	0.000152	-0.000420	0.028850	0.001873	-0.003688	-0.000138
24	0.000195	-0.000032	0.002480	0.000659	-0.005188	-0.000026
25	0.000020	-0.000016	0.000400	0.000162	-0.003382	-0.000007
26	0.000040	-0.000024	0.001330	0.000087	-0.000613	-0.000017
27	-0.000011	-0.000018	0.000667	0.000068	-0.000544	-0.000005
28	0.000009	-0.000023	0.001163	0.000072	-0.000587	-0.000016
29	-0.000005	-0.000019	0.000813	0.000071	-0.000570	-0.000004
30	0.000014	-0.000013	0.000525	0.000066	-0.000429	-0.000005
31	0.0	0.0	0.0	0.0	0.0	0.0
32	-0.027268	-0.008138	0.019436	0.001562	-0.005508	-0.000075
33	-0.017882	-0.008739	0.015588	0.001724	-0.003587	-0.000069
34	-0.169163	-0.045374	0.018953	0.002455	-0.010583	-0.001220
35	-0.187647	-0.045282	0.017143	0.002069	-0.010197	-0.001322
36	0.999983	0.035567	0.631026	0.002238	-0.061543	-0.001100
37	0.999983	0.052942	-0.340743	0.002238	-0.061543	-0.001100
38	0.999998	0.042676	0.202268	0.002241	-0.040156	-0.001100
39	0.160372	0.005031	0.630734	0.002231	-0.061509	-0.001099
40	0.160372	0.022388	-0.340496	0.002231	-0.061509	-0.001099
41	0.160284	0.012114	0.176059	0.002113	-0.022364	-0.001099
42	0.160284	0.015273	0.111764	0.002113	-0.022364	-0.001099
43	0.106226	0.005315	0.206765	0.002068	-0.021279	-0.001090

QUAL GROUP VII

PAGE 17

44	0.106226	0.012277	0.070898	0.002068	-0.021279	-0.001090
45	0.073402	0.006660	0.070997	0.002075	-0.020718	-0.000090
46	-0.070053	-0.007706	0.070997	0.002075	-0.020718	-0.000090
47	-0.101674	-0.014263	0.203692	0.002070	-0.020763	-0.000769
48	-0.101674	-0.009351	0.071118	0.002070	-0.020763	-0.000769
49	-0.145470	-0.017494	0.171701	0.002096	-0.020333	-0.000719
50	-0.145470	-0.015426	0.113243	0.002096	-0.020333	-0.000719
51	-0.145407	-0.020213	0.165554	0.002784	-0.004495	-0.000716
52	-0.145407	-0.012695	0.118357	0.002784	-0.004495	-0.000716
53	-0.268291	-0.096527	0.161348	0.002812	-0.013172	-0.000659
54	-0.268285	-0.099035	0.165719	0.002816	-0.004512	-0.000659
55	-0.268285	-0.092116	0.118338	0.002816	-0.004512	-0.000659
56	0.000271	-0.000331	0.019436	0.001562	-0.005508	-0.000075
57	0.000053	-0.000119	0.015588	0.001724	-0.003587	-0.000069
58	0.002394	0.000269	0.001163	0.000072	-0.000587	-0.000016
59	-0.002375	-0.000315	0.001163	0.000072	-0.000587	-0.000016
60	0.002309	0.000270	0.000813	0.000071	-0.000570	-0.000004
61	-0.002319	-0.000308	0.000813	0.000071	-0.000570	-0.000004
62	0.000040	-0.000013	0.000839	0.000066	-0.000429	-0.000005
63	-0.000011	-0.000013	0.000211	0.000066	-0.000429	-0.000005
64	-0.027325	-0.008138	0.018241	0.001562	-0.005508	-0.000075
65	0.018041	0.008502	0.016907	0.001724	-0.003587	-0.000069
66	-0.163872	-0.044147	0.018953	0.002455	-0.010583	-0.001220
67	-0.182548	-0.044247	0.017143	0.002069	-0.010197	-0.001322
68	-0.207122	-0.059487	0.152289	.002837	-0.004514	-0.000659
69	-0.215683	-0.059487	0.115412	.002837	-0.004514	-0.000659

S T A T I C S E I S M I C A N A L Y S I S

THE VALVE AXIS IS POSITIONED Z-UP

ACCELERATION OF GRAVITY, $G = 386.400$

DIRECTION OF SEISMIC ACCELERATION	NO. OF G'S	COMPONENTS OF UNIT ACCELERATION IN VALVE COORDINATE SYSTEM		
		X-COMP.	Y-COMP.	Z-COMP.
HORIZONTAL (1)	9.500	0.0	1.0000	0.0
HORIZONTAL (2)	9.500	1.0000	0.0	0.0
VERTICAL	9.500	0.0	0.0	-1.0000

REACTION RESPONSE TO STATIC SEISMIC LOAD IN HORIZ(1) DIRECTION

ELT. NO.	JNT. NO.	ELEMENT FORCES.			ELEMENT MOMENTS.		
		F1	F2	F3	M1	M2	M3
1	1	-1.	0.	672.	11.	-67.	-7.
	6	1.	-0.	-728.	-1414.	67.	5.
2	6	-2.	-0.	1061.	1416.	2.	-5.
	2	2.	0.	-1382.	-15574.	-2.	-14.
3	38	4.	1.	3.	0.	-6.	357.
	4	-104.	-1.	-3.	-5.	0.	-249.
4	9	5.	-1.	3.	-0.	6.	359.
	5	-105.	1.	-3.	-5.	-6.	-250.
5	7	923.	1.	5.	-10.	-7786.	-958.
	42	-1023.	-1.	-5.	0.	7786.	2903.
6	41	-1023.	-1.	5.	0.	7787.	-2900.
	8	923.	1.	-5.	-10.	-7787.	955.
7	38	-0.	3.	-5.	-6.	-0.	-1.
	41	0.	-3.	-17.	-79.	0.	-1.
8	9	-5.	-3.	0.	-1.	-0.	6.
	42	-17.	3.	-0.	-1.	0.	79.
9	4	105.	1.	3.	5.	-6.	251.
	36	-337.	-1.	-3.	-17.	6.	734.
10	37	-337.	-1.	3.	-17.	6.	-735.
	5	105.	1.	-3.	5.	-6.	-250.
11	40	691.	1.	5.	-31.	-7786.	2640.
	7	-923.	-1.	-5.	10.	7786.	957.
12	8	-923.	-1.	5.	10.	7787.	-954.
	39	691.	1.	-5.	-31.	-7787.	-2642.
13	3	-2.	-0.	2080.	15730.	3.	26.
	10	2.	0.	-2167.	-20640.	-3.	-31.
14	43	-0.	14.	-221.	-174.	-104.	-3.
	11	0.	-14.	243.	812.	104.	2.
15	12	-0.	14.	-285.	-1999.	-104.	1.
	47	0.	-14.	306.	2811.	104.	-2.
16	11	-0.	14.	-243.	-812.	-104.	-2.
	12	0.	-14.	285.	1999.	104.	-1.
17	46	15.	-450.	-2350.	19810.	4480.	-204.
	48	-14.	450.	2301.	-16234.	-4480.	227.
18	14	-4.	-0.	121.	96.	-58.	3.
	46	5.	0.	-160.	-267.	58.	-8.
19	45	12.	0.	-356.	283.	304.	10.
	13	-11.	-0.	317.	125.	-304.	3.
20	44	-66.	-14.	1945.	20457.	-5327.	607.
	45	68.	14.	-1994.	-23487.	5327.	-711.
21	13	1.	0.	-23.	-125.	-58.	-4.
	14	4.	0.	-121.	-97.	58.	-3.
22	15	-61.	-436.	-1994.	17803.	-3700.	704.
	19	61.	436.	1908.	-13412.	3700.	-841.
23	49	-787.	32.	-47.	0.	-6433.	-34.
	51	678.	-32.	47.	180.	6433.	-2757.
24	52	949.	-32.	-403.	1536.	6431.	483.
	50	-1058.	32.	403.	0.	-6431.	3344.

QUAL GROUP VII

PAGE 20

25	50	1.	-94.	-32.	274.	-1.	20.
	21	-1.	94.	-13.	-13.	1.	17.
26	49	1.	14.	-32.	274.	-1.	20.
	53	-1.	-14.	-13.	-13.	1.	17.
27	17	-64.	-356.	-1627.	12864.	-3698.	647.
	20	64.	356.	1314.	9742.	3698.	-1626.
28	20	-3.	80.	-1834.	5151.	1.	-154.
	16	3.	-80.	1578.	16280.	-1.	121.
29	53	13.	-1.	-2.	0.	-13.	80.
	54	-100.	1.	2.	8.	13.	134.
30	55	-101.	1.	-82.	313.	13.	-136.
	21	13.	-1.	82.	0.	-13.	-81.
31	22	2357.	-2578.	235.	-2451.	-848.	8966.
	18	-2357.	2339.	-235.	741.	848.	8160.
32	18	2416.	2523.	-201.	2405.	757.	8549.
	23	-2416.	-2762.	201.	-945.	-757.	9005.
33	22	-2625.	-2357.	-235.	-848.	2712.	-8966.
	56	2739.	2357.	235.	1687.	-2712.	-589.
34	56	-3537.	-2838.	-1514.	5563.	-6604.	1915.
	24	3647.	2838.	1514.	-360.	6604.	-14262.
35	23	2762.	2416.	201.	757.	945.	9006.
	57	-2876.	-2416.	-201.	-1473.	-945.	1036.
36	57	3455.	2838.	-1513.	5610.	-4184.	-1839.
	25	-3565.	-2838.	1513.	-410.	4184.	13903.
37	24	-2838.	3647.	-1514.	-6604.	-360.	14262.
	26	2838.	-3785.	1514.	10411.	360.	-21400.
38	26	567.	-188.	62.	-334.	12.	2698.
	28	-567.	71.	-62.	202.	-12.	-1494.
39	29	567.	79.	62.	125.	12.	-1481.
	27	-567.	-196.	-62.	-258.	-12.	2685.
40	27	-2836.	-3703.	-1513.	7989.	-410.	-21036.
	25	2836.	3565.	1513.	-4184.	410.	13903.
41	58	282.	-40.	31.	-82.	1.	743.
	60	-282.	-35.	-31.	-81.	-1.	737.
42	59	285.	-31.	31.	-82.	1.	750.
	61	-285.	-44.	-31.	-81.	-1.	744.
43	26	3973.	-3404.	1575.	-372.	-10076.	-18702.
	62	-3973.	3404.	-1575.	-1105.	10076.	22429.
44	27	3899.	3403.	-1575.	422.	-7731.	-18350.
	63	-3899.	-3403.	1575.	1055.	7731.	22008.
45	30	7872.	-2.	1.	51.	-32775.	-76771.
	31	-8173.	2.	-1.	-52.	32775.	93314.
46	64	-617.	-1278.	-481.	4847.	1693.	-5940.
	66	469.	1278.	481.	2303.	-1693.	-2134.
47	65	-579.	174.	420.	-6236.	1123.	-9331.
	67	331.	-1714.	-420.	-4203.	-1123.	-1976.
48	66	-539.	-152.	318.	-2096.	-76.	-3846.
	67	539.	22.	-318.	-2043.	76.	-3162.
49	34	650.	-1240.	317.	2126.	-389.	2737.
	68	-650.	1240.	-242.	-4466.	389.	2707.
50	35	-1086.	1299.	353.	1993.	-443.	-4607.
	69	1086.	-1299.	-278.	-4631.	443.	-4487.

QUAL GROUP VII

TYPE	JNT. NO. BOUNDARY OR JUNCTION REACTION					
		Fx	FY	FZ	MX	MY	MZ
BODY	31	2.	-8173.	1.	32775.	-52.	-93314.
A -X-Z	30	-2.	7872.	-1.	-32775.	51.	76771.

REACTION RESPONSE TO STATIC SEISMIC LOAD IN HORIZ(2) DIRECTION

ELT. NO.	JNT. NO.	ELEMENT FORCES.			ELEMENT MOMENTS.		
		F1	F2	F3	M1	M2	M3
1	1	511.	-26.	1.	-1.	-1.	4769.
	6	-566.	29.	-1.	-2.	1.	-3686.
2	6	901.	-1.	1.	-0.	-1.	3669.
	2	-1222.	1.	-1.	-6.	1.	8638.
3	38	-0.	95.	-1650.	0.	0.	1.
	4	0.	10.	1650.	3300.	-0.	-1.
4	9	-0.	-95.	-1650.	0.	-0.	-0.
	5	0.	-10.	1650.	3301.	0.	0.
5	7	0.	-843.	-3003.	6005.	-3.	1.
	42	-0.	943.	3003.	0.	3.	-0.
6	41	-0.	946.	-3003.	0.	3.	-1.
	8	0.	-846.	3003.	6006.	-3.	1.
7	38	94.	-2082.	0.	-0.	-0.	621.
	41	-110.	2082.	-0.	-0.	0.	809.
8	9	0.	2082.	-94.	621.	-0.	0.
	42	-0.	-2082.	116.	809.	0.	0.
9	4	-0.	-28.	-1650.	-3299.	0.	1.
	35	0.	260.	1650.	10653.	0.	-0.
10	37	0.	251.	-1651.	10658.	0.	-0.
	5	-0.	-29.	1651.	-3299.	0.	1.
11	40	0.	-611.	-3002.	19388.	-3.	1.
	7	-0.	643.	3002.	-6004.	3.	0.
12	8	-0.	643.	-3004.	-6006.	3.	-1.
	39	0.	-610.	3004.	19392.	-3.	-0.
13	3	2117.	-0.	1.	6.	-2.	-16236.
	10	-2207.	0.	-1.	-9.	2.	21238.
14	43	47.	-1971.	343.	-1716.	136.	122.
	11	-25.	1971.	-343.	772.	-136.	-23.
15	12	-17.	-1971.	343.	773.	136.	4.
	47	36.	1971.	-343.	-1716.	-136.	-79.
16	11	25.	-1971.	343.	-772.	136.	23.
	12	17.	1971.	-343.	-772.	-136.	-4.
17	46	-1094.	677.	328.	3414.	-3356.	-4189.
	48	1045.	-677.	-329.	-3919.	3356.	2543.
18	14	114.	1.	4.	4.	78.	-79.
	46	-153.	-1.	-5.	-10.	-78.	241.
19	45	-364.	-1.	-12.	9.	-364.	-310.
	13	325.	1.	10.	5.	364.	-107.
20	44	2241.	1972.	418.	-1427.	3874.	-8584.
	45	-2290.	-1972.	-420.	783.	-3874.	12068.
21	13	-31.	0.	-1.	-4.	77.	108.
	14	-114.	0.	-4.	-3.	-77.	79.
22	15	-395.	-1292.	20.	-1523.	1834.	-11250.
	19	910.	1292.	-20.	1478.	-1834.	9106.
23	49	-58.	418.	2957.	-0.	720.	-803.
	51	58.	-309.	-2957.	-11272.	-720.	581.
24	52	-76.	-309.	1902.	-7254.	-720.	546.
	50	76.	418.	-1902.	-0.	720.	-837.

QUAL GROUP VII

PAGE 23

25	50	-37.	393.	1.	-19.	0.	-326.
	21	-8.	-393.	-1.	-9.	-0.	-84.
26	49	-37.	-629.	1.	-18.	0.	-326.
	53	-8.	629.	-1.	-9.	-0.	-84.
27	17	-617.	-1055.	18.	-1441.	1833.	-6985.
	20	304.	1055.	-18.	1163.	-1833.	-97.
28	20	-1622.	237.	-2.	7.	-1.	-3726.
	16	1566.	-237.	2.	18.	1.	-17555.
29	53	1.	-7.	571.	-0.	-9.	2.
	54	-1.	94.	-571.	-2175.	9.	2.
30	55	-1.	95.	334.	-1273.	9.	-2.
	21	1.	-8.	-334.	-0.	-9.	-2.
31	22	-2665.	190.	771.	-547.	6168.	-1070.
	18	2426.	-190.	-771.	-5051.	-6168.	-17420.
32	18	1477.	171.	-530.	3044.	-4731.	9724.
	23	-1716.	-171.	530.	806.	4731.	1874.
33	22	190.	2712.	-770.	6430.	547.	1070.
	56	-190.	-2826.	770.	-3685.	-547.	-393.
34	56	170.	4473.	34.	-24421.	-258.	1333.
	24	-170.	-4583.	-34.	24302.	258.	-748.
35	23	171.	1716.	530.	-4731.	-806.	1874.
	57	-171.	-1830.	-530.	2842.	806.	-1264.
36	57	171.	2558.	44.	7570.	-312.	1992.
	25	-171.	-2668.	-44.	-7721.	312.	-1403.
37	24	4583.	-170.	34.	-258.	24302.	748.
	26	-4721.	170.	-34.	172.	-24302.	10952.
38	26	-258.	-125.	-4.	20.	282.	-911.
	28	142.	125.	4.	-11.	-282.	486.
39	29	9.	-125.	-4.	-10.	282.	-137.
	27	-125.	125.	4.	19.	-282.	280.
40	27	-2606.	-171.	44.	201.	-7721.	-5480.
	25	2668.	171.	-44.	-312.	7721.	-1403.
41	58	-102.	-62.	-2.	5.	13.	-325.
	60	27.	62.	2.	5.	-13.	-14.
42	59	-39.	-62.	-2.	5.	13.	-161.
	61	-36.	62.	2.	5.	-13.	151.
43	26	-46.	4979.	-39.	24020.	-192.	10042.
	62	46.	-4979.	39.	-23984.	192.	-10084.
44	27	47.	2931.	48.	8003.	-221.	-5200.
	63	-47.	-2931.	-48.	-8048.	221.	5244.
45	30	1.	7910.	9.	32032.	-0.	14569.
	31	-1.	-8211.	-9.	-32051.	0.	-14567.
46	64	-20.	805.	1467.	-19509.	-320.	-88.
	66	20.	-805.	-1318.	-1204.	320.	-211.
47	65	0.	486.	728.	-14050.	-171.	122.
	67	-0.	-486.	-480.	-967.	171.	-122.
48	66	-68.	-28.	8.	-52.	80.	-72.
	67	-61.	28.	-8.	-51.	-80.	28.
49	34	-447.	1423.	-8.	419.	44.	-1750.
	68	467.	-1350.	8.	-352.	-44.	-2080.
50	35	-348.	531.	28.	161.	43.	-1256.
	69	368.	-459.	-28.	-396.	-43.	-1743.

QUAL GROUP VII

TYPE	JNT. NO. BOUNDARY OR JUNCTION REACTION						
		FX	FY	FZ	MX	MY	MZ	
BODY	31	-8211.	-1.	9.	0.	-32051.	14567.	
A -X-Z	30	7910.	1.	-9.	-0.	32032.	-14569.	

REACTION RESPONSE TO STATIC SEISMIC LOAD IN VERTICAL DIRECTION

ELT. NO.	JNT. NO.	ELEMENT FORCES.			ELEMENT MOMENTS		
		F1	F2	F3	M1	M2	M3
1	1	-19.	-109.	1.	-1.	1.	-81.
	6	16.	54.	-1.	-1.	-1.	45.
2	6	-15.	276.	1.	-1.	1.	-46.
	2	15.	-597.	-1.	-10.	-1.	-130.
3	38	0.	-1.	412.	-1.	0.	0.
	4	-0.	1.	-311.	-722.	-0.	-0.
4	9	-0.	2.	-363.	1.	-0.	-0.
	5	0.	-2.	263.	625.	0.	-1.
5	7	1.	8.	-487.	1075.	-6.	-1.
	42	-1.	-8.	588.	0.	6.	2.
6	41	-1.	-10.	677.	-1.	6.	-2.
	8	1.	10.	-577.	-1253.	-6.	0.
7	38	-2.	417.	0.	-0.	0.	-10.
	41	2.	-439.	-0.	-0.	-0.	-12.
8	9	0.	356.	2.	-10.	0.	0.
	42	-0.	-377.	-2.	-12.	-0.	0.
9	4	-0.	7.	311.	719.	-0.	-0.
	36	0.	-7.	-79.	-1586.	0.	-0.
10	37	-0.	-8.	-30.	1273.	0.	-0.
	5	0.	8.	262.	-622.	-0.	-0.
11	40	1.	7.	-254.	2724.	-5.	1.
	7	-1.	-7.	486.	-1074.	5.	1.
12	8	-0.	-7.	576.	1251.	6.	0.
	39	0.	7.	-343.	-3299.	-6.	-2.
13	3	-19.	2079.	2.	11.	1.	241.
	10	19.	-2167.	-2.	-15.	-1.	-286.
14	43	-7.	383.	138.	-521.	55.	-40.
	11	7.	-404.	-138.	141.	-55.	21.
15	12	-7.	447.	138.	482.	55.	10.
	47	7.	-468.	-138.	-862.	-55.	-28.
16	11	-7.	405.	138.	-141.	55.	-21.
	12	7.	-447.	-138.	-482.	-55.	-10.
17	46	604.	-1523.	485.	954.	636.	-1239.
	48	-604.	1474.	-485.	-1701.	-636.	2167.
18	14	16.	123.	5.	-67.	-11.	25.
	46	-16.	-162.	-5.	61.	11.	-6.
19	45	16.	-354.	5.	357.	-11.	-232.
	13	-16.	316.	-5.	-363.	11.	251.
20	44	-30.	1782.	139.	-6729.	-997.	4373.
	45	30.	-1831.	-139.	6514.	997.	-4419.
21	13	16.	-20.	5.	-90.	-11.	96.
	14	-16.	-124.	-5.	69.	11.	-26.
22	15	626.	-998.	327.	-2056.	847.	3899.
	19	-626.	912.	-327.	1320.	-847.	-2491.
23	49	132.	-309.	-357.	-0.	644.	-69.
	51	-132.	309.	466.	1569.	-644.	570.
24	52	-194.	309.	-887.	3589.	-644.	-50.
	50	194.	-309.	996.	0.	644.	-689.

QUAL GROUP VII

PAGE 26

25	50	4.	-285.	1.	-17.	0.	59.
	21	-4.	240.	-1.	-9.	-0.	50.
26	49	4.	13.	1.	-16.	0.	59.
	53	-4.	-57.	-1.	-9.	-0.	50.
27	17	617.	-420.	325.	-1288.	847.	1945.
	20	-617.	107.	-325.	-3712.	-847.	7544.
28	20	-5.	-1626.	-2.	4.	-0.	-398.
	16	5.	1370.	2.	18.	0.	329.
29	53	1.	-4.	-23.	-0.	-9.	2.
	54	-1.	4.	111.	255.	9.	2.
30	55	-1.	3.	-118.	618.	9.	-2.
	21	1.	-3.	206.	-0.	-9.	-2.
31	22	385.	313.	2616.	-1609.	-4260.	-37.
	18	-385.	-313.	-2377.	-16527.	4260.	2834.
32	18	-260.	-12.	-1522.	10893.	5205.	-1038.
	23	260.	12.	1761.	1033.	-5205.	-249.
33	22	313.	-385.	-2663.	-4259.	1609.	37.
	56	-313.	385.	2778.	13951.	-1609.	1078.
34	56	-212.	8.	-4181.	-25901.	-6958.	-173.
	24	212.	-8.	4291.	40460.	6958.	-557.
35	23	-12.	-259.	1761.	5205.	-1034.	-249.
	57	12.	259.	-1875.	-11682.	1034.	206.
36	57	-211.	-30.	2848.	19551.	2173.	-529.
	25	211.	30.	-2958.	-29531.	-2173.	-196.
37	24	8.	212.	-4291.	-6958.	40461.	557.
	26	-8.	-212.	4429.	17922.	-40461.	-536.
38	26	3.	12.	215.	-715.	197.	31.
	28	-3.	-12.	-99.	381.	-197.	-24.
39	29	3.	12.	-51.	-256.	197.	7.
	27	-3.	-12.	168.	489.	-197.	0.
40	27	30.	211.	3096.	-9788.	-29531.	271.
	25	-30.	-211.	-2959.	2174.	29531.	-196.
41	58	-20.	-25.	50.	-66.	9.	-45.
	60	20.	25.	26.	4.	-9.	-61.
42	59	24.	37.	50.	-66.	9.	70.
	61	-24.	-37.	26.	4.	-9.	54.
43	26	200.	5.	4642.	40264.	-17207.	-504.
	62	-200.	-5.	-4642.	-44618.	17207.	692.
44	27	-199.	-27.	3264.	29728.	9299.	271.
	63	199.	27.	-3264.	-32790.	-9299.	-457.
45	30	2.	-22.	7907.	77408.	-14462.	-85.
	31	-2.	22.	-8208.	-94023.	14462.	88.
46	64	-525.	-1222.	394.	-9979.	604.	-7012.
	66	525.	1074.	-394.	4116.	-604.	-802.
47	65	198.	-972.	230.	-9013.	498.	4944.
	67	-198.	725.	-230.	3297.	-498.	-8.
48	66	-102.	-431.	132.	-634.	-7.	-1105.
	67	102.	431.	-3.	-242.	7.	-215.
49	34	985.	28.	95.	540.	73.	3965.
	68	-913.	-49.	-95.	-1333.	-73.	3981.
50	35	789.	123.	232.	-304.	-37.	3138.
	69	-717.	-144.	-232.	-1639.	37.	3167.

QUAL GROUP VII

TYPE	JNT. NO. BOUNDARY OR JUNCTION REACTION					
		FX	FY	FZ	MX	MY	MZ
BODY	31	22.	-2.	8208.	14462.	-94023.	-88.
A -X-Z	30	-22.	2.	-7907.	-14462.	77408.	85.

QUAL GROUP VII

PAGE 28

REACTION RESPONSE TO OPERATIONAL LOADS (INCLUDING DEADWEIGHT)

ELT. NO.	JNT. NO.	ELEMENT FORCES.			ELEMENT MOMENTS		
		F1	F2	F3	M1	M2	M3
1	1	-2.	-11.	-1.	-1.	-1.	-9.
	6	2.	6.	1.	3.	1.	5.
2	6	-2.	29.	-1.	1.	-1.	-5.
	2	2.	-63.	1.	9.	1.	-14.
3	38	0.	-0.	43.	-0.	-0.	-0.
	4	-0.	0.	-33.	-76.	0.	0.
4	9	1.	0.	-38.	0.	0.	1.
	5	-1.	-0.	28.	66.	-0.	0.
5	7	-1.	1.	-51.	113.	5.	1.
	42	1.	-1.	62.	0.	-5.	-2.
6	41	1.	-1.	71.	-0.	-5.	1.
	8	-1.	1.	-61.	-132.	5.	-0.
7	38	-0.	44.	-0.	0.	-0.	-1.
	41	0.	-46.	0.	0.	0.	-1.
8	9	-0.	37.	0.	-1.	-0.	-0.
	42	0.	-40.	-0.	-1.	0.	-0.
9	4	0.	1.	33.	76.	-0.	0.
	36	-0.	-1.	-8.	-167.	0.	-0.
10	37	0.	-1.	-3.	134.	0.	0.
	5	-0.	1.	28.	-66.	-0.	0.
11	40	-0.	1.	-27.	287.	5.	-1.
	7	0.	-1.	51.	-113.	-5.	-1.
12	8	0.	-1.	61.	132.	-5.	0.
	39	-0.	1.	-36.	-348.	5.	2.
13	3	-2.	219.	-2.	-11.	-1.	26.
	10	2.	-228.	2.	14.	1.	-30.
14	43	-1.	45.	1.	-78.	1.	-4.
	11	1.	-48.	-1.	75.	-1.	2.
15	12	-1.	52.	1.	-70.	1.	1.
	47	1.	-55.	-1.	67.	-1.	-2.
16	11	-1.	48.	1.	-75.	1.	-2.
	12	1.	-52.	-1.	70.	-1.	-1.
17	46	70.	-222.	-105.	2798.	318.	-27.
	48	-70.	217.	105.	-2637.	-318.	134.
18	14	2.	13.	1.	-9.	-2.	3.
	46	-2.	-17.	-1.	6.	2.	-1.
19	45	2.	-37.	1.	39.	-1.	-24.
	13	-2.	33.	-1.	-40.	1.	26.
20	44	-3.	183.	-1.	-749.	-9.	429.
	45	3.	-188.	1.	750.	9.	-433.
21	13	2.	-2.	1.	-10.	-1.	10.
	14	-2.	-13.	-1.	7.	1.	-3.
22	15	67.	-161.	-108.	2240.	-203.	636.
	19	-67.	152.	108.	-1996.	203.	-486.
23	49	-45.	-33.	-75.	0.	-973.	-10.
	51	45.	33.	86.	306.	973.	-163.
24	52	60.	33.	-176.	694.	973.	38.
	50	-60.	-33.	188.	0.	-973.	192.

QUAL GROUP VII

PAGE 29

25	50	1.	-49.	-1.	25.	-0.	12.
	21	-1.	44.	1.	12.	0.	10.
26	49	1.	10.	-1.	25.	-0.	12.
	53	-1.	-15.	1.	12.	0.	10.
27	17	65.	-90.	-106.	1946.	-203.	377.
	20	-65.	57.	106.	-319.	203.	625.
28	20	-1.	-161.	3.	-8.	0.	-83.
	16	1.	134.	-3.	-25.	-0.	66.
29	53	-1.	-1.	-8.	-0.	12.	-2.
	54	1.	1.	17.	49.	-12.	-3.
30	55	1.	1.	-29.	126.	-12.	2.
	21	-1.	-1.	38.	-0.	12.	3.
31	22	85.	-44.	-119.	-281.	-637.	145.
	18	-85.	44.	144.	1237.	637.	470.
32	18	16.	63.	-611.	4624.	386.	2.
	23	-16.	-63.	636.	-93.	-386.	113.
33	22	-44.	-85.	114.	-637.	280.	-145.
	56	44.	85.	-102.	252.	-280.	-11.
34	56	-16.	13.	65.	-2448.	646.	69.
	24	16.	-13.	-53.	2244.	-646.	-123.
35	23	63.	16.	636.	386.	93.	113.
	57	-63.	-16.	-648.	-2674.	-93.	112.
36	57	-17.	-15.	805.	2344.	1293.	-130.
	25	17.	15.	-817.	-5131.	-1293.	71.
37	24	13.	16.	53.	646.	2245.	123.
	26	-13.	-16.	-39.	-762.	-2245.	-90.
38	26	2.	1.	7.	3.	-56.	8.
	28	-2.	-1.	5.	-5.	56.	-5.
39	29	2.	1.	-21.	-62.	-56.	-3.
	27	-2.	-1.	33.	119.	56.	6.
40	27	15.	17.	831.	-3365.	-5131.	-32.
	25	-15.	-17.	-817.	1293.	5131.	71.
41	58	7.	-2.	-2.	13.	-3.	19.
	60	-7.	2.	10.	21.	3.	18.
42	59	-6.	3.	-2.	13.	-3.	-14.
	61	6.	-3.	10.	21.	3.	-15.
43	26	15.	12.	-31.	2301.	759.	-82.
	62	-15.	-12.	31.	-2272.	-759.	95.
44	27	-16.	-14.	864.	5075.	3246.	-26.
	63	16.	14.	-864.	-5865.	-3246.	11.
45	30	-2.	-2.	833.	8157.	8260.	14.
	31	2.	2.	-864.	-9906.	-8260.	-18.
46	64	28.	-18.	98.	-1708.	-16.	195.
	66	-28.	2.	-98.	254.	16.	224.
47	65	80.	-157.	-31.	486.	-6.	1721.
	67	-80.	131.	31.	286.	6.	275.
48	66	20.	-29.	-23.	174.	9.	117.
	67	-20.	29.	36.	208.	-9.	143.
49	34	56.	107.	-57.	-118.	-49.	204.
	68	-48.	-109.	57.	595.	49.	230.
50	35	77.	-75.	-52.	-157.	-53.	303.
	69	-70.	72.	52.	589.	53.	312.

QUAL GROUP VII

PAGE 30

TYPE	JNT. NO. BOUNDARY OR JUNCTION REACTION					
		Fx	FY	FZ	MX	MY	MZ
BODY	31	2.	2.	864.	-8260.	-9906.	18.
A -x-z	30	-2.	-2.	-833.	8260.	8157.	-14.

DEFORMATION RESPONSE TO STATIC SEISMIC LOAD IN HORIZ(1) DIRECTION

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	-0.002411	0.007741	-0.000392	0.000387	0.000109	0.000061
2	-0.000930	0.002274	-0.000403	0.000377	0.000109	0.000061
3	-0.000930	0.002243	-0.000403	0.000200	0.000105	0.000061
4	-0.002411	0.007962	-0.000776	0.000387	0.000110	0.000061
5	-0.002411	0.007543	-0.000030	0.000387	0.000110	0.000061
6	-0.002193	0.006950	-0.000403	0.000387	0.000109	0.000061
7	-0.000930	0.002045	-0.000032	0.000254	0.000110	0.000061
8	-0.000930	0.002463	-0.000774	0.000254	0.000110	0.000061
9	-0.002411	0.007666	-0.000250	0.000387	0.000107	0.000061
10	-0.000687	0.001803	-0.000403	0.000131	0.000105	0.000061
11	-0.000229	0.001627	-0.001111	0.000129	0.000104	0.000033
12	0.000237	0.001037	-0.001110	0.000122	0.000104	-0.000010
13	-0.000229	0.001285	-0.000441	0.000120	0.000103	0.000038
14	0.000235	0.000734	-0.000441	0.000120	0.000103	0.000042
15	0.000450	0.000585	-0.000463	0.000110	0.000104	0.000026
16	-0.000078	0.036598	-0.000628	-0.001229	-0.000030	-0.000026
17	0.000683	0.000486	-0.000608	-0.001249	-0.000024	0.000001
18	0.000003	0.000928	-0.000302	0.000120	0.000103	0.000046
19	0.000683	0.000453	-0.000466	0.000053	0.000101	0.000002
20	0.000297	0.020409	-0.000632	-0.001256	-0.000030	-0.000026
21	-0.000078	0.036637	-0.000465	-0.001227	0.000044	-0.000026
22	-0.000175	0.000880	-0.000303	-0.000176	-0.000005	0.000047
23	0.000175	0.000876	0.000134	-0.000191	0.000007	0.000047
24	-0.000125	0.000077	-0.000339	-0.000143	-0.000003	0.000024
25	0.000125	0.000077	0.000294	-0.000108	0.000004	0.000023
26	-0.000039	0.000062	-0.000098	-0.000025	0.000000	0.000016
27	0.000039	0.000062	0.000098	-0.000024	-0.000000	0.000016
28	-0.000011	0.000063	-0.000050	-0.000021	0.000000	0.000016
29	0.000011	0.000063	0.000051	-0.000021	0.000000	0.000015
30	-0.000000	0.000050	-0.000000	-0.000021	0.000000	0.000008
31	0.0	0.0	0.0	0.0	0.0	0.0
32	-0.000180	0.003817	0.000684	-0.000667	-0.000006	0.000075
33	0.000182	0.001840	-0.000003	-0.000274	0.000006	0.000074
34	-0.001257	0.016954	0.001026	-0.000826	-0.000057	0.000265
35	0.002985	0.016931	0.000167	-0.000761	0.000075	0.000284
36	-0.002411	0.008228	-0.001263	0.000387	0.000109	0.000061
37	-0.002411	0.007267	0.000457	0.000387	0.000109	0.000061
38	-0.002411	0.007841	-0.00055	0.000387	0.000107	0.000061
39	-0.000930	0.002755	-0.001263	0.000377	0.000109	0.000061
40	-0.000930	0.001794	0.000457	0.000377	0.000109	0.000061
41	-0.000930	0.002331	-0.000554	0.000200	0.000105	0.000061
42	-0.000930	0.002156	-0.000252	0.000200	0.000105	0.000061
43	-0.000516	0.002000	-0.001111	0.000131	0.000105	0.000061
44	-0.000516	0.001611	-0.000441	0.000131	0.000105	0.000061
45	-0.000355	0.001405	-0.000441	0.000120	0.000103	0.000046
46	0.000360	0.000576	-0.000441	0.000120	0.000103	0.000046
47	0.000523	0.000669	-0.001109	0.000110	0.000104	0.000026
48	0.000523	0.000503	-0.000444	0.000110	0.000104	0.000026

QUAL GROUP VII

49	0.000683	0.000456	-0.000612	0.000053	0.000101	0.000002
50	0.000683	0.000449	-0.000320	0.000053	0.000101	0.000002
51	0.000683	0.000490	-0.000483	-0.001249	-0.000024	0.000001
52	0.000683	0.000481	-0.000733	-0.001249	-0.000024	0.000001
53	-0.000078	0.036563	-0.000590	-0.001227	0.000044	-0.000026
54	-0.000078	0.036462	-0.000472	-0.001229	-0.000030	-0.000026
55	-0.000078	0.036733	-0.000783	-0.001229	-0.000030	-0.000026
56	-0.000152	0.000480	0.000684	-0.000667	-0.000006	0.000075
57	0.000152	0.000471	-0.000003	-0.000274	0.000006	0.000074
58	-0.000011	-0.000024	-0.000050	-0.000021	0.000000	0.000016
59	-0.000011	0.000150	-0.000050	-0.000021	0.000000	0.000016
60	0.000011	-0.000024	0.000051	-0.000021	0.000000	0.000015
61	0.000011	0.000150	0.000051	-0.000021	0.000000	0.000015
62	-0.000039	0.000050	-0.000098	-0.000021	0.000000	0.000008
63	0.000039	0.000050	0.000098	-0.000021	0.000000	0.000008
64	-0.000122	0.003817	0.001195	-0.000667	-0.000006	0.000075
65	0.000064	-0.000898	-0.000212	-0.000274	0.000006	0.000074
66	-0.001228	0.016541	0.001026	-0.000826	-0.000057	0.000265
67	0.002947	0.016551	0.000167	-0.000761	0.000075	0.000284
68	0.000392	0.020409	-0.005263	-0.001256	-0.000030	-0.000026
69	0.000057	0.020409	0.011061	-0.001256	-0.000030	-0.000026

QUAL GROUP VII

PAGE 33

DEFORMATION RESPONSE TO STATIC SEISMIC LOAD IN HORIZ(2) DIRECTION

JOINT NO.	DEFLECTION			ROTATION		
	X	Y	Z	X	Y	Z
1	0.045925	-0.003214	-0.002120	-0.000147	-0.003024	-0.000113
2	0.004593	-0.001233	-0.001817	-0.000147	-0.003022	-0.000113
3	0.004584	-0.001233	-0.001815	-0.000147	-0.000603	-0.000113
4	0.045927	-0.003612	0.007522	-0.000147	-0.003412	-0.000113
5	0.045927	-0.002838	-0.011153	-0.000147	-0.003412	-0.000113
6	0.039860	-0.002932	-0.001817	-0.000147	-0.003024	-0.000113
7	0.004587	-0.000846	-0.010280	-0.000147	-0.003729	-0.000113
8	0.004587	-0.001620	0.006650	-0.000147	-0.003729	-0.000113
9	0.045926	-0.003063	-0.004251	-0.000147	-0.001694	-0.000113
10	0.003213	-0.000894	-0.001815	-0.000147	-0.000532	-0.000113
11	0.001493	-0.000805	0.000241	-0.000153	-0.000504	-0.000117
12	-0.000773	-0.000085	0.000139	-0.000153	-0.000506	-0.000061
13	0.001443	-0.000368	-0.003073	-0.000145	-0.000501	-0.000018
14	-0.000815	0.000273	-0.003073	-0.000145	-0.000501	-0.000013
15	-0.001976	0.000580	-0.001933	-0.000147	-0.000491	-0.000066
16	0.023034	0.000615	-0.002419	0.000012	0.000883	-0.000040
17	-0.003009	0.000902	-0.002361	0.000005	0.000899	-0.000053
18	0.000309	-0.000041	-0.003747	-0.000145	-0.000501	-0.000012
19	-0.003014	0.000903	-0.001941	-0.000141	-0.000453	-0.000054
20	0.011154	0.000766	-0.002432	0.000012	0.000916	-0.000040
21	0.023034	0.000673	-0.001984	0.000013	0.000097	-0.000040
22	0.000163	-0.000037	-0.002607	0.000273	0.000284	0.000004
23	0.000084	-0.000044	-0.001474	-0.000353	0.000101	-0.000020
24	0.000093	-0.000005	-0.000043	-0.000003	0.000270	-0.000007
25	0.000041	-0.000001	-0.000033	-0.000004	0.000098	0.000001
26	0.000017	-0.000005	-0.000040	-0.000000	0.000027	-0.000005
27	0.000004	-0.000002	-0.000037	-0.000000	0.000021	0.000001
28	0.000008	-0.000004	-0.000039	-0.000000	0.000025	-0.000005
29	0.000003	-0.000002	-0.000037	-0.000000	0.000023	0.000001
30	0.000010	-0.000001	-0.000019	-0.000000	0.000018	-0.000001
31	0.0	0.0	0.0	0.0	0.0	0.0
32	0.001573	0.000228	-0.000901	-0.000052	0.000287	-0.000001
33	0.000584	0.000313	-0.000502	-0.000063	0.000104	-0.000009
34	0.010726	0.001039	-0.000755	-0.000046	0.000650	-0.000036
35	0.010154	0.001042	-0.000443	-0.000044	0.000511	-0.000041
36	0.045925	-0.004114	0.022054	-0.000147	-0.003024	-0.000113
37	0.045925	-0.002336	-0.025689	-0.000147	-0.003024	-0.000113
38	0.045926	-0.003387	0.000620	-0.000147	-0.001694	-0.000113
39	0.004593	-0.002122	0.022041	-0.000147	-0.003022	-0.000113
40	0.004593	-0.000344	-0.025675	-0.000147	-0.003022	-0.000113
41	0.004584	-0.001395	-0.000948	-0.000147	-0.000603	-0.000113
42	0.004584	-0.001071	-0.002682	-0.000147	-0.000603	-0.000113
43	0.002897	-0.001258	0.000316	-0.000147	-0.000532	-0.000113
44	0.002897	-0.000539	-0.003083	-0.000147	-0.000532	-0.000113
45	0.002044	-0.000559	-0.003073	-0.000145	-0.000501	-0.000012
46	-0.001425	0.000445	-0.003073	-0.000145	-0.000501	-0.000012
47	-0.002160	0.000368	0.000064	-0.000147	-0.000491	-0.000066
48	-0.002160	0.000786	-0.003069	-0.000147	-0.000491	-0.000066

QUAL GROUP VII

49	-0.003014	0.000825	-0.001289	-0.000141	-0.000453	-0.000054
50	-0.003014	0.000980	-0.002592	-0.000141	-0.000453	-0.000054
51	-0.003009	0.000624	-0.007081	0.000005	0.000899	-0.000053
52	-0.003009	0.001181	0.002358	0.000005	0.000899	-0.000053
53	0.023034	0.000558	-0.002264	0.000013	0.000097	-0.000040
54	0.023034	0.000406	-0.007055	0.000012	0.000883	-0.000040
55	0.023034	0.000825	0.002217	0.000012	0.000883	-0.000040
56	0.000136	-0.000030	-0.000901	-0.000052	0.000287	-0.000001
57	0.000066	-0.000004	-0.000502	-0.000063	0.000104	-0.000009
58	-0.000094	-0.000005	-0.000039	-0.000000	0.000025	-0.000005
59	0.000110	-0.000003	-0.000039	-0.000000	0.000025	-0.000005
60	-0.000092	-0.000003	-0.000037	-0.000000	0.000023	0.000001
61	0.000099	-0.000001	-0.000037	-0.000000	0.000023	0.000001
62	0.000017	-0.000001	-0.000019	-0.000000	0.000018	-0.000001
63	0.000003	-0.000001	-0.000019	-0.000000	0.000018	-0.000001
64	0.001572	0.000228	-0.000861	-0.000052	0.000287	-0.000001
65	-0.000445	-0.000320	-0.000551	-0.000063	0.000104	-0.000009
66	0.010401	0.001016	-0.000755	-0.000046	0.000650	-0.000036
67	0.009899	0.001020	-0.000443	-0.000044	0.000511	-0.000041
68	0.011301	0.000766	-0.002388	0.000012	0.000916	-0.000040
69	0.010783	0.000766	-0.002544	0.000012	0.000916	-0.000040

QUAL GROUP VII

PAGE 35

DEFORMATION RESPONSE TO STATIC SEISMIC LOAD IN VERTICAL DIRECTION

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	-0.022572	-0.005468	-0.018356	-0.000263	0.001091	0.000015
2	-0.007733	-0.001898	-0.018450	-0.000263	0.001091	0.000015
3	-0.007733	-0.001898	-0.017863	-0.000263	0.001056	0.000015
4	-0.022572	-0.005415	-0.022041	-0.000263	0.001160	0.000015
5	-0.022572	-0.005517	-0.014569	-0.000263	0.001034	0.000015
6	-0.020389	-0.004941	-0.018466	-0.000263	0.001091	0.000015
7	-0.007733	-0.001949	-0.014410	-0.000263	0.000981	0.000015
8	-0.007733	-0.001846	-0.021856	-0.000263	0.001223	0.000015
9	-0.022572	-0.005488	-0.016622	-0.000263	0.001072	0.000015
10	-0.005293	-0.001290	-0.017849	-0.000263	0.001055	0.000015
11	-0.002373	-0.000502	-0.020500	-0.000264	0.001042	0.000014
12	0.002297	0.000699	-0.020478	-0.000264	0.001038	0.000039
13	-0.002376	-0.000592	-0.013774	-0.000260	0.001042	0.000001
14	0.002309	0.000577	-0.013773	-0.000260	0.001041	0.000001
15	0.005053	0.001313	-0.017814	-0.000260	0.001046	0.000038
16	0.025806	0.005322	-0.018142	-0.000130	0.000675	0.000050
17	0.007374	0.001877	-0.018043	-0.000124	0.000658	0.000044
18	-0.000034	-0.000009	-0.012372	-0.000260	0.001041	0.000001
19	0.007378	0.001883	-0.017820	-0.000254	0.001035	0.000043
20	0.017330	0.003683	-0.018060	-0.000130	0.000674	0.000050
21	0.025806	0.005251	-0.016740	-0.000129	0.000874	0.000050
22	-0.000005	-0.000003	-0.006946	0.001151	0.000499	-0.000002
23	-0.000004	-0.000009	-0.005627	-0.001201	0.000379	0.000002
24	-0.000001	0.000001	-0.000546	-0.000188	0.000468	0.000000
25	-0.000001	-0.000001	-0.000265	0.000077	0.000355	-0.000000
26	-0.000000	0.000000	-0.000203	-0.000016	0.000065	0.000000
27	0.000000	-0.000000	-0.000114	-0.000005	0.000060	-0.000000
28	0.000000	0.000000	-0.000178	-0.000010	0.000063	0.000000
29	0.000000	-0.000000	-0.000132	-0.000010	0.000062	-0.000000
30	-0.000000	0.000000	-0.000106	-0.000009	0.000048	0.000000
31	0.0	0.0	0.0	0.0	0.0	0.0
32	0.002461	-0.000253	-0.002849	0.000054	0.000492	0.000002
33	0.001862	0.002359	-0.002743	-0.000475	0.000373	0.000001
34	0.012819	0.002745	-0.003042	-0.000231	0.000777	0.000069
35	0.014000	0.002726	-0.003294	-0.000094	0.000789	0.000094
36	-0.022572	-0.005349	-0.027082	-0.000263	0.001091	0.000015
37	-0.022572	-0.005584	-0.009849	-0.000263	0.001091	0.000015
38	-0.022572	-0.005445	-0.019703	-0.000263	0.001072	0.000015
39	-0.007733	-0.001780	-0.027066	-0.000263	0.001091	0.000015
40	-0.007733	-0.002015	-0.009834	-0.000263	0.001091	0.000015
41	-0.007733	-0.001876	-0.019380	-0.000263	0.001056	0.000015
42	-0.007733	-0.001919	-0.016346	-0.000263	0.001056	0.000015
43	-0.005251	-0.001242	-0.020515	-0.000263	0.001055	0.000015
44	-0.005251	-0.001337	-0.013782	-0.000263	0.001055	0.000015
45	-0.003638	-0.000906	-0.013773	-0.000260	0.001041	0.000001
46	0.003571	0.000891	-0.013773	-0.000260	0.001041	0.000001
47	0.005159	0.001435	-0.020461	-0.000260	0.001046	0.000038
48	0.005159	0.001193	-0.013780	-0.000260	0.001046	0.000038

QUAL GROUP VII

PAGE 36

49	0.007378	0.001945	-0.019308	-0.000254	0.001035	0.000043
50	0.007378	0.001821	-0.016333	-0.000254	0.001035	0.000043
51	0.007374	0.002105	-0.021497	-0.000124	0.000658	0.000044
52	0.007374	0.001648	-0.014589	-0.000124	0.000658	0.000044
53	0.025806	0.005394	-0.019253	-0.000129	0.000874	0.000050
54	0.025806	0.005583	-0.021688	-0.000130	0.000675	0.000050
55	0.025806	0.005062	-0.014597	-0.000130	0.000675	0.000050
56	-0.000001	0.000019	-0.002849	0.000054	0.000492	0.000002
57	-0.000001	-0.000014	-0.002743	-0.000475	0.000373	0.000001
58	-0.000256	-0.000039	-0.000178	-0.000010	0.000063	0.000000
59	0.000257	0.000040	-0.000178	-0.000010	0.000063	0.000000
60	-0.000252	-0.000039	-0.000132	-0.000010	0.000062	-0.000000
61	0.000252	0.000039	-0.000132	-0.000010	0.000062	-0.000000
62	-0.000000	0.000000	-0.000149	-0.000009	0.000048	0.000000
63	0.000000	0.000000	-0.000063	-0.000009	0.000048	0.000000
64	0.002462	-0.000253	-0.002890	0.000054	0.000492	0.000002
65	-0.001865	-0.002386	-0.003106	-0.000475	0.000373	0.000001
66	0.012430	0.002630	-0.003042	-0.000231	0.000777	0.000069
67	0.013606	0.002679	-0.003294	-0.000094	0.000789	0.000094
68	0.017147	0.003683	-0.018542	-0.000130	0.000674	0.000050
69	0.017793	0.003683	-0.016845	-0.000130	0.000674	0.000050

QUAL GROUP VII

PAGE 37

DEFORMATION RESPONSE TO OPERATIONAL LOADS (INCLUDING DEADWEIGHT)

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	-0.002410	0.005036	-0.001360	0.000240	0.000117	0.000001
2	-0.000825	0.001770	-0.001370	0.000240	0.000117	0.000001
3	-0.000824	0.001770	-0.001308	0.000240	0.000113	0.000001
4	-0.002410	0.005038	-0.001754	0.000240	0.000124	0.000001
5	-0.002410	0.005033	-0.000956	0.000240	0.000111	0.000001
6	-0.002177	0.004555	-0.001372	0.000240	0.000117	0.000001
7	-0.000824	0.001767	-0.000939	0.000240	0.000105	0.000001
8	-0.000824	0.001773	-0.001734	0.000240	0.000130	0.000001
9	-0.002410	0.005035	-0.001175	0.000240	0.000115	0.000001
10	-0.000564	0.001214	-0.001307	0.000240	0.000113	0.000001
11	-0.000254	0.000556	-0.002345	0.000240	0.000112	0.000001
12	0.000246	-0.000523	-0.002342	0.000240	0.000111	0.000002
13	-0.000254	0.000550	-0.001626	0.000241	0.000111	0.000001
14	0.000247	-0.000533	-0.001626	0.000241	0.000111	0.000001
15	0.000546	-0.001189	-0.001307	0.000239	0.000112	0.000002
16	0.001802	-0.002502	-0.001362	0.000028	0.000038	-0.000001
17	0.000793	-0.001714	-0.001350	0.000035	0.000037	0.000001
18	-0.000004	0.000008	-0.001476	0.000241	0.000111	0.000001
19	0.000793	-0.001716	-0.001308	0.000232	0.000110	0.000001
20	0.001331	-0.002148	-0.001354	0.000028	0.000037	-0.000001
21	0.001802	-0.002501	-0.001223	0.000027	0.000078	-0.000001
22	-0.000001	0.000007	-0.000344	0.000103	0.000030	0.000000
23	-0.000000	0.000007	-0.001079	-0.000200	0.000062	0.000001
24	0.000000	0.000000	0.000035	0.000015	0.000028	0.000000
25	-0.000000	-0.000000	-0.000115	0.000039	0.000058	0.000000
26	0.000000	0.000000	0.000008	0.000005	0.000006	0.000000
27	-0.000000	-0.000000	-0.000042	0.000006	0.000007	0.000000
28	0.000000	0.000000	-0.000003	0.000005	0.000006	0.000000
29	-0.000000	-0.000000	-0.000029	0.000005	0.000007	0.000000
30	-0.000000	-0.000000	-0.000011	0.000005	0.000005	-0.000000
31	0.0	0.0	0.0	0.0	0.0	0.0
32	0.000150	-0.000465	-0.000221	0.000093	0.000030	0.000001
33	0.000305	0.000067	-0.000457	-0.000013	0.000061	0.000001
34	0.001058	-0.001974	-0.000294	0.000092	0.000070	-0.000001
35	0.001018	-0.001974	-0.000499	0.000098	0.000054	-0.000000
36	-0.002410	0.005042	-0.002292	0.000240	0.000117	0.000001
37	-0.002410	0.005029	-0.000451	0.000240	0.000117	0.000001
38	-0.002410	0.005037	-0.001504	0.000240	0.000115	0.000001
39	-0.000825	0.001776	-0.002291	0.000240	0.000117	0.000001
40	-0.000825	0.001764	-0.000449	0.000240	0.000117	0.000001
41	-0.000824	0.001771	-0.001470	0.000240	0.000113	0.000001
42	-0.000824	0.001769	-0.001146	0.000240	0.000113	0.000001
43	-0.000562	0.001217	-0.002347	0.000240	0.000113	0.000001
44	-0.000562	0.001212	-0.001627	0.000240	0.000113	0.000001
45	-0.000389	0.000842	-0.001626	0.000241	0.000111	0.000001
46	0.000382	-0.000825	-0.001626	0.000241	0.000111	0.000001
47	0.000552	-0.001182	-0.002340	0.000239	0.000112	0.000002
48	0.000552	-0.001195	-0.001627	0.000239	0.000112	0.000002

QUAL GROUP VII

PAGE 38

49	0.000793	-0.001714	-0.001465	0.000232	0.000110	0.000001
50	0.000793	-0.001717	-0.001150	0.000232	0.000110	0.000001
51	0.000793	-0.001710	-0.001541	0.000035	0.000037	0.000001
52	0.000793	-0.001717	-0.001158	0.000035	0.000037	0.000001
53	0.001802	-0.002504	-0.001446	0.000027	0.000078	-0.000001
54	0.001802	-0.002507	-0.001560	0.000028	0.000038	-0.000001
55	0.001802	-0.002498	-0.001165	0.000028	0.000038	-0.000001
56	0.000000	0.000002	-0.000221	0.000093	0.000030	0.000001
57	-0.000000	0.000000	-0.000457	-0.000013	0.000061	0.000001
58	-0.000026	0.000022	-0.000003	0.000005	0.000006	0.000000
59	0.000026	-0.000022	-0.000003	0.000005	0.000006	0.000000
60	-0.000027	0.000022	-0.000029	0.000005	0.000007	0.000000
61	0.000027	-0.000022	-0.000029	0.000005	0.000007	0.000000
62	0.000000	-0.000000	0.000013	0.000005	0.000005	-0.000000
63	-0.000000	-0.000000	-0.000036	0.000005	0.000005	-0.000000
64	0.000151	-0.000465	-0.000293	0.000093	0.000030	0.000001
65	-0.000306	-0.000067	-0.000467	-0.000013	0.000061	0.000001
66	0.001023	-0.001928	-0.000294	0.000092	0.000070	-0.000001
67	0.000991	-0.001925	-0.000499	0.000098	0.000054	-0.000000
68	0.001334	-0.002148	-0.001250	0.000028	0.000037	-0.000001
69	0.001324	-0.002148	-0.001617	0.000028	0.000037	-0.000001

EVALUATION OF VALVE

DEFORMATION RESPONSE OF COMBINED STATIC SEISMIC AND OPERATIONAL LOADS

JOINT NO.	. . . DEFLECTION ROTATION . . .		
	X	Y	Z	X	Y	Z
1	-0.053640	0.015043	-0.019843	0.000730	0.003333	0.000130
2	-0.009867	0.004978	-0.019914	0.000722	0.003331	0.000130
3	-0.009862	0.004956	-0.019267	0.000602	0.001333	0.000130
4	-0.053641	0.015322	-0.025056	0.000730	0.003729	0.000130
5	-0.053641	0.014800	-0.019304	0.000730	0.003678	0.000130
6	-0.047002	0.013573	-0.019931	0.000730	0.003334	0.000130
7	-0.009864	0.004716	-0.018640	0.000634	0.003962	0.000129
8	-0.009864	0.005252	-0.024593	0.000634	0.004056	0.000130
9	-0.053641	0.014947	-0.018334	0.000730	0.002122	0.000130
10	-0.006794	0.003605	-0.019252	0.000569	0.001299	0.000130
11	-0.003066	0.002439	-0.022877	0.000572	0.001274	0.000124
12	0.002681	-0.001776	-0.022851	0.000568	0.001271	0.000074
13	-0.003044	0.002012	-0.015746	0.000561	0.001272	0.000043
14	0.002707	-0.001506	-0.015745	0.000561	0.001272	0.000045
15	0.005990	-0.002738	-0.019231	0.000558	0.001272	0.000082
16	0.036392	-0.039490	-0.019676	0.001264	0.001150	-0.000069
17	0.008787	-0.003652	-0.019556	0.001290	0.001151	0.000069
18	-0.000315	0.000937	-0.014407	0.000561	0.001271	0.000049
19	0.008792	-0.003852	-0.019239	0.000527	0.001244	0.000070
20	0.021942	-0.022901	-0.019589	0.001291	0.001175	-0.000069
21	0.036393	-0.039519	-0.018087	0.001261	0.000958	-0.000069
22	-0.000240	0.000888	-0.007769	0.001299	0.000605	0.000048
23	-0.000194	0.000884	-0.006898	-0.001466	0.000454	0.000052
24	0.000156	0.000078	0.000679	0.000251	0.000569	0.000025
25	-0.000131	-0.000077	-0.000512	0.000172	0.000427	0.000023
26	0.000043	0.000062	0.000237	0.000035	0.000076	0.000017
27	-0.000039	-0.000062	-0.000197	0.000031	0.000071	0.000016
28	0.000014	0.000063	-0.000192	0.000029	0.000074	0.000016
29	-0.000012	-0.000063	-0.000176	0.000029	0.000073	0.000015
30	-0.000010	-0.000050	-0.000118	0.000028	0.000056	-0.000008
31	0.0	0.0	0.0	0.0	0.0	0.0
32	0.003077	-0.004297	-0.003286	0.000765	0.000600	0.000076
33	0.002265	0.003075	-0.003246	-0.000565	0.000448	0.000075
34	0.017819	-0.019180	-0.003592	0.000951	0.001085	-0.000277
35	0.018568	-0.019155	-0.003827	0.000865	0.000997	-0.000302
36	-0.053640	0.015683	-0.037241	0.000730	0.003333	0.000130
37	-0.053640	0.014487	-0.027967	0.000730	0.003333	0.000130
38	-0.053641	0.015166	-0.021225	0.000730	0.002122	0.000130
39	-0.009867	0.005683	-0.037219	0.000722	0.003331	0.000130
40	-0.009867	0.004483	-0.027947	0.000722	0.003331	0.000130
41	-0.009862	0.005072	-0.020882	0.000602	0.001333	0.000130
42	-0.009862	0.004847	-0.017712	0.000602	0.001333	0.000130
43	-0.006581	0.003886	-0.022894	0.000569	0.001299	0.000130
44	-0.006581	0.003374	-0.015756	0.000569	0.001299	0.000130

QUAL GROUP VII

PAGE 40

45	-0.004577	0.002605	-0.015744	0.000561	0.001271	0.000049
46	0.004243	-0.001976	-0.015744	0.000561	0.001271	0.000049
47	0.006170	-0.002808	-0.022831	0.000558	0.001272	0.000082
48	0.006170	-0.002710	-0.015752	0.000558	0.001272	0.000082
49	0.008792	-0.003876	-0.020826	0.000527	0.001244	0.000070
50	0.008792	-0.003833	-0.017691	0.000527	0.001244	0.000070
51	0.008787	-0.003960	-0.024180	0.001290	0.001151	0.000069
52	0.008787	-0.003801	-0.015954	0.001290	0.001151	0.000069
53	0.036393	-0.039467	-0.020841	0.001261	0.000958	-0.000069
54	0.036392	-0.039396	-0.024371	0.001264	0.001150	-0.000069
55	0.036392	-0.039587	-0.015950	0.001264	0.001150	-0.000069
56	0.000204	0.000484	-0.003286	0.000765	0.000600	0.000076
57	-0.000166	0.000471	-0.003246	-0.000565	0.000448	0.000075
58	-0.000299	0.000069	-0.000192	0.000029	0.000074	0.000016
59	0.000306	-0.000177	-0.000192	0.000029	0.000074	0.000016
60	-0.000296	0.000068	-0.000176	0.000029	0.000073	0.000015
61	0.000299	-0.000177	-0.000176	0.000029	0.000073	0.000015
62	0.000042	-0.000050	0.000193	0.000028	0.000056	-0.000008
63	-0.000039	-0.000050	-0.000153	0.000028	0.000056	-0.000008
64	0.003075	-0.004297	-0.003536	0.000765	0.000600	0.000076
65	-0.002225	-0.002637	-0.003629	-0.000565	0.000448	0.000075
66	0.017277	-0.018708	-0.003592	0.000951	0.001085	-0.000277
67	0.018072	-0.018722	-0.003827	0.000865	0.000997	-0.000302
68	0.021874	-0.022901	-0.020672	0.001291	0.001175	-0.000069
69	0.022129	-0.022901	-0.021929	0.001291	0.001175	-0.000069

QUAL GROUP VII

PAGE 41

BEAM STRESS FOR COMBINED STATIC AND OPERATIONAL LOADS

ELM NO.	JNT NO.	SPT NO.	C1 K	C2 FAC1	C3 FAC3/2	STRESS/10(3) SMAX SAL		MATERIAL DESCRIPTION	SMAX /SAL	NOTE
31	18	6	0.0 1.12	0.0 1.50	-0.56 1.00	8.6	27.0	STEEL	0.32	
32	18	6	0.0 1.12	0.0 1.50	-0.56 1.00	7.6	27.0	STEEL	0.28	
33	56	11	-0.73 0.83	0.0 3.50	-5.00 1.00	2.6	27.0	STEEL	0.10	
34	24	9	-0.73 0.83	0.0 3.50	5.00 1.00	6.4	27.0	STEEL	0.24	
35	23	1	3.23 0.0	0.0 1.00	5.00 1.00	2.0	27.0	STEEL	0.07	
36	25	11	-0.73 0.83	0.0 3.50	-5.00 1.00	4.4	27.0	STEEL	0.16	
37	26	5	0.0 1.84	0.0 1.50	0.94 1.00	6.6	27.0	STEEL	0.25	
38	26	3	-5.50 0.0	0.0 1.00	-0.94 1.00	0.2	27.0	STEEL	0.01	
39	27	3	-5.50 0.0	0.0 1.00	-0.94 1.00	0.2	27.0	STEEL	0.01	
40	27	5	0.0 1.84	0.0 1.50	0.94 1.00	4.9	27.0	STEEL	0.18	
41	58	3	-1.44 0.0	0.0 1.00	-0.94 1.00	0.4	27.0	STEEL	0.01	
42	59	3	-1.44 0.0	0.0 1.00	-0.94 1.00	0.4	27.0	STEEL	0.01	
45	31	5	3.52 8.99	0.0 2.42	-2.38 1.37	3.3	27.0	STEEL	0.12	
46	64	2	1.50 0.0	0.0 1.00	-2.50 1.00	6.2	27.0	STEEL	0.23	
47	65	4	-1.50 0.0	0.0 1.00	2.50 1.00	5.9	27.0	STEEL	0.22	
48	66	4	2.50 0.0	0.0 1.00	-0.38 1.00	6.4	27.0	STEEL	0.24	
49	68	1	0.38 0.0	0.0 1.00	2.25 1.00	14.4	27.0	STEEL	0.53	
50	69	4	0.38 0.0	0.0 1.00	-2.25 1.00	16.2	27.0	STEEL	0.60	

BOLTED JOINT STRESS FOR COMBINED STATIC AND OPERATIONAL LOADS
(N=NUMBER OF BOLTS, AREA=AREA PER BOLT)

BOLT JNT	DESCRIPTION	BOLT	STRESS/10(3)		MATERIAL	SMAX	NOTE
JNT LOC.	TYPE	N	AREA	NO.	DESCRIPTION	SAL	/SAL
30	A	PAD	4	0.31	4	45.9 46.0	SAE GR5 1.00

THIS EQUIPMENT IS ACCEPTABLE FOR THE SPECIFIED SEISMIC DISTURBANCE

THIS REPORT HAS BEEN PREPARED BY /

BARRY L. GAARDER
SENIOR DRAFTSMAN

FISHER CONTROLS COMPANY

VERSION 04/22/82

ATTACHMENT 3

FQP-11AB-7

Pressure Retaining Parts Stress Calculations
for 14-inch Type 9280 Valves

Vogtle Group VII

NA-140



MARSHALLTOWN, IOWA

BUTTERFLY VALVE TYPE 9280

NO. SAG 1034

Calculation Procedure
for
Pressure Retaining Parts

BY BLG 9-5-8

JHM 9-27-8

PAGE 1 OF 15

REV

Following are stress calculations to determine:

1. Valve body hoop and bending stress
2. Retaining ring hoop stress
3. Shaft torsional, bending, and shear stress
4. Disc bending stress

NA-140, Page 1, Rev. A

These calculations are for a Type 9280 Butterfly Valve constructed of the following materials:

- | | |
|-------------------|---------------------|
| 1. Body | <u>SA-182</u> |
| 2. Disc | <u>SA-351-CF8M</u> |
| 3. Retaining ring | <u>SA-351-CF8M</u> |
| 4. Shaft | <u>SA-564 H1075</u> |

Reference:

- | | |
|-----------|-----------------------------|
| Order No. | <u>22B-X5AC03-NIT, N2-T</u> |
| P.O. | <u>PAV-206, PAV-2-34</u> |
| Item No. | <u>147-150, 179-182</u> |
| Category | <u>Seismic Category I</u> |
| Type | <u>14" 9280</u> |

Serial
Valve [REDACTED] No's.

Tag
[REDACTED] No's.

8672365, 66, 67, 68, 69

{ 1HV-2628B, 1HV-2627B, 1HV-2629B
2HV-2627B, 2HV-2629B

8673191

1HV-2626B

8670354, 55

{ 2HV-2626B

2HV-2628B



MARSHALLTOWN, IOWA

BUTTERFLY VALVE TYPE 9280

Calculation Procedure
for
Pressure Retaining Parts

NO. SAG 1034

BY BLG 9-5-84


9-27-84

PAGE 3 OF 15

REV

1. Body Hoop & Bending Stress

NA-140, Page 3, Rev. A



$$\sigma_h = \frac{P(2a)}{2t} \text{ for thin cylinder}$$

$$= \frac{P(b^2 + a^2)}{(b^2 - a^2)} \text{ for thick cylinder}$$

$$= \frac{60(7.875^2 + 6.875^2)}{7.875^2 - 6.875^2}$$

$$= 445 \text{ psi}$$


Where

- P = Internal pressure (PSIG)
- 2a = Inside diameter (In)
- 2b = Outside diameter (In)
- t = Wall thickness (In)
- σ_h = Hoop stress in Body (PSI)

$$S_r = -P$$


$$= -60 \text{ PSI}$$

NOTE: The body is considered to be a thick walled cylinder since $b/t < 10$.

 MARSHALLTOWN, IOWA	BUTTERFLY VALVE TYPE 9280		NO. SAG 1034
	Calculations Procedure for Pressure Retaining Parts		BY BLG 9-5-84
			9-27-84
			PAGE 4 OF 15
			REV

Hoop Stress at Shaft Hole

NA-140, Page 4, Rev. 4



$$\sigma = P \frac{d^2(1-2\lambda) + D^2(1+\lambda)}{D^2 - d^2} *$$

$$\sigma = 60 \frac{13.75^2 [1 - 2(0.3)] + 25.125^2 (1 + 0.3)}{25.125^2 - 13.75^2}$$

$$= 122 \text{ psi}$$

Where

- P = Internal Pressure (PSIG)
- d = Inside Diameter (In)
- D = Outside Diameter (In)
- λ = Poissons Ratio (0.3 for Steel)
- σ = Maximum Unit Stress (PSI)

*Clavarinos formula for thick walled cylinder $d/(2t) < 10$, King, R. C. and Crocker, "Piping Handbook", Pages 3-13. Fifth Edition, McGraw-Hill, New York, 1967.



BUTTERFLY VALVE TYPE 9280

NO.	SAG 1034
BY	BLG 9-5-8
	9-27-8
PAGE	5 OF 15
REV	

Calculation Procedure
for
Pressure Retaining Parts

NA-140, Page 5, Rev. A

To conservatively allow for shaft hole, unit stress for solid block (L by 2a) should be multiplied by the ratio of the face to face dimension (2a) over that value minus the packing hole diameter.


$$\sigma_s = \sigma \left(\frac{2a}{2a - 2b} \right) = 122 \left(\frac{4.75}{4.75 - 2.25} \right) = 232 \text{ psi}$$

$$\sigma_h = P \frac{a^2 + b^2}{a^2 - b^2} \quad \text{(This expression includes a ratio of the cross-sectional areas available to carry the hoop stress load.)}$$


$$= 60 \left(\frac{2.375^2 + 1.125^2}{2.375^2 - 1.125^2} \right) = 95 \text{ psi}$$

- Where:
- a = Outside Radius of Shaft Hole (In)
 - b = Inside Radius of Shaft Hole (In)(Largest)
 - σ_h = Hoop Stress of Shaft Hole (PSI)

Body bending stress at weakest supporting section:



Bending Moment



Section X-X

Bending Moment

$$M = W (G_{Load} + 1) D$$

$$= 804(4.5+1)10.63 = 50514 \text{ In-Lb}$$

Where

- G_{Load} = Seismic Acceleration in g's
- W = Weight of Extended Structure (Lb)
- D = Distance to Extended Structure C.G. (I



MARSHALLTOWN, IOWA

BUTTERFLY VALVE TYPE 9280

 Calculation Procedure
 for
 Pressure Retaining Parts


NO. SAG 1034

BY BLG 9-6-8

9-27-8

PAGE 6 OF 15

REV



$$a = 4.75 \text{ NA-740, Page 6, Rev. A}$$

$$b = 3.727$$

$$c = 2.250$$

$$d = 5.977$$

$$e = 12.00$$

$$f = \frac{d+e}{4} = \frac{5.977+12.00}{4} = 4.494$$

$$I_{xx} = \frac{ab^3}{12} - \frac{\pi(c)^4}{64} + 2 \left[\frac{a(\frac{e-d}{2})^3}{12} + (\frac{e-d}{2})(a)(f)^2 \right]$$

$$= \frac{4.75(3.727)^3}{12} - \frac{\pi(2.25)^4}{64} + 2 \left[\frac{4.75(\frac{12.00-5.977}{2})^3}{12} + (\frac{12.00-5.977}{2})(4.75)(4.494)^2 \right]$$

$$= 618.65 \text{ in}^4$$

$$\text{Bending Stress } (\sigma_{xx}) = \frac{M(e/2)}{I_{xx}}$$

(Based upon 4.5 G Load)

$$= \frac{50514(\frac{12.00}{2})}{618.65}$$


$$\sigma_{xx} = 490 \text{ PSI}$$

Assume weight of extended structure acts 90° from previous calculation:

$$I_{yy} = \frac{(b)(a)^3}{12} - \frac{\pi(c)^4}{64} + 2 \left[\frac{(\frac{e-d}{2})(a)^3}{12} \right]$$

$$= \frac{3.727(4.75)^3}{12} - \frac{\pi(2.25)^4}{64} + 2 \left[\frac{(\frac{12.00-5.977}{2})(4.75)^3}{12} \right]$$

$$= 85.82 \text{ in}^4$$

 FISHER <i>Controls</i> MARSHALLTOWN, IOWA	BUTTERFLY VALVE TYPE 9280		NO. SAG 1034	C
	Calculation Procedure for Pressure Retaining Parts		BY <i>BLG</i>	9-6-84
			<i>[Signature]</i>	9-27-84
			PAGE 7	OF 15
		REV		

Bending Stress (based on a 4.5 G load)

NA-740, Page 7, Rev. A

$$\begin{aligned}\sigma_{yy} &= \frac{M(a/2)}{I_{yy}} \\ &= \frac{50514 \left(\frac{4.75}{2}\right)}{85.82} \\ &= 1409 \text{ PSI}\end{aligned}$$

Consider an accident condition with bending about the xx and yy axes simultaneously:

$$\begin{aligned}\sigma &= \sigma_{xx} + \sigma_{yy} \\ &= 490 + 1409 \\ &= 1899 \text{ PSI}\end{aligned}$$

This value is conservative because it includes the 1G load (weight) of the actuator and bracket in the yy axis. However, the stress is significantly below the allowable stress of 25650 PSI.

Torsional Shear Stress

Conservatively omitting the load carrying capacity of material on outside of bolt holes and modeling shaft hole as a rectangle.

$$\begin{aligned}\tau_1 &= \frac{4T}{(a^2 - c^2)(b + c)} \\ &= \frac{4(9800)}{(4.75^2 - 2.25^2)(3.727 + 2.25)} \\ &= 375 \text{ psi} \\ \tau_2 &= \frac{4T}{(b^2 - c^2)(a + c)} = \frac{4(9800)}{(3.727^2 - 2.25^2)(4.75 + 2.25)}\end{aligned}$$

635 PSI



MARSHALLTOWN, IOWA

BUTTERFLY VALVE TYPE 9280

NO. SAG 1034


Calculation Procedure
for
Pressure Retaining Parts

BY BLG 9-6-8
WJA 9-27-8
PAGE 8 OF 15

REV

2. Retaining Ring Hoop Stress

NA-740, Page 8, Rev. A



$$\text{Hoop Stress } (S_t) = \frac{P(2a)}{2t} \text{ for thin ring}$$

$$= \frac{a^2 P}{b^2 - a^2} \left(1 + \frac{b^2}{r^2}\right) \text{ for thick ring}$$

S_{tmax} at $r = a$

$$= \frac{0.625^2 60}{7.784^2 - 0.625^2} \left(1 + \frac{7.784^2}{0.625^2}\right)$$

$$= 376 \text{ PSI}$$


P = Internal Pressure

2a = Inside Diameter

t = Min. Wall Thickness

2b = Outside Diameter

Note: The ring is considered to be a thick walled cylinder since $a/t < 10$.

 MARSHALLTOWN, IOWA	BUTTERFLY VALVE TYPE 9280		NO. SAG 1034	
	Calculation Procedure for Pressure Retaining Parts		51 BLG	9-6-8
			<i>[Signature]</i>	9-27-8
			PAGE 9	OF 15
		REV		

3. Shaft Torsional, Bending, & Shear Stresses

NA-140, Page 9, Rev. A

$$\text{Maximum Torsional Shear Stress (Ss)} = \frac{T(d/2)}{J}$$

$$J = \frac{\pi d^4}{32}$$

$$J = \frac{\pi (1.75)^4}{32}$$

$$J = .9208 \text{ In}^4$$

$$S_s = \frac{T(d/2)}{J}$$

$$S_s = \frac{5800(1.75)}{.9208}$$

$$S_s = 9313 \text{ PSI}$$

Where

T = Torque

d = Shaft Diameter

J = Polar moment of inertia

$$\text{Bending Stress } (\sigma_B) = \frac{M(d/2)}{I}$$

$$\text{Force (F)} = \Delta P \cdot A$$

Where A is area of disc

$$I = \frac{\pi d^4}{64}$$

Where d is dia. of shaft

$$\text{Moment (M)} = (F/2)L$$


Where L is the distance from outer edge of bushing to edge of disc

$$I = \frac{\pi (1.75)^4}{64} = .4604$$

$$F = 60(138) = 8280$$

$$M = \left(\frac{8280}{2}\right) \cdot .875 = 3623$$

$$\sigma_B = (\sigma_x) = \frac{3623 \left(\frac{1.75}{2}\right)}{.4604} = 6886 \text{ psi}$$





MARSHAL TOWN, IOWA

BUTTERFLY VALVE TYPE 9280

NO. SAG 1034

C

Calculation Procedure
for
Pressure Retaining Parts

BY BLG 9-6-86

HAM 9-27-86

PAGE 10 OF 15

REV

Max. Shear Stress at neutral axis due to shear load:

NA-190, Page 10, Rev. A

$$\begin{aligned}\tau_{\max} &= 1.38 \frac{2F}{\pi d^2} \quad \text{from experimental results} \\ &= 1.38 \frac{2(8280)}{\pi (1.75)^2} \\ &= 2376 \quad \text{PSI}\end{aligned}$$

Combine max. torsional shear and max. shear stresses:

$$\begin{aligned}\tau_{\text{comb}} &= S_s + \tau_{\max} \\ &= 9313 + 2376 \\ &= 11689 \quad \text{PSI}\end{aligned}$$

Combine max. torsional shear and bending stress using maximum shear stress theory of failure:

$$\sigma_x = \sigma_B = 6886 \quad \text{PSI}$$


$$\sigma_y = 0 \quad \text{PSI}$$

$$\tau_{xy} = S_s = 9313 \quad \text{PSI}$$

Principal stresses


$$\begin{aligned}\sigma_1 &= \frac{\sigma_x + \sigma_y}{2} + \sqrt{\left(\frac{\sigma_x - \sigma_y}{2}\right)^2 + \tau_{xy}^2} \\ &= \frac{6886 + 0}{2} + \sqrt{\left(\frac{6886 - 0}{2}\right)^2 + 9313^2}\end{aligned}$$

$$\sigma_1 = 13372 \quad \text{PSI}$$

 MARSHALLTOWN, IOWA	BUTTERFLY VALVE TYPE 9280	NO. SAG 1034
	Calculation Procedure for Pressure Retaining Parts	BY <i>BLG</i> 9-6-8
		<i>[Signature]</i> 9-27-8
		PAGE 12 OF 15
	REV	

~~NA-740~~, Page 12, Rev. A

4. Disc Bending Stress



Section A-A

(A) Bending stress (σ) = $\frac{M(h_1/2)}{I}$ @ Sect AA

Bending Moment (M) = $0.083(\Delta P)(D^3)^*$

$I = \frac{Dh^3}{12} = \frac{D[h_1^3 - h_2^3]}{12}$

- Where h_1 = Total width
- h_2 = Diameter of hole
- D = Diameter of disc
- ΔP = Pressure drop

$M = .083(60)13.25^3 = 11585$

$I = \frac{13.25 [3.625^3 - 1.75^3]}{12} = 47$

$\sigma = \frac{11585 (\frac{3.625}{2})}{47} = 447$

(B) Bending stress (σ_B) = $\frac{M(h_1/2)}{I}$ @ Sect BB

Bending moment (M) = $0.3927 D^2 \Delta P [L_0 + 0.2878D]^*$


$I = \frac{Dh_1^3}{12} - \frac{\pi h_2^4}{64}$

- Where
- h_1 = Total width
- h_2 = Diameter of hole
- D = Diameter of disc
- L_0 = Distance from center of the bushing to the edge of disc

$M = .3927(13.25)^2 60 [1.813 + .2878(13.25)]$
 $= 23279$

$I = \frac{13.25 (3.625)^3}{12} - \frac{\pi (1.75)^4}{64}$

$= 52.14$



* See Appendix 1 for derivation.




MARSHALLTOWN, IOWA

BUTTERFLY VALVE TYPE 9280
 Calculation Procedure
 for
 Pressure Retaining Parts

SUMMARY OF STRESSES

COMPONENT	MATERIAL SPECIFICATION	STRESS CALCULATION	ALLOWABLE (DESIGN) STRESS (PSI)	CALCULATED (ACTUAL) STRESS (PSI)
BODY	SA-182	HOOP	25650	445
		HOOP @ SHAFT	25650	95
		BENDING	25650	1899
RETAINING RING	SA-351-CF8M	HOOP	25650	376
SHAFT	SA-564 H1075	TORSIONAL SHEAR	27150	9313
		BENDING	54300	6886
		SHEAR	27150	11689
		MAX SHEAR BY FAILURE THEORY	27150	9929
DISC	SA-351-CF8M	BENDING @ SHAFT	25650	447
		BENDING PERPEN SHAFT	25650	810

NO. SAG 1034
 BY BLC 9-6-8
 JHM 9-27-8
 PAGE 14 OF 15
 REV

 FISHER <i>Controls</i> MARSHALLTOWN, IOWA	BUTTERFLY VALVE TYPE 9280	NO. SAG 1034
	Calculation Procedure for Pressure Retaining Parts	BY <u>BLG</u> 9-6-80
		<u>JHM</u> 9-27-80
	PAGE 15 OF 15	
REV		

5. ASME CODE CASE 1635-1

NA-140, Page 15, Rev. A

Section Modulus of Piping:

Pipe Size 14" Schedule STD

O.D. = 14.00

I.D. = 13.25

$$Z_p = \frac{\pi(d_o^4 - d_i^4)}{32 d_o}$$

$$= \frac{\pi(14.00^4 - 13.25^4)}{32(14.00)}$$

$$= 53.26 \text{ In}^3$$

Sectional Modulus of Valve Body:

O.D. = 15.75

I.D. = 13.25

$$Z_v = \frac{\pi(d_o^4 - d_i^4)}{32 d_o}$$

$$= \frac{\pi(15.75^4 - 13.25^4)}{32(13.75)}$$

$$= 220$$

$$\text{Ratio} = \frac{Z_v}{Z_p} = \frac{220}{53.26} = 4.14$$

Allowable Stress for SA312-TP309 Piping = 30000 PSI

Allowable Stress for SA-182 Body = 25650 PSI

Based upon this information, this valve meets the conditions set forth in Code Case 1635-1.

NA-140, Page 76, Rev. A

APPENDIX A

EQUATION DERIVATION



MARSHALLTOWN, IOWA


BUTTERFLY VALVE TYPE 9280

Calculation Procedure
for
Pressure Retaining Parts


NO.	SAG 1034
BY	BLG 9-6-80
	9-27-80
PAGE	A1 OF 15
REV	

Derivation of disc bending moment equations

~~NA-190~~, Page ~~17~~, Rev. ~~A~~



Section "AA"



$$\Sigma M_{AA} = \frac{1}{2} P e$$

Where: P = Load on Disc = ($\Delta P A$)

e = Distance to Centroid

$$= .2122D = \frac{2D}{3\pi}$$

$$\Sigma M_{AA} = \frac{1}{2} \Delta P \frac{\pi D^2}{4} (.2122D)$$

$$= .083 \Delta P D^3$$

ATTACHMENT 4

FQP-11AB-7

Static Sideload Test of Vogtle Item 149

14" Type 9280 Butterfly Valve with
Bettis NT316B-SR2-M3 Actuator

Fisher Lab Problem 1662, Report 70

Fisher Controls

FISHER**Laboratory Report**

Problem	1662
Report	70
Page	1
Date	10-5-84

©Fisher Controls

1984

**DISTRIBUTION
RESTRICTED**

STATIC SIDeload TEST OF VOGTLE ITEM 149
14" TYPE 9280 BFV WITH BETTIS ACTUATOR MODEL NO. NT316B-SR2-M3

*by Jon Milliken*ABSTRACT

A static sideload test was performed on a 14" Type 9280 BFV with Bettis actuator Model No. NT316B-SR2-M3. This valve was a production valve intended for service in the Vogtle Nuclear Power Plant (Rep. Order No. 22B-X5AC03-N2T; Item No. 149; S/N 8670355; Project No. 78EC07). A sideload force equivalent to 10g acceleration was applied near the center-of-gravity of the extended structure of the valve assembly. This load was applied along the axis of least rigidity as determined by an earlier resonant frequency test (Problem 1667, Report 192). The static sideload was intended to conservatively simulate dynamic loads encountered in a seismic event as specified by Bechtel (A&E for the Vogtle Project). Operability tests were performed before, during and after application of the sideload as a means of evaluating performance of the valve assembly during a simulated seismic event. Testing was performed according to FTP-33, Rev. D and the results of the tests successfully satisfied all criteria required by this procedure and the associated requirements in the Test Valve Data Sheet.

REP25/15

Fisher Controls



Laboratory Report

Problem	1662
Report	70
Page	2
Date	10-5-84

©Fisher Controls 1984

TABLE OF CONTENTS

Abstract	1
Table of Contents	2
<u>Section</u>	<u>Page</u>
Introduction	3
Test Procedure	4
Results	7
Conclusions	12
List of Instrumentation & Test Equipment	13
Test Valve Data Sheet	15
Test Request Letter	16

Tables, Sketches and Photos

Table 1; Sideload Test Results	8
Table 2; Sideload Test Results	9
Table 3; Sideload Test Results	11
Sketch 1, Mechanical Test Setup	17
Photo 1, Overall Test Setup A	18
Photo 2, Overall Test Setup B	18
Photo 3, Dial Indicator Location	19

REP25/15

Fisher Controls**Laboratory Report**


Problem	1662
Report	70
Page	3
Date	10-5-84

©Fisher Controls

1984

INTRODUCTION

The test of Item 149, Vogtle Project, was requested by the Nuclear Qualification Group via the test request letter included in this report. The purpose of this report is to evaluate the operability of the valve assembly when subjected to a sideload of the magnitude specified in the Test Valve Data Sheet included in this report. The test valve was in a fully operational mode with the valve body in a pressurized test fixture. A baseline series of functional tests were performed prior to the application of the sideload. The sideload was then applied in increments of 50%, 75% and 100%. At 100% sideload functional tests were then again conducted and recorded. The sideload was then incrementally removed in reverse sequence. At zero sideload a final series of functional tests was performed. Every functional test consisted of a packing leakage test, a bidirectional seat leakage test, limit switch trip point test, and a series of stroking time tests which included verification of the "fail-safe" mode. Deflection measurements of the extended structure were made during the incremental application and incremental release of the sideload. This series of before, during and after tests provided a method of comparing normal operation under no sideload to operation during sideload. This test also allowed a comparison of before and after performance to see the detrimental effects, if any, caused by the sideload. Structural yield, binding of internal components, and loss of pressure retaining ability would be revealed, if present, by this test. A full evaluation of the valve assembly is presented in the Conclusion to this report.

Fisher Controls**Laboratory Report**

Problem	1662
Report	70
Page	4
Date	10-5-84

©Fisher Controls

1984

TEST PROCEDURE

The detailed test procedure is presented in FTP-33, Rev. D. A brief summary of the test procedure, aided by Sketch 1, is presented in this section.

The pre-functional and post-functional tests consisted of the same procedure. The packing leakage test was performed first at a pressure of 180 psi with tap water as the test fluid. The valve disc was at mid-travel during this test. The test pressure was held for 5 minutes and all gasketing and packing was checked for leaks.

Next a bidirectional seat leakage was performed with tap water. First the inlet was pressurized to 60 psig with the valve disc closed and the outlet at atmospheric pressure. The test fixture was previously filled with water to evacuate all air pockets. The vertical fittings shown in Sketch 1 were used to observe any leakage to atmosphere. After a period of 10 minutes at these conditions a 2 minute period followed for measurement of seat leakage. This test was then repeated with the outlet at 60 psig and the inlet at atmospheric pressure.

Finally, a stroking time test was conducted. The actuation signal (solenoid: 0-125 VDC) and direct stem movement were recorded on adjacent channels of a strip chart recorder. An RVDT was used to record the true stem position. A

REP25/15

Fisher Controls

FISHER**Laboratory Report**

Problem	1662
Report	70
Page	5
Date	10-5-84

©Fisher Controls

1984

pressure transducer was used to record the piston pressure in the actuator. The limit switch points were recorded using a 5V power supply to each limit switch.

The following sequence of operational cycles were recorded on the strip chart recorder:

Cycle 1; CLOSE TO OPEN
 OPEN TO CLOSE
 Cycle 2; CLOSE TO OPEN
 OPEN TO CLOSE
 Cycle 3; CLOSE TO OPEN
 OPEN TO CLOSE
 Cycle 4; CLOSE TO OPEN
 OPEN TO CLOSE

Each half cycle stroking time was recorded to make sure that the required stroking time (Test Valve Data Sheet) was never exceeded. Average stroking times were computed for each half cycle (CL+OP and OP+CL).

Stroking time constants (time required to travel from the closed or open position to 63.2% of full travel in the direction opposite of the starting position) were also determined so that changes in stroking speed could be evaluated throughout the testing.

REP25/15

Fisher Controls

FISHER**Laboratory Report**

Problem	1662
Report	70
Page	6
Date	10-5-84

©Fisher Controls

1984

The overall testing sequence was as follows: Pre-Functional+Sideload+Post-Functional. In the previously described functional tests, packing leakage, bidirectional seat leakage and operational cycles were done for each of the three portions of the test, however, the sideload portion had the following additional test steps for measurement of deflection due to the sideload application:

- 1) Measurement of deflections with disc closed at 50%, 75% and 100% of the sideload.
- 2) Functionals as previously described.
- 3) Measurement of deflection with the disc at Fail-Safe position for 100%, 75%, 50% and 0% of the sideload.

During application and release of the sideload the valve body was not pressurized.

The magnitude of the sideload force equivalent to 10g at the center-of-gravity of the extended structure was determined as 2446 lb. (100% sideload). The distance from the center of the shaft to the center-of-gravity was 4.75 inches in the Z axis as given in the Test Valve Data Sheet. The actual point of application of the sideload was 19.125 inches from the center-of-gravity representing a moment arm of 19.125 inches. Since the Z axis of the actuator was in the horizontal direction and the sideload was applied in the vertical direction, the sideload magnitude was determined by $S = RW + W$ from FTP-33 where S was the sideload force at the c.g., R was the resultant g load, and W was the weight of the extended structure. Since the force, F, at the point of application

REP25/15

Fisher Controls**FISHER****Laboratory Report**

Problem	1662
Report	70
Page	7
Date	10-5-84

©Fisher Controls

1984

had to create the same moment at the shaft axis as the force S at the c.g. produced at the shaft axis, then,

$$F = S(S \text{ moment arm}) / (F \text{ moment arm})$$

$$F = [(10g)(895) + 895] (4.75) / (19.125) = 2446 \text{ lb.}$$

The values for R and W are given in the Test Valve Data Sheet.

RESULTS

The results of all tests described in the previous section are presented in Tables 1, 2 and 3. Table 1 gives the results of the Pre-Functional Tests. Table 2 gives the results of the Sideload Tests. Table 3 gives the results of the Post-Functional Tests.

At no time during any of the tests did any packing or seat leakage occur. All valve closure times were less than the required 5 seconds. The average close-to-open stroking time was 10.0 seconds. The average open-to-close stroking time was 2.92 seconds. All stroking time constants deviations were well within the +20% criteria. No yielding or any other structural damage was observed. All limit switch trip points were well within the allowable deviation of $\pm 2^\circ$ degrees of valve travel. When fail-safe operation was required, it was maintained without deviation during the incremental release of the sideload.

REP25/15

Fisher Controls



Laboratory Report

Problem	1662
Report	70
Page	8
Date	10-5-84

©Fisher Controls 1984

Rep. 70 / Item 149

TABLE 1
SIDELOAD TEST RESULTS

PRE-FUNCTIONAL TEST RESULTS

1) PACKING LEAKAGE @ 180 psi: CRITERIA No Leakage TEST No Leakage

2) BIDIRECTIONAL SEAT LEAKAGE @ 60 ΔPSI: CRITERIA No Leakage

DIRECTION OF FLOW TEST No Leakage
REVERSE FLOW TEST No Leakage

3) STROKING TIMES & STROKING TIME CONSTANTS: CRITERIA Closing Time < 5 Sec.

		ACTUATOR SUPPLY PRESSURE	STROKING TIME	STROKING TIME CONSTANT
A) CYCLE 1,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.05</u> <u>2.95</u>	<u>6.75</u> * <u>2.15</u> *
B) CYCLE 2,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.9</u>	<u>6.7</u> <u>2.15</u>
C) CYCLE 3,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.9</u>	<u>6.75</u> <u>2.2</u>
D) CYCLE 4,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.05</u> <u>2.95</u>	<u>6.75</u> <u>2.2</u>
E) AVG TIME	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.03</u> <u>2.93</u>	<u>6.74</u> <u>2.18</u>
F) MAXIMUM STROKING TIME CONSTANT CHANGE	<u>2.3</u> % OF INITIAL VALUE			

* TEST FLUID Water
**INITIAL VALUE

REP1!

Fisher Controls

FISHER**Laboratory Report**

Problem	1662
Report	70
Page	9
Date	10-5-84

©Fisher Controls

1984

Rep. 70 / Item 149

TABLE 2
SIDELOAD TEST RESULTS

SIDELOAD TEST RESULTS (1-3 @ 100% SIDELOAD ONLY)

- 1) PACKING LEAKAGE @ 180 psi: CRITERIA No Leakage TEST No Leakage
 2) BIDIRECTIONAL SEAT LEAKAGE @ 60 ΔPSI: CRITERIA No Leakage

DIRECTION OF FLOW TEST No Leakage
 REVERSE FLOW TEST No Leakage

- 3) STROKING TIMES & STROKING TIME CONSTANTS: CRITERIA Closing Time < 5 Sec.

		ACTUATOR SUPPLY PRESSURE	STROKING TIME	STROKING TIME CONSTANT
A) CYCLE 1,	ΔP= <u>60</u> , CL→OP P= <u>60</u> , OP→CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.9</u>	<u>6.75</u> <u>2.2</u>
B) CYCLE 2,	ΔP= <u>60</u> , CL→OP P= <u>60</u> , OP→CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.95</u>	<u>6.75</u> <u>2.2</u>
C) CYCLE 3,	ΔP= <u>60</u> , CL→OP P= <u>60</u> , OP→CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.9</u>	<u>6.75</u> <u>2.15</u>
D) CYCLE 4,	ΔP= <u>60</u> , CL→OP P= <u>60</u> , OP→CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.9</u>	<u>6.75</u> <u>2.2</u>
E) AVG. TIME	ΔP= <u>60</u> , CL→OP P= <u>60</u> , OP→CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.91</u>	<u>6.75</u> <u>2.19</u>
F) MAXIMUM STROKING TIME CONSTANT CHANGE	<u>2.3</u> % OF INITIAL VALUE**			

REP15

Fisher Controls



Laboratory Report

Problem	1662
Report	70
Page	10
Date	10-5-84

©Fisher Controls 1984

Rep. 70 / Item 149

TABLE 2 (CONTINUED)

4) DEFLECTION MEASUREMENTS: CRITERIA No Structural Damage
 TEST No Damage

% Side Load	Force	Gage 1	Gage 2	Gage 3	Gage 4	Gage 5	Disc
0	223	0	0	0	0	0	CLOSED
50	1223	.012	.003	.0015	-.005	0	CLOSED
75	1835	.0195	.004	.0025	-.0015	0	CLOSED
100	2446	.029	.007	.004	-.011	.0005	CLOSED
75	1835	.020	.0045	.0025	-.0075	0	CLOSED
50	1223	.013	.003	.0015	-.0075	0	CLOSED
0	223	.0005	0	0	0	0	CLOSED

DIAL INDICATOR LOCATIONS #1(+35-3/4); #2(+8-7/8"); #3(+4-3/4"); #4(-21-1/8"); #5(On Limit Switch Plate) [Ref. Shaft Axis, Upstream: +]

5) FAIL-SAFE OPERATION DURING DECREASING SIDELOAD Maintained Safety-related Position without Measureable Deviation

*Test Fluid Water

**See Table 1 for Initial Stroking Time Constants

REP15

Fisher Controls



Laboratory Report

Problem	1662
Report	70
Page	11
Date	10-5-84

©Fisher Controls 1984

Rep. 70 / Item 149

TABLE 3
SIDELOAD TEST RESULTS

POST-FUNCTIONAL TEST RESULTS*

- 1) PACKING LEAKAGE @ 180 psi: CRITERIA No Leakage TEST No Leakage
- 2) BIDIRECTIONAL SEAT LEAKAGE @ 60 ΔPSI: CRITERIA No Leakage
 DIRECTION OF FLOW TEST No Leakage
 REVERSE FLOW TEST No Leakage
- 3) STROKING TIMES & STROKING TIME CONSTANTS: CRITERIA Closing Time < 5 Sec.

		ACTUATOR SUPPLY PRESSURE	STROKING TIME	STROKING TIME CONSTANT
A) CYCLE 1,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>9.95</u> <u>2.9</u>	<u>6.8</u> <u>2.2</u>
B) CYCLE 2,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.95</u>	<u>6.75</u> <u>2.2</u>
C) CYCLE 3,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>9.95</u> <u>2.9</u>	<u>6.7</u> <u>2.2</u>
D) CYCLE 4,	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>10.0</u> <u>2.9</u>	<u>6.75</u> <u>2.2</u>
E) AVG. TIME	ΔP= <u>60</u> , CL+OP P= <u>60</u> , OP+CL	<u>80 psi</u> <u>0</u>	<u>9.98</u> <u>2.91</u>	<u>6.75</u> <u>2.2</u>
F) MAXIMUM STROKING TIME CONSTANT CHANGE	<u>2.3</u> % OF INITIAL VALUE**			

*TEST FLUID Water
 **SEE TABLE 1 FOR INITIAL STROKING TIME CONSTANTS

REP15

Fisher Controls**FISHER®****Laboratory Report**

Problem	1662
Report	70
Page	12
Date	10-5-84

©Fisher Controls

1984

CONCLUSION

All applicable criteria given in FTP-33 and in the Test Valve Data Sheet have been successfully met without exception by Vogtle Item 149.



J.B. Milliken
Evaluation & Analysis Department

REP15

INSTRUMENTATION EQUIPMENT SHEET

9510-AXENC03-5151-2

1041
PAGE NO. 13

PROBLEM NO. 1662
REPORT NO. 70

DATE 9-24-84 PROBLEM NO. 1662 REPORT NO. 70 TEST AREA Seismic
 TECHNICIAN Bob Roe TEST ENGINEER Jon Milliken TEST DESCRIPTION Static Sideload

NO.	INSTRUMENT	MANUFACTURER	MODEL NO.	SERIAL NO.	FISHER CONTROL NO.	USEABLE RANGE	ACCURACY	CALIBRATION	
								ON	DUE
1	Power Supply	Instant Instru.	LD5.2	None	None	+5V.			
2	" "	" "	LD15.2	"	"	±15V.			
3	RVDT		600-000	C-7	"				
4	Oscillograph	Gould	2007-6690	747	7514-2			7-84	1-85
5	DC Preamp	"	13-4615-00	9214	7526-4			9-84	3-85
6	" "	"	13-4615-10	9217	7521-8			"	"
7	" "	"	13-4615-10	1568	7521-6			7-84	1-85
8	Bridge Amp.	"	13-4615-30	827	7522-4			9-84	3-85
9	Power Supply	Hewlett Packard	6443B	None	2049-1	0-125V.	--	SET WITH FLUKE METER 4033-23 (7-84 New)	
10	Force Gage	Dillon	X-CT	9412	9405-1	+5000 Lb.		9-84	9-85
11	3/4" Turnbuckle	None	None	None	None				
12	I-Beam	"	"	"	"				
13	Bell Flanges	Ladish	"	"	"				
14	Bookend Pair	Fabricated	"	"	"				
15	Pressure Tank		"	"	"				
16	Pressure Gage	Marsh	2358	"	9609-2	0-300psi	±1% F.S.	5-84	5-85
17	Pressure Gage	"	"	"	9608-2	0-160psi	±1% F.S.	5-84	5-85
18	Dial Indicator	Starrett	25-3041	None	9902-6	0-2.25	±0.001	1-84	1-85

CALIBRATION GUIDELINES PER FTP-26

CHECKED BY Jon Milliken

INSTRUMENTATION EQUIPMENT SHEET

9510-AX50003-S151-2

1 PAGE NO. 14

PROBLEM NO. 1662
REPORT NO. 70

DATE 9-24-84 PROBLEM NO. 1662 REPORT NO. 70 TEST AREA Seismic
 TECHNICIAN Bob Roe TEST ENGINEER Jon Milliken TEST DESCRIPTION Static Sideload

NO.	INSTRUMENT	MANUFACTURER	MODEL NO.	SERIAL NO.	FISHER CONTROL NO.	USEABLE RANGE	ACCURACY	CALIBRATION	
								DN	DUE
19	Dial Indicator	Starrett	25-3041	None	9902-4	0-3"	±0.001	1-84	1-85
20	" "	"	"	"	9902-5	0-3"	"	"	"
21	" "	"	"	"	9902-2	0-3"	"	"	"
22	" "	"	25-441	"	9901-2	0-1"	"	"	"
23	Pressure Transducer	C.E.C.	4-326-00	10932	--	0-100psi	CALIBRATED TO PRESS. GAGE #9806-2, EQUIP. ITEM#L&(+1F.S.)		
24	Box Beam	Fabricated	None	None	None				
25	Pressure Gauge	Marsh		"	9608-1	0-160	±1% F.S.	5-84	5-85
26	DC Preamp	Gould	13-4615-00	4861	7521-3			9-84	3-85

CALIBRATION GUIDELINES PER FTP-26

CHECKED BY Jon Milliken

Fisher Controls

FISHER**Laboratory Report**

Problem	1662
Report	70
Page	15
Date	10-5-84

©Fisher Controls 1984

TEST VALVE DATA SHEET

Item No. 149 S/N 8670355 Assembly Drwg. 48A9882
 Order No. 228-X5AC03-N2T Installation Drwg. 39A2460


Valve Body:	Actuator:	Appurtenances:
14" Type 9280 (RF X BWE)	Bettis NT316B-SR2-M3 (per 17A6601)	Namco EA 180-31302/32302 ASCO NPK8316A74E Type 262C Air Filter Type 95H Regulator Type H120 Relief Valve Ashcroft Pressure Gauge

ANSI B16.34 Body Class	<u>Class 150</u>
Rated Pressure at 100°F	<u>275 Psig</u>
Nominal Valve Stroke	<u>90°</u>
Valve Closure Time	<u>5 Seconds</u>
Nominal Actuator Supply	<u>80 Psig</u>
Allowable Seat Leakage	<u>0</u>
Seat Leak Test	<u>60 Psid/5 Min.</u>
Bi-Directional Seat Leak Test	<u>60 Psid</u>
Service Condition Pressure	<u>-4.75 Inches W.C.</u>
Service Pressure Drop	<u>0.86 Inches W.C.</u>
Valve Safety Related Function	<u>Spring to Close</u>
Measured Extended Structure Weight	<u>895 Pounds</u>
Measured Extended Structure C.G. (From Shaft Axis)	<u>4.75 Inches</u>
Extended Structure Uniaxial G-load	<u>10.0 g</u>
Calculated Lowest Natural Frequency/Axis	<u>37.1 Hz/X</u>
P _B (Shaft Packing)	<u>180 Psig</u>
P _L (Seat Leak)	<u>60 Psid</u>
P _S (Body Pressure for Stroking Tests)	<u>60 Psig</u>
Test Fluid	<u>Water</u>

N11-32/ 1

Fisher Controls


Laboratory Report



Problem	1662
Report	70
Page	16
Date	10-5-84

©Fisher Controls 1984

NEAL RINEHART 15
7-23-82



Memorandum

JB
7-23-82

To: Tom Buresh

From: Cynthia Alexander

Date: July 23, 1982

cc: Floyd Jury

Subject: Natural Frequency and Static Sideload Testing; Vogtle Jon Milliken

Reference: Vogtle 78EC07 PCO-1 (LWS 7-2-82 List)

PCO-1

Tom,


Since the time I submitted my request for lab work for the Vogtle project, several valves have been released from customer hold. A current list of required testing is attached. Please forward this list to the test engineer.

Thank you.


Cynthia Alexander

Cynthia Alexander


CA/ew




Overall Test Setup A
Photo 1



Overall Test Setup B
Photo 2



Overall Test Setup A
Photo 1



Overall Test Setup B
Photo 2

Prob. 1662
Rep. 70
Page 19
Date 10-5-84



Dial Indicator Location
Photo 3

Revised
October 31, 1985

ATTACHMENT 5


FQP-11AB-7

Certificates of Compliance and Related Documentation

Bettis Actuators: NT-316-SR2-M3

NAMCO Limit Switches: EA180-31302/32302

ASCO Solenoids: NPK8316A74E



Assembly Test Report

DRAWING NO. - 39A2459
 REV. 2
 79P26-2
 REV. 2
 79P26-2-2
 REV. 0
 DATE 11/7/83
 ISSUED BY F. Hubbard
 DATE 11/7/83
 ITEM NO. 179
 REVISED BY
 DATE
 APR NO. 79P26-2
 TAG NO.
 DRAWING NO. - 39A2459
 REV. 2
 79P26-2
 REV. 2
 79P26-2-2
 REV. 0
 DATE 11/7/83
 ISSUED BY F. Hubbard
 DATE 11/7/83
 ITEM NO. 179
 REVISED BY
 DATE
 CUSTOMER ORDER NO. PAV-206
 VALVE SERIAL NO. 8669191
 SIZE AND TYPE 14" 9280
 CODE ASME BOILER & PRESSURE VESSEL CODE
 SECT III 1974 EDITION WINTER 1975 ADDENDA
 CLASS NCR NO. 3
 STAMP
 X YES NO

CONTROLLED PARTS VERIFICATION			
PART	PIECE S/N	HEAT NO.	HEAT NO.
BODY	AC 6450-1	1G 3801-1	P4506-2
BONNET		Removal Ring	SOLENOID ✓ 825446-1
VALVE PLUG		Disc	SOLENOID ✓ 570265-1
STUDS		Disc Stop	
NUTS		Switch	
		Switch	

PARTS VERIFIED BY _____ Date _____
 Authorized Inspector _____ Date _____
 Quality Assurance _____ Date _____
 SPECIAL PROCESSING, TESTING AND RESULTS

HOLD/WIT PTS / CUST. INSP	HOLD PTS / AUTH. INSP	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE	FISHER INSP.
✓	See Attached	HYDROSTATIC TEST	FMP 2X14	1	AM-6	2	See		Attached	ATR		
✓	See Attached	SEAT LEAK TEST 1st	FMP 2X16	3	AM-8	1				Blank	Edwards	11/9/83
✓	See Attached	DISC HYDRO	FMP 2X14.1	0	AM-7	0	66	2	0	Blank	Edwards	11/9/83
✓	See Attached	Seat Leak 2nd	FMP 2X16	3	AM-8	1	60	40	0	Blank	Edwards	11/9/83
✓	See Attached	DIAPH TO CASE LEAK TEST	FMP 206.2	3	AM-21	0		N/A				
✓	See Attached	OPERATIONAL TEST					SIGNAL	TIME 12.50	TIME 3.30	CLOSE	Edwards	11/9/83
✓	See Attached	HYSTERESIS TEST					MAX. ERROR					
✓	See Attached	CLEANING PRIOR TO ASSEMBLY										
✓	See Attached	PAINTING										
✓	See Attached	FINAL CLEANING										
✓	See Attached	SEAL ENDS	FMP 10L2	3	AM-17	0						
✓	See Attached	FINAL INSPECTION										
✓	See Attached	PACKAGING	FMP 11A2	3	APR V.C							

APPROVED: F. Perry DATE: 11-7-83
 REVIEWED: Kent Coakley DATE: NOV 17 1983
 AUTHORIZED INSPECTOR: _____ DATE: _____

S/N 8669191

10/5/83
11/3/83



ASSEMBLY TEST REPORT

VALVE SERIAL NO: 8669191
 SIZE AND TYPE: 14" 9280
 CODE: AXRE 5-1122 & 1122-206
 SECT: III 19-17 EDITION: WENTEC 19-75 ADDENDA
 CUSTOMER ORDER NO: PAV-206
 APR NO: 79720
 TAG NO: IHV-26268
 CLASS: 02
 DYES: IINO
 DRAWING NO: 542454
 REP ORDER NO: 4824881
 22B-XS AC03-NIT
 NCR NO: 5
 ATR: 1/1/84
 ISSUED BY: F.M.
 REVISED BY: F.M.
 DATE: 4/29/82

CONTROLLED PARTS VERIFICATION

PART	PIECES/S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.
✓ BODY	✓ AC 6450-1	1G 3801-1	✓ AC 6448-1	AC 6448-1	D 4 506-2	✓ SOLENOID	825446-1	✓
BONNET			✓ DISC	AC 6442-1	D 4 498-1	✓ SOLENOID	570265-1	✓
VALVE PLUG			✓ DISC STOP	AC 6447-1	75854-1			
STUDS			✓ SWITCH	780593-1				
NUTS			✓ SWITCH	780592-1				

PARTS VERIFIED BY: O. Prangon
 Date: 9-15-83
 AUTHORIZED INSPECTOR: G. F. [Signature]

SPECIAL PROCESSING, TESTING AND RESULTS

PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE	FISHER INSP.
✓ IMP 2X14	1	AM-C	2	450	29	0	0-Sub	McJ... 10/5/83	Sub... 10/5/83
✓ IMP 2X16	3	AM-B	1	60	5	0	0-Sub	Edwards 11/3/83	Edwards 11/3/83
✓ IMP 206.2	3	AM-21	0	SIGNAL	TIME 12:50	TIME 3:30	OPEN CLOSE	Edwards 10-28-82	Edwards 10-28-82
✓ APR 10 A				MAX ERROR					
✓ APR IVA1A	2								
✓ APR V. D.									
✓ APR F. C.									

APPROVED BY: A. P. [Signature]
 DATE: 2-5-82
 REVIEWED AUTHORIZED INSPECTOR: Kent Coberg
 DATE: SEP 7 1983

HOLD A...

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

SIN 8669191

ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NOS

ISSUED BY DATE

Tom L. 1/24/83

PURCHASE ORDER NO.

PURCHASE REQ. NO.

REP. ORDER NO.

ITEM NO.

QUANTITY

5181294-002 780592

22B-ISA:03-NIT

0179

1

DESCRIPTION

SIZE

TYPE

MATERIAL TYPE

PROJECT NO.

PIECE SERIAL NO.

72h

14

9200

Supplied Standard

79P126

780592-1

74157x022P

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

REV.

E61 13A1, 13F1

NUC CLASS

STAMP

19

EDITION.

19

ADDENDA

NA

YES

NO

HOLD POINTS

CUST. INSP.

AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL, SECTION 11

NUCLEAR

STANDARD

MSS-SP-55

G. Miller

1-24-83

RECORD

HEAT NUMBER

LOT NUMBER

VENDOR

5282K33611

manno controls

G. Miller

1-24-83

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION

Q.A. APPROVAL

DATE

A.I. REVIEW

DATE

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

SIN 8669191



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO 8

ISSUED BY Tom L. 1/24/83 DATE

PURCHASE ORDER NO. 5181294-802

PURCHASE REQ. NO. 780592

REP. ORDER NO. 328-XSAC03-NIT

ITEM NO. 0179 QUANTITY 1

DESCRIPTION
MEG Sw. Rod

SIZE 14

TYPE 9280

MATERIAL TYPE
Supplied Standard

PROJECT NO. 79P126

PIECE SERIAL NO. 780592-1

PART NO. 15A4157x022P

ROUGH DRAWING NO.

REV. FINISHED DRAWING NO. 15A4157

REV. B

CODE: EG1 13A1, 13F1

NUC. CLASS NA

STAMP

SECT 19 EDITION 19 ADDENDA

YES NO

HOLD POINTS

✓	CUST. INSP	✓	AUTH. INSP

INSPECTION OPERATION

INSPECT PER Q.A. MANUAL, SECTION 11
 NUCLEAR STANDARD MSS-SP-55

RECORD
 HEAT NUMBER _____
 LOT NUMBER 5282X33611
 VENDOR manno controls

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION

OPERATION PERFORMED BY	DATE
<u>G. Miller</u>	<u>1-24-83</u>
<u>G. Miller</u>	<u>1-24-83</u>

Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

NAMCO CONTROLS
an Acme-Cleveland Company
1300 Burris Road (P. O. Box 730)
Newton, NC 28658

S/N 8609191

QUALITY CONTROL PROCEDURE
Certification of Compliance

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158
Attn: Q. A. Documentation Department

PURCHASE ORDER NUMBER S 181294 ITEM NUMBER 000
CUSTOMER PART NUMBER 15A4157X022
NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 2
LOT NUMBER 33611 DATE CODE 5282
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-41769 DATE SHIPPED 1/14/83

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS.

NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2, AS APPLICABLE.

NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180 SWITCH SERIES, WHICH WAS QUALIFIED TO IEEE STANDARDS 323(1974), 344(1975), AND 382(1972), PER REPORT NO. QTR-105.

1/14/83
DATE

Frank J. Napoli
QUALITY ASSURANCE MANAGER

S/N 8669191



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8

ISSUED BY DATE

Tml. 11/3/86

PURCHASE ORDER NO.

5181286-002

PURCHASE REQ. NO.

780593

REP. ORDER NO.

228-15AC03-NIT

ITEM NO.

0179

QUANTITY

1

DESCRIPTION

2mc
Switch

SIZE

14

TYPE

9280

MATERIAL TYPE

SUPPLIM STANDARD

PROJECT NO.

79P126

PIECE SERIAL NO.

780593-1

PART NO.

15A5650 x 392P

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

15A5650

REV.

NA

CODE:

FGS 13A1, 13F1

NUC. CLASS

STAMP

SECT 19

EDITION.

19

ADDENDA

NA

YES

NO

HOLD POINTS

CUST. INSP. AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL, SECTION 11

NUCLEAR STANDARD MSS-SP-55

G. Miller

1-24-83

RECORD

HEAT NUMBER

LOT NUMBER 0283K32101

VENDOR hamer controls

G. Miller

1-24-83

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION



Q.A. APPROVAL

DATE

A.I. REVIEW

DATE

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

9510 01/01/83 1151-2 117
NAMCO CONTROLS
an Acme-Cleveland Company
1300 Burris Road (P. O. Box 730)
Newton, NC 28658

S/N 8669191

QUALITY CONTROL PROCEDURE
Certification of Compliance

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158
Attn: Q. A. Documentation Department

PURCHASE ORDER NUMBER S 181286 ITEM NUMBER 000
CUSTOMER PART NUMBER _____
NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 2
LOT NUMBER 32101 DATE CODE 0283
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-41768 DATE SHIPPED 1/14/83

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS.

NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2, AS APPLICABLE.

NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180 SWITCH SERIES, WHICH WAS QUALIFIED TO IEEE STANDARDS 323(1974), 344(1975), AND 382(1972), PER REPORT NO. QTR-105.

1/14/83
DATE

Frank J. Nasoli
QUALITY ASSURANCE MANAGER

SIN 8669191



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8
ISSUED BY Tom L DATE 8/22/83
PURCHASE ORDER NO. 5181979-104 PURCHASE REQ. NO. 570265
REP. ORDER NO. 228-X5AC03-NIT ITEM NO. 0179 QUANTITY 1

DESCRIPTION Delco 1 SIZE 14 TYPE 9280 MATERIAL TYPE Supplier Standard PROJECT NO. 79P126 PIECE SERIAL NO. 570265-1
PART NO. 1M3429X0452 ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 1M3429 REV. NA

CODE: F6513A1, 13E10 NUC. CLASS NA STAMP YES NO
SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>Shuribait</u>	<u>8/24/83</u>
		RECORD HEAT NUMBER _____ LOT NUMBER <u>43243M-4</u> VENDOR <u>Automatic Switch</u>	<u>Shuribait</u>	<u>8/24/83</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 · N. J. · 201-966-2000 / N. Y. · 212-344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S181979
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 43243M
 ASCO Part No. NPK 8316A-74-E Quantity 5
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, IEEE-382-1980 (Revision of IEEE-382-1972) and IEEE-627-1980, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21680/Rev. C, dated July 13, 1981. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 250°F for 18¼ days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 8 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and Figure 2 for additional information regarding service periods for solenoid coils.
- B. Wear Aging Simulation - 20,000 operations at maximum operating pressure differential and nominal voltage. Ten percent of the wear aging simulation (2,000 cycles) was conducted concurrently with the thermal aging simulation.
- C. Pressurization Aging Simulation - 15 ambient pressure excursions from atmospheric pressure to 80 psig to simulate the expected periodic pressurization of the containment for leak testing during the life of the plant.
- D. Radiation Aging Simulation - 20 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- E. Vibration Aging Simulation - Continuous sinusoidal sweeps from 5 to 200 to 5 Hz at a rate of 2 octaves per minute, with a minimum peak acceleration level of 0.75g (except at low frequencies where the acceleration level was reduced such that the displacement did not exceed 0.025" double amplitude), for a minimum of 90 minutes in each of three orthogonal axes. The test valves were alternately de-energized or energized every 15 minutes during this exposure. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids (Solenoid 'A' for NP8323 valves) vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- F. Seismic Aging (OBE) Simulation and Resonance Testing - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 35 to 1 Hz, with a peak acceleration level (within machine limits) of 3g, in each of three orthogonal axes at a rate of not more than 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's. During this testing, accelerometers were attached to the solenoids of the test valves to determine if the valves exhibited any resonance. Resonance is defined as a response with a magnitude of acceleration at least twice as great as the input acceleration. No valve resonances were detected.

II. Design Basis Event (DBE) Phases:

A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to a series of single-frequency, single-axis sine-beat tests at 37 test frequencies between 1 and 35 Hz. The excitation was in the form of a continuous series of sine beats, with 12-15 oscillations per beat, for a minimum duration of 15 seconds at each test frequency. The successive beats were phased such that any superposition of response motion was additive. At each test frequency, the peak input acceleration was increased (up to 15g maximum) and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure. The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO using single-frequency continuous sinusoidal inputs (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:

11.2g

- B. Radiation DBE Simulation - 180 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 163 megarads of accident radiation exposure.
- C. Environmental DBE Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure to steam, chemical spray and clear water spray simulating a combined loss-of-coolant accident/high-energy-line-break event and post event cool-down. The peak ambient temperature of the simulation was 420°F and the peak ambient pressure was 70 psig. The valves were pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce thermal saturation of the solenoid coils). They were de-energized when the temperature of the first transient reached 420°F (to demonstrate the ability to perform a typical safety function) and were normally de-energized but were cycled periodically during the 30-day exposure to demonstrate the ability to operate on demand. The qualified temperature profile demonstrated by this simulation (after consideration of margin as suggested in IEEE-323-1974) is shown in Figure 3.


Test Report AQR-67368 is on file at Automatic Switch Company in Florham Park, N.J., and is available for customer perusal.

Dated AUGUST 15, 1983

Authorized Signature


QUALITY CONTROL MANAGER

MAXIMUM SERVICE PERIOD (YEARS)



NP-1 VALVES SHOULD BE REBUILT USING APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

1. WEAR AGING - 20,000 CYCLES
2. RADIATION AGING - 2×10^7 RAD
3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.

FIGURE 1

MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS IN ASCO CATALOG NP-1 VALVES

16/6/98 N/S

95100X56003-5151-2-121



**ROUGH STOCK/PURCHASE PARTS
INSPECTION REPORT**

NCR NO. 8

ISSUED BY Tom L. DATE 11/3/84

PURCHASE ORDER NO. S181282-802 PURCHASE REQ. NO. 780590 REP ORDER NO. 228-K5A103-NIT ITEM NO. 0179 QUANTITY 1

T DESCRIPTION Bettis Actuator SIZE 14 TYPE 9280 MATERIAL TYPE suppl. ins standard PROJECT NO. 79P126 PIECE SERIAL NO. 780590-1
 PART NO. 17AG601K112P ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 17A 6601 REV. 8

CODE: EGS 13A1, 13C1 NUC CLASS NA STAMP YES NO
 SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>[Signature]</u>	<u>9/09/83</u>
		RECORD HEAT NUMBER _____ SERIAL NUMBER <u>82-9056-2</u> VENDOR <u>Bettis Corp.</u>	<u>[Signature]</u>	<u>6/09/83</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

FCI 02
JUN 9 1983

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
 Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.



A Galveston-Houston Company

4901 Woodway
 P.O. Box 549
 Houston, Texas 77001
 (713) 960-9494 Telex 76 2713

May 31, 1983

Fisher Control Co.
 P. O. Box 190
 Marshalltown, Iowa 50158

Attention: Mr. Larry Rathje

Subject: Certification of Compliance for the Fisher Control
 Purchase Order 181282; G.H. Bettis Sales Order
 82-9056-00

Dear Mr. Rathje:

This letter is to certify that the equipment furnished on line number 01 our sales order, item 1 your purchase order, were manufactured, assembled, and tested in accordance with written G.H. Bettis Engineering Specifications and Standards, and the G.H. Bettis Qualification Test Report 37274.

Units Shipped:

Qty.	Model	G.H. Bettis P/N	Serial Number
2	NT-316-SR2-M3	49470	1 & 2

Cordially,
 GH BETTIS COMPANY

Anthony T. Locascio
 Quality Assurance Manager

ATL:jw
 cc: File

Assembly Test Report

REV. 79126-3-2	REV. 1	ATR 79126-3-2
DRAWING NO. 39A 3461 48A 9883	ITEM NO 180	ISSUED BY F. Hubbard
REP ORDER NO 22B-XSAC03-N114	DATE 11/17/83	REVISED BY DATE
R NO 79126-2	CLASS 22B-XSAC03-N114	DATE 11/17/83
TAG NO. 1HV-2627B	NCR NO. 5 75854-1	
CUSTOMER ORDER NO PAV-206	STAMP WINTER 1975 ADDENDA	
SIZE AND TYPE 14" 9280	CLASS PRESSURE VESSEL CODE	
CODE ASME BOILER & PRESSURE VESSEL CODE	NO 2	
VALVE SERIAL NO 8672366	YES <input checked="" type="checkbox"/> NO <input type="checkbox"/>	

CONTROLLED PARTS VERIFICATION										
PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N
BODY	AC 7219-1	1G 3801-3	Bringing Ring	AC 7217-1	D 4442-1					
BONNET			Disc	AC 7211-1	R 4086-1					
VALVE PLUG			Disc Stop	AC 7216-1	75854-1					
STUDS										
NUTS										

PARTS VERIFIED BY _____ Date _____
 Quality Assurance _____ Date _____
 Authorized Inspector _____ Date _____

SPECIAL PROCESSING, TESTING AND RESULTS													
HOLD/WIT PTS / CUST. INSP	HOLD PTS / AUTH. INSP	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME ALLOW (MIN)	LEAKAGE RESULTS	FINAL RESULTS	ASSEMBLER	SIGNATURE/DATE	FISHER INSP
See Attached ATR		HYDROSTATIC TEST	FMP 2X14	1	AM-6	2		See Attached			A.T.B.		
Signature of Customer		SEAT LEAK TEST 1st	FMP 2X16	3	AM-8	1	60	5	0	0 Leak	Edwards	11/17/83	
Signature of Customer		DISC HYDR0	FMP 2X14.1	0	AM-7	0	60	2	0	0 Leak	Edwards	11/17/83	
Signature of Customer		Seat Leak Test 2nd Section	FMP 2X16	3	AM-8	1	60	40	0	0 Leak	Edwards	11/17/83	
Signature of Customer		DIAPH TO CASE LEAK TEST	FMP 206.2	3	AM-21	0		N/A					
Signature of Customer		OPERATIONAL TEST											
Signature of Customer		HYSTERESIS TEST											
Signature of Customer		CLEANING PRIOR TO ASSEMBLY											
Signature of Customer		PAINTING											
Signature of Customer		FINAL CLEANING											
Signature of Customer		SEAL ENDS	FMP 10L2	3	AM-17	0					Edwards	11-21-83	
Signature of Customer		FINAL INSPECTION											
Signature of Customer		PACKAGING	FMP 11A2	3	APR V.C								

APPROVED: F. Perry DATE: 11-7-83
 REVIEWED AUTHORIZED INSPECTOR: Kent Cochran DATE: NOV 9 1983
 Signature: [Signature] DATE: 1-24-84

10/6/83

12-20-83

ASSEMBLY TEST REPORT				APR NO		DRAWING NO		REV	
SIZE AND TYPE		CUSTOMER ORDER NO		TAG NO		48A 1883		ATR	
14" 9280		PAV-206		1HV-2627B		22B-XSAC03-NIA		1/1/21	
CODE AXME 5-1122 & AXES-2E 125-26 C.C.E.		1975 ADDENDA		STAMP		MCR NO 5		ISSUED BY	
SECT III		1975 ADDENDA		XYES () NO ()		180		E.H.H. 2/5/82	
VALVE SERIAL NO		HEAT NO.		PIECE S/N		HEAT NO.		REVISED BY	
8672366		1G3801-3		AC7217-1		P4442-1		F.J.H. 4/29/82	
PART		PART		PART		PART		DATE	
BODY		AC7219-1		AC7217-1		P4442-1		Date	
BONNET		DISC		AC7211-1		D4086-1		Date	
VALVE PLUG		DISC STOP		AC7216-1		75854-1		Date	
STUDS								Date	
NUTS								Date	
PARTS VERIFIED BY		Quality Assurance		Date		Authorized Inspector		Date	
D. Casper		9-13-83				E.H.H.			
SPECIAL PROCESSING, TESTING AND RESULTS									
HOLD/WITH	DESCRIPTION	PROCEDURE	REV	AMENDMENT	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE
✓	STATIC TEST	Imp 2x14	1	Am-6	450	29	0	0 Leaks	Bud Simon
✓	SEAL LEAK TEST	Imp 2x16	3	Am-8	60	5	0		
✓	DISC HYDRO								
✓	DIAPH TO CASE LEAK TEST								
✓	OPERATIONAL TEST	Imp 206-2	3	Am-21					Sp. G. G. G. 12-20-83
✓	HYSTERESIS TEST								L.P. 20-83 B. V. Khas
✓	CLEANING PRIOR TO ASSEMBLY	APR III A							
✓	PAINTING	APR III A 2	2	Am-33					Edwards 10-27-83
✓	FINAL CLEANING								
✓	SEAL ENDS	APR V. D.							
✓	FINAL INSPECTION								
✓	ASME STAMP								
✓	PACKAGING	APR Z.C.							
<p>HOLD</p> <p>NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.</p>									
APPROVED QUALITY ASSURANCE		DATE		REVIEWED AUTHORIZED INSPECTOR		DATE		DATE	
A. Perry		2-5-82		Kent Corbin		5-17-83		5-17-83	

3/W 8672366



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO 8 ISSUED BY Tony 3/2/83 DATE

PURCHASE ORDER NO. 5181676-001 PURCHASE REQ. NO. 829415 REP ORDER NO. 22B-XSAC03-N14 ITEM NO. 0100 QUANTITY 1

DESCRIPTION ANCO Switch SIZE EA100 TYPE 3/302 MATERIAL TYPE Supplier Standard PROJECT NO. 79P126 PIECE SERIAL NO. 829415-1

PART NO. 15A4157X022P ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 15A4157 REV. B

CODE: _____ NUC. CLASS NA STAMP YES NO
SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP	✓ AUTH. INSP			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>Mike Wood</u>	<u>4-8-83</u>
		RECORD HEAT NUMBER _____ LOT NUMBER _____ VENDOR _____		
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

951 NAMCO CONTROLS 151-2 120
an Acme-Cleveland Company
1300 Burriss Road (P. O. Box 730)
Newton, NC 28658

S/N 8672366

QUALITY CONTROL PROCEDURE
Certification of Compliance

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158
Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER S 181676 ITEM NUMBER 001
CUSTOMER PART NUMBER 15A4157X022
NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 1
LOT NUMBER 31648 DATE CODE 1283
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-43331 DATE SHIPPED 3/30/83

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS.

NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2, AS APPLICABLE.

NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180 SWITCH SERIES, WHICH WAS QUALIFIED TO IEEE STANDARDS 323(1974), 344(1975), AND 382(1972), PER REPORT NO. QTR-105.

3/30/83
DATE

Frank J. Napoli
QUALITY ASSURANCE MANAGER



**ROUGH STOCK/PURCHASE PARTS
INSPECTION REPORT**

NCR NO.8
ISSUED BY *Tom* DATE *11/3/82*
PURCHASE ORDER NO. *5181172-002* PURCHASE REQ. NO. *781899* REP. ORDER NO. *228-XSAC03-NIU* ITEM NO. *0180* QUANTITY *1*

DESCRIPTION *14 ANCO SWITCH* SIZE *14* TYPE *9280* MATERIAL TYPE *SUPPLIER STANDARD* PROJECT NO. *79P126* PIECE SERIAL NO. *781899-1*
PART NO. *15A5650 X 392 I* ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. *15A5650* REV. *NA*

CODE: *FGS 13A1, 12E1* NUC. CLASS *NA* STAMP YES NO
SECT *19* EDITION. *19* ADDENDA

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<i>David York</i>	<i>11/29/82</i>
		RECORD HEAT NUMBER _____ LOT NUMBER _____ VENDOR <i>3953</i>	<i>David York</i>	<i>11/29/82</i>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER 181172 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A5650X392 P REV
 NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 6
 LOT NUMBER 29501 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40379 DATE SHIPPED 11/17/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/17/82
 DATE

Frank J. Kyeol
 QUALITY CONTROL MANAGER

9/N 8672366



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 5

ISSUED BY Tom L DATE 8/22/83

PURCHASE ORDER NO. 5181979-002

PURCHASE REQ. NO. 576110

REP. ORDER NO. 228-X5AC03-NIU

ITEM NO. 0100 QUANTITY 1

DESCRIPTION Solenoid

SIZE 14

TYPE 9280

MATERIAL TYPE supplies STANDARD

PROJECT NO. 79P126

PIECE SERIAL NO. 576110-1

PART NO. 1M3429X0452

ROUGH DRAWING NO. _____

REV. _____ FINISHED DRAWING NO. 1M3429

REV. NA

CODE: F6513A1, 13E10

NUC. CLASS NA

STAMP YES NO

SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS

✓ CUST. INSP. ✓ AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY DATE

INSPECT PER Q.A. MANUAL SECTION 11
 NUCLEAR STANDARD MSS-SP-55

Schwarzbart 8/24/83


RECORD
HEAT NUMBER _____
LOT NUMBER 43243 M-2
VENDOR Automatic Switch

Schwarzbart 8/24/83

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION



Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 - N. J. (201) 966-2000 / N. Y. (212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S181979
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 43243M
 ASCO Part No. NPK 8316A-74-E Quantity 5
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, IEEE-382-1980 (Revision of IEEE-382-1972) and IEEE-627-1980, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21680/Rev. C, dated July 13, 1981. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 250°F for 18½ days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 8 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and Figure 2 for additional information regarding service periods for solenoid coils.
- B. Wear Aging Simulation - 20,000 operations at maximum operating pressure differential and nominal voltage. Ten percent of the wear aging simulation (2,000 cycles) was conducted concurrently with the thermal aging simulation.
- C. Pressurization Aging Simulation - 15 ambient pressure excursions from atmospheric pressure to 80 psig to simulate the expected periodic pressurization of the containment for leak testing during the life of the plant.
- D. Radiation Aging Simulation - 20 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- E. Vibration Aging Simulation - Continuous sinusoidal sweeps from 5 to 200 to 5 Hz at a rate of 2 octaves per minute, with a minimum peak acceleration level of 0.75g (except at low frequencies where the acceleration level was reduced such that the displacement did not exceed 0.025" double amplitude), for a minimum of 90 minutes in each of three orthogonal axes. The test valves were alternately de-energized or energized every 15 minutes during this exposure. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids (Solenoid 'A' for NP8323 valves) vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- F. Seismic Aging (OBE) Simulation and Resonance Testing - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 35 to 1 Hz, with a peak acceleration level (within machine limits) of 3g, in each of three orthogonal axes at a rate of not more than 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's. During this testing, accelerometers were attached to the solenoids of the test valves to determine if the valves exhibited any resonance. Resonance is defined as a response with a magnitude of acceleration at least twice as great as the input acceleration. No valve resonances were detected.

II. Design Basis Event (DBE) Phases:

- A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to a series of single-frequency, single-axis sine-beat tests at 37 test frequencies between 1 and 35 Hz. The excitation was in the form of a continuous series of sine beats, with 12-15 oscillations per beat, for a minimum duration of 15 seconds at each test frequency. The successive beats were phased such that any superposition of response motion was additive. At each test frequency, the peak input acceleration was increased (up to 15g maximum) and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure. The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO using single-frequency continuous sinusoidal inputs (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:

11.2g

- B. Radiation DBE Simulation - 180 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 163 megarads of accident radiation exposure.
- C. Environmental DBE Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure to steam, chemical spray and clear water spray simulating a combined loss-of-coolant accident/high-energy-line-break event and post event cool-down. The peak ambient temperature of the simulation was 420°F and the peak ambient pressure was 70 psig. The valves were pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce thermal saturation of the solenoid coils). They were de-energized when the temperature of the first transient reached 420°F (to demonstrate the ability to perform a typical safety function) and were normally de-energized but were cycled periodically during the 30-day exposure to demonstrate the ability to operate on demand. The qualified temperature profile demonstrated by this simulation (after consideration of margin as suggested in IEEE-323-1974) is shown in Figure 3.


Test Report AQR-67368 is on file at Automatic Switch Company in Florham Park, N.J., and is available for customer perusal.

Dated AUGUST 15, 1983

Authorized Signature


QUALITY CONTROL MANAGER

MAXIMUM SERVICE PERIOD (YEARS)



VALVES SHOULD BE REBUILT USING APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

1. WEAR AGING - 20,000 CYCLES
2. RADIATION AGING - 2×10^7 RAD
3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.

951 (AS) 003-5151-2 134

FIGURE 1
MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS IN ASCO CATALOG NP-1 VALVES

S/M 8672366

AUTOMATIC SWITCH CO.

NUCLEAR VALVE TEST LOG

Florham Park, N.J. 0 332

ORDER DATA
(To be completed by Valve Sales)

TEST DATA
(To be completed by Test Dept. Supervisor)

CUSTOMER Fisher Controls

ASCO DWG. NO. NVA 208 279 CHG. LTR. —

P.O. NO. 181979 S.O. NO. 43243M

ASCO TEST PROCEDURE NP8316 CHG. LTR. G

CATALOG NO. NP8316A74B TY. —

TEST MEDIUM AIR

CONSIGNEE Fisher Controls

TEST 020 AMPS/~~VOLTS~~ (Cross Out One)

CONSIGNEE P.O. —

SALES ENGINEER

(Signed) T. Hays DATE 8-12-83

TEST DEPT. (Signed) Brown DATE 8-12-83

CONFORMANCE TO TEST REQUIREMENT. (To be completed by Test Dept.) - a check (✓) indicates conformance to test requirements as listed in above test procedure.

SERIAL NUMBER	COIL TEST Volts	SEAT LEAKAGE				OPERATIONAL TEST		EXTERNAL LEAKAGE SERW TEST 250 PSIG	HYPOT TEST (Volts/Time) 1250V 1MIN	NOISE TEST
		DE-ENERGIZED		ENERGIZED		175 PSIG MAX	10 PSIG MIN			
43243M	64.4	175 PSIG	10 PSIG	175 PSIG	10 PSIG	175 PSIG MAX	10 PSIG MIN	250 PSIG	1250V 1MIN	N/A
1	✓	✓	✓	✓	✓	✓	✓	✓	✓	—
2	✓	✓	✓	✓	✓	✓	✓	✓	✓	—
3	✓	✓	✓	✓	✓	✓	✓	✓	✓	—
4	✓	✓	✓	✓	✓	✓	✓	✓	✓	—
5	✓	✓	✓	✓	✓	✓	✓	✓	✓	—

I HEREBY CERTIFY THE ABOVE RESULTS ARE A TRUE RECORD OF EACH ITEM INDICATED

- TESTER (Signed) Robert Evans DATE 9/15/83
- ASCO QUALITY CONTROL (Signed) _____ DATE _____
- CUSTOMER REPRESENTATIVE (Signed) _____ DATE _____
- GOV'T. QUALITY ASSURANCE REPRESENTATIVE (Signed) _____ DATE _____



Assembly Test Report

NO. 17P126-2		DRAWING NO. 39A 2459 48A 9881		REV. A	ATR 79P126-2	REV. 0
SIZE AND TYPE 14" 9280	CUSTOMER ORDER NO. PAV-206	TAG NO. 1HV-2628B	REP. ORDER NO. 22B-XSAC03-NIT	ITEM NO. 181A	ISSUED BY F. Hubbard	DATE 11/7/83
VALVE SERIAL NO. 8672365	CODE ASME BOILER & PRESSURE VESSEL CODE	STAMP	CLASS	NCR NO. 5	REVISED BY	DATE
SECT. III	1974 EDITION WINTER 1975 ADDENDA	X YES <input type="checkbox"/> NO <input checked="" type="checkbox"/>	2			

CONTROLLED PARTS VERIFICATION

PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.
BODY	AC 8820-1	163801-7	Retaining Ring	AC 8818-1	24506-3	Solenoid	785426-1	
BONNET			Disc	AC 8812-1	24498-2	Solenoid	570313-1	
VALVE PLUG			Disc Stop	AC 8817-1	75854-7			
STUDS			Switch	785423-1				
NUTS			Switch	785424-1				

PARTS VERIFIED BY D. Conyon Date 9-15-83 Quality Assurance Authorized Inspector G. R. E. 229 Date

SPECIAL PROCESSING, TESTING AND RESULTS

HOLD/WIT POINTS	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE
<input checked="" type="checkbox"/> HOLD POINT	STATIC TEST	FMP 2X14	1	AM-6	2	450	29	0	0 Leak	Edwards Budkins 11/22/83
<input checked="" type="checkbox"/> HOLD POINT	SEAT LEAK TEST 1st	FMP 2X16	3	AM-8	1	40	5	0	0 LEAK	Edwards Shander 12/1/83
<input checked="" type="checkbox"/> HOLD POINT	DISC HYDRO	FMP 2X14.1	0	AM-7	0	46	2		0 Leak	Edwards Shander 12/1/83
<input checked="" type="checkbox"/> HOLD POINT	SEAT LEAK 2nd	FMP 2X16	3	AM-8	1	40	40	0	0 LEAK	Edwards Shander 12/1/83
	DIAPH TO CASE LEAK TEST	FMP 206.2	3	AM-21	0				N/A	
	OPERATIONAL TEST	FMP 206.2	3	AM-21	0	SIGNAL:	TIME OPEN 12		TIME CLOSE 3 15	Edwards B. Wilkins 11-20-83
	HYSTERESIS TEST					MAX. ERROR:				
	CLEANING PRIOR TO ASSEMBLY			APR III. A						Edwards 11-28-83
	PAINTING			APR IV. B					OK	M. Shuster 1-20-84
	FINAL CLEANING									
	SEAL ENDS	FMP 10L2	3	AM-12	0					Edwards 12-21-83
	FINAL INSPECTION			APR V. B.						Edwards 12/21/83
	STAMP									DeHaven 1-5-84
	PACKAGING	FMP 11A2	3	APR V. C						DeHaven 12/21/83

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

APPROVED: F. Percy DATE: 11-7-83 REVIEWED AUTHORIZED INSPECTOR: Kent Coeking DATE: NOV 9 1983

S/N 8672365



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8

ISSUED BY DATE

Tom L. 1/24/83

PURCHASE ORDER NO.

PURCHASE REQ. NO.

REP ORDER NO.

ITEM NO.

QUANTITY

5181294-001

785423

22B-XSAL03-NIT

181A

1

ITEM DESCRIPTION

SIZE

TYPE

MATERIAL TYPE

PROJECT NO.

PIECE SERIAL NO.

SA. 724

14

9280

Supplies Standard

79P126

785423-1

PART NO.

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

REV.

15A4157x022P

15A4157

B

CODE

EB1 13A1, 13E1

NUC CLASS

STAMP

SECT 19

EDITION 19

ADDENDA

NA

YES

NO

HOLD POINTS

CUST. INSP

AUTH. INSP

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL SECTION 11

NUCLEAR

STANDARD

MSS-SP-55

G. Miller

1-24-83

RECORD

HEAT NUMBER

LOT NUMBER

VENDOR

520 K33611

Danco Controls


G. Miller

1-24-83

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION



Q.A. APPROVAL

DATE

A.I. REVIEW

DATE

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

NAMCO CONTROLS
an Acme-Cleveland Company
1300 Burris Road (P. O. Box 730)
Newton, NC 28658

QUALITY CONTROL PROCEDURE
Certification of Compliance

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158
Attn: Q. A. Documentation Department

PURCHASE ORDER NUMBER S 181294 ITEM NUMBER 000
CUSTOMER PART NUMBER 15A4157X022
NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 2
LOT NUMBER 33611 DATE CODE 5282
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-41769 DATE SHIPPED 1/14/83

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS.

NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2, AS APPLICABLE.

NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180 SWITCH SERIES, WHICH WAS QUALIFIED TO IEEE STANDARDS 323(1974), 344(1975), AND 382(1972), PER REPORT NO. QTR-105.

1/14/83
DATE

Frank J. Napoli
QUALITY ASSURANCE MANAGER

S/N 8672365



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8
ISSUED BY Tom L. DATE 11/3/82

PURCHASE ORDER NO. S181286-001 PURCHASE REQ. NO. 785424 REP. ORDER NO. 228-15AC03-NIT ITEM NO. 181A QUANTITY 1

PART DESCRIPTION Amco Switch SIZE 14 TYPE 9280 MATERIAL TYPE SUPPLIA STANDARD PROJECT NO. 79P126 PIECE SERIAL NO. 785424-1

PART NO. 1EA5650 X392P ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 1SA5650 REV. NA

CODE: FGI 13A1, 13E1 NUC. CLASS NA STAMP YES NO
SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP	✓ AUTH. INSP			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>G. Muller</u>	<u>1-24-83</u>
		RECORD HEAT NUMBER _____ LOT NUMBER <u>0283 K32101</u> VENDOR <u>hamo controls</u>	<u>G. Muller</u>	<u>1-24-83</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		



Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

1
2
3
4
5
6
7
8
9
10

951 (NAMCO CONTROLS 151-2 148
an Acme-Cleveland Company
1300 Burris Road (P. O. Box 730)
Newton, NC 28658

S/N 8672365

QUALITY CONTROL PROCEDURE
Certification of Compliance

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. A. Documentation Department

PURCHASE ORDER NUMBER S 181286 ITEM NUMBER 000

CUSTOMER PART NUMBER _____

NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 2

LOT NUMBER 32101 DATE CODE 0283

NAME LIMIT SWITCH

NAMCO SHIPPER NUMBER E-41768 DATE SHIPPED 1/14/83

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS.

NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45-2, AS APPLICABLE.

NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180 SWITCH SERIES, WHICH WAS QUALIFIED TO IEEE STANDARDS 323(1974), 344(1975), AND 382(1972), PER REPORT NO. QTR-105.

1/14/83
DATE

Frank J. Nagoli
QUALITY ASSURANCE MANAGER

S/N 8672365



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8

ISSUED BY Tam L DATE 9/15/83

PURCHASE ORDER NO. 5181963-001

PURCHASE REQ. NO. 570313

REP. ORDER NO. 22B-XSAC03-NIT

ITEM NO. 181A QUANTITY 1

DESCRIPTION Solenoid

SIZE 14 TYPE 9280

MATERIAL TYPE supplies STANDARD

PROJECT NO. 79P126

PIECE SERIAL NO. 570313-1

PART NO. 1M3429X0452

ROUGH DRAWING NO.

REV. FINISHED DRAWING NO. 1M3429

REV.

CODE: EGS 13A1, 13E10

NUC. CLASS NA

STAMP YES NO

SECT 19 EDITION 19 ADDENDA

HOLD POINTS

CUST. INSP. AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY DATE

INSPECT PER Q.A. MANUAL SECTION 11

NUCLEAR STANDARD MSS-SP-55

Wayne Barton 8-25-83

RECORD

HEAT NUMBER _____
LOT NUMBER NPK 8316 A 74E
VENDOR 0910

Wayne Barton 8-25-83

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION

Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 • N. J. (201) 966-2000 / N. Y. (212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S181963
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 41826M
 ASCO Part No. NP K 8316A-74-E Quantity 1
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, IEEE-382-1980 (Revision of IEEE-382-1972) and IEEE-627-1980, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21680/Rev. C, dated July 13, 1981. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 250°F for 18½ days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 8 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and Figure 2 for additional information regarding service periods for solenoid coils.
- B. Wear Aging Simulation - 20,000 operations at maximum operating pressure differential and nominal voltage. Ten percent of the wear aging simulation (2,000 cycles) was conducted concurrently with the thermal aging simulation.
- C. Pressurization Aging Simulation - 15 ambient pressure excursions from atmospheric pressure to 80 psig to simulate the expected periodic pressurization of the containment for leak testing during the life of the plant.
- D. Radiation Aging Simulation - 20 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- E. Vibration Aging Simulation - Continuous sinusoidal sweeps from 5 to 200 to 5 Hz at a rate of 2 octaves per minute, with a minimum peak acceleration level of 0.75g (except at low frequencies where the acceleration level was reduced such that the displacement did not exceed 0.025" double amplitude), for a minimum of 90 minutes in each of three orthogonal axes. The test valves were alternately de-energized or energized every 15 minutes during this exposure. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids (Solenoid 'A' for NP8323 valves) vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- F. Seismic Aging (OBE) Simulation and Resonance Testing - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 35 to 1 Hz, with a peak acceleration level (within machine limits) of 3g, in each of three orthogonal axes at a rate of not more than 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's. During this testing, accelerometers were attached to the solenoids of the test valves to determine if the valves exhibited any resonance. Resonance is defined as a response with a magnitude of acceleration at least twice as great as the input acceleration. No valve resonances were detected.

ASCO SHOP ORDER NO. 41826M

II. Design Basis Event (DBE) Phases:

A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to a series of single-frequency, single-axis sine-beat tests at 37 test frequencies between 1 and 35 Hz. The excitation was in the form of a continuous series of sine beats, with 12-15 oscillations per beat, for a minimum duration of 15 seconds at each test frequency. The successive beats were phased such that any superposition of response motion was additive. At each test frequency, the peak input acceleration was increased (up to 15g maximum) and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure. The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO using single-frequency continuous sinusoidal inputs (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:


11.2g

- B. Radiation DBE Simulation - 180 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 163 megarads of accident radiation exposure.
- C. Environmental DBE Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure to steam, chemical spray and clear water spray simulating a combined loss-of-coolant accident/high-energy-line-break event and post event cool-down. The peak ambient temperature of the simulation was 420°F and the peak ambient pressure was 70 psig. The valves were pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce thermal saturation of the solenoid coils). They were de-energized when the temperature of the first transient reached 420°F (to demonstrate the ability to perform a typical safety function) and were normally de-energized but were cycled periodically during the 30-day exposure to demonstrate the ability to operate on demand. The qualified temperature profile demonstrated by this simulation (after consideration of margin as suggested in IEEE-323-1974) is shown in Figure 3.

Test Report AQR-67368 is on file at Automatic Switch Company in Florham Park, N.J., and is available for customer perusal.

Dated AUGUST 12, 1983

Authorized Signature


QUALITY CONTROL MANAGER

NOTE: IN ORDER TO MAINTAIN QUALIFICATION, CATALOG NP-1 VALVES SHOULD BE REBUILT USING THE APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

- 1. WEAR AGING - 20,000 CYCLES
- 2. RADIATION AGING - 2×10^7 RAD
- 3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.





FIGURE 1
MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS IN ASCO CATALOG NP-1 VALVES

5/11 8672365



NOTE:
 IN ORDER TO MAINTAIN QUALIFICATION, CATALOG NP-1 VALVES SHOULD BE REBUILT USING THE APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS, SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

1. WEAR AGING - 20,000 CYCLES
2. RADIATION AGING - 2×10^7 RAD
3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE

FIGURE 2
 MAXIMUM SERVICE PERIODS FOR SOLENOID COILS
 IN ASCO CATALOG NP-1 VALVES




FIGURE 3

QUALIFIED AMBIENT TEMPERATURE PROFILE DEMONSTRATED BY THE COMBINED LOSS-OF-COOLANT ACCIDENT (LOCA)/HIGH-ENERGY-LINE BREAK (HELB) SIMULATION (AFTER APPLICATION OF ALL MARGIN SUGGESTED IN IEEE 323-1974)

S/N 8672365



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT


NCR NO. 8
ISSUED BY Tom L. DATE 4/3/83

PURCHASE ORDER NO. 5181282-001 PURCHASE REQ. NO. 785421
REP. ORDER NO. 220-KSA03-NIT ITEM NO. 181A QUANTITY 1

DESCRIPTION Bettis ACTUATOR SIZE 14 TYPE 9280 MATERIAL TYPE supplies standard
PROJECT NO. 79P126 PIECE SERIAL NO. 785421-1

PART NO. 17AG601K112P ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 17A 6601 REV. B

CODE: _____ EGS 13A1, 13C1 NUC. CLASS NA STAMP YES NO
SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL, SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>Shawaribut</u>	<u>6/09/83</u>
		RECORD HEAT NUMBER _____ S.I. NUMBER <u>82-9056-1</u> VENDOR <u>Bettis Corp.</u>	<u>Shawaribut</u>	<u>6/09/83</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

S/N 8672365



A Galveston-Houston Company

4900 Woodway
 P.O. Box 849
 Houston, Texas 77001
 (713) 960-9494 Telex 76 2713

May 31, 1983

Fisher Control Co.
 P. O. Box 190
 Marshalltown, Iowa 50158

Attention: Mr. Larry Rathje

Subject: Certification of Compliance for the Fisher Control
 Purchase Order 181282; G.H. Bettis Sales Order
 82-9056-00

Dear Mr. Rathje:

This letter is to certify that the equipment furnished on line number 01 our sales order, item 1 your purchase order, were manufactured, assembled, and tested in accordance with written G.H. Bettis Engineering Specifications and Standards, and the G.H. Bettis Qualification Test Report 37274.

Units Shipped:

Qty.	Model	G.H. Bettis P/N	Serial Number
2	NT-316-SR2-M3	49470	1 & 2

Cordially,
 GH BETTIS COMPANY

Anthony T. Locascio
 Quality Assurance Manager

ATL:jw
 cc: File



Assembly Test Report

NO. 79P126-2		DRAWING NO. 59A 2461 48A 9823		REV. C	ATR 79P126-2-2	REV. 0
SIZE AND TYPE 14" 9280	CUSTOMER ORDER NO. PAV-206	TAG NO. 1HV-2629B	REP. ORDER NO. 22B-XEAC03-NIU	ITEM NO. 182	ISSUED BY F. Hubbard	DATE 11/7/83
VALVE SERIAL R0723	CODE ASME BOILER & PRESSURE VESSEL CODE	STAMP	CLASS 2	NCR NO'S	REVISED BY	DATE
SECT. III	EDITION 1974	ADDENDA WINTER 1975	<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO			

CONTROLLED PARTS VERIFICATION

PART	✓	PIECE S/N	HEAT NO.	PART	✓	PIECE S/N	HEAT NO.	PART	✓	PIECE S/N	HEAT NO.
BODY	✓	AC7231-1	163801-4	Retaining Ring	✓	AC7229-1	D4442-2	Solenoid	✓	781926-1	
BONNET	✓			Disc	✓	AC7223-1	F5190-4	Solenoid	✓	5761371	
VALVE PLUG				Disc Stop	✓	AC7228-1	75854-4				
STUDS				Switch	✓	781924-1					
NUTS				Switch	✓	781923-1					

PARTS VERIFIED BY _____ Date _____ Quality Assurance _____ Date _____ Authorized Inspector _____ Date _____

SPECIAL PROCESSING, TESTING AND RESULTS

HOLD/WIT PTS	HOLD PTS	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE	
✓ CUST. INSP	✓ AUTH. INSP										ASSEMBLER	FISHER INSP
✓	✓	HYDROSTATIC TEST	FMP 2X14	1	AM-6	2				See Attached	ATR	
✓	✓	SEAT LEAK TEST 1st	FMP 2X16	3	AM-8	1				See Attached	ATR	
✓	✓	DISC HYDRQ	FMP 2X14.1	0	AM-7	0	140	2		0 Leak	Edwards	11/16/83
✓	✓	SEAT LEAK 2nd	FMP 2X16	3	AM-8	1	160	60	0	0 Leak	Edwards	11/18/83
		DIAPH TO CASE LEAK TEST	FMP 206.2	3	AM-21	0				N/A		
✓		OPERATIONAL TEST					SIGNAL:	TIME 15.000 OPEN	TIME 3.000 CLOSE		Edwards	
		HYSTERESIS TEST					MAX. ERROR:					
✓	✓	CLEANING PRIOR TO ASSEMBLY			APR III.A					See Attached	ATR	
✓	✓	PAINTING			APR IV.B							
		FINAL CLEANING										
✓	✓	SEAL ENDS	FMP 10C2	3	AM-12	0					Edwards	12-22-83
✓	✓	FINAL INSPECTION			APR V.B.							
✓	✓	PACKAGING	FMP 11A2	3	APR V.C							

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

APPROVED: F. Perry DATE: 11-7-83 REVIEWED AUTHORIZED INSPECTOR: Kent Cochran DATE: NOV 9 1983

9510-AVAC03-6151-2-1-199

S/N 0672367

9/N 8672367

9310-AX5AC03-5101-8 150

10/19/83
11/18/83

1/6/84

ASSEMBLY TEST REPORT

APR. NO. 49721
DRAWING NO. 54A 3421
REP ORDER NO. 4DA 7583
REV. 1
ISSUED BY ATR 7/1/26
DATE 1/5/82
REVISED BY F.M. 4/28, 82

CUSTOMER ORDER NO. PAV-206
TAG NO. IHV-2629B
CLASS 2AB-XSAC03-NIU 182
STAMP BYES LINO
1975 ADDENDA

SIZE AND TYPE 14" 9280
CODE AXME EX-ILLER & PRESSURE VESSEL
SECT III 1974 EDITION, MAR/EC
VALVE SERIAL NO. 8672367

PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.
BODY	AC7231-1	1G3801-4	AC7229-1	D442-2	SOLENOID	781926-1		
BONNET			AC7223-1	F5190-4	SOLENOID	576137-1		
VALVE PLUG			AC7228-1	75854-4				
STUDS			781924-1					
NUTS			781923-1					

PARTS VERIFIED BY O. Blaney Date 9-13-82
Authorized Inspector Leaf Date

HOLD/WIT PTS		SPECIAL PROCESSING, TESTING AND RESULTS											
✓	CUST. WSH. AUTH. INSP.	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	ASSEMBLER	SIGNATURE/DATE	FISHER INSP.
		OPERATIONAL TEST	IMP 2X14	1	A-11-6	2	420	29	0	0-LEAK	Chandler	J. Chandler	
		HYSTERESIS TEST	IMP 2X16	3	A-11-8	1	60	5	0	0-LEAK	Chandler	J. Chandler	
		DIAPH TO CASE LEAK TEST											
		OPERATIONAL TEST	IMP 2C6-2	3	A-11-21	0					Edman	Edman	10-21-83
		HYSTERESIS TEST											
		CLEANING PRIOR TO ASSEMBLY	APR III A										
		PAINTING	APR IV A2	2									
		FINAL CLEANING											
		SEAL ENDS	APR V D										
		FINAL INSPECTION											
		PACKAGING	APR I C										

HOLD AND STAMP

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

APPROVED BY A. Blaney DATE 2-5-82
REVIEWED BY Kent Carling DATE SEP 7 1983

S/N 8672367



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

PURCHASE ORDER NO. 5181170-005 PURCHASE REQ. NO. 7819-23 REP. ORDER NO. 220-XSAC03-NIU ITEM NO. 0192 QUANTITY 1

PA. DESCRIPTION MOMO SWITCH SIZE 14 TYPE 9280 MATERIAL TYPE supplim standard PROJECT NO. 79P126 PIECE SERIAL NO. 781923-1

PART NO. 15A4157X022P ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 15A4157 REV. B

CODE: _____ EGS BA1, BE1 NUC. CLASS NA STAMP YES NO
 SECT 19 EDITION. 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	G. Miller	12-1-82
		RECORD HEAT NUMBER _____ LOT NUMBER <u>4682K31119</u> VENDOR _____	G. Miller	12-1-82
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

FCC-QA
DEC 1 1982

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
 Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. C. Documentation Dept.

PURCHASE ORDER NUMBER S 181170 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A4157X022
 NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 6
 LOT NUMBER 31119 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40380 DATE SHIPPED 11/19/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/19/82
 DATE

Frank J. Heath
 QUALITY CONTROL MANAGER

S/N 8672367



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8
ISSUED BY Tom Y 11/3/82 DATE
ITEM NO. 0102 QUANTITY 1

PURCHASE ORDER NO. 5181172-004
PURCHASE REQ. NO. 781924

REP. ORDER NO. 228-XSAC03-N14

DESCRIPTION NANCO SWITCH SIZE 14 TYPE 9200 MATERIAL TYPE SUPPLIER STANDARD PROJECT NO. 79P126 PIECE SERIAL NO. 781924-1

PART NO. 15A5650 X 392 T ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 15A5650 REV. _____

CODE: FGS 13A1, 12E1 NUC. CLASS NA STAMP YES NO
SECT 19 EDITION. 19 ADDENDA

HOLD POINTS		INSPECTION OPERATION		OPERATION PERFORMED BY	DATE
✓	CUST. INSP.	✓	AUTH. INSP.		
			INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>David York</u>	<u>11/29/82</u>
			RECORD	<u>David York</u>	<u>11/29/82</u>
			HEAT NUMBER _____		
			LOT NUMBER <u>4682 K 29501</u>		
			VENDOR <u>3953</u>		
			STAMP PIECE SERIAL NO. ON PART		
			STORE MATERIAL		
			Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
An Acme-Cleveland Company
1300 Burris Road (P.O. Box 730)
Newton, NC 28658

QUALITY CONTROL PROCEDURE
CERTIFICATION OF COMPLIANCE

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158

Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER 181172 ITEM NUMBER 000
CUSTOMER PART NUMBER 15A5650X392 P REV
NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 6
LOT NUMBER 29501 DATE CODE 4682
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-40379 DATE SHIPPED 11/17/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/17/82
DATE

Frank J. Kozlowski
QUALITY CONTROL MANAGER

S/N 8672367



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 5

ISSUED BY Tom L DATE 8/22/83

PURCHASE ORDER NO. 5181979-001

PURCHASE REQ. NO. 576137

REP. ORDER NO. 228-X5AC03-MIU

ITEM NO. 0182 QUANTITY 1

DESCRIPTION Solenoid

SIZE 14 TYPE 9280

MATERIAL TYPE suppliers STANDARD

PROJECT NO. 79P126

PIECE SERIAL NO. 576137-1

PART NO. 1M3429X0452

ROUGH DRAWING NO. _____

REV. _____ FINISHED DRAWING NO. 1M3429

REV. NA

CODE FGS 13A1, 13E10

NUC. CLASS NA

STAMP YES NO

SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL, SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>Schurmeier</u>	<u>8/24/83</u>
		RECORD HEAT NUMBER _____ LOT NUMBER <u>43243 M-1</u> VENDOR <u>Automatic Switch</u>	<u>Schurmeier</u>	<u>8/24/83</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		<u>AUG 24 1983</u>
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 - N. J. (201) 968-2000 / N. Y. (212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S181979
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 43243M
 ASCO Part No. NPK 8316A-74-E Quantity 5
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, IEEE-382-1980 (Revision of IEEE-382-1972) and IEEE-627-1980, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21680/Rev. C, dated July 13, 1981. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 250°F for 18 1/4 days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 8 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and Figure 2 for additional information regarding service periods for solenoid coils.
- B. Wear Aging Simulation - 20,000 operations at maximum operating pressure differential and nominal voltage. Ten percent of the wear aging simulation (2,000 cycles) was conducted concurrently with the thermal aging simulation.
- C. Pressurization Aging Simulation - 15 ambient pressure excursions from atmospheric pressure to 80 psig to simulate the expected periodic pressurization of the containment for leak testing during the life of the plant.
- D. Radiation Aging Simulation - 20 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- E. Vibration Aging Simulation - Continuous sinusoidal sweeps from 5 to 200 to 5 Hz at a rate of 2 octaves per minute, with a minimum peak acceleration level of 0.75g (except at low frequencies where the acceleration level was reduced such that the displacement did not exceed 0.025" double amplitude), for a minimum of 90 minutes in each of three orthogonal axes. The test valves were alternately de-energized or energized every 15 minutes during this exposure. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids (Solenoid 'A' for NP8323 valves) vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- F. Seismic Aging (OBE) Simulation and Resonance Testing - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 35 to 1 Hz, with a peak acceleration level (within machine limits) of 3g, in each of three orthogonal axes at a rate of not more than 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's. During this testing, accelerometers were attached to the solenoids of the test valves to determine if the valves exhibited any resonance. Resonance is defined as a response with a magnitude of acceleration at least twice as great as the input acceleration. No valve resonances were detected.

II. Design Basis Event (DBE) Phases:

A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to a series of single-frequency, single-axis sine-beat tests at 37 test frequencies between 1 and 35 Hz. The excitation was in the form of a continuous series of sine beats, with 12-15 oscillations per beat, for a minimum duration of 15 seconds at each test frequency. The successive beats were phased such that any superposition of response motion was additive. At each test frequency, the peak input acceleration was increased (up to 15g maximum) and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure. The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO using single-frequency continuous sinusoidal inputs (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:

11.2g

- B. Radiation DBE Simulation - 180 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 163 megarads of accident radiation exposure.
- C. Environmental DBE Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure to steam, chemical spray and clear water spray simulating a combined loss-of-coolant accident/high-energy-line-break event and post event cool-down. The peak ambient temperature of the simulation was 420°F and the peak ambient pressure was 70 psig. The valves were pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce thermal saturation of the solenoid coils). They were de-energized when the temperature of the first transient reached 420°F (to demonstrate the ability to perform a typical safety function) and were normally de-energized but were cycled periodically during the 30-day exposure to demonstrate the ability to operate on demand. The qualified temperature profile demonstrated by this simulation (after consideration of margin as suggested in IEEE-323-1974) is shown in Figure 3.

Test Report AQR-67368 is on file at Automatic Switch Company in Florham Park, N.J., and is available for customer perusal.

Dated AUGUST 15, 1983 Authorized Signature 
QUALITY CONTROL MANAGER

NP-1 VALVES SHOULD BE REBUILT USING APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

- 1. WEAR AGING - 20,000 CYCLES
- 2. RADIATION AGING - 2×10^7 RAD
- 3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.




FIGURE 1
MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS IN ASCO CATALOG NP-1 VALVES

S/N 8672367

AUTOMATIC SWITCH CO.

NUCLEAR VALVE TEST LOG

Florham Park, N.J. 0 332

ORDER DATA
(To be completed by Valve Sales)

TEST DATA
(To be completed by Test Dept. Supervisor)

CUSTOMER Fisher Controls

ASCO DWG. NO. NVA 208 279 CHG. LTR. —

P.O. NO. 181979 S.O. NO. 43243M

ASCO TEST PROCEDURE NP8316 CHG. LTR. G

CATALOG NO. NPK 8316A74 TY. —

TEST MEDIUM AIR

CONSIGNEE Fisher Controls

TEST 080 AMPS/~~VOLTS~~ (Cross Out One)

CONSIGNEE P.O. —

SALES ENGINEER

(Signed) T. Hays DATE 8-12-83 TEST DEPT. (Signed) Browne DATE 8-12-83

CONFORMANCE TO TEST REQUIREMENT. (To be completed by Test Dept.) — a check (✓) indicates conformance to test requirements as listed in above test procedure.

SERIAL NUMBER	COIL TEST Volts	SEAT LEAKAGE				OPERATIONAL TEST		EXTERNAL LEAKAGE SERW TEST 250 PSIG	HYPOT TEST (Volts/Time) 1250 V 1 MIN.	NOISE TEST
		DE-ENERGIZED		ENERGIZED		175 PSIG MAX	10 PSIG MIN			
		175 PSIG	10 PSIG	175 PSIG	10 PSIG					
43243M	644	✓	✓	✓	✓	✓	✓	✓	N/A	
1	✓	✓	✓	✓	✓	✓	✓	✓	—	
2	✓	✓	✓	✓	✓	✓	✓	✓	—	
3	✓	✓	✓	✓	✓	✓	✓	✓	—	
4	✓	✓	✓	✓	✓	✓	✓	✓	—	
5	✓	✓	✓	✓	✓	✓	✓	✓	—	

I HEREBY CERTIFY THE ABOVE RESULTS ARE A TRUE RECORD OF EACH ITEM INDICATED

- TESTER (Signed) Robert Evans DATE 9/15/83
- ASCO QUALITY CONTROL (Signed) _____ DATE _____
- CUSTOMER REPRESENTATIVE (Signed) _____ DATE _____
- GOV'T. QUALITY ASSURANCE REPRESENTATIVE (Signed) _____ DATE _____

ASSEMBLY TEST REPORT

SIZE AND TYPE: **14" 9280**
 CUSTOMER ORDER NO: **PAV 2-34**
 CODE: **AXME MILLER & PESSIERE**
 SECT: **III** 1974 EDITION, WINTER 1975 ADDENDA

DRAWING NO: **39A 2440**
 48A 1882
 REP ORDER NO: **22B-XSAC03-NAT**
 MCR NO. 5

APH NO: **74026 2**
 TAG NO: **2**
 CLASS: **B2**

REVISED BY: **FMH** 4/29/82
 ISSUED BY: **FMH** 2/5/82

REV: **1**
 DATE: **2/5/82**

CONTROLLED PARTS VERIFICATION

PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART
BODY	AC 6619-1	16 3801-2	ASSEMBLY	AC 6617-1	66693-1	
BONNET			DISC	AC 6611-1	04086-2	
VALVE PLUG			DISC STOP	AC 6616-1	75854-2	
STUDS			SWITCH	780979-1		
NUTS			SWITCH	780978-1		

DATE: **9-15-83**
 AUTHORIZED INSPECTOR: **G. Perry**

SPECIAL PROCESSING, TESTING AND RESULTS

DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE	FISHER INSP.
SEAT LEAK TEST	IMP 2X14	1	A11-C	2	450	29	0	OK	<i>[Signature]</i>	10/26/83
DISC HYDRO	IMP 2X16	3	A11-B	1	60	5	0			
DIAPH TO CASE LEAK TEST										
OPERATIONAL TEST	IMP 266-2	3	A11-21	0						
HYSTERESIS TEST										
CLEANING PRIOR TO ASSEMBLY	APR III-A									
PAINTING	APR IV-A1A	2							<i>[Signature]</i>	8-28-83
FINAL CLEANING										
SEAL ENDS	APR V-D									
FINAL INSPECTION										
ASSEMBLY STAMP PACKAGING	APR V-E								<i>[Signature]</i>	10/26/83

PARTS VERIFIED BY: **G. Perry** 9-15-83
 QUALITY ASSURANCE

APPROVED QUALITY ASSURANCE: **A. Perry** 2-5-82
 DATE: **2-5-82**

REVIEWED AUTHORIZED INSPECTOR: **Kent Coakley** SEP 7 1983
 DATE: **SEP 7 1983**



Assembly Test Report

PR NO

79P126-2

DRAWING NO.

374 2460
48A 9882REV.
A

ATR

79P126

REV.
2 0

SIZE AND TYPE

14" 9280

CUSTOMER ORDER NO.

PAV2-34

TAG NO.

2-HV-2626B

REP. ORDER NO.

22B-XSAC03-NAT

ITEM NO.

147

ISSUED BY

F. Hubbard 11/7/83

DATE

VALVE SERIAL NO.

8670354

CODE ASME BOILER & PRESSURE VESSEL CODE

SECT. III 1974 EDITION, WINTER 1975 ADDENDA

STAMP

CLASS

NCR NO.'S

X YES NO

2

REVISED BY

DATE

CONTROLLED PARTS VERIFICATION

PART	✓	PIECE S/N	HEAT NO.	PART	✓	PIECE S/N	HEAT NO.	PART	✓	PIECE S/N	HEAT NO.
BODY	✓	AC 6619-1	1G3801-2	Remaining Ring	✓	AC 6617-1	R6693-1				
BONNET	✓			Disc	✓	AC 6611-1	D4086-2 MAYL SPEC A 61.				
VALVE PLUG				Disc Stop	✓	AC 6616-1	75854-2				
STUDS				Switch	✓	780979-1					
NUTS				Switch	✓	780978-1					

PARTS VERIFIED BY

Quality Assurance

Date

Authorized Inspector

Date

SPECIAL PROCESSING, TESTING AND RESULTS

HOLD/WIT PTS	HOLD PTS	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE	
✓ CUST. INSP.	✓ AUTH. INSP.										ASSEMBLER	FISHER INSP.
✓		HYDROSTATIC TEST	FMP 2X14	1	AM-6	2		See Attached		ATR		
✓		SEAT LEAK TEST 1 st	FMP 2X16	3	AM-8	1	60	5	0	Ok	Edwards	Bill Viskus 11/21/83
✓		DISC HYDRO	FMP 2X14.1	0	AM-7	0	66	2		Ok	Edwards	Bill Viskus 11/21/83
✓		SEAT LEAK 2 nd Section	FMP 2X16	3	AM-8	1	60	60	0	Ok	McLean	Bill Viskus 11/21/83
		DIAPH TO CASE LEAK TEST	FMP 206.2	3	AM-71	0		N/A				
✓		OPERATIONAL TEST					SIGNAL:	TIME OPEN 9:30	TIME CLOSE 3:25		Edwards	Bill Viskus 12-20-83
		HYSTERESIS TEST					MAX. ERROR:					
		CLEANING PRIOR TO ASSEMBLY			APR III. A					See Attached ATR		
✓		PAINTING			APR IV. B						Edwards	
		FINAL CLEANING										
		SEAL ENDS	FMP 10L2	3	AM-12	0					Edwards	12-21-83
		FINAL INSPECTION			APR V. B.							Thacker
		ASME STAMP										11/6/84
✓		PACKAGING	FMP 11A2	3	APR V. C						Edwards	1-17-84

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

F. Percy
APPROVED

11-7-83
DATE

Kent Cocking
REVIEWED AUTHORIZED INSPECTOR

11-7-83
DATE



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO 8

ISSUED BY Tom Z DATE 12/1/82

PURCHASE ORDER NO. 5181170-003

PURCHASE REQ. NO. 780978

REP. ORDER NO. 228-XSAC03-NRT

ITEM NO. 0147

QUANTITY 1

DESCRIPTION
MANCO SWITCH

SIZE 14 TYPE 9280

MATERIAL TYPE supplim standard

PROJECT NO. 79P126

PIECE SERIAL NO. 780978-1

PART NO. ISA4157X022P

ROUGH DRAWING NO.

REV. FINISHED DRAWING NO. 15A4157

REV. 8

CODE: EGS 13A1, 13F1

NUC. CLASS NA

STAMP

YES NO

SECT 19 EDITION 19 ADDENDA

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>G. Miller</u>	<u>12-1-82</u>
		RECORD HEAT NUMBER _____ LOT NUMBER <u>4682 K 31119</u> VENDOR _____	<u>G. Miller</u>	<u>12-1-82</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		



Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
An Acme-Cleveland Company
1300 Burris Road (P.O. Box 730)
Newton, NC 28658

QUALITY CONTROL PROCEDURE
CERTIFICATION OF COMPLIANCE

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158
Attn: Q. C. Documentation Dept.

PURCHASE ORDER NUMBER s 181170 ITEM NUMBER 000
CUSTOMER PART NUMBER 15A4157X022
NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 6
LOT NUMBER 31119 DATE CODE 4682
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-40380 DATE SHIPPED 11/19/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/19/82
DATE

Frank J. [Signature]
QUALITY CONTROL MANAGER



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO.8

ISSUED BY DATE

Tom 2/13/82

PURCHASE ORDER NO.

PURCHASE REQ. NO.

REP. ORDER NO.

ITEM NO.

QUANTITY

5181172-806

780979

228-XSAC03-N2T

047

1

DESCRIPTION

SIZE

TYPE

MATERIAL TYPE

PROJECT NO.

PIECE SERIAL NO.

*NAMCO
Switch*

14

9280

SUPPLIER STANDARD

79126

780979-1

PART NO.

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

REV.

15A5650X392

15A5650

CODE:

FGI 13A1, 13E1

NUC. CLASS

STAMP

SECT

19

EDITION.

19

ADDENDA

NA

YES

NO

HOLD POINTS

CUST. INSP. AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL SECTION 11

NUCLEAR STANDARD MSS-SP-55

Paul York

11/29/82

RECORD

HEAT NUMBER _____

LOT NUMBER _____

VENDOR *3953*

Paul York

11/29/82

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION

Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
An Acme-Cleveland Company
1300 Burris Road (P.O. Box 730)
Newton, NC 28658

QUALITY CONTROL PROCEDURE
CERTIFICATION OF COMPLIANCE

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158

Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER 181172 ITEM NUMBER 000

CUSTOMER PART NUMBER 15A5650X392 P REV

NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 6

LOT NUMBER 29501 DATE CODE 4682

NAME LIMIT SWITCH

NAMCO SHIPPER NUMBER E-40379 DATE SHIPPED 11/17/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/17/82
DATE

Frank J. Negoli
QUALITY CONTROL MANAGER

S/N 8670354



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 9
ISSUED BY DATE
Tom L 4/22/83

PURCHASE ORDER NO. *5181979-005* PURCHASE REQ. NO. *576164* REP. ORDER NO. *228-X5AC03-N2T* ITEM NO. *0147* QUANTITY *1*

DESCRIPTION *Solenoid* SIZE *14* TYPE *9280* MATERIAL TYPE *SUPPLIER STANDARD* PROJECT NO. *79P126* PIECE SERIAL NO. *576164-1*

PART NO. *1M3429X0452* ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. *1M3429* REV. *NA*

CODE: *FGS 13A1, 13E10* NUC. CLASS *NA* STAMP YES NO
SECT _____ 19 _____ EDITION _____ 19 _____ ADDENDA

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP	✓ AUTH. INSP			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<i>Schumhart</i>	<i>3/24/83</i>
		RECORD HEAT NUMBER _____ LOT NUMBER <i>43243M-5</i> VENDOR <i>Automatic Switch</i>	<i>Schumhart</i>	<i>3/24/83</i>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 • N.J.-(201) 966-2000 / N.Y.-(212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S181979
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 43243M
 ASCO Part No. NPK 8316A-74-E Quantity 5
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, IEEE-382-1980 (Revision of IEEE-382-1972) and IEEE-527-1980, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21680/Rev. C, dated July 13, 1981. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 250°F for 18½ days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 8 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and Figure 2 for additional information regarding service periods for solenoid coils.
- B. Wear Aging Simulation - 20,000 operations at maximum operating pressure differential and nominal voltage. Ten percent of the wear aging simulation (2,000 cycles) was conducted concurrently with the thermal aging simulation.
- C. Pressurization Aging Simulation - 15 ambient pressure excursions from atmospheric pressure to 80 psig to simulate the expected periodic pressurization of the containment for leak testing during the life of the plant.
- D. Radiation Aging Simulation - 20 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- E. Vibration Aging Simulation - Continuous sinusoidal sweeps from 5 to 200 to 5 Hz at a rate of 2 octaves per minute, with a minimum peak acceleration level of 0.75g (except at low frequencies where the acceleration level was reduced such that the displacement did not exceed 0.025" double amplitude), for a minimum of 90 minutes in each of three orthogonal axes. The test valves were alternately de-energized or energized every 15 minutes during this exposure. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids (Solenoid 'A' for NP8323 valves) vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- F. Seismic Aging (OBE) Simulation and Resonance Testing - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 35 to 1 Hz, with a peak acceleration level (within machine limits) of 3g, in each of three orthogonal axes at a rate of not more than 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's. During this testing, accelerometers were attached to the solenoids of the test valves to determine if the valves exhibited any resonance. Resonance is defined as a response with a magnitude of acceleration at least twice as great as the input acceleration. No valve resonances were detected.

II. Design Basis Event (DBE) Phases:

- A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to a series of single-frequency, single-axis sine-beat tests at 37 test frequencies between 1 and 35 Hz. The excitation was in the form of a continuous series of sine beats, with 12-15 oscillations per beat, for a minimum duration of 15 seconds at each test frequency. The successive beats were phased such that any superposition of response motion was additive. At each test frequency, the peak input acceleration was increased (up to 15g maximum) and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure. The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO using single-frequency continuous sinusoidal inputs (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:


11.2g

- B. Radiation DBE Simulation - 180 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 163 megarads of accident radiation exposure.
- C. Environmental DBE Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure to steam, chemical spray and clear water spray simulating a combined loss-of-coolant accident/high-energy-line-break event and post event cool-down. The peak ambient temperature of the simulation was 420°F and the peak ambient pressure was 70 psig. The valves were pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce thermal saturation of the solenoid coils). They were de-energized when the temperature of the first transient reached 420°F (to demonstrate the ability to perform a typical safety function) and were normally de-energized but were cycled periodically during the 30-day exposure to demonstrate the ability to operate on demand. The qualified temperature profile demonstrated by this simulation (after consideration of margin as suggested in IEEE-323-1974) is shown in Figure 3.

Test Report AQR-67368 is on file at Automatic Switch Company in Florham Park, N.J., and is available for customer perusal.

Dated AUGUST 15, 1983

Authorized Signature


QUALITY CONTROL MANAGER




FIGURE 1
MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS IN ASCO CATALOG NP-1 VALVES

S/N 867035A

AUTOMATIC SWITCH CO.

NUCLEAR VALVE TEST LOG

Florham Park, N.J. 08832

ORDER DATA (To be completed by Valve Sales)

TEST DATA (To be completed by Test Dept. Supervisor)

CUSTOMER Fisher Controls

ASCO DWG. NO. NVA 208 279 CHG. LTR. -

P.O. NO. 181979 S.O. NO. 432434

ASCO TEST PROCEDURE NP8316 CHG. LTR. G

CATALOG NO. NPX 8316A74B TY. -

TEST MEDIUM AIR

CONSIGNEE Fisher Controls

TEST .020 AMPS/VOLTS (Cross Out One)

CONSIGNEE P.O. -

SALES ENGINEER

(Signed) T. Hays DATE 8-12-83

TEST DEPT. (Signed) Brown DATE 8-12-83

CONFORMANCE TO TEST REQUIREMENT. (To be completed by Test Dept.) - a check (✓) indicates conformance to test requirements as listed in above test procedure.

SERIAL NUMBER	COIL TEST Volts	SEAT LEAKAGE				OPERATIONAL TEST		EXTERNAL LEAKAGE SERV TEST 250 PSIG	HYPOT TEST (Volts/Time) 1250 V 1 MIN	NOISE TEST
		DE-ENERGIZED		ENERGIZED		17.5 PSIG MAX.	10 PSIG MIN.			
		17.5 PSIG	10 PSIG	17.5 PSIG	10 PSIG					
432434	644									
1	✓	✓	✓	✓	✓	✓	✓	✓	-	
2	✓	✓	✓	✓	✓	✓	✓	✓	-	
3	✓	✓	✓	✓	✓	✓	✓	✓	-	
4	✓	✓	✓	✓	✓	✓	✓	✓	-	
5	✓	✓	✓	✓	✓	✓	✓	✓	-	

I HEREBY CERTIFY THE ABOVE RESULTS ARE A TRUE RECORD OF EACH ITEM INDICATED

- TESTER (Signed) Robert Gray DATE 9/15/83
- ASCO QUALITY CONTROL (Signed) _____ DATE _____
- CUSTOMER REPRESENTATIVE (Signed) _____ DATE _____
- GOVT. QUALITY ASSURANCE REPRESENTATIVE (Signed) _____ DATE _____

ASSEMBLY TEST REPORT

DRAWING NO. **3AA 2962**
 REV. **A**
 ISSUED BY **TR/20**
 DATE **1/15/82**
 TAG NO. **79720 2**
 REF. ORDER NO. **48A 9884**
 REV. **1**
 DATE **4/29/82**
 CUSTOMER ORDER NO. **PAV 2-34**
 CLASS **228-XSAC03-N24**
 NCR NO. **148**
 VALVE SERIAL NO. **14" 9280**
 CODE **AXME BICLER & RESERVE**
 SECT. **III**
 1974 EDITION, M.M.T.C. 1975 ADDENDA
 XYES NO

CONTROLLED PARTS VERIFICATION

PART	PIECE S/N	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.
BODY	AC 7243-1	163801-5	AC 7241-1	04442-3	Solenoid	781951-1	
BONNET			AC 7235-1	ES190-2			
VALVE PLUG			AC 7240-1	75854-5			
STUDS			781948-1				
NUTS			781949-1				

PARTS VERIFIED BY **A. Rogers** Date **9-15-83**
 Authorized Inspector **6/6/83** Date

SPECIAL PROCESSING, TESTING AND RESULTS

DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	ASSEMBLER	SIGNATURE/DATE	FISHER INSP.
DISC HYDRO	Temp 2x14	1	Am-6	2	450	29	0	Check of Valve 3	Burdynio		19/83
DISC HYDRO	Temp 2x16	3	Am-8	1	60	5	0	0-LEAK	Dep. H. 19-83	J. K. ...	1/17/83
DIAPH TO CASE LEAK TEST											
OPERATIONAL TEST	Temp 206.2	3	Am-21	0							
HYSTERESIS TEST											
CLEANING PRIOR TO ASSEMBLY	APR 10. A										
PAINTING	APR 10. A	2	Am-33	0							
FINAL CLEANING											
SEAL ENDS	APR 10. D.										
FINAL INSPECTION											
ASME STAMP											
PACKAGING	APR 10. C.										

HOLD

ASME

SEP 7 1983

Kent Corbin

2-5-82

A. Rogers

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

Assembly Test Report



NO. 17P126-2		DRAWING NO. 39A 2462 4RA 9884		REV. 6	ATR 79P126-2	REV. 0
SIZE AND TYPE 14" 9280	CUSTOMER ORDER NO. PAV 2-34	TAG NO. 24V-2627B	REP. ORDER NO. 22B-XSAC03-N24	ITEM NO. 148	ISSUED BY F. Hubbard	DATE 11/7/83
VALVE SERIAL NO. 8672368	CODE ASME BOILER & PRESSURE VESSEL CODE	STAMP WINTER 1975 EDITION	CLASS WINTER 1975 ADDENDA	NCR NO. 5	REVISED BY	DATE
SECT. III		<input checked="" type="checkbox"/> YES <input type="checkbox"/> NO 3				

CONTROLLED PARTS VERIFICATION

PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.
BODY	✓ AC 7243-1	163801-S	Retaining Ring	✓ AC 7241-1	D4442-3	Sole Noid	✓ 781951-1	
BONNET	✓		Disc	✓ AC 7235-1	F5190-2			
VALVE PLUG			Disc Stop	✓ AC 7240-1	ASME Spec A Gr. 75854-5			
STUDS			Switch	✓ 781948-1				
NUTS			Switch	✓ 781949-1				

PARTS VERIFIED BY _____ Date _____ Quality Assurance _____ Date _____ Authorized Inspector _____ Date _____

SPECIAL PROCESSING, TESTING AND RESULTS

HOLD/WIT PTS	HOLD PTS	DESCRIPTION	PROCEDURE	REV	AMENDMENT	REV	TEST PRESSURE	TIME (MIN)	ALLOW LEAKAGE	FINAL RESULTS	SIGNATURE/DATE	
											ASSEMBLER	FISHER INSP.
✓	See Attached ATR	HYDROSTATIC TEST	✓ FMP 2X14	1	AM-6	2				See Attached ATR		
✓	See Attached ATR	SEAT LEAK TEST 1 st	✓ FMP 2X16	3	AM-8	1	60	5	0	OK	Edwards	11/21/83
✓	See Attached ATR	DISC HYDRO	✓ FMP 2X14.1	0	AM-7	0	66	2		0-leak	Edwards	11/21/83
✓	See Attached ATR	SEAT LEAK 2 nd DISC	✓ FMP 2X16	3	AM-8	1	60	60	0	0-leak	Edwards	11/21/83
		DIAPH TO CASE LEAK TEST	✓ FMP 206.2	3	AM-21	0			N/A			
		OPERATIONAL TEST					SIGNAL: 100#	TIME OPEN 2025	TIME CLOSE 35	agcon	Edwards	12-20-83
		HYSTERESIS TEST					MAX. ERROR:					
		CLEANING PRIOR TO ASSEMBLY	✓		APR III.A					See Attached ATR		
		PAINTING	✓		APR IV.B					OK	M. Barber	1-24-84
		FINAL CLEANING										
		SEAL ENDS	✓ FMP 10L2	3	AM-12	0					Edwards	12-21-83
		FINAL INSPECTION	✓		APR V.B.							
		STAMP	✓									
		PACKAGING	✓ FMP 11A2	3	APR V.C							

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

F. Percy **11-7-83** **Kent Coking** **NOV-9-1983**
 APPROVED DATE REVIEWED AUTHORIZED INSPECTOR DATE

SN 8672366

5AC03-5151-2 173



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT			NCR NO. 8		ISSUED BY <i>Tom 2</i>	DATE <i>12/1/82</i>
PURCHASE ORDER NO. <i>S181170-001</i>		PURCHASE REQ. NO. <i>781948</i>		REP. ORDER NO. <i>228-XSAC03-ABU</i>	ITEM NO. <i>0148</i>	QUANTITY <i>1</i>
DESCRIPTION <i>MANCO Switch</i>	SIZE <i>14</i>	TYPE <i>9280</i>	MATERIAL TYPE <i>supplim standard</i>	PROJECT NO. <i>79P126</i>	PIECE SERIAL NO. <i>781948-1</i>	
PART NO. <i>15A4157X022P</i>	ROUGH DRAWING NO.			REV.	FINISHED DRAWING NO. <i>15A4157</i>	REV. <i>8</i>
CODE:	<i>EGS 13A1, 13E1</i>			NUC. CLASS <i>NA</i>	STAMP <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
SECT	<i>19</i>	EDITION	<i>19</i>	ADDENDA		

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓	CUST. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<i>G Miller</i>	<i>12-1-82</i>
		RECORD HEAT NUMBER _____ LOT NUMBER <i>4622K3119</i> VENDOR _____	<i>G Miller</i>	<i>12-1-82</i>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		



Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. C. Documentation Dept.

PURCHASE ORDER NUMBER s 181170 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A4157X022
 NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 6
 LOT NUMBER 31119 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40380 DATE SHIPPED 11/19/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/19/82
 DATE

Frank J. Heath
 QUALITY CONTROL MANAGER



**ROUGH STOCK/PURCHASE PARTS
INSPECTION REPORT**

NCR NO. 8

ISSUED BY DATE

Tom Y 11/3/82

PURCHASE ORDER NO.

5181172-001

PURCHASE REQ. NO.

781949

REP. ORDER NO.

228-XSAC03-N24

ITEM NO.

0148

QUANTITY

1

DESCRIPTION

NAMCO SWITCH

SIZE

14

TYPE

9280

MATERIAL TYPE

SUPPLIER STANDARD

PROJECT NO.

79P126

PIECE SERIAL NO.

781949-1

PART NO.

15A5650x392 P

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

15A5650

REV.

CODE

SECT

19

EDITION

19

ADDENDA

FGS 12A1, 12E1

NUC. CLASS

NA

STAMP

YES

NO

HOLD POINTS

✓ CUST. INSP. ✓ AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL SECTION 11

NUCLEAR STANDARD MSS-SP-55

David York

11/29/82

RECORD

HEAT NUMBER _____

LOT NUMBER _____

VENDOR _____

3953

David York

11/29/82

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION

Q.A. APPROVAL

DATE

A.I. REVIEW

DATE

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER 181172 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A5650X392 - P REV
 NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 6
 LOT NUMBER 29501 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40379 DATE SHIPPED 11/17/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/17/82
 DATE

Frank J. Nestle
 QUALITY CONTROL MANAGER

SA 8672368



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. S

ISSUED BY Tom L. Ward DATE

PURCHASE ORDER NO.

PURCHASE REQ. NO.

REP. ORDER NO.

ITEM NO.

QUANTITY

5182014-002

576218

228-XSAC03-N24

0148

1

DESCRIPTION

SIZE

TYPE

MATERIAL TYPE

PROJECT NO.

PIECE SERIAL NO.

Solenoid

14

9280

supplies STANDARD

79P126

576218-1

PART NO.

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

REV.

1M3429X0452

1M3429

NA

CODE:

FGS 13A1, 13E10

NUC CLASS

STAMP

SECT

19

EDITION

19

ADDENDA

NA

YES

NO

HOLD POINTS

✓ CUST. INSP. ✓ AUTH INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL, SECTION 11

NUCLEAR STANDARD MSS-SP-55

Mik. Ward

11-22-83

RECORD

HEAT NUMBER _____


LOT NUMBER _____

VENDOR _____

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION



Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888**ASCO**

FLORHAM PARK, NEW JERSEY 07932 • N.J.-(201) 966-2000 / N.Y.-(212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S182014
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 57589M
 ASCO Part No. NP K 8316A-74-E Quantity 1
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, and IEEE-382-1972, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21678, Revision "B", dated February 15, 1978. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 268°F for 12 days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 10 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and solenoid coils.
- B. Radiation Aging Simulation - 50 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- C. Wear Aging Simulation - 40,000 operations at maximum operating pressure differential and nominal voltage.
- D. Vibration Aging Simulation - 1 million cycles, distributed equally among the three orthogonal axes, between 50 and 100 Hz, at an input acceleration level of 0.75g. The valves were cycled once every 15 minutes during the test. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- E. Seismic Aging (OBE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 33 to 1 Hz, with a peak acceleration level of 3g within machine limits, in each of three orthogonal axes at a rate of 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's.

ASCO SHOP ORDER NO. 57589M

II. Design Basis Event (DBE) Phases:

- A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to single frequency sinusoidal tests at $\frac{1}{3}$ octave frequency interval dwell points from 1-40 Hz. At each test frequency, the peak input acceleration was increased and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure (up to 10g maximum). The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:

11.2g

- B. Radiation DBE Simulation - 150 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 136 megarads of accident radiation exposure.
- C. Environmental DBE (LOCA/HELB) Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure of steam and chemical spray following the suggestions of IEEE-382-1972 (chemical spray per Table 1(b) and test chamber temperature profile per Figure 1 and Table 2). The valves had been pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce coil saturation). They were de-energized when the temperature of the first transient reached 280°F, to show satisfactory shifting for demonstration of safety function. The valves were kept pressurized and were cycled during the 30-day exposure, as suggested in IEEE-382-1972, to demonstrate their ability to operate on demand during the LOCA or HELB.

Test report AQS-21678/TR, Rev. A, is on file at Automatic Switch Company in Florham Park, New Jersey, and is available for customer perusal.

Dated NOVEMBER 10, 1983 Authorized Signature [Signature]
ASST. QUALITY CONTROL MANAGER

NOTE: IN ORDER TO MAINTAIN QUALIFICATION, CATALOG NP-1 VALVES SHOULD BE REBUILT USING THE APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS, SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

- 1. WEAR AGING - 40,000 CYCLES
- 2. RADIATION AGING - 5×10^7 RAD
- 3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.




FIGURE 1

MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS AND SOLENOID COILS IN ASCO CATALOG NP-1 VALVES

S/N 8672368



Assembly Test Report

APR NO: 79126-2
 TAG NO: 2HV-2628B
 CLASS: NAT
 NCR NO: 2

DRAWING NO: 38A2460
 48A9882
 REP ORDER NO: 22B-XSAC03-NAT

REV: ATR 79126-3-2
 DATE: 11/17/83

ISSUED BY: F.H. Hobard
 REVISED BY:

SIZE AND TYPE: 14" 9280
 CODE: ASME BOILER & PRESSURE VESSEL CODE
 SECT: III 1974 EDITION WINTER 1975 ADDENDA

CUSTOMER ORDER NO: PAV-2-34
 STAMP: XYES I NO 2

CONTROLLED PARTS VERIFICATION			
PART	PIECE S/N	HEAT NO	HEAT NO
BODY	AC 6632-1	IG 3801-1	D4152-1
BONNET		Retaining Ring	SWITCH
VALVE PLUG		Disc	SWITCH
STUDS		Disc Stop	SOLENOID
NUTS			SOLENOID

PARTS VERIFIED BY: *Kent Gebing* Date: 5-9-84
 Authorized Inspector: *Kent Gebing* Date: 9/19/84

SPECIAL PROCESSING, TESTING AND RESULTS									
HOLD/WIT PTS	PROCEDURE	REV	AMENDMENT	REV	TEST	TIME	ALLOW	FINAL	SIGNATURE/DATE
CUST INSP	DESCRIPTION	AMOUNT	REV	TEST	PRESSURE	(MIN)	LEAKAGE	RESULTS	ASSEMBLER
1	SEAT LEAK TEST 1st	1	AM-6	2	450	39	0	OK	Edwards
3	SEAT LEAK TEST 2nd	3	AM-8	1	60'	5	0	OK	Edwards
0	DISC HYDRO	0	AM-7	0	66	2	0	OK	Edwards
3	SEAT LEAK TEST 3rd	3	AM-8	1	60	60	0	OK	Edwards
3	DIAPHRAGM LEAK TEST	3	AM-21	0	SIGNAL	N/A	OPEN 20.5	CLOSE 3.356	John Edwards
3	OPERATIONAL TEST	3	APR III.A	0	MAX ERROR				
3	HYSTERESIS TEST	3	APR IV.B	0					
3	CLEANING PRIOR TO ASSEMBLY	3	AM-12	0					
3	PAINTING	3	AM-13	0					
3	FINAL CLEANING	3	AM-14	0					
3	SEAL ENDS	3	AM-15	0					
3	FINAL INSPECTION	3	AM-16	0					
3	PACKAGING	3	AM-17	0					

APPROVED: *Kent Gebing* DATE: 11-7-83
 REVIEWED AUTHORIZED INSPECTOR: *Kent Gebing* DATE: 11-7-83

DATE: MAY 8 1984



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT			NCR NO. 8		ISSUED BY <i>Tom 2</i>	DATE <i>12/1/82</i>
PURCHASE ORDER NO. <i>5181170-006</i>		PURCHASE REQ. NO. <i>781002</i>		REP. ORDER NO. <i>228-XSAC03-NLT</i>	ITEM NO. <i>0149</i>	QUANTITY <i>1</i>
DESCRIPTION <i>MARCO SWITCH</i>	SIZE <i>14</i>	TYPE <i>9280</i>	MATERIAL TYPE <i>supplim standard</i>	PROJECT NO. <i>79P126</i>	PIECE SERIAL NO. <i>781002-1</i>	
PART NO. <i>ISA4157X022P</i>	ROUGH DRAWING NO.			REV.	FINISHED DRAWING NO. <i>ISA4157</i>	REV <i>B</i>
CODE: <i>EGS 13A1, 13E1</i>	SECT <i>19</i> EDITION <i>19</i> ADDENDA			NUC. CLASS <i>NA</i>	STAMP <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<i>G. Muller</i>	<i>12-1-82</i>
		RECORD HEAT NUMBER _____ LOT NUMBER <i>4682 K3119</i> VENDOR _____	<i>G. Muller</i>	<i>12-1-82</i>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION	F&C-QA DEC 1 1982 ERN	

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158


Attn: Q. C. Documentation Dept.

PURCHASE ORDER NUMBER S 181170 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A4157X022
 NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 6
 LOT NUMBER 31119 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40380 DATE SHIPPED 11/19/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/19/82
 DATE

Frank J. [Signature]
 QUALITY CONTROL MANAGER

		ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT			NCR NO. 8		ISSUED BY <u>Tom 2</u> DATE <u>11/3/82</u>	
PURCHASE ORDER NO. <u>5181172-005</u>		PURCHASE REQ. NO. <u>781003</u>		REP. ORDER NO. <u>228-XSAC03-NAT</u>		ITEM NO. <u>0149</u>	QUANTITY <u>1</u>	
P. DESCRIPTION <u>NAMCO SWITCH</u>		SIZE <u>14</u>	TYPE <u>9280</u>	MATERIAL TYPE <u>SUPPLIER STANDARD</u>		PROJECT NO. <u>79P126</u>	PIECE SERIAL NO. <u>781003-1</u>	
PART NO. <u>15A5650X392 P</u>			ROUGH DRAWING NO. _____			REV. _____	FINISHED DRAWING NO. <u>15A5650</u>	
CODE: <u>EGS 13A1, 12E1</u>				NUC. CLASS <u>NA</u>		STAMP <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		
SECT <u>19</u>		EDITION <u>19</u>		ADDENDA _____				
HOLD POINTS		INSPECTION OPERATION				OPERATION PERFORMED BY		DATE
<input checked="" type="checkbox"/> CUST. INSP.	<input checked="" type="checkbox"/> AUTH. INSP.	INSPECT PER Q.A. MANUAL SECTION 11				<u>David York</u>		<u>11/29/82</u>
		<input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55						
		RECORD				<u>David York</u>		<u>11/29/82</u>
		HEAT NUMBER _____						
		LOT NUMBER _____						
		VENDOR <u>3953</u>						
		STAMP PIECE SERIAL NO. ON PART						
		STORE MATERIAL						
		Q.A. DOCUMENTATION VERIFICATION						

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____
 Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
An Acme-Cleveland Company
1300 Burris Road (P.O. Box 730)
Newton, NC 28658

QUALITY CONTROL PROCEDURE
CERTIFICATION OF COMPLIANCE

Fisher Controls Company
205 South Center Street
Marshalltown, Iowa 50158

Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER 181172 ITEM NUMBER 000
CUSTOMER PART NUMBER 15A5650X392 P REV
NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 6
LOT NUMBER 29501 DATE CODE 4682
NAME LIMIT SWITCH
NAMCO SHIPPER NUMBER E-40379 DATE SHIPPED 11/17/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/17/82
DATE

Frank J. Kuylenstierna
QUALITY CONTROL MANAGER

S/N 8670355



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 3 ISSUED BY DATE
Tom L 4/22/83

PURCHASE ORDER NO. 5181979-003 PURCHASE REQ. NO. 576191
REP. ORDER NO. 22B-X5AC03-NAT ITEM NO. 0149 QUANTITY 1

DESCRIPTION SIZE TYPE MATERIAL TYPE PROJECT NO. PIECE SERIAL NO.
Solenoil 14 9280 supplies STANDARD 79P126 576191-1

PART NO. 1M3429X0452 ROUGH DRAWING NO. REV. FINISHED DRAWING NO. REV.
1M3429 NA

CODE: FGS 13A1, 13E10 NUC. CLASS STAMP
SECT 19 EDITION 19 ADDENDA NA YES NO

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP	✓ AUTH. INSP			
		INSPECT PER Q.A. MANUAL, SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<i>L. Schumaker</i>	8/24/83
		RECORD HEAT NUMBER _____ LOT NUMBER 43243 M-3 VENDOR Automatic Switch	<i>L. Schumaker</i>	8/24/83
		STAMP PIECE SERIAL NO. ON PART	AUG 24 1983 LPM	
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 • N. J. - (201) 966-2000 / N. Y. - (212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S181979
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 43243M
 ASCO Part No. NPK 8316A-74-E Quantity 5
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, IEEE-382-1980 (Revision of IEEE-382-1972) and IEEE-627-1980, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21680/Rev. C, dated July 13, 1981. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 250°F for 18 1/4 days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 8 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and Figure 2 for additional information regarding service periods for solenoid coils.
- B. Wear Aging Simulation - 20,000 operations at maximum operating pressure differential and nominal voltage. Ten percent of the wear aging simulation (2,000 cycles) was conducted concurrently with the thermal aging simulation.
- C. Pressurization Aging Simulation - 15 ambient pressure excursions from atmospheric pressure to 80 psig to simulate the expected periodic pressurization of the containment for leak testing during the life of the plant.
- D. Radiation Aging Simulation - 20 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- E. Vibration Aging Simulation - Continuous sinusoidal sweeps from 5 to 200 to 5 Hz at a rate of 2 octaves per minute, with a minimum peak acceleration level of 0.75g (except at low frequencies where the acceleration level was reduced such that the displacement did not exceed 0.025" double amplitude), for a minimum of 90 minutes in each of three orthogonal axes. The test valves were alternately de-energized or energized every 15 minutes during this exposure. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids (Solenoid 'A' for NP8323 valves) vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- F. Seismic Aging (OBE) Simulation and Resonance Testing - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 35 to 1 Hz, with a peak acceleration level (within machine limits) of 3g, in each of three orthogonal axes at a rate of not more than 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's. During this testing, accelerometers were attached to the solenoids of the test valves to determine if the valves exhibited any resonance. Resonance is defined as a response with a magnitude of acceleration at least twice as great as the input acceleration. No valve resonances were detected.

II. Design Basis Event (DBE) Phases:

A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to a series of single-frequency, single-axis sine-beat tests at 37 test frequencies between 1 and 35 Hz. The excitation was in the form of a continuous series of sine beats, with 12-15 oscillations per beat, for a minimum duration of 15 seconds at each test frequency. The successive beats were phased such that any superposition of response motion was additive. At each test frequency, the peak input acceleration was increased (up to 15g maximum) and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure. The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO using single-frequency continuous sinusoidal inputs (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:


11.2g

- B. Radiation DBE Simulation - 180 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 163 megarads of accident radiation exposure.
- C. Environmental DBE Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure to steam, chemical spray and clear water spray simulating a combined loss-of-coolant accident/high-energy-line-break event and post event cool-down. The peak ambient temperature of the simulation was 420°F and the peak ambient pressure was 70 psig. The valves were pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce thermal saturation of the solenoid coils). They were de-energized when the temperature of the first transient reached 420°F (to demonstrate the ability to perform a typical safety function) and were normally de-energized but were cycled periodically during the 30-day exposure to demonstrate the ability to operate on demand. The qualified temperature profile demonstrated by this simulation (after consideration of margin as suggested in IEEE-323-1974) is shown in Figure 3.


Test Report AQR-67368 is on file at Automatic Switch Company in Florham Park, N.J., and is available for customer perusal.

Dated AUGUST 15, 1983

Authorized Signature


QUALITY CONTROL MANAGER

MAXIMUM SERVICE PERIOD (YEARS)



NP-1 VALVES SHOULD BE REBUILT USING THE APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

1. WEAR AGING - 20,000 CYCLES
2. RADIATION AGING - 2×10^7 RAD
3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.

ASCO - ANSAC008-0101-2 189

FIGURE 1

MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS IN ASCO CATALOG NP-1 VALVES

S/N 8670355

AUTOMATIC SWITCH CO.

NUCLEAR VALVE TEST LOG

Florham Park, N.J. 0 332

ORDER DATA
(To be completed by Valve Sales)

TEST DATA
(To be completed by Test Dept. Supervisor)

CUSTOMER Fisher Controls

ASCO DWG. NO. NVA 208 279 CHG. LTR. -

P.O. NO. 181979 S.O. NO. 43243M

ASCO TEST PROCEDURE NP8316 CHG. LTR. 9

CATALOG NO. NPK 8316A74FTY.

TEST MEDIUM AIR

CONSIGNEE Fisher Controls

TEST .020 AMPS/~~VOLTS~~ (Cross Out One)

CONSIGNEE P.O. _____

SALES ENGINEER

(Signed) T. Hays DATE 8-12-83 TEST DEPT. (Signed) Brown DATE 8-12-83

CONFORMANCE TO TEST REQUIREMENT. (To be completed by Test Dept.) - a check (✓) indicates conformance to test requirements as listed in above test procedure.

SERIAL NUMBER	COIL TEST Volts	SEAT LEAKAGE				OPERATIONAL TEST		EXTERNAL LEAKAGE SERIAL TEST 1250 PSIG	HYPOT TEST (Volts/Time) 1250 V 15 MIN.	NOISE TEST
		DE-ENERGIZED		ENERGIZED		175 PSIG MAX.	10 PSIG MIN.			
		175 PSIG	10 PSIG	175 PSIG	10 PSIG					
43243M	644	✓	✓	✓	✓	✓	✓	✓	N/A	
1	✓	✓	✓	✓	✓	✓	✓	✓	-	
2	✓	✓	✓	✓	✓	✓	✓	✓	-	
3	✓	✓	✓	✓	✓	✓	✓	✓	-	
4	✓	✓	✓	✓	✓	✓	✓	✓	-	
5	✓	✓	✓	✓	✓	✓	✓	✓	-	

I HEREBY CERTIFY THE ABOVE RESULTS ARE A TRUE RECORD OF EACH ITEM INDICATED

- TESTER (Signed) Robert Evans DATE 9/15/83
- ASCO QUALITY CONTROL (Signed) _____ DATE _____
- CUSTOMER REPRESENTATIVE (Signed) _____ DATE _____
- GOV'T. QUALITY ASSURANCE REPRESENTATIVE (Signed) _____ DATE _____



Assembly Test Report

VALVE SERIAL NO 8672369	SIZE AND TYPE 14" 9280	CUSTOMER ORDER NO PAV 2-34	APR NO 79P126-2	DRAWING NO 45A 7884	REV. NO AT
CODE ASME BOILER & PRESSURE VESSEL CODE	SECTION III	EDITION 1974	TAG NO 2HV-2629B	REP. ORDER NO 228-XSALC3-N24	ISSUED BY F. Hubbard
DATE 11/7/83	DATE 11/7/83	DATE 11/7/83	CLASS 2	ITEM NO 150	DATE 11/7/83
REVISED BY	REVISED BY	REVISED BY	NO. OF PARTS	NO. OF PARTS	NO. OF PARTS

CONTROLLED PARTS VERIFICATION

PART	PIECE S/N	HEAT NO.	PART	PIECE S/N	HEAT NO.
BODY	AC 7666-1	163801-6	Retaining Ring	AC 7664-1	D4443-4
BONNET			Disc	AC 7658-1	ES190-3
VALVE PLUG			Disc Stop	AC 7663-1	25834-2
STUDS			Switch	782764-1	
NUTS			Switch	782765-1	

PARTS VERIFIED BY: **[Signature]** Date: **11/7/83**

Authorized Inspector: **[Signature]** Date: **11/7/83**

SPECIAL PROCESSING, TESTING AND RESULTS

HOLD/VALVE	HOLD PITS	DESCRIPTION	PROCEDURE	REV	AMENDMENT	TEST PRESSURE	TIME ALLOW	FINAL RESULTS	SIGNATURE/DATE
Hold		HYDROSTATIC TEST	FMP 2X14	1	AM-6	450	29	OK	Edwards 11/2/83
Hold		SPAT LEAK TEST 1st	FMP 2X16	3	AM-8	60	5	OK	Edwards 11/2/83
Hold		DISC HYDRO	FMP 2X14.1	0	AM-7	66	2	OK	Edwards 11/2/83
Hold		Seal Leak Section	FMP 2X16	3	AM-8	60	60	OK	Edwards 11/2/83
Hold		DIAPH TO CASE LEAK TEST							
Hold		OPERATIONAL TEST	FMP 2660	3	AM-21			TIME 13:58 TIME 3:55	Edwards 11/2/83
Hold		HYSTERESIS TEST							
Hold		CLEANING PRIOR TO ASSEMBLY							
Hold		PAINTING							
Hold		FINAL CLEANING							
Hold		SEAL ENDS	FMP 10L2	3	AM-12				DeFosse 1-19-84
Hold		FINAL INSPECTION							
Hold		STAMP							
Hold		PACKAGING	FMP 11A2	3	APR F.C				Stinson 2/9/84

NOTE: Notify Customer Service for customer hold points. Notify authorized inspector for authorized inspector hold points.

APPROVED: **[Signature]** DATE: **11-7-83**

REVIEWED AUTHORIZED INSPECTOR: **[Signature]** DATE: **NOV 2 1983**



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 8 ISSUED BY T. M. Z DATE 12/1/82

PURCHASE ORDER NO. 5181170-004 PURCHASE REQ. NO. 782764 REP. ORDER NO. 228-XSAC03-ALBA ITEM NO. 0150 QUANTITY 1

PART DESCRIPTION WAMCA SWITCH SIZE 14 TYPE 9380 MATERIAL TYPE suppline standard PROJECT NO. 79P126 PIECE SERIAL NO. 782764-1

PART NO. 15A4157X022P ROUGH DRAWING NO. _____ REV. _____ FINISHED DRAWING NO. 15A4157 REV. B

CODE: _____ NUC. CLASS NA STAMP YES NO
SECT 19 EDITION 19 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>G. Miller</u>	<u>12-1-82</u>
		RECORD HEAT NUMBER _____ LOT NUMBER <u>4682K 31119</u> VENDOR _____	<u>G. Miller</u>	<u>12-1-82</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION	<u>DEC 1 1982</u>	

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. C. Documentation Dept.

PURCHASE ORDER NUMBER S 181170 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A4157X022
 NAMCO PART NUMBER EA180-31302 B/M REV. K QTY. 6
 LOT NUMBER 31119 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40380 DATE SHIPPED 11/19/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/19/82
 DATE

Frank J. [Signature]
 QUALITY CONTROL MANAGER



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NO. 3

ISSUED BY Tom Y DATE 11/3/82

PURCHASE ORDER NO. 5181172-003

PURCHASE REQ. NO. 78-2765

REP ORDER NO. 228-XSAC03-N24

ITEM NO. 0150 QUANTITY 1

DESCRIPTION NANCO SWITCH

SIZE 14 TYPE 9280

MATERIAL TYPE SUPPLIER STANDARD

PROJECT NO. 79P126

PIECE SERIAL NO. 782765-1

PART NO. 15A5650X392

ROUGH DRAWING NO. _____

REV. _____ FINISHED DRAWING NO. 15A5650

REV. _____

CODE: FGS 13A1, 13E1

NUC. CLASS NA

STAMP YES NO

SECT 19 EDITION _____ 18 ADDENDA _____

HOLD POINTS		INSPECTION OPERATION	OPERATION PERFORMED BY	DATE
✓ CUST. INSP.	✓ AUTH. INSP.			
		INSPECT PER Q.A. MANUAL SECTION 11 <input type="checkbox"/> NUCLEAR <input checked="" type="checkbox"/> STANDARD <input type="checkbox"/> MSS-SP-55	<u>David York</u>	<u>11/29/82</u>
		RECORD HEAT NUMBER _____ LOT NUMBER _____ VENDOR <u>3953</u>	<u>David York</u>	<u>11/29/82</u>
		STAMP PIECE SERIAL NO. ON PART		
		STORE MATERIAL		
		Q.A. DOCUMENTATION VERIFICATION		

Q.A. APPROVAL _____ DATE _____ A.I. REVIEW _____ DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Namco Controls
 An Acme-Cleveland Company
 1300 Burris Road (P.O. Box 730)
 Newton, NC 28658

QUALITY CONTROL PROCEDURE
 CERTIFICATION OF COMPLIANCE

Fisher Controls Company

205 South Center Street

Marshalltown, Iowa 50158

Attn: Q. A. Documentation Dept.

PURCHASE ORDER NUMBER 181172 ITEM NUMBER 000
 CUSTOMER PART NUMBER 15A5650X392 P REV
 NAMCO PART NUMBER EA180-32302 B/M REV. K QTY. 6
 LOT NUMBER 29501 DATE CODE 4682
 NAME LIMIT SWITCH
 NAMCO SHIPPER NUMBER E-40379 DATE SHIPPED 11/17/82

NAMCO CONTROLS CERTIFIES THAT SWITCHES FURNISHED HAVE BEEN MANUFACTURED, INSPECTED, TESTED, AND FOUND TO MEET APPLICABLE B/M AND DRAWING SPECIFICATIONS. NAMCO QUALITY ASSURANCE MANUAL, REV. "F", INCORPORATES 10CFR50(B) AND ANSI 45.2 AS APPLICABLE. NAMCO FURTHER CERTIFIES THAT THESE SWITCHES WERE MANUFACTURED TO THE SAME SPECIFICATIONS AS SWITCH MODEL EA180-11302, REV. H, WHICH WAS QUALIFIED TO IEEE STANDARDS 323 (1974), 344 (1975), AND 382 (1972), PER REPORT NO. QTR-105.

11/17/82
 DATE

Frank J. Nyquist
 QUALITY CONTROL MANAGER

5/18672369



ROUGH STOCK/PURCHASE PARTS INSPECTION REPORT

NCR NOS

ISSUED BY DATE
Tom Z 7/83

PURCHASE ORDER NO.

PURCHASE REQ. NO.

REP. ORDER NO.

ITEM NO.

QUANTITY

5182014-001

818590

22B-X5AC03-N24

0150

1

T DESCRIPTION

SIZE

TYPE

MATERIAL TYPE

PROJECT NO.

PIECE SERIAL NO.

solenoid

14

9280

supplies STANDARD

79P126

818590-1

PART NO.

ROUGH DRAWING NO.

REV.

FINISHED DRAWING NO.

REV.

1M3429X0452

1M3429

CODE

FGS 13A1, 13E10

NUC. CLASS

STAMP

SECT 19

EDITION

19

ADDENDA

NA

YES

NO

HOLD POINTS

CUST. INSP. AUTH. INSP.

INSPECTION OPERATION

OPERATION PERFORMED BY

DATE

INSPECT PER Q.A. MANUAL, SECTION 11

NUCLEAR

STANDARD

MSS-SP-55

Wayne Boston

10-10-83

RECORD

HEAT NUMBER _____

LOT NUMBER _____

VENDOR *0910*

Wayne Boston

10-10-83

STAMP PIECE SERIAL NO. ON PART

STORE MATERIAL

Q.A. DOCUMENTATION VERIFICATION

Q.A. APPROVAL _____

DATE _____

A.I. REVIEW _____

DATE _____

Inspection activities required are checked. Return this form to Quality Documentation Coordinator after part is stored.

Automatic Switch Co.

Manufacturers of
DEPENDABLE CONTROL
Since 1888



FLORHAM PARK, NEW JERSEY 07932 • N.J.-(201) 966-2000 / N.Y.-(212) 344-3765

CERTIFICATE OF COMPLIANCE

Customer Name FISHER CONTROLS INTERNATIONAL, INC.
 Customer P.O. No. S182014
 Consignee _____
 Consignee P.O. No. _____
 ASCO Shop Order No. 45945M
 ASCO Part No. NP K 8316A-74-E Quantity 1
 Voltage 125/DC Eng. Job No. _____

This is to certify that the subject valve(s) meet the performance requirements of IEEE-323-1974, IEEE-344-1975, and IEEE-382-1972, as substantiated by testing valves of generically equal design in accordance with ASCO Qualification Specification AQS-21678, Revision "B", dated February 15, 1978. The following test levels were included in this qualification test program:

I. Aging Simulation Phases:

- A. Thermal Aging Simulation - 268°F for 12 days. These aging parameters were determined by Arrhenius calculations to simulate a minimum of 10 years in a 140°F continuous ambient. Refer to Figure 1 for additional information regarding service periods for elastomeric components and solenoid coils.
- B. Radiation Aging Simulation - 50 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate expected non-accident radiation exposure.
- C. Wear Aging Simulation - 40,000 operations at maximum operating pressure differential and nominal voltage.
- D. Vibration Aging Simulation - 1 million cycles, distributed equally among the three orthogonal axes, between 50 and 100 Hz, at an input acceleration level of 0.75g. The valves were cycled once every 15 minutes during the test. The valves were attached to the shaker table by rigid test fixtures using the standard valve mounting provisions with the solenoids vertical and upright. Flexible hoses were used on all ports; therefore, the set-up did not affect the rigidity or mass of the valves being tested.
- E. Seismic Aging (OBE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to two sinusoidal sweeps from 1 to 33 to 1 Hz, with a peak acceleration level of 3g within machine limits, in each of three orthogonal axes at a rate of 1 octave per minute. One sweep in each axis was conducted with the valves energized and the other with the valves de-energized. These sinusoidal sweeps are considered to provide the equivalent dynamic effect of 5 OBE's.

ASCO SHOP ORDER NO. 45945M

II. Design Basis Event (DBE) Phases:

A. Seismic DBE (SSE) Simulation - The valves were mounted to the shaker table as described for the vibration aging simulation and were exposed to single frequency sinusoidal tests at 1/3 octave frequency interval dwell points from 1-40 Hz. At each test frequency, the peak input acceleration was increased and the g-levels were recorded at which the cylinder port pressure (zero when de-energized and full inlet pressure when energized for a normally closed valve, opposite for a normally open valve) differed from the nominal by 0%, 5% and 10% of inlet pressure (up to 10g maximum). The valves are considered to function properly up to a 10% change in cylinder port pressure. This level was selected as being sufficiently low to prevent spurious shifting of the customer's main valve or other equipment. Motion was applied at the same frequency and acceleration limits in each of the three orthogonal axes separately. Based on this testing and/or additional testing conducted by ASCO (after consideration of margin as suggested in IEEE-323-1974), the following acceptable maximum acceleration levels have been determined:

11.2g

- B. Radiation DBE Simulation - 150 megarads of gamma radiation at a rate not exceeding 1 megarad per hour to simulate (after consideration of margin as suggested in IEEE-323-1974) at least 136 megarads of accident radiation exposure.
- C. Environmental DBE (LOCA/HELB) Simulation - The valves were installed in a pressure vessel and subjected to a 30-day exposure of steam and chemical spray following the suggestions of IEEE-382-1972 (chemical spray per Table 1(b) and test chamber temperature profile per Figure 1 and Table 2). The valves had been pressurized to maximum operating pressure and continuously energized for 4 hours prior to the first transient (to produce coil saturation). They were de-energized when the temperature of the first transient reached 280°F, to show satisfactory shifting for demonstration of safety function. The valves were kept pressurized and were cycled during the 30-day exposure, as suggested in IEEE-382-1972, to demonstrate their ability to operate on demand during the LOCA or HELB.

Test report AQS-21678/TR, Rev. A, is on file at Automatic Switch Company in Florham Park, New Jersey, and is available for customer perusal.

Dated SEPTEMBER 28, 1983

Authorized Signature *Robert A. [unclear]* C.A. Tech.

NOTE: IN ORDER TO MAINTAIN QUALIFICATION, CATALOG NP-1 VALVES SHOULD BE REBUILT USING THE APPROPRIATE SPARE PARTS WHENEVER INDICATED BY THE PERIODIC INSPECTION OF VALVE COMPONENTS OR WHENEVER ANY OF THE FOLLOWING LEVELS, SIMULATED DURING QUALIFICATION TESTING, ARE REACHED:

- 1. WEAR AGING - 40,000 CYCLES
- 2. RADIATION AGING - 5×10^7 RAD
- 3. THERMAL AGING - THE MAXIMUM SERVICE PERIOD INDICATED FOR THE APPLICABLE SERVICE AMBIENT TEMPERATURE.




FIGURE 1

MAXIMUM SERVICE PERIODS FOR ELASTOMERIC COMPONENTS AND SOLENOID COILS IN ASCO CATALOG NP-1 VALVES

S/N 8672369

ATTACHMENT 6

FQP-11AB-7

Arrhenius Rate Equation Calculation

Arrhenius Rate Equation Calculations

The Arrhenius rate equation as referenced in IEEE 382 can be expressed as follows:

$$\frac{t_1}{t_2} = e^{\frac{\phi}{K} \left(\frac{1}{T_1} - \frac{1}{T_2} \right)}$$

- where: t_1 = service life
- t_2 = test duration
- T_1 = service temperature
- T_2 = test temperature
- ϕ = activation energy
- K = Boltzman's constant = 0.8617×10^{-4} eV/K

Values determined by the aging segment of the Wyle Test Report No. 45088-1, Fisher Lab Problem 1685-3, Report 11, and Bechtel Specification X5AC03, Appendix EA, result in the following numbers for a service temperature of 135°F.

- $t_2 = 28.5$ days
- $T_1 = 135$ °F = 330.2 K
- $T_2 = 227.8$ °F = 381.8 K
- $\phi = 0.79$ eV

hence:

$$t_1 = (t_2) e^{\frac{\phi}{K} \left(\frac{1}{T_1} - \frac{1}{T_2} \right)}$$

$$t_1 = (28.5) \text{days} \cdot e^{\frac{(0.79) \text{eV}}{(0.8617 \times 10^{-4}) \text{eV/K}} \left(\frac{1}{330.2 \text{K}} - \frac{1}{381.8 \text{K}} \right)}$$

$$t_1 = 1215 \text{ days} = 3 \text{ years } 120 \text{ days}$$

ARRHENIUS ACCELERATED-AGING RULE TEMPERATURE CALCULATION
of
MAXIMUM-ALLOWABLE NORMAL-SERVICE TEMPERATURE
to
ASSURE FOUR-YEAR LIFE OF NUCLEAR-SERVICE EQUIPMENT ELASTOMERIC MATERIALS
(Limited to ethylene propylene T-rings and graphoil packing)

This calculation is based on an accelerated-aging high-temperature test conducted by Fisher Controls Company. The test temperature was held constant at 227.8°F for the complete 28.5-day test. The four-year life calculation, below, utilizes the activation energy constant for ethylene propylene (0.79 eV) which is the most limiting of the regular nuclear-service butterfly-valve materials.

The unknown-time form of Arrhenius accelerated-aging equation is given below:

$$t_1 = (t_2)e^{\frac{\phi}{K} \left[\frac{1}{T_1} - \frac{1}{T_2} \right]}$$

where:

- ϕ (activation energy constant) = 0.79 eV
- K (Boltzman's constant) = 0.8617×10^{-4}
- t_1 (normal service-temperature life) = 4 years = 1461 days
- t_2 (test duration) = 28.5 days
- T_1 (maximum allowable service temperature) = unknown
- T_2 (test temperature) = 227.8°F

Rearranging the equation to the inverse-temperature form:

$$\frac{1}{T_1} = \frac{1}{T_2} + \frac{K}{\phi} \ln \frac{t_1}{t_2}$$

Substituting above values into equation:

$$\frac{1}{T_1} = \frac{1}{382} + \frac{0.8617 \times 10^{-4}}{0.79} \ln \frac{1461}{28.5}$$

Solving for the four-year life temperature:

$$T_1 = 328.17^\circ\text{K} = 131.3^\circ\text{F}$$

ATTACHMENT 7

FQP-11AB-7

Effects of Gamma Radiation Exposure to 200 Mrads
on 20" Type 9220 Valve With Bettis Actuator

Fisher Lab Problem 1685-3, Report 8

CONFIDENTIAL
RESTRICTED

204

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWA

Project 78EC07

W. H. Harlett

LAB FILE COPY
RETURN TO
R. A. ENGEL TECH CENTER

PROB. 1685-3
REPORT 8
PAGE 1
DATE 2-17-81

LABORATORY REPORT

EFFECTS OF GAMMA RADIATION EXPOSURE TO 200 Mrads
ON 20" TYPE 9220 VALVE WITH BETTIS ACTUATOR

ABSTRACT

The SNUPPS environmental test valve (20" Type 9220 with Bettis T420B-SR2) was exposed to a total of 200 Mrads of Cobalt-60 (gamma) radiation. Testing was performed after completion of the qualification testing per FQP-19 without changing or readjusting the T-ring. A dramatic increase in air leak rate occurred between 10 Mrads and 100 Mrads exposure over the entire test range (2.5 psid to 75 psid). With the addition of another 100 Mrads, the leak rate at the low ΔP again increased sharply. However, at the high end of the ΔP range there was essentially no further change in leak rate.

INTRODUCTION

1.0 - This report covers work performed at Isomedix Inc., Parsippany, New Jersey on the SNUPPS Environmental Test Valve. The test valve was a 20" Type 9220 with a Bettis T-420B-SR2 actuator and associated appurtenances. Prior to this test sequence, the valve assembly had undergone the entire test sequence described in Fisher Controls Environmental Qualification Plan FQP-19 (reference 1) up to, but not including, the post-DBE (Design Basis Event) Radiation Exposure Test (see Section 9.3, p. 28, of above mentioned document). In addition, the valve assembly was subjected to an extra thermal exposure of 400°F for 15 minutes in an air oven, in accordance with FGS 14A2 (reference 1). The testing reported here essentially completes the intent of FQP-19 and extends the radiation testing by an additional 100 Mrads. The procedures were modified somewhat due to factors described below.

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 2
DATE 2-17-81

LABORATORY REPORT

During the post-DBE functional testing (Section 9.2, FQP-19), the Versa valve remained in the exhaust mode (the fail-safe position) thus preventing the opening of the test valve. Since the remaining tests were for information only, it was decided to eliminate the stroking time tests and to monitor leak rates only in determining radiation effects. Also, since no test chamber was available at Isomedix, the leak rates were determined at ambient conditions instead of at 120°F as called for in FQP-19. This necessitated running an additional baseline leak test prior to irradiation. There was no readjustment of the EPDM T-ring nor had there been since the post-thermal aging adjustment early in the testing sequence. In other words, the elastomeric seal ring had been adjusted for zero leakage at 75 psid and ambient temperature after a 50 day thermal and humidity aging sequence and then the valve assembly had undergone (1) 10 Mrads of gamma radiation, (2) seismic vibration testing, and (3) a design basis event (DBE) which consisted of a 30 day loss-of-coolant-accident (LOCA) simulation, and now, with this study, two additional doses of gamma radiation (90 Mrads and 100 Mrads) without touching the T-ring adjustment.

TEST PROCEDURE

2.0 - A complete description of the SNUPPS environmental test valve can be found in FQP-19, Rev. F (reference 1). The condition of the valve assembly at the start of this test sequence and details of prior testing can be found in Wyle Labs Test Reports No. 45088-1 and No. 45390-1 (references 2 and 3). The test valve was

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 3
DATE 2-17-81

LABORATORY REPORT

shipped directly from Wyle Labs, Huntsville, Alabama to Isomedix Inc., Parsippany, New Jersey. The two spool flanges had been removed prior to shipment.

PREPARATION FOR TESTING

2.1 - The two spool flanges with blind flanges already attached were rebolted across the test valve. The bolting was torqued to 540 ft-lbs, which was the same torque used previously at Wyle Labs.

BASELINE LEAK TEST

2.2 - Throughout this test sequence the valve assembly was oriented in the same manner as in the LOCA chamber (i.e., the disc was horizontal with the inlet side up). (See Figure 3.) The inlet air line was connected from a portable air compressor through a regulator to the top blind flange. The outlet air line was connected to the bottom blind flange with the other end submerged in water. Air leak rates were measured by noting the time required to displace a known quantity of water with air when an inverted water-filled container was held over the end of the outlet air line. This technique worked well for all the baseline leak tests. One problem was encountered with the test setup regulator in that its maximum output was about 35 psig. To obtain leak rates above 30 psig, the regulator was removed from the inlet air line and the inlet pressure was "controlled" using a needle valve located at the compressor volume tank.

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 4
DATE 2-17-81

LABORATORY REPORT

PREPARATION FOR RADIATION EXPOSURE (90 Mrad Dose)

2.3 - The two blind flanges were removed from the inlet and outlet spool flanges to prepare the valve assembly for irradiation. The two spool flanges were left on the valve. At this point the valve assembly was turned over to Isomedix for radiation exposure.

RADIATION EXPOSURE

2.4 - The radiation exposure of 90 Mrads equivalent air dose was carried out as described in FGS14C1 (reference 4) and as reported in Isomedix letter dated February 3, 1981 (see Appendix C).

POST-RADIATION LEAK TESTS

2.5 - On completion of the radiation exposure the valve assembly was removed from the radiation chamber and the two blind flanges were reinstalled. Air leak tests were run using the same technique described in Paragraph 2.2. However, at high flow rates the technique was modified to a dry-fill measurement. (i.e., The outlet air flow was collected in a collapsed plastic bag. The time to inflate the bag to a known volume was measured.) Also, at the high leak rates it became obvious that the pressure drop in the outlet air line was significant. Hence, the pressure (P_2) at the outlet blind flange was measured for several tests and these values were plotted to obtain correction factors for the other leak tests. (See plot in Appendix A.)

PREPARATION FOR SECOND RADIATION EXPOSURE (100 Mrad Dose)

2.6 - The procedure was identical to that described in Paragraph 2.3.

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 5
DATE 2-17-61

LABORATORY REPORT

RADIATION EXPOSURE

2.7 - The radiation exposure of 100 Mrads equivalent air dose was carried out as described in FCS14C2 (reference 5) and as reported in Isomedix letter dated February 3, 1981 (See Appendix C).

POST-RADIATION LEAK TESTS

2.8 - On the completion of the radiation exposure, the valve assembly was removed from the radiation chamber and the two blind flanges were reinstalled. Air leakage was measured by two techniques: (1) the water displacement technique described in paragraph 2.2 and (2) using an orifice well flowmeter. The calibration curves for the orifice sizes used are included in Appendix B.

INSPECTION

2.9 - At the completion of the leak testing, the two spool flanges were removed and the valve assembly inspected for visual damage. The valve disc was rotated to the open position by applying air pressure directly to the actuator cylinder. (i.e., Bypassing the solenoid and the Versa valve.)

3.0 - DISCUSSION OF RESULTSAIR LEAK RATE TESTS

3.1 - The air leak rate test results for the baseline test and the two post-radiation tests are summarized in Table I. The individual data sheets for each test are included in Appendix A. In Figure 1, the leak rates are

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWA

PROB. 1685-3
REPORT 8
PAGE 6
DATE 2-17-81

LABORATORY REPORT

plotted versus the differential pressure for all three runs. (The use of log-log plot is for convenience only and is not otherwise significant.) The four different curves for the 200 Mrads data represent four different "fresh starts" (i.e., starting at zero pressure and increasing P_1 incrementally). Both post-radiation tests (100 Mrad & 200 Mrad total dosage) showed a pronounced leakage increase over the entire pressure range as compared with the baseline test (10 Mrad level). Additionally, for the 200 Mrad test there was a certain amount of instability in the 10 to 20 psig inlet pressure range with the leak rate starting high and then dropping down to a lower level in a matter of minutes. This was probably due to a slight movement of the disc into a more favorable position in the seal ring. For 30 psid and above the leak rates after 100 Mrads and 200 Mrads were practically identical.

In Figure 2, the leakage at 2.5 psid is plotted versus total radiation dose. Here again, there is the obvious radiation effect, but compared with the SNUPPS post-DBE leakage criteria (reference 1) only the 200 Mrad test exceeds the allowable leakage level. If this test had been performed at 100°F instead of less than 70°F it might well have been within the allowable level.

VISUAL INSPECTION

3.2 - The entire valve assembly was visually inspected for obvious damage. There was much rust and scale on almost every surface. Very little of the original paint was intact. A photograph of the general condition of the valve assembly is shown in Figure 3. Actually most, if not all, of the degradation reported here was due to the thermal/humidity aging and the LOCA simulation.

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 7
DATE 2-17-81

LABORATORY REPORT

Removing the spool flanges revealed much evidence of corrosion on the valve internals. Figure 4 is a photo of the inlet side of the disc showing much rust and scale. Also, Figure 5 is a close-up of the scale and debris that was in the sealing area, first noticed when the valve was stroked open. The only damage to the T-ring was a small cut in one of the "rub" areas near the shaft (see Figure 6). There was some wear, but it was not really excessive for the 1000 plus open/close cycles the valve had been subjected to. There was a very pronounced "permanent set" to the T-ring due to the disc pressing into the rubber T-ring throughout most of the test sequence. (See Figures 7 and 8). Again, this phenomenon was not due to radiation exposure alone, but to the sum total of the thermal/humidity aging, the LOCA simulation and the radiation.

CONCLUSION

4.0 - While the test sequence was performed for information only, it is important to note that after 100 Mrads total radiation dose, the leak rate at 2.5 psid was still within the SNUPPS acceptance criteria for the post-DBE leakage as specified on Page 39.1 in FQP-19 (reference 1). Also, after 200 Mrads, the 2.5 psid leak rate was only moderately larger than this same acceptance level, which was specified for 100°F. Had the post-200 Mrad test been performed at 100°F instead of less than 70°F, the actual leakage would have been less and probably would have been close to the allowable 2944 cc/minute.


FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 8
DATE 2-17-81

LABORATORY REPORT

It is also important to note that there was a dramatic radiation effect, with the greatest change occurring in the 10 to 20 psid range between the baseline (10 Mrads) and the 100 Mrads dose.

RECOMMENDATION

5.0 - In the past, 10 Mrads of radiation dosage was considered a safe maximum level for valve or appurtenances containing elastomeric materials (including Ethylene-propylene rubber [EPDM]). The results of this test sequence would tend to substantiate this 10 Mrad limit. In any application where a valve might receive greater than 10 Mrads total radiation, the customer should be cautioned that a certain loss of pressure retaining properties would be expected.

W.H. Haslett
Evaluation & Analysis Department

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWAPROB. 1685-3
REPORT 8
PAGE 9
DATE 2-17-81

LABORATORY REPORT

REFERENCES

1. Fisher Controls Environmental Qualification Plan, FQP-19, Rev. F, dated April 14, 1980 modified by "Change of Scope to P.O. 217770" - dated October 28, 1980. Further modified by Fisher Controls Test Program FGS14A2, dated October 28, 1980. Referenced to P.O. No. 220272, Test Part No. 1R0101X0022.
2. Wyle Laboratory Report No. 45088-1, dated November 21, 1980.
3. Wyle Laboratory Report No. 45390-1, dated November 7, 1980.
4. Fisher Controls General Specification, FGS 14C1, Rev. A dated November 20, 1980. "Subcontracted Services, Isomedix Inc. Environmental Performance Testing (90 Mrad) 20" Type 9220 with Bettis T420B-SR2".
5. Fisher Controls General Specifications, FGS 14C2, Rev. A., dated November 20, 1980. "Environmental Performance Testing 100 Mrad Radiation Exposure 20" Type 9220 with a Bettis T420B-SR2".

TABLE I. - SUMMARY OF POST-DBE (RADIATION EFFECTS) LEAK TESTS

TESTS PERFORMED AT ISOMEDIX, INC., PARSIPPANY, N.J.

TEST FLUID: AIR

TEST TEMP.: ROOM AMBIENT (~65°F)

P ₁ INLET PRESSURE	BASELINE (10 MRADS PREV. DOSE)				AFTER ADD'L. 90 MRADS (100 TOTAL)				AFTER ADD'L. 100 MRADS (200 TOTAL)			
	P ₂ AT OUTLET	ΔP	LEAK RATE		P _L AT OUTLET	ΔP	LEAK RATE		P _L AT OUTLET	ΔP	LEAK RATE	
psig	psig	psid	cc/min.	SCFH	psig	psid	cc/min.	SCFH	psig	psid	cc/min.	SCFH
2.5	0	2.5	215	0.46	0.2	2.3	875	1.85	0	2.5	4315	9.1
2.8	—	—	—	—	0.3	2.5	1270	2.7	0.2	2.3	4250	9.0
10	0.1	9.9	510	1.08	2.6	7.4	14,400	30.6	1.2 2.5 3.9	8.8 7.5 6.1	94,400 16,300 20,300	200 345 43
20	0.2	19.8	884	1.87	2.6	17.4	14,300	30.3	0.4 1.25 5.0 0.75	19.6 18.75 15.0 19.25	56,600 11,300 86,400 33,500	120 24 183 71
30	0.5	29.5	2160	4.57	3.8	26.2	23,100	48.9	0.9	29.1	36,800	78
40	—	—	—	—	6.0	34.0	36,400	77.2	1.5	38.5	46,300	98
50	—	—	—	—	7.2	42.8	49,400	105	2.4	47.6	58,300	124
55	2.3	52.7	12,250	26.0	—	—	—	—	—	—	—	—
60	—	—	—	—	10.0	50.0	76,900	163	3.9	56.1	76,500	162
75	3.6	71.4	21,000	44.5	14.0	61.0	107,800	228	—	—	—	—

* MAX. PRESSURE POSSIBLE WAS 62 PSIG DUE TO LIMITATIONS OF THE AIR COMPRESSOR.

9510-AX50003

51-2 213


Rep. 8

PROB. 1685-3
 REP. 8
 FIG. 1

20" TYPE 9110 BUTTERFLY VALVE

LEAK RATE VS. ΔP

RADIATION EFFECTS



KE SEMI-LOGARITHMIC 46 6212
 5 CYCLES X 70 DIVISIONS
 MADE IN U.S.A.
 KEUFFEL & ESSER CO.

FISHER CONTROLS CO.

PROB. 1685-3
REP. 8
FIG. 2

20" TYPE 9220

EFFECT OF RADIATION DOSE

ON LEAK RATE


AT 2.5 PSID

TEST TEMP. 120°F

DIETZEN CORPORATION
MADE IN U.S.A.

NO. 340-20 DIETZEN GRAPH PAPER
20 X 20 PER INCH


LEAK RATE, SCFH




ALLOWABLE POST-DOSE
LEAKAGE AT 100°F
(PER FQP-19)

ALLOWABLE POST-DOSE
LEAKAGE AT 120°F
(PER FQP-19)


TOTAL RADIATION DOSE, MRADS




Overall view of valve assembly with spool flanges attached.



Photograph of inlet side of disc after radiation. Corrosive damage due primarily to previous test conditions. (Thermal/humidity aging and loss-of-coolant-accident, LOCA.)




Close-up of sealing area with disc open.



View showing small cut in T-ring.



Same view as Figure 6, but with different lighting to show "permanent set" of T-ring.



Another close-up of T-ring showing indentation or "permanent set".

ATTACHMENT 8

FQP-11AB-7

Valve Closure Test
6" Prototype Snupps Butterfly Valve

Wyle Report Number 44503-0

Valve Closure Test
Six-Inch Prototype
Snapps Butterfly Valve

For
Fisher Controls Company
Marshalltown, Iowa

TABLE OF CONTENTS

	<u>Page No.</u>
1.0 PURPOSE	1
2.0 REFERENCES	1
3.0 MANUFACTURER	1
4.0 TEST SPECIMEN	1
5.0 SUMMARY	1
6.0 REQUIREMENTS	2
7.0 PROCEDURES AND RESULTS	2
TABLE I TEST RESULTS	5
Figure 1 Test System Schematic	6
PHOTOGRAPH 1 TEST SPECIMEN	7
PHOTOGRAPH 2 TEST SPECIMEN IN FLOW SYSTEM	8
PHOTOGRAPH 3 TEST SPECIMEN IN FLOW SYSTEM	9
PHOTOGRAPH 4 REMOTE POSITION INDICATOR	10
APPENDIX I INSTRUMENTATION EQUIPMENT SHEET	11
APPENDIX II FLOW DATA	13
EXHIBIT I FQP-24, REVISION B, PROTOTYPE CLOSURE TEST PROCEDURE	19

TEST REPORT

WYLE LABORATORIES
SCIENTIFIC SERVICES AND SYSTEMS GROUP
HUNTSVILLE, ALABAMA

Fisher Controls Company
P. O. Box 190
Marshalltown, Iowa 50158

REPORT NO. 44503-0
OUR JOB NO. 44503
YOUR P. O. NO. 213517
Change Order #1
CONTRACT N/A
PAGE 1 of 39 PAGE REPORT
DATE November 29, 1979

1.0 PURPOSE

The purpose of this report is to present the requirements, procedures, and results of a test program conducted to determine the closure time, flow capability, and subsequent leakage of a six-inch prototype butterfly valve.

2.0 REFERENCES

- 2.1 Wyle Laboratories Quotation 546/1048/CP dated October 9, 1978.
- 2.2 Fisher Controls Company Purchase Order Number 213517 dated August 14, 1979 and Change Order Number 1.
- 2.3 Fisher Controls Company, "Prototype Closure Test Procedure," FQP-24, Revision B.

3.0 MANUFACTURER

Fisher Controls Company
P. O. Box 190
Marshalltown, Iowa 50158

4.0 TEST SPECIMEN

The test specimen was a Fisher Controls Company, normally closed, Six-inch Type 6221, Butterfly Control Valve equipped with an air operated, solenoid controlled actuator. (Prototype).

5.0 SUMMARY

During system checkout and testing, the test specimen was closed a total of 10 times without steam flow and four times with steam flow.

STATE OF ALABAMA }
COUNTY OF MADISON }

William W. Holbrook being duly sworn

deposes and says: The information contained in this report is the result of complete and carefully conducted tests and is to the best of his knowledge true and correct in all respects.

SEAL William W. Holbrook
SUBSCRIBED and sworn to before me this 29 day of Dec 19 79

Judith S. Malley
Notary Public in and for the State of Alabama at large

My Commission expires 6-21 19 81

Wyle shall have no liability for damages of any kind to person or property, including special or consequential damages, resulting from Wyle's providing the services covered by this report.

TEST BY Steam Services

William W. Holbrook
L. J. KIMBRETT

WYLE Q. A. William W. Holbrook
M. S. J. KIMBRETT

QAS DCAS WYLE William W. Holbrook

7.0 PROCEDURES AND RESULTS (Continued)

7.2 (Continued)

the open marker. This condition was reported to the Fisher Controls Company (FCC) representatives. The condition did not affect the operation of the test specimen disc since the disc rotated away from the disc stop which was installed on the upstream side of the disc.

7.3 The test specimen was then cycled five additional times to verify recording equipment, air pressure recovery time, and closure time.

7.4 The system was pressurized to 40 psig with saturated steam and the control valve opened with the test specimen in the open position. Recorded data showed that the upstream pressure was 10 psig rather than the required 20 psig. Since the test specimen was exhausting to atmosphere, it was decided to install a tailpipe and gate valve so that sufficient backpressure could be obtained to increase the upstream pressure to 20 psig. A pressure transducer was also installed on the tailpipe.

7.5 Four closure tests were conducted and the data for each test is shown in Table I. It was necessary to increase the test specimen upstream pressure above 20 psig, however, in order to obtain the desired steam flow rate.

7.6 Data recordings for each test run are included in the appendix.

7.7 Flow rates were obtained by measuring the upstream pressure and differential pressure across a sharp edged orifice installed in an 8-inch diameter pipe and calculating the flow as follows:

$$W_h = ID^2 \sqrt{hw/v}$$

Where:

W_h = Steam flow rate (pph)

I = ASME meter constant


D = Inside diameter of pipe

hw = Differential pressure (in. of water)


v = Specific volume of saturated steam at orifice inlet.

TABLE I
TEST DATA
AT CLOSURE SIGNAL

TEST NO.	UPSTREAM PRESSURE (PSIG)	DOWNSTREAM PRESSURE (PSIG)	ΔP (PSI)	STEAM FLOW pph	STEAM TEMP ($^{\circ}$ F)	CLOSING TIME (SEC)		ACTUATOR PRESSURE (PSIG)
						WITH FLOW	WITHOUT FLOW	
1	18	8	10	25,360	265	1.25	1.01	70
2	21	8	13	32,557	272	1.16	1.06	70
3	25	11	14	31,130	279	1.21	1.10	70
4	24	10	14	30,764	272	1.25	1.12	70



PHOTOGRAPH 1
TEST SPECIMEN



PHOTOGRAPH 3
TEST SPECIMEN IN FLOW SYSTEM

PAGE NO. 11
REPORT NO. 44503-0


APPENDIX I
INSTRUMENTATION EQUIPMENT SHEET

PAGE NO. 13


REPORT NO. 44503-0

APPENDIX II
FLOW DATA

Job Number	44503	Customer	FISHER CONTROLS Co.
Date	11-15-77	Job No.	Z
Chart Speed	20	Transducer Range	N/A
Study Time	82	PS Range	N/A
Test Set Pressure	N/A	PS Duty Cycle	N/A
Post Calc Start Factor	N/A	PS Duty Cycle Time	N/A
Controlled Set Pressure	N/A	PS Duty Cycle Time	N/A
Post Test Start Reading	N/A	PS Duty Cycle Time	N/A
Remarks:	With <i>A. D. Maffei</i> who DC <i>Winkfield</i> Prep'd by <i>R. W. Kelly</i> Cal'd by		



Job Number	44503	Customer	FISHER CONTROLS CO.
Date	11-15-79	Part No.	4
Crust Speed	20	Test/Op Timing Slip	N/A
Body Temp	72	Is Board Temp	N/A
Test Set Pressure	N/A	PSIG Delay Time	N/A
Prod Cycle Time (Min)	N/A	PSIG Stroke Time	N/A
Control Set Pressure	N/A	PSIG Release Time	N/A
Event Test Start Label	NONE		
Operator			
Wired to	S. Phillips & Assoc. Memphis		
Wired by	S. Phillips		



PAGE NO. 19

REPORT NO. 44503-0

EXHIBIT I
FQP-24, REVISION B
PROTOTYPE CLOSURE TEST PROCEDURE
FOR
SNUPPS BUTTERFLY VALVE

FQP-24

PROTOTYPE CLOSURE TEST PROCEDURE

FOR

FISHER CONTROLS COMPANY

CONTINENTAL DIVISION

BUTTERFLY CONTROL VALVES

PER

BECHTEL POWER CORPORATION ORDER 10466-M-237

DATE: July 9, 1979 Revision B
March 15, 1978 Revision A

PREPARED BY: Richard C. Sekerchak
Richard C. Sekerchak, Project Engineer

REVIEWED BY: Carl D. Wilson
Carl D. Wilson, Senior Engineer

APPROVED BY: Richard Hooper
Richard L. Hooper, Manager of Engineering

1.0 SCOPE:

This procedure delineates the method to be used by Wyle Laboratories of Huntsville, Alabama, to perform a prototype closure test on a 6" Type 9221 Fisher Controls Company Butterfly Control Valve per Bechtel Power Corporation Specification No. 10466-M-237.

The intent of this procedure is to demonstrate the capability of an 18" Type 9221 to close within 3 seconds, should a Design Basis Event occur when the valve is in the full open position, by extrapolation of the test results for the 6" Type 9221 prototype valve.

FISHER CONTROLS COMPANY
CONTINENTAL DIVISION

Page No. 25
Report No. 44503-0

3.0 ANALYSIS:

The results of the closure test for the prototype 6" Type 9221 will be extrapolated to determine the closing time for the 18" Type 9221 by utilization of the following equation:

$$\text{Closing time for } 18" \text{ W/flow} \approx \text{(Closing time for } 18" \text{ W/O flow)} \times \left(\frac{\text{Closing time for } 6" \text{ W/flow}}{\text{Closing time for } 6" \text{ W/O flow}} \right)$$

3.1 Verification of Structural Integrity:

Structural integrity will be verified by way of the stress calculation format which has been submitted for Bechtel information only. These calculations will be included as Appendix A.

3.2 The analysis will include a description of the geometric similarity between the prototype 6" Type 9221 and the 18" Type 9221.

FISHER CONTROLS COMPANY
CONTINENTAL DIVISION

Page No. 27

Report No. 44503-0

formed per Fisher Controls, Continental Test Specification, CTS 1.21, Rev. 0, with Appendix CCN 6F133-21, Unidirectional Seat Leak Test Procedure for Elastomer and Teflon Seated, Adjustable Type 9200 T-Ring Valves (all valves 20" or less and larger valves for use in vertical pipelines, or in horizontal pipelines with shafts vertical). This specification is included as Appendix B.

5.5 Test Equipment Used, Calibration, and Equipment Accuracy (to be supplied by Wyle Laboratories).

5.6 Closure time for 18" Type 9221 with no flow = _____ seconds


FISHER CONTROLS COMPANY
CONTINENTAL DIVISION

Page No. 31
Report No. 44503-0

7.0 CONCLUSIONS:

APPENDIX B
(FQP-24)

UNIDIRECTIONAL SEAT LEAK TEST PROCEDURE FOR
ELASTOMER AND TEFLON, ADJUSTABLE TYPE 9200
T-RING VALVES, CTS 1.21, REV. 0, WITH
APPEDIX CCN 6F133-21.

 CONTINENTAL DIV.	CONTINENTAL TEST SPECIFICATION	DATE 9/10/75
	UNIDIRECTIONAL SEAT LEAK TEST PROCEDURE FOR ELASTOMER AND TEFLON SEATED, ADJUSTABLE TYPE 9200 T-RING VALVES (all valves 20" or less, & larger valves for use in vertical pipelines, or in horizontal pipelines with shafts vertical)	DIST. EDL-17
JOB NO. CD73-168		PAGE 2 OF 5

5. POLICY:
- Order entry documents shall reference this test specification and shall describe position of valve and actuator when in service.
 - Type 9200 T-ring valves covered by this specification are tested with the valve body and shaft horizontal.
 - Thrust collars are provided on the valve shaft to prevent disc end shaft movement along the shaft axis.
 - Seat leak testing follows any body or disc hydrostatic testing that may be required.
 - Provision for liquid leak testing of Teflon seated valves is included. Liquid leak testing is performed however only as provided by appendices to this specification and as a substitute to the air leak test.
 - Seat leak testing is unidirectional with pressure applied to the shaft side of the seal.
 - It is not necessary to verify disc material and taper pin leak tightness on valves which have previously passed a disc hydrostatic test.
 - Neolube lubricant is placed on adjusting set screw threads and the threaded holes for these set screws prior to initial adjustment.

6. TEST CONDITIONS:

- 6.1 Valve Assembly - The valve shall be fully assembled, except that the actuator need not be mounted.

SPECIAL PROVISIONS TO ENSURE PERSONNEL SAFETY MAY BE EMPLOYED TO PREVENT ACCIDENTAL DISC OPENING WHILE UNDER PRESSURE.

APPROVED BY:		WRITTEN BY:
Manager, Quality Assurance <i>E.L. Becheron</i>	Manager, Sales & Marketing <i>[Signature]</i>	EH: sb <i>[Signature]</i>
Manager, Materials NOT REQUIRED	Manager, Manufacturing <i>[Signature]</i>	Manager, Engineering <i>[Signature]</i>



CONTINENTAL DIV.

CONTINENTAL TEST SPECIFICATION

Continental Standard

UNIDIRECTIONAL SEAT LEAK TEST PROCEDURE
FOR ELASTOMER AND TEFLON SEATED, ADJUSTABLE
TYPE 9200 T-RING VALVES (all valves 20" or less,
larger valves for use in vertical pipelines, or in
horizontal pipelines with shafts vertical)

CTS-
NO. 1.21 REV: 0
DATE 9/10/75
DIST. EDL-17
PAGE 4 OF 5

JOB NO. CD73-168

Packing Seal - No visible leakage in the form of bubbles or spray is permitted upon application of the leak detecting fluid. Two applications of leak detecting fluid are required with the second following the first by a period no less than 5 minutes.

Taper Pins and Disc Material - No visible leakage in the form of bubbles or spray is permitted for a period not less than 2 minutes.

Seat - No visible leakage in the form of bubbles or spray is permitted for a period not less than 10 minutes.

b. Teflon T-Ring

Packing Seal - Same as elastomer T-ring air test

Taper Pins and Disc Material - Test not required

Seat - Leakage past the disc may not exceed the amounts shown in Table I. Interpolation for intermediate pressures is permitted.

VALVE SIZE	TEST PRESSURE (PSI)					
	10	20	40	60	80	100
2-6	5.00	7.00	11.00	15.00	19.00	23.00
8-12	12.50	17.50	27.50	37.50	47.50	57.50
14-18	20.00	28.00	44.00	60.00	76.00	92.00
20-24	27.50	38.50	60.50	82.50	104.50	126.50
30-36	42.50	59.50	93.50	127.50	161.50	195.50
42-48	57.50	80.50	126.50	172.50	218.50	264.50

TABLE I - MAXIMUM ACCEPTABLE AIR LEAK RATES FOR TEFLON T-RING, SCFH

APPROVED BY:		WRITTEN BY:
Manager, Quality Assurance <i>T. L. Resch</i>	Manager, Sales & Marketing <i>[Signature]</i>	<i>[Signature]</i>
Manager, Materials NOT REQUIRED	Manager, Manufacturing <i>Dan A. Biele</i>	EH: sb Manager, Engineering <i>[Signature]</i>



SPECIFICATION/PROCEDURE APPENDIX NUMBER CCN 6F133-21

UNIDIRECTIONAL SEAT LEAK TEST PROCEDURE
FOR ELASTOMER AND TEFLON SEATED, ADJUSTABLE
TYPE 9200 T-RING VALVES (All valves 20" or less, &
larger valves for use in vertical pipelines, or in
horizontal pipelines with shafts vertical)

Nuclear Class: ---
Quality Level: ---
Revisor: 0
Date: 3 15 78
Page: 1 of 1

Page No. 39
Report No. 44503-0

I. SCOPE:

This appendix modifies and shall only be used with CTS 1.21, Rev. 0 in order to conform to the applicable Bechtel Power Corporation specifications.

II. REFERENCE DOCUMENTS:

- A. Bechtel Spec. No. 10466-M-237(Q)
- B.
- C.

III. MODIFICATIONS TO CTS 1.21 :

- A. The test pressure differential is to be 70 PSIG.
- B. Duration of seat leak test is to be 15 minutes.
- C. Allowable seat leakage - (Bubble Tight)
- D. Actuator will be mounted on valves during test.

WRITTEN BY Richard C. Sekulich

CHECKED BY John Weekley

PROJECT ENGINEER <u>R. Sekulich</u>	MANAGER, ENGINEERING <u>Richard Hooper</u>	MANAGER, MANUFACTURING <u>Dan O'Brien</u>	MANAGER, QUALITY ASSURANCE <u>E. L. Beckman</u>
--	---	--	--

ATTACHMENT 9

FQP-11AB-7

Combined Loads Shaft Analysis

ABSTRACT OF STRESS DETERMINATION

Loads due to pressure and seismic disturbance were used in an ANSYS finite element model of the 14 inch butterfly, Bettis actuated, control valve. The torsional shear stress and bearing stresses were generated with the "shaft" sizing program. Data were generated for both open and closed positions. Stresses from the two computer programs were manually combined according to the maximum shear theory. Stresses were found to peak at the butterfly disc hub and the pin connection to the shaft. In all cases the maximum normal, shear, and bearing stresses were below the allowables.

PROBLEM STATEMENT

The object of this analysis is to determine that the B.F.V. shafts have sufficient strength to withstand a simultaneous combination of pressure drop and seismic loads. Fully closed and fully open positions of the valve are to be investigated.

ANALYSIS PROCEDURE


A worst case scenario was chosen for this analysis: a 4.5 triaxial "g" load acts in the direction of gravity and the valve is installed in such fashion that the pressure load on the disc is both coincident and colinear with the "g" load. The pressure load was determined for the closed position (0°) as the product of the disc area and stagnation pressure (60 psig). When the valve is open (90°) the pressure drop already includes the frontal area and drag coefficient product so that the pressure drop times disc area yields the dynamic direct shear force on the disc. These resultant loads are assumed transferred to the shaft equally, at both hub locations of the disc. The force due to seismic activity and gravity is simply summed with the pressure load. The weight of the disc is estimated with the aid of the casting drawing. ANSYS, a finite element program is used to obtain the bending stresses and shear forces which result from the application of these loads. For this analysis the shaft was modeled as 22 segments with tenth point moment printed out in order to scan for the areas which will result in highest bending and shear stress. Multiple runs were made with model, changing the various shaft clearances through their tolerance range and observing which combination resulted in the severest stresses. These normally occur near the bearing edge, disc hub and disc pin connections. The bending stress must be combined with the shear stress according to the maximum shear principle in order to determine the maximum stress. ANSYS gives the transverse shear force from which the shear stress as a result of bending is calculated; however it does not provide the torsional stress in the shaft. For this the Coraopolis shaft sizing program is employed. This program gives the concentrated shear stress at the pin location from which the torsional stress between the pin and bearing can be found by simply dividing by the concentration factor.

$$\frac{\text{STRS4}}{K_T} = T_T$$

Where "STRS4" is the concentrated shear stress near the pin and K_T is the factor of stress concentration. K_T and the similar K_M are both taken from the ASME code for the design of transmission shafting, B17C-1927. The bearing compressive stress was also output by the program when the material (Graphite-Bronze) and 320°F temperature was given. This stress can be directly compared to allowables which is internally generated by the program. When the bending, direct shear, and torsional shear stresses are combined in the appropriate manner, the maximum normal and shear stresses are found. These are compared to the allowables generated internal to the program and was based on the 17-4PH shaft material at 320°F.


RESULTS

Shaft stresses were greatest at the disc hub location and, because of the concentration factor, at the pin connection. Normal stress and maximum shear stress was computed on the neutral axis and the extreme fiber position for each location along the shaft. The calculations were performed for both a full open and closed valve. The load carrying limitation of the shaft results from the maximum shear stress at the pin hole location when the valve is in a fully open position. In all cases the normal, shear and bearing stresses in this shaft were below the allowable stresses.




Jerry McDaniel
Stress Analyst
December 5, 1984

Reviewed by:



Barry Gaarder
Qualification Analyst

CALCULATION OF SHAFT LOADS



- PRESSURE: $F_p = \frac{\pi}{4} (\text{DISC})^2 \Delta P$

CLOSED: $F_{p1} = \frac{\pi}{4} (13.244)^2 \times 60 = 8,266 \text{ Lb}$

OPEN: $F_{p2} = \frac{\pi}{4} (13.244)^2 \times 50 = 6,888 \text{ Lb}$

- SEISMIC: $F_s = \frac{W}{g} \times a = \frac{73}{g} \times 4.5 \sqrt{3} g = 569 \text{ Lb}$

ASSUME AS A WORSE CASE THAT ALL LOADS ARE COINCIDENT IN THE DIRECTION OF GRAVITY.

VALVE CLOSED: $F = 8,266 + 569 + 73 = 8,908 \text{ Lb}$

VALVE OPEN : $F = 6,888 + 569 + 73 = 7,530 \text{ Lb}$

JDM
11/29/84 BLG

ACTUATOR
HUB &
KEY

FOLLOWER

PACKING
RINGS

PACKING
BOX RING

BUSHING

1ST PIN
PIN

DISC



BUSHING

PACKING
BOX RING

PACKING
RINGS

FOLLOWER


BUSHING



COMBINED SEISMIC AND PRESSURE LOADS

JDM P1
11/29/84
B.L.G.

1. FULLY CLOSED (0°)



SHAFT CROSS SECTION

σ_b = BENDING STRESS DUE TO SIMULTANEOUS AND COLINEAR PRESSURE AND SEISMIC LOADS.

τ_T = SHEAR STRESS DUE TO SHAFT TORQUE

τ_v = SHEAR STRESS DUE TO SHAFT BENDING.

V = SHEAR FORCE ON SHAFT

K_t = STRESS RISER DUE TO SHEAR PIN HOLE FOR SHEAR.

K_M = " " " " " " " " BENDING.

A = SHAFT CROSS SECTIONAL AREA

ST = NORMAL STRESS $\leq 51,450$ PSI ALLOWABLE

SS = SHEAR STRESS $\leq 25,725$ PSI ALLOWABLE

SHAFT STRESSES AT THE HUB LOCATION, 0° CLOSED

AT POINT A:

$$\sigma_b = 0$$

$$\tau_T = 2745 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$V = 4,382 \text{ LB FROM ANSYS PROGRAM}$$

$$\tau_V = \frac{4}{3} \frac{V}{A} = \frac{4 \times 4382}{3 \times \frac{\pi}{4} (1.748)^2} = 2,435 \text{ PSI}$$

$$K_T = 0$$

$$K_M = 0$$

$$ST = \frac{\sigma_b}{2} + \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 5,180 \text{ PSI} < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 5,180 \text{ PSI} < 25,725 \text{ PSI}$$

AT POINT B:

$$\sigma_b = 5,433 \text{ PSI FROM ANSYS PROGRAM}$$

$$\tau_T = 2,745 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$\tau_V = 0$$

$$K_T = 0$$

$$K_M = 0$$

$$ST = \frac{\sigma_b}{2} + \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 6,578 \text{ PSI} < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 3,862 \text{ PSI} < 25,725 \text{ PSI}$$

SHAFT STRESSES AT THE PIN CONNECTION, 0° CLOSED

AT POINT A:

$$\sigma_b = 0$$

$$\tau_T = 2,745 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$V = 71.7 \text{ LB FROM ANSYS PROGRAM}$$

$$\tau_V = \frac{4}{3} \frac{V}{A} = \frac{4 \times 71.7}{3 \times \frac{\pi}{4} (1.748)^2} = 40 \text{ PSI}$$

$$K_T = 2.0$$

$$K_M = 2.0$$

$$ST = \frac{K_M \sigma_b}{2} + \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 5,570 \text{ PSI} < 51,450 \text{ P.}$$

$$SS = \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 5,570 \text{ PSI} < 25,725 \text{ PSI}$$

AT POINT B:

$$\sigma_b = 5,288 \text{ PSI FROM ANSYS PROGRAM}$$

$$\tau_T = 2,745 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$\tau_V = 0$$

$$K_T = 2.0$$

$$K_M = 2.0$$




$$ST = \frac{K_M \sigma_b}{2} + \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 12,910 < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 7,623 \text{ PSI} < 25,725 \text{ PSI}$$

JDM
11/29/84

B.L.G.

2. FULLY OPEN (90°)



SHAFT CROSS SECTION

SYMBOL DEFINITION THE SAME AS WHEN BUTTERFLY VALVE IS FULLY CLOSED.

SHAFT STRESSES AT THE HUB LOCATION, 90° OPEN
AT POINT A:

$$\sigma_b = 0$$

$$\tau_T = 10,592 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$V = 3,741 \text{ LB FROM ANSYS PROGRAM}$$

$$\tau_V = \frac{4}{3} \frac{V}{A} = \frac{4 \times 3741}{3 \times \frac{\pi}{4} (1.748)^2} = 2,079 \text{ PSI}$$

$$K_T = 0$$

$$K_m = 0$$

$$ST = \frac{\sigma_b}{2} + \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 12,671 \text{ PSI} < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 12,671 \text{ PSI} < 25,725 \text{ PSI}$$

AT POINT B:

$$\sigma_b = 4,769 \text{ PSI FROM ANSYS PROGRAM}$$

$$\tau_T = 10,592 \text{ FROM "SHAFT" PROGRAM}$$

$$\tau_V = 0$$

$$K_T = 0$$

$$K_m = 0$$

$$ST = \frac{\sigma_b}{2} + \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 13,242 \text{ PSI} < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{\sigma_b}{2}\right)^2 + (\tau_T + \tau_V)^2} = 10,857 \text{ PSI} < 25,725 \text{ PSI}$$

COMBINED CONT.

JDM
11/29/84P6
B.L.G.SHAFT STRESSES AT THE PIN LOCATION, 90° OPEN

AT POINT A:

$$\sigma_b = 0$$

$$\tau_T = 10,592 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$V = 24 \text{ LB FROM ANSYS PROGRAM}$$

$$\tau_V = \frac{4}{3} \frac{V}{A} = \frac{4 \times 24}{3 \times \frac{\pi}{4} (1.748)^2} = 13 \text{ PSI}$$

$$K_T = 2.0$$

$$K_M = 2.0$$

$$ST = \frac{K_M \sigma_b}{2} + \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 21,210 < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 21,210 \text{ PSI} < 25,725 \text{ PSI}$$

AT POINT B:

$$\sigma_b = 9,720 \text{ PSI FROM ANSYS PROGRAM}$$

$$\tau_T = 10,592 \text{ PSI FROM "SHAFT" PROGRAM}$$

$$\tau_V = 0$$

$$K_T = 2.0$$

$$K_M = 2.0$$

$$ST = \frac{K_M \sigma_b}{2} + \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 26,423 \text{ PSI} < 51,450 \text{ PSI}$$

$$SS = \sqrt{\left(\frac{K_M \sigma_b}{2}\right)^2 + (K_T \tau_T + K_T \tau_V)^2} = 21,703 \text{ PSI} < 25,725 \text{ PSI}$$

9510
VOGT 1, FULL CLOSED, 60 PSI 4.5 g SEISMIC, 320°F

DISC/SHAFT GAP MIN = .004"

BEARING/SHAFT GAP MIN = 0.010" (NODE 1)

ACTUATOR HUB/SHAFT GAP MAX = 0.014" (EST, NODE 22)

T_{MAX} @ NODE 13 = 5,433 PSI

@ NODE 8 = 4,871 PSI

ANSYS - ENGINEERING ANALYSIS SYSTEM REVISION 4.1 B FISHER CONTROLS JAN 1, 1983
 SWANSON ANALYSIS SYSTEMS, INC. HOUSTON, PENNSYLVANIA 15342 PHONE (412) 746-3304 TWX 510-690-8655
 10-2140 11/28/84 CP= 35.780

VOU11

***** DISPLACEMENT SOLUTION ***** TIME = 0.00000E+00 LOAD STEP= 1 ITERATION= 10 CUM. ITER.= 6

NODE	LX	LY	ROTZ
1	0.286049E-05	0.100012E-01	-0.521495E-03
2	0.293595E-05	0.908006E-02	-0.536089E-03
3	0.22119E-05	0.636818E-02	-0.706453E-03
4	0.276430E-05	0.523534E-02	-0.806241E-03
5	0.253255E-05	0.416788E-02	-0.905779E-03
6	0.186699E-05	0.289546E-02	-0.110336E-02
7	0.922589E-05	0.000000E+00	-0.130178E-02
8	0.398209E-06	-0.117565E-02	-0.126483E-02
9	-0.376561E-06	-0.35672E-02	-0.849544E-03
10	0.000000E+00	-0.517662E-02	-0.176443E-04
11	-0.353072E-06	-0.344889E-02	0.847996E-03
12	-0.811950E-06	-0.249199E-02	0.106677E-02
13	-0.155373E-05	-0.124208E-02	0.130380E-02
14	-0.231462E-05	0.000000E+00	0.136520E-02
15	-0.376568E-05	0.225249E-02	0.121052E-02
16	-0.508065E-05	0.457767E-02	0.105097E-02
17	-0.571871E-05	0.583732E-02	0.965966E-03
18	-0.635271E-05	0.721699E-02	0.875745E-03
19	-0.716602E-05	0.920391E-02	0.756024E-03
20	-0.776257E-05	0.109428E-01	0.670368E-03
21	-0.828591E-05	0.125042E-01	0.619858E-03
22	-0.874273E-05	0.140007E-01	0.602575E-03
101	0.000000E+00	0.000000E+00	0.000000E+00
103	0.000000E+00	0.000000E+00	0.000000E+00
105	0.000000E+00	0.000000E+00	0.000000E+00
109	0.000000E+00	0.000000E+00	0.000000E+00
109	0.000000E+00	-0.117565E-02	0.000000E+00
110	0.000000E+00	-0.117565E-02	0.000000E+00
111	0.000000E+00	-0.117565E-02	0.000000E+00
115	0.000000E+00	0.000000E+00	0.000000E+00
116	0.000000E+00	0.000000E+00	0.000000E+00
113	0.000000E+00	0.000000E+00	0.000000E+00
122	0.000000E+00	0.000000E+00	0.000000E+00

MAXIMUMS

NODE	VALUE	22	14
109	-0.874273E-05	0.140007E-01	0.136520E-02

ANSYS - ENGINEERING ANALYSIS SYSTEM REVISION 4.1 B FISHER CONTROLS JAN 1, 1983
SWANSON ANALYSIS SYSTEMS, INC. HOUSTON, PENNSYLVANIA 15342 PHONE (412)746-3304 TWX 510-690-8655

VOGTT 10.2144 11/28/84 CP= 36.570

***** ELEMENT STRESSES ***** TIME = 0.000000E+00 LOAD STEP= 1 ITERATION= 10 CUM. ITER.= 6

EL= 1 NODES= 1 2 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 FORCE SDIR MOM SBEND SDPB SDMB
 I 11.827 4.9278 0.12506E-11 0.23917E-11 4.9278 4.9278
 J 11.827 4.9278 -208.09 -397.96 -393.03 402.89
 TENTH POINT MOMENTS
 0.125E-11 -20.8 -41.0 -62.4 -83.2 -104. -125. -146. -166. -187. -208.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 1 11.8893 118.900 0.125056E-11
 2 -11.8893 -118.900 208.086

EL= 2 NODES= 2 3 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 FORCE SDIR MOM SBEND SDPB SDMB
 I 11.817 4.9239 -208.09 -397.96 -393.04 402.88
 J 11.817 4.9239 -740.79 -1416.7 -1411.8 1421.7
 TENTH POINT MOMENTS
 -238. -261. -315. -366. -421. -474. -528. -581. -634. -688. -741.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 2 11.8893 118.900
 3 -11.8893 -118.900 740.792

EL= 3 NODES= 3 4 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 FORCE SDIR MOM SBEND SDPB SDMB
 I 11.900 4.9155 -740.79 -1416.7 -1411.8 1421.7
 J 11.900 4.9165 -919.16 -1757.9 -1752.9 1762.8
 TENTH POINT MOMENTS
 -741. -759. -776. -794. -812. -830. -848. -866. -883. -901. -919.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 3 11.8893 118.900
 4 -11.8893 -118.900 919.155

EL= 4 NODES= 4 5 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 FORCE SDIR MOM SBEND SDPB SDMB
 I 11.728 4.9115 -919.16 -1757.9 -1752.9 1762.8
 J 11.728 4.9115 -1067.8 -2042.1 -2037.2 2047.0
 TENTH POINT MOMENTS
 -919. -936. -949. -964. -979. -993. -1010E+04 -0.102E+04 -0.104E+04 -0.105E+04 -0.107E+04
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 4 11.8893 118.900
 5 -11.8893 -118.900 1067.79

EL= 5 NODES= 5 6 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 FORCE SDIR MOM SBEND SDPB SDMB
 I 11.770 4.9043 -1067.8 -2042.1 -2037.2 2047.0
 J 11.770 4.9043 -1313.9 -2512.9 -2508.0 2517.8
 TENTH POINT MOMENTS
 -1070E+04 -0.109E+04 -0.112E+04 -0.114E+04 -0.117E+04 -0.119E+04 -0.122E+04 -0.124E+04 -0.126E+04 -0.129E+04 -0.131E+04
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 5 11.8893 118.900
 6 -11.8893 -118.900 1313.94

EL= 6 NODES= 6 7 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 FORCE SDIR MOM SBEND SDPB SDMB
 I 11.747 4.8944 -1313.9 -2512.9 -2508.0 2517.8
 J 11.747 4.8944 -1521.6 -2910.0 -2905.1 2914.8

TENTH POINT MOMENTS

-0.131E+04 -0.133E+04 -0.136E+04 -0.138E+04 -0.140E+04 -0.142E+04 -0.144E+04 -0.146E+04 -0.148E+04 -0.150E+04 -0.152E+04
MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE 6 11.8893 113.900 -1313.94
STATIC FORCES ON NODE 7 -11.8893 -118.900 1521.57

EL= 7 NODES= 7 8 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDMB 2-D BEAM 3
I 17.808 7.4199 -1521.6 -2910.0 -2902.5 2917.4
J 17.808 7.4199 2547.0 4871.1 4878.6 -4863.7

TENTH POINT MOMENTS

-0.152E+04 -0.111E+04 -708. -301. 106. 513. 920. 0.133E+04 0.173E+04 0.214E+04 0.255E+04
MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE 7 11.8893 -4525.71 -1521.57
STATIC FORCES ON NODE 8 -11.8893 4525.71 -2547.03

EL= 8 NODES= 8 9 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDMB 2-D BEAM 3
I 11.865 4.9428 2547.0 4871.1 4876.1 -4866.2
J 11.865 4.9428 2495.4 4772.4 4777.4 -4767.5

TENTH POINT MOMENTS

0.255E+04 0.254E+04 0.254E+04 0.253E+04 0.253E+04 0.252E+04 0.252E+04 0.251E+04 0.251E+04 0.250E+04 0.250E+04
MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 8 11.8893 25.0979 2547.03
STATIC FORCES ON NODE 9 -11.8893 -25.0979 -2495.43

EL= 9 NODES= 9 10 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDMB 2-D BEAM 3
I 11.879 4.9494 2495.4 4772.4 4777.4 -4767.5
J 11.879 4.9494 2388.7 4568.4 4573.4 -4563.5

TENTH POINT MOMENTS

0.250E+04 0.248E+04 0.247E+04 0.246E+04 0.245E+04 0.244E+04 0.243E+04 0.242E+04 0.241E+04 0.240E+04 0.239E+04
MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 9 11.8893 25.0979 2495.43
STATIC FORCES ON NODE 10 -11.8893 -25.0979 -2388.74

EL= 10 NODES= 10 11 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDMB 2-D BEAM 3
I -0.29153E-01 -0.12147E-01 2388.7 4568.4 4568.4 -4568.4
J -0.29153E-01 -0.12147E-01 2693.5 5151.3 5151.3 -5151.3

TENTH POINT MOMENTS

0.239E+04 0.242E+04 0.245E+04 0.248E+04 0.251E+04 0.254E+04 0.257E+04 0.260E+04 0.263E+04 0.266E+04 0.269E+04
MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE 10 0.382749E-13 -71.7135 2388.74
STATIC FORCES ON NODE 11 -0.382749E-13 71.7135 -2693.53

EL= 11 NODES= 11 12 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDMB 2-D BEAM 3
I -0.68623E-01 -0.23593E-01 2693.5 5151.3 5151.3 -5151.3
J -0.68623E-01 -0.28593E-01 2765.2 5288.4 5288.4 -5288.5

TENTH POINT MOMENTS

0.269E+04 0.270E+04 0.271E+04 0.272E+04 0.272E+04 0.273E+04 0.274E+04 0.274E+04 0.275E+04 0.276E+04 0.277E+04
MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE 11 0.426326E-13 -71.7135 2693.53
STATIC FORCES ON NODE 12 -0.426326E-13 71.7135 -2765.24

EL= 12 NODES= 12 13 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDMB 2-D BEAM 3
I -0.84962E-01 -0.35401E-01 2765.2 5288.4 5288.4 -5288.5
J -0.84962E-01 -0.35401E-01 2340.9 5433.1 5433.1 -5433.2

TENTH POINT MOMENTS

0.277E+04 0.277E+04 0.278E+04 0.279E+04 0.280E+04 0.280E+04 0.281E+04 0.282E+04 0.283E+04 0.283E+04 0.284E+04													
MAXIMUM MOMENT IS AT END J													
STATIC FORCES ON NODE 12 0.337508E-13 -71.7135 2765.24													
STATIC FORCES ON NODE 13 -0.337508E-13 71.7135 -2840.90													
EL=	13	NODES=	13	14	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END	FORCE		SDIR		MOM		SBEND		SDPB		SDMB		
I	5.9353	2.4814	2840.9	5433.1	5435.6	-5430.7							
J	5.9353	2.4814	-1164.5	-2227.1	-2224.6	2229.6							
TENTH POINT MOMENTS													
0.264E+04 0.244E+04 0.204E+04 0.164E+04 0.124E+04 838. 438. 37.1 -363. -764. -0.116E+04													
MAXIMUM MOMENT IS AT END I													
STATIC FORCES ON NODE 13 0.319744E-13 4332.29 2840.90													
STATIC FORCES ON NODE 14 -0.319744E-13 -4382.29 1164.51													
EL=	14	NODES=	14	15	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END	FORCE		SDIR		MOM		SBEND		SDPB		SDMB		
I	-0.91573E-01	-0.33197E-01	-1164.5	-2227.1	-2227.1	2227.1							
J	-0.91573E-01	-0.33197E-01	-1039.7	-1988.5	-1988.5	1988.4							
TENTH POINT MOMENTS													
-0.116E+04 -0.115E+04 -0.114E+04 -0.113E+04 -0.111E+04 -0.110E+04 -0.109E+04 -0.108E+04 -0.106E+04 -0.105E+04 -0.104E+04													
MAXIMUM MOMENT IS AT END I													
STATIC FORCES ON NODE 14 0.337508E-13 -71.2631 -1164.51													
STATIC FORCES ON NODE 15 -0.337508E-13 71.2631 1039.73													
EL=	15	NODES=	15	16	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END	FORCE		SDIR		MOM		SBEND		SDPB		SDMB		
I	-0.60436E-01	-0.33515E-01	-1039.7	-1988.5	-1988.5	1988.4							
J	-0.60436E-01	-0.33515E-01	-892.93	-1707.7	-1707.7	1707.7							
TENTH POINT MOMENTS													
-0.104E+04 -0.103E+04 -0.101E+04 -996. -931. -966. -952. -937. -922. -908. -893.													
MAXIMUM MOMENT IS AT END I													
STATIC FORCES ON NODE 15 0.328626E-13 -71.2631 -1039.73													
STATIC FORCES ON NODE 16 -0.328626E-13 71.2631 892.926													
EL=	16	NODES=	16	17	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END	FORCE		SDIR		MOM		SBEND		SDPB		SDMB		
I	-0.71815E-01	-0.29922E-01	-892.93	-1707.7	-1707.7	1707.7							
J	-0.71815E-01	-0.29922E-01	-803.85	-1537.3	-1537.4	1537.3							
TENTH POINT MOMENTS													
-893. -884. -875. -866. -857. -848. -839. -831. -822. -813. -804.													
MAXIMUM MOMENT IS AT END I													
STATIC FORCES ON NODE 16 0.355271E-13 -71.2631 -892.926													
STATIC FORCES ON NODE 17 -0.234217E-13 71.2631 803.848													
EL=	17	NODES=	17	18	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END	FORCE		SDIR		MOM		SBEND		SDPB		SDMB		
I	-0.65547E-01	-0.27311E-01	-803.85	-1537.3	-1537.4	1537.3							
J	-0.65547E-01	-0.27311E-01	-696.95	-1332.9	-1332.9	1332.9							
TENTH POINT MOMENTS													
-804. -793. -782. -772. -761. -750. -740. -729. -718. -708. -697.													
MAXIMUM MOMENT IS AT END I													
STATIC FORCES ON NODE 17 0.328626E-13 -71.2631 -803.848													
STATIC FORCES ON NODE 18 -0.328626E-13 71.2631 696.953													
EL=	18	NODES=	18	19	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END	FORCE		SDIR		MOM		SBEND		SDPB		SDMB		
I	-0.57939E-01	-0.24141E-01	-696.95	-1332.9	-1332.9	1332.9							
J	-0.57939E-01	-0.24141E-01	-522.36	-999.00	-999.02	998.97							
TENTH POINT MOMENTS													
-697. -679. -662. -645. -627. -610. -592. -575. -557. -540. -522.													

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 18 0.777156E-15 -71.2631 -696.953
 STATIC FORCES ON NODE 19 -0.777156E-15 71.2631 522.358

EL= 19 NODES= 19 20 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3

END FORCE SDIR MOM SBEND SDPB SDMB
 I -0.50640E-01 -0.21100E-01 -522.36 -999.00 998.98
 J -0.50640E-01 -0.21100E-01 -348.48 -666.45 666.43

TENTH POINT MOMENTS
 -522. -505. -488. -470. -453. -435. -418. -401. -383. -366. -348.

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 19 0.732747E-14 -71.2631 -522.358
 STATIC FORCES ON NODE 20 -0.732747E-14 71.2631 348.476

EL= 20 NODES= 20 21 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3

END FORCE SDIR MOM SBEND SDPB SDMB
 I -0.45790E-01 -0.19079E-01 -348.48 -666.45 666.43
 J -0.45790E-01 -0.19079E-01 -175.31 -335.27 335.25

TENTH POINT MOMENTS
 -348. -331. -314. -297. -279. -262. -245. -227. -210. -193. -175.

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 20 0.158762E-13 -71.2631 -348.476
 STATIC FORCES ON NODE 21 -0.158762E-13 71.2631 175.307

EL= 21 NODES= 21 22 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3

END FORCE SDIR MOM SBEND SDPB SDMB
 I -0.43352E-01 -0.18063E-01 -175.31 -335.27 335.25
 J -0.43352E-01 -0.18063E-01 0.54570E-11 0.10436E-10 -0.18063E-01 -0.18063E-01

TENTH POINT MOMENTS
 -175. -158. -140. -123. -105. -87.7 -70.1 -52.6 -35.1 -17.5 0.546E-11

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 21 0.455191E-14 -71.2631 -175.307
 STATIC FORCES ON NODE 22 -0.455191E-14 71.2631 -0.545697E-11

EL= 23 NODES= 1 101 USEP=-0.000001 USLIDE=-0.000003 FN=-118.90 FS=-11.890 STAT=-2 OLDST=-2 2-D GAP 12

STATIC FORCES ON NODE 1 -11.8893 -118.900
 STATIC FORCES ON NODE 101 11.8893 118.900

EL= 24 NODES= 6 106 USEP= 0.007905 USLIDE=-0.000002 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12

STATIC FORCES ON NODE 6 0.000000E+00 0.000000E+00
 STATIC FORCES ON NODE 106 0.000000E+00 0.000000E+00

EL= 25 NODES= 15 115 USEP= 0.007748 USLIDE= 0.000004 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12

STATIC FORCES ON NODE 15 0.000000E+00 0.000000E+00
 STATIC FORCES ON NODE 115 0.000000E+00 0.000000E+00

EL= 26 NODES= 3 103 USEP= 0.034632 USLIDE=-0.000003 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12

STATIC FORCES ON NODE 3 0.000000E+00 0.000000E+00
 STATIC FORCES ON NODE 103 0.000000E+00 0.000000E+00

EL= 27 NODES= 18 118 USEP= 0.033783 USLIDE= 0.000006 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12

STATIC FORCES ON NODE 18 0.000000E+00 0.000000E+00
 STATIC FORCES ON NODE 118 0.000000E+00 0.000000E+00

EL= 28 NODES= 5 105 USEP= 0.039832 USLIDE=-0.000003 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12

STATIC FORCES ON NODE 5 0.000000E+00 0.000000E+00
 STATIC FORCES ON NODE 105 0.000000E+00 0.000000E+00

EL= 29 NODES= 16 116 USEP= 0.039422 USLIDE= 0.000005 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12

STATIC FORCES ON NODE 16 0.000000E+00 0.000000E+00
 STATIC FORCES ON NODE 116 0.000000E+00 0.000000E+00

9510-AKFC03-5151-2-283

EL= 31	NODES= 110	USEP=-0.000001	USLIDE= 0.000000	FN= -96.811	FS= 0.00000E+00	STAT= 1	OLDST= 1	2-D GAP	12
STATIC FORCES ON NODE	110	0.00000E+00	-96.8114						
STATIC FORCES ON NODE	10	0.00000E+00	96.8114						
EL= 32	NODES= 109	USEP= 0.007829	USLIDE= 0.000000	FN= 0.00000E+00	FS= 0.00000E+00	STAT= 3	OLDST= 3	2-D GAP	12
STATIC FORCES ON NODE	109	0.00000E+00	0.00000E+00						
STATIC FORCES ON NODE	9	0.00000E+00	0.00000E+00						
EL= 33	NODES= 111	USEP= 0.007727	USLIDE= 0.000000	FN= 0.00000E+00	FS= 0.00000E+00	STAT= 3	OLDST= 3	2-D GAP	12
STATIC FORCES ON NODE	111	0.00000E+00	0.00000E+00						
STATIC FORCES ON NODE	11	0.00000E+00	0.00000E+00						
EL= 35	NODES= 22	USEP=-0.000001	USLIDE= 0.000009	FN= -71.263	FS= 0.00000E+00	STAT= 2	OLDST= -2	2-D GAP	12
STATIC FORCES ON NODE	22	0.00000E+00	-71.2631						
STATIC FORCES ON NODE	122	0.00000E+00	71.2631						

SWANSON ENGINEERING SYSTEMS, INC. JAN 1, 1983

ANYS - ENGINEERING ANALYSIS SYSTEM REVISION 4.1 B FISHER CONTROLS JAN 1, 1983
SWANSON ANALYSIS SYSTEMS, INC. HOUSTON, PENNSYLVANIA 15342 PHONE (412)746-3304 TWX 510-690-8655

10.2152 11/28/84 CP= 39.120

***** REACTION FORCES ***** TIME = 0.00000E+00 LOAD STEP= 1 ITERATION= 10 CUM. ITER.= 6

NOTE - REACTION FORCES ARE IN THE NODAL COORDINATE SYSTEM

NODE	FX	FY	MZ
7		6644.61	
10	11.8893	4453.55	
14		-118.900	
101	-11.8893	0.000000E+00	0.000000E+00
103	0.000000E+00	0.000000E+00	0.000000E+00
105	0.000000E+00	0.000000E+00	0.000000E+00
106	0.000000E+00	0.000000E+00	0.000000E+00
115	0.000000E+00	0.000000E+00	0.000000E+00
116	0.000000E+00	0.000000E+00	0.000000E+00
118	0.000000E+00	0.000000E+00	0.000000E+00
122	0.000000E+00	-71.2631	0.000000E+00
TOTAL	-0.466294E-13	3508.00	0.000000E+00

STATUS CHANGED FOR 0 BILINEAR ELEM THIS ITER

DISPLACEMENT INCREMENT = 0.27641E-05 AT NODE 1 CRITERION = 0.10000E-02

*** LOAD STEP 1 ITER 10 COMPLETED. TIME= 0.000000E+00 TIME INC= 0.000000E+00 NEW TRIANG MATRIX CUM. ITER.= 6

END OF INPUT ENCOUNTERED ON FILE27

***** INPUT FILE SWITCHED FROM FILE27 TO FILE 5

SAWSON ANALYSIS SYSTEMS, INC. HOUSTON, PENNSYLVANIA 15342
FISHER CONTROLS JAN 1, 1983
PHONE (412)746-3304 TWX 510-690-8655

VOGT1 10.2156 11/28/84 CP= 39.620

***** ANSYS RUN TIME ESTIMATOR *****

***** ANSYS RUN TIME ESTIMATOR *****

COMPUTER = VAX 11/780 NUMBER OF MASTER DOF = 0
ANALYSIS TYPE = 0 RMS WAVE FRONT = 23
NUMBER OF NODES = 21 TOTAL NO. OF ITERATIONS = 1
MAX. DOF PER NODE = 3 STIFF. MATRIX SAVE KEY = 0
NUMBER OF MATRICES = 1 ELEM. MATRIX SAVE KEY = 0
NUMBER OF STRESS SOLUTIONS = 1 ROTATED NODE FRACTION = 0.000

STIF NUMBER FORM. TIME STRESS TIME NAME
3 21 0.053 0.067 ELASTIC BEAM, 2-D
12 11 0.015 0.040 INTERFACE ELEM. 2-D

ANALYSIS PHASE	FIRST ITERATION	SUBSEQUENT ITERATIONS	TOTAL
ELEMENT FORMULATION	1.06	1.06	1.06
WAVE FRONT SOLUTION	0.42	0.42	0.42
BACK SUBSTITUTION	0.12	0.12	0.12
ELEMENT STRESSES	1.54	1.54	1.54
TOTAL TIME (SEC)	3.14	3.14	3.14

***** ROUTINE COMPLETED ***** CP = 39.730

END OF INPUT ENCOUNTERED ON FILE 5

***** RUN COMPLETED ***** CP= 39.8200 TIME= 10.2157

VOGT 1

FULL OPEN (90°), 50 PSI @ 4.5g SEISMIC, 320 °F

DISC / SHAFT GAP MIN = 0.004"

BEARING / SHAFT GAP MIN = 0.010"

ACTIVATOR HUB / SHAFT GAP MAX PLUS = 0.014" (ESTIMATED)

σ_{MAX} AT NODE 13 = 4,769 PSI

τ AT NODE 8 = 4,187 PSI

ANSYS -- ENGINEERING ANALYSIS SYSTEM REVISION 4.1 B FISHER CONTROLS JAN 1, 1983
SWANSON ANALYSIS SYSTEMS, INC. HOUSTON, PENNSYLVANIA 15342 PHONE (412)746-3304 TWX 510-690-8655

VOGT1

11-1286 11/28/84 CP= 31.970

***** DISPLACEMENT SOLUTION ***** TIME = 0.00000E+00 LOAD STEP= 1 ITERATION= 10 CUM. ITER.= 5

NODE	UX	UY	ROTZ
1	0.316473E-05	0.100010E-01	-0.573473E-03
2	0.312565E-05	0.899056E-02	-0.585150E-03
3	0.285281E-05	0.612090E-02	-0.721456E-03
4	0.263378E-05	0.498098E-02	-0.801294E-03
5	0.237461E-05	0.393083E-02	-0.880932E-03
6	0.172385E-05	0.194932E-02	-0.103902E-02
7	0.866337E-06	0.000000E+00	-0.119776E-02
8	0.431230E-06	-0.107944E-02	-0.116273E-02
9	-0.258727E-05	-0.309562E-02	-0.798101E-03
10	0.000000E+00	-0.484230E-02	-0.180440E-04
11	-0.318111E-06	-0.319950E-02	0.726952E-03
12	-0.719143E-06	-0.230428E-02	0.993793E-03
13	-0.152610E-05	-0.114537E-02	0.120356E-02
14	-0.200836E-05	0.000000E+00	0.126098E-02
15	-0.326739E-05	0.209828E-02	0.113800E-02
16	-0.445511E-05	0.430860E-02	0.101115E-02
17	-0.505247E-05	0.552375E-02	0.943576E-03
18	-0.507044E-05	0.688986E-02	0.871850E-03
19	-0.649967E-05	0.890373E-02	0.776669E-03
20	-0.717053E-05	0.107107E-01	0.708969E-03
21	-0.77451E-05	0.123788E-01	0.668415E-03
22	-0.828049E-05	0.140006E-01	0.654675E-03
101	0.000000E+00	0.000000E+00	0.000000E+00
103	0.000000E+00	0.000000E+00	0.000000E+00
105	0.000000E+00	0.000000E+00	0.000000E+00
106	0.000000E+00	0.000000E+00	0.000000E+00
109	0.000000E+00	-0.107944E-02	0.000000E+00
110	0.000000E+00	-0.107944E-02	0.000000E+00
111	0.000000E+00	0.000000E+00	0.000000E+00
115	0.000000E+00	0.000000E+00	0.000000E+00
116	0.000000E+00	0.000000E+00	0.000000E+00
118	0.000000E+00	0.000000E+00	0.000000E+00
122	0.000000E+00	0.000000E+00	0.000000E+00

MAXIMUMS

NODE	22	22	14
VALUE	-0.828049E-05	0.140006E-01	0.126098E-02

VOGT1

11.1291 11/28/84 CP= 32.800

***** ELEMENT STRESSES ***** TIME = 0.000000E+00 LOAD STEP= 1 ITERATION= 10 CUM. ITER.= 5

EL= 1 NODES= 1 2 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 END FORCE SDIR MOM SBEND SDPB SDMB
 I 9.4572 3.9405 -0.22737E-12 -0.43485E-12 3.9405 3.9405
 J 9.4572 3.9405 -166.49 -318.40 -314.46 322.34

TENTH POINT MOMENTS
 -0.227E-12 -16.6 -33.3 -49.9 -66.6 -83.2 -99.9 -117. -133. -150. -166.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 1 9.51215 95.1296 -0.227374E-12
 STATIC FORCES ON NODE 2 -9.51215 -95.1296 166.486

EL= 2 NODES= 2 3 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 END FORCE SDIR MOM SBEND SDPB SDMB
 I 9.4512 3.9330 -166.49 -318.40 -314.46 322.34
 J 9.4512 3.9330 -592.69 -1133.5 -1129.6 1137.4

TENTH POINT MOMENTS
 -166. -209. -252. -294. -337. -380. -422. -465. -507. -550. -593.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 2 9.51215 95.1296 -166.486
 STATIC FORCES ON NODE 3 -9.51215 -95.1296 592.694

EL= 3 NODES= 3 4 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 END FORCE SDIR MOM SBEND SDPB SDMB
 I 9.4399 3.9333 -592.69 -1133.5 -1129.6 1137.4
 J 9.4399 3.9333 -735.40 -1406.4 -1402.5 1410.4

TENTH POINT MOMENTS
 -593. -507. -621. -636. -650. -664. -678. -693. -707. -721. -735.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 3 9.51215 95.1296 -592.694
 STATIC FORCES ON NODE 4 -9.51215 -95.1296 735.400

EL= 4 NODES= 4 5 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 END FORCE SDIR MOM SBEND SDPB SDMB
 I 9.4322 3.9301 -735.40 -1406.4 -1402.5 1410.4
 J 9.4322 3.9301 -854.32 -1633.9 -1629.9 1637.8

TENTH POINT MOMENTS
 -735. -747. -759. -771. -783. -795. -807. -819. -831. -842. -854.
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 4 9.51215 95.1296 -735.400
 STATIC FORCES ON NODE 5 -9.51215 -95.1296 854.322

EL= 5 NODES= 5 6 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 END FORCE SDIR MOM SBEND SDPB SDMB
 I 9.4211 3.9255 -854.32 -1633.9 -1629.9 1637.8
 J 9.4211 3.9255 -1051.3 -2010.5 -2006.6 2014.4

TENTH POINT MOMENTS
 -854. -874. -894. -913. -933. -953. -972. -992. -0.101E+04 -0.103E+04 -0.105E+04
 MAXIMUM MOMENT IS AT END J
 STATIC FORCES ON NODE 5 9.51215 95.1296 -854.322
 STATIC FORCES ON NODE 6 -9.51215 -95.1296 1051.26

EL= 6 NODES= 6 7 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00 2-D BEAM 3
 END FORCE SDIR MOM SBEND SDPB SDMB
 I 9.4059 3.9191 -1051.3 -2010.5 -2006.6 2014.4
 J 9.4059 3.9191 -1217.4 -2328.2 -2328.2 2332.1

9110-AXSND03-5151-2-1289

TENTH POINT MOMENTS

-0.105E+04 -0.107E+04 -0.108E+04 -0.110E+04 -0.112E+04 -0.113E+04 -0.115E+04 -0.117E+04 -0.118E+04 -0.120E+04 -0.122E+04

MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE	6	9.51215	95.1296	-1051.26
STATIC FORCES ON NODE	7	-9.51215	-95.1296	1217.37

EL=	7	NODES=	7	8	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END		FORCE		SDIR		MOM		SBEND		SDPB		SDMB	
I		14.062		5.3591		-1217.4		-2328.2		-2322.3		2334.1	
J		14.062		5.3591		2189.0		4186.5		4192.3		-4180.6	

TENTH POINT MOMENTS

-0.122E+04 -877. -536. -195. 145. 486. 826. 0.117E+04 0.151E+04 0.185E+04 0.219E+04

MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE	7	9.51215	-3789.13	-1217.37
STATIC FORCES ON NODE	8	-9.51215	3789.13	-2189.05

EL=	8	NODES=	8	9	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END		FORCE		SDIR		MOM		SBEND		SDPB		SDMB	
I		9.5358		3.9733		2189.0		4186.5		4190.5		-4182.5	
J		9.5358		3.9733		2238.6		4281.3		4285.3		-4277.3	

TENTH POINT MOMENTS

0.219E+04 0.219E+04 0.220E+04 0.220E+04 0.221E+04 0.221E+04 0.222E+04 0.222E+04 0.223E+04 0.223E+04 0.224E+04

MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE	8	9.51215	-24.1344	2189.05
STATIC FORCES ON NODE	9	-9.51215	24.1344	-2238.62

EL=	9	NODES=	9	10	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END		FORCE		SDIR		MOM		SBEND		SDPB		SDMB	
I		9.5221		3.9675		2238.6		4281.3		4285.3		-4277.3	
J		9.5221		3.9675		2341.2		4477.4		4481.4		-4473.5	

TENTH POINT MOMENTS

0.224E+04 0.225E+04 0.226E+04 0.227E+04 0.228E+04 0.229E+04 0.230E+04 0.231E+04 0.232E+04 0.233E+04 0.234E+04

MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE	9	9.51215	-24.1344	2238.62
STATIC FORCES ON NODE	10	-9.51215	24.1344	-2341.18

EL=	10	NODES=	10	11	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END		FORCE		SDIR		MOM		SBEND		SDPB		SDMB	
I		-0.93289E-02		-0.38870E-02		2341.2		4477.4		4477.4		-4477.4	
J		-0.93289E-02		-0.38870E-02		2443.7		4673.6		4673.6		-4673.6	

TENTH POINT MOMENTS

0.234E+04 0.235E+04 0.236E+04 0.237E+04 0.238E+04 0.239E+04 0.240E+04 0.241E+04 0.242E+04 0.243E+04 0.244E+04

MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE	10	0.115186E-13	-24.1344	2341.18
STATIC FORCES ON NODE	11	-0.115186E-13	24.1344	-2443.75

EL=	11	NODES=	11	12	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END		FORCE		SDIR		MOM		SBEND		SDPB		SDMB	
I		-0.21605E-01		-0.90022E-02		2443.7		4673.6		4673.6		-4673.6	
J		-0.21605E-01		-0.90022E-02		2467.9		4719.8		4719.7		-4719.8	

TENTH POINT MOMENTS

0.244E+04 0.245E+04 0.245E+04 0.245E+04 0.245E+04 0.246E+04 0.246E+04 0.246E+04 0.246E+04 0.247E+04 0.247E+04

MAXIMUM MOMENT IS AT END J

STATIC FORCES ON NODE	11	0.710543E-14	-24.1344	2443.75
STATIC FORCES ON NODE	12	-0.177636E-13	24.1344	-2467.88

EL=	12	NODES=	12	13	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM	3
END		FORCE		SDIR		MOM		SBEND		SDPB		SDMB	
I		-0.26511E-01		-0.11046E-01		2467.9		4719.8		4719.7		-4719.8	
J		-0.26511E-01		-0.11046E-01		2493.3		4768.5		4768.4		-4768.5	

TENTH POINT MOMENTS

0010-AXI003-5151-2 201

0.247E+04	0.247E+04	0.247E+04	0.248E+04	0.248E+04	0.248E+04	0.248E+04	0.248E+04	0.249E+04	0.249E+04	0.249E+04	0.249E+04	
MAXIMUM MOMENT IS AT END J												
STATIC FORCES ON NODE		12	0.106581E-13	-24.1344		2467.88						
STATIC FORCES ON NODE		13	-0.355271E-14	24.1344		-2493.34						
EL=	13	NODES=	13	14	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM 3
END	FORCE		SDIR		MOM		SBEND		SDPB	SDMB		
I	4.6378	1.9533	2493.3	4768.5	4770.4	-4766.5						
J	4.6378	1.9533	-925.80	-1770.6	-1768.6	1772.5						
TENTH POINT MOMENTS												
0.249E+04	0.215E+04	0.181E+04	0.147E+04	0.113E+04	784.	442.	99.9	-242.	-584.	-926.		
MAXIMUM MOMENT IS AT END I												
STATIC FORCES ON NODE		13	0.142109E-13	3740.87		2493.34						
STATIC FORCES ON NODE		14	-0.142109E-13	-3740.87		925.804						
EL=	14	NODES=	14	15	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM 3
END	FORCE		SDIR		MOM		SBEND		SDPB	SDMB		
I	-0.67892E-01	-0.28288E-01	-925.80	-1770.6	-1770.6	1770.5						
J	-0.67892E-01	-0.28288E-01	-826.60	-1580.9	-1580.9	1580.8						
TENTH POINT MOMENTS												
-926.	-916.	-906.	-896.	-886.	-876.	-866.	-856.	-846.	-837.	-827.		
MAXIMUM MOMENT IS AT END I												
STATIC FORCES ON NODE		14	0.150990E-13	-56.6553		-925.804						
STATIC FORCES ON NODE		15	-0.150990E-13	56.6553		826.601						
EL=	15	NODES=	15	16	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM 3
END	FORCE		SDIR		MOM		SBEND		SDPB	SDMB		
I	-0.60790E-01	-0.23329E-01	-826.60	-1580.9	-1580.9	1580.8						
J	-0.60790E-01	-0.23329E-01	-709.89	-1357.6	-1357.7	1357.6						
TENTH POINT MOMENTS												
-827.	-815.	-803.	-792.	-780.	-768.	-757.	-745.	-733.	-722.	-710.		
MAXIMUM MOMENT IS AT END I												
STATIC FORCES ON NODE		15	0.102141E-13	-56.6553		-826.601						
STATIC FORCES ON NODE		16	-0.102141E-13	56.6553		709.891						
EL=	16	NODES=	16	17	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM 3
END	FORCE		SDIR		MOM		SBEND		SDPB	SDMB		
I	-0.55339E-01	-0.23058E-01	-709.89	-1357.6	-1357.7	1357.6						
J	-0.55339E-01	-0.23058E-01	-639.07	-1222.2	-1222.2	1222.2						
TENTH POINT MOMENTS												
-710.	-703.	-696.	-689.	-682.	-674.	-667.	-660.	-653.	-646.	-639.		
MAXIMUM MOMENT IS AT END I												
STATIC FORCES ON NODE		16	0.799361E-14	-56.6553		-709.891						
STATIC FORCES ON NODE		17	0.621725E-14	56.6553		639.072						
EL=	17	NODES=	17	18	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM 3
END	FORCE		SDIR		MOM		SBEND		SDPB	SDMB		
I	-0.51379E-01	-0.21408E-01	-639.07	-1222.2	-1222.2	1222.2						
J	-0.51379E-01	-0.21408E-01	-554.09	-1059.7	-1059.7	1059.7						
TENTH POINT MOMENTS												
-639.	-631.	-622.	-614.	-605.	-597.	-588.	-580.	-571.	-563.	-554.		
MAXIMUM MOMENT IS AT END I												
STATIC FORCES ON NODE		17	0.888178E-14	-56.6553		-639.072						
STATIC FORCES ON NODE		18	-0.888178E-14	56.6553		554.089						
EL=	18	NODES=	18	19	MAT=	1	TTOP,TBOT=	0.0	0.0	LOAD=	0.00000E+00	2-D BEAM 3
END	FORCE		SDIR		MOM		SBEND		SDPB	SDMB		
I	-0.46570E-01	-0.19404E-01	-554.09	-1059.7	-1059.7	1059.7						
J	-0.46570E-01	-0.19404E-01	-415.28	-794.22	-794.24	794.20						
TENTH POINT MOMENTS												
-55	-540.	-526.	-512.	-499.	-485.	-471.	-457.	-443.	-429.	-415.		

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 18 -0.119904E-13 -56.6553 -554.089
STATIC FORCES ON NODE 19 0.843769E-14 56.6553 415.284

EL= 19 NODES= 19 20 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDBM
I -0.41957E-01 -0.17482E-01 -415.28 -794.22 -794.22 794.20
J -0.41957E-01 -0.17482E-01 -277.04 -529.84 -529.86 529.82

2-D BEAM 3

TENTH POINT MOMENTS
-415. -401. -388. -374. -360. -346. -332. -319. -305. -291. -277.

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 19 0.333067E-14 -56.6553 -415.284
STATIC FORCES ON NODE 20 -0.333067E-14 56.6553 277.045

EL= 20 NODES= 20 21 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDBM
I -0.38892E-01 -0.15205E-01 -277.04 -529.84 -529.86 529.82
J -0.38892E-01 -0.15205E-01 -139.37 -266.55 -266.56 266.53

2-D BEAM 3

TENTH POINT MOMENTS
-277. -263. -250. -236. -222. -208. -194. -181. -167. -153. -139.

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 20 -0.277556E-14 -56.6553 -277.045
STATIC FORCES ON NODE 21 0.277556E-14 56.6553 139.372

EL= 21 NODES= 21 22 MAT= 1 TTOP,TBOT= 0.0 0.0 LOAD= 0.00000E+00
END FORCE SDIR MOM SBEND SDPB SDBM
I -0.37350E-01 -0.15563E-01 -139.37 -266.55 -266.56 266.53
J -0.37350E-01 -0.15563E-01 -0.27285E-11 -0.52182E-11 -0.15563E-01 -0.15563E-01

2-D BEAM 3

TENTH POINT MOMENTS
-139. -125. -111. -97.6 -83.6 -69.7 -55.7 -41.8 -27.9 -13.9 -0.273E-11

MAXIMUM MOMENT IS AT END I

STATIC FORCES ON NODE 21 0.144329E-14 -56.6553 -139.372
STATIC FORCES ON NODE 22 -0.499600E-14 56.6553 0.272848E-11

EL= 23 NODES= 1 101 USEP=-0.000001 USLIDE=-0.000003 FN= -95.130 FS= -9.5130 STAT= -2 OLDST= -2 2-D GAP 12
STATIC FORCES ON NODE 1 -9.51215 -95.1296
STATIC FORCES ON NODE 101 9.51215 95.1296

EL= 24 NODES= 5 106 USEP= 0.008051 USLIDE=-0.000002 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12
STATIC FORCES ON NODE 6 0.000000E+00 0.000000E+00
STATIC FORCES ON NODE 106 0.000000E+00 0.000000E+00

EL= 25 NODES= 15 115 USEP= 0.007902 USLIDE= 0.000003 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12
STATIC FORCES ON NODE 15 0.000000E+00 0.000000E+00
STATIC FORCES ON NODE 115 0.000000E+00 0.000000E+00

EL= 26 NODES= 3 103 USEP= 0.034879 USLIDE=-0.000003 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12
STATIC FORCES ON NODE 3 0.000000E+00 0.000000E+00
STATIC FORCES ON NODE 103 0.000000E+00 0.000000E+00

EL= 27 NODES= 18 118 USEP= 0.034110 USLIDE= 0.000006 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12
STATIC FORCES ON NODE 18 0.000000E+00 0.000000E+00
STATIC FORCES ON NODE 118 0.000000E+00 0.000000E+00

EL= 28 NODES= 5 105 USEP= 0.040069 USLIDE=-0.000002 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12
STATIC FORCES ON NODE 5 0.000000E+00 0.000000E+00
STATIC FORCES ON NODE 105 0.000000E+00 0.000000E+00

EL= 29 NODES= 16 116 USEP= 0.039691 USLIDE= 0.000004 FN= 0.00000E+00 FS= 0.00000E+00 STAT= 3 OLDST= 3 2-D GAP 12
STATIC FORCES ON NODE 16 0.000000E+00 0.000000E+00
STATIC FORCES ON NODE 116 0.000000E+00 0.000000E+00

EL= 31	NODES= 110	10	USEP= 0.000237	USLIDE= 0.000000	FN= 0.00000E+00	FS= 0.00000E+00	STAT= 3	OLDST= 3	2-D GAP	12
STATIC FORCES ON NODE	110	0.00000E+00	0.00000E+00	0.00000E+00						
STATIC FORCES ON NODE	10	0.00000E+00	0.00000E+00							
EL= 32	NODES= 109	9	USEP= 0.007934	USLIDE= 0.000000	FN= 0.00000E+00	FS= 0.00000E+00	STAT= 3	OLDST= 3	2-D GAP	12
STATIC FORCES ON NODE	109	0.00000E+00	0.00000E+00	0.00000E+00						
STATIC FORCES ON NODE	9	0.00000E+00	0.00000E+00							
EL= 33	NODES= 111	11	USEP= 0.007880	USLIDE= 0.000000	FN= 0.00000E+00	FS= 0.00000E+00	STAT= 3	OLDST= 3	2-D GAP	12
STATIC FORCES ON NODE	111	0.00000E+00	0.00000E+00	0.00000E+00						
STATIC FORCES ON NODE	11	0.00000E+00	0.00000E+00							
EL= 35	NODES= 22	122	USEP=-0.000001	USLIDE= 0.000008	FN= -56.655	FS= 0.00000E+00	STAT= 2	OLDST= 2	2-D GAP	12
STATIC FORCES ON NODE	22	0.00000E+00	-56.6553							
STATIC FORCES ON NODE	122	0.00000E+00	56.6553							

ANSYS - ENGINEERING ANALYSIS SYSTEM REVISION 4.1 B FISHER CONTROLS JAN 1-1983
 SWANSON ANALYSIS SYSTEMS, INC. HOUSTON, PENNSYLVANIA 15342 PHONE (412)746-3304 TX 510-690-8655

VOGT1 11.1300 11/28/84 CP= 35.470

***** REACTION FORCES ***** TIME = 0.00000E+00 LOAD STEP= 1 ITERATION= 10 CUM. ITER.= 5

NOTE - REACTION FORCES ARE IN THE NODAL COORDINATE SYSTEM

NODE	FX	FY	MZ
7	9.51215	3834.26	
10		3797.52	
14		-95.1295	
101	0.00000E+00	0.00000E+00	0.00000E+00
103	0.00000E+00	0.00000E+00	0.00000E+00
105	0.00000E+00	0.00000E+00	0.00000E+00
106	0.00000E+00	0.00000E+00	0.00000E+00
115	0.00000E+00	0.00000E+00	0.00000E+00
116	0.00000E+00	0.00000E+00	0.00000E+00
118	0.00000E+00	0.00000E+00	0.00000E+00
122	0.00000E+00	-56.6553	0.00000E+00
TOTAL	-0.104361E-13	7530.00	0.000000E+00

STATUS CHANGED FOR 0 BILINEAR ELEM THIS ITER

DISPLACEMENT INCREMENT = 0.29725E-05 AT NODE 1 CRITERION = 0.10000E-02

*** LOAD STEP 1 ITER 10 COMPLETED. TIME= 0.000000E+00 TIME INC= 0.000000E+00 NEW TRIANG MATRIX CUM. ITER.= 5

END OF INPUT ENCOUNTERED ON FILE27

***** INPUT FILE SWITCHED FROM FILE27 TO FILE 5

ATTACHMENT 10

FQP-11AB-7

ES 199, Rev. A

Verification of Rotary Valve Shaft Stress Analysis Program

No.	ES 199	A
By	<i>DCB</i>	10-29-85
Apvd	<i>DCB</i>	10-29-85
Page	1	of



©Fisher Controls 1985

Rev

Title:

VERIFICATION OF ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

Page Number	Revision Level	Page Number	Revision Level	Page Number	Revision Level	Page Number	Revision Level
1	A						
2	A						
3	A						
4	A						
5	A						
6	A						
7	A						
8	A						
9	A						
10	A						
11	A						
12	A						
13	A						
14	A						
				NOTE: Revision of this document shall be approved by the Manager, Engineering Qualification and Analysis.			

This page is the cover sheet of all documents containing 3 or more pages of specifications. The table above shows the revision level of each page of this document. A revision of this

page will be made when any page of this document is revised. When referring to this document specify the revision level of this page.

Fisher Controls

Engineering Standard

VERIFICATION OF

ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

No.	ES 199	A
By	<i>DCB</i>	10-29-85
Apvd	<i>[Signature]</i>	10-29-85
Page	2	of



©Fisher Controls

--	--	--	--	--	--	--	--	--	--

Rev

TABLE OF CONTENTS

COVER PAGE..... 1

TABLE OF CONTENTS..... 2

1. SCOPE..... 3


2. INTRODUCTION..... 3

3. VERIFICATION PROCEDURE..... 4

EXHIBIT 1..... 13

EXHIBIT 2..... 14

No.	ES 199	A
By	<i>DCB</i>	10-29-85
Apvd	<i>FO</i>	10-29-85
Page	3	of



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

©Fisher Controls										Rev	
------------------	--	--	--	--	--	--	--	--	--	-----	--

1. SCOPE

Verify the programing accuracy of the Rotary Valve Shaft Stress Analysis Program.

2. INTRODUCTION

The purpose of ES 199 is to provide assurance that the shaft analysis procedures are properly executed by the Rotary Valve Shaft Stress Analysis Program.

3. VERIFICATION PROCEDURE

Verification of the programing accuracy of Rotary Valve Shaft Stress Analysis Program is accomplished by a comparison of the computer generated values and manual calculations. The following two examples are chosen to exercise the two options that are present in the program. Verification Example 1 is chosen for conditions present when the valve disc is seated (ANG is zero). For a seated valve disc, the seating torque (TQS) is represented in the torque equations and the dynamic torque (TQD) is not. Verification Example 2 is chosen for conditions present when the valve disc is not seated (ANG is greater than zero). For an unseated valve disc, the dynamic torque is present in the torque equations and the seating torque is not.

3.1 Verification Example 1. Verification Example 1 is used for verification of the program for conditions present when the valve disc is seated (seating torque is present in the equations and the dynamic torque is not). This example also shows application of cam forces due to an offset disc (DM) and inertial forces due to fast stroking times (TQI). The conditions of disc offset and fast stroking time may or may not be present in particular applications. Because of a difference in seal arrangements and service conditions for different valves with specified service factors, TQS and TQI are data inputs and are calculated prior to running the program. Verification Example 1 is a special 14" Type 9280 with Adjustable T-Ring. The seat material is EPDM. The 17-4PH Class 4 shaft is pinned (C1 = 0.5) at the cast disc and keyed (C2 = 0.75) to the drive lever. The bushing material is bronze/graphite (Bushing Type 2). Gas flow direction is toward the hub. Process temperature is 320°F. The stroking time is 0.25 seconds.

3.1.1 Data Input. The following table presents the input variables and the values used for Verification Example 1.

No.	ES 199	A
By	<i>DCL</i>	10-29-85
Apvd	<i>Fly</i>	10-29-85
Page 4	of	



VERIFICATION OF ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

©Fisher Controls

Rev

Variable	Value	Description
ANG	0.0	Angle opening, deg.
DDISC	13.244	Valve disc diameter, in.
DELTP	60.0	Pressure drop, psi
DLO	0.906	Disc hub to bushing distance, in.
TQS	1805.89	Seating torque (0° only), in-lbf
TQI	60.67	Inertial torque, in-lbf
DM	0.020	Amount of disc offset, in.
DTF	0.0	Dynamic torque factor, dimensionless
DPIN	60.0	Inlet pressure, psi
DELTPF	60.0	Effective pressure drop factor, dimensionless
C1	0.5	Disc/shaft connection factor, dimensionless
C2	0.75	Drive/shaft connection factor, dimensionless
BSHTYP	2	Bushing type identification code(sets DMU=0.2)
DSHFT	1.748	Shaft diameter, in.

3.1.2 Torque Calculations

(a) TQF: Valve Bushing Friction Torque (in-lbf)

$$TQF = (DMU)(0.393)(DDISC)^2(DELTP)(DSHFT) \tag{1}$$

$$TQF = (0.2)(0.393)(13.244)^2(60.0)(1.748)$$

$$TQF = 1445.95$$

(b) TQP: Packing Torque (in-lbf)

$$TQP = 100(DSHFT)^{1.5} \tag{2}$$

$$TQP = 100(1.748)^{1.5}$$

$$TQP = 231.11$$

(c) TQC: Cam Torque (in-lbf)

$$TQC = (0.785)(DDISC)^2(DELTP)(DM) \tag{3}$$

$$TQC = (0.785)(13.244)^2(60.0)(0.020)$$

$$TQC = 165.23$$

No.	ES 199	A
By	DCB	10-29-85
Apvd	[Signature]	10-29-85
Page	5	of
Rev		



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

©Fisher Controls

(d) TQD: Dynamic Torque (in-lbf)

$$\text{DELTP} = \text{DELTP} \text{ (for ANG} = 0.0\text{)}$$

$$\text{DELTP} = 60.00$$

$$\text{DELTP} = 60.00$$

$$\text{TQD} = \text{DTF}\{\text{smaller value of DELTP and DELTP}\} \quad (4)$$

$$\text{TQD} = 0.0\{60.0\}$$

$$\text{TQD} = 0.0$$

(e) TQV: Valve Torque at Drive End of Shaft (in-lbf)

$$\text{TQV} = \text{TQF} + \text{TQP} + \text{TQS} + \text{TQI} + \text{TQC} + \text{TQD} \quad (5)$$

$$\text{TQV} = 1445.95 + 231.11 + 1805.89 + 60.67 + 165.23 + 0.0$$

$$\text{TQV} = 3708.85$$

(f) TA: Shaft Torque at Point A (in-lbf)

$$\text{TA} = \text{TQV} \quad (6)$$

$$\text{TA} = 3708.85$$

(g) TB: Shaft Torque at Point B (in-lbf)

$$\text{TB} = \text{TQV} - \text{TQP}/2 - \text{TQF}/2 \quad (7)$$

$$\text{TB} = 3708.85 - 231.11/2 - 1445.95/2$$

$$\text{TB} = 2870.32$$

(h) TC: Shaft Torque at Point C (in-lbf)

$$\text{TC} = \text{TQV} - \text{TQP}/2 - \text{TQF}/2 \quad (8)$$

$$\text{TC} = 3708.85 - 231.11/2 - 1445.95/2$$

$$\text{TC} = 2870.32$$



VERIFICATION OF ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

By *DLB* 10-29-85

Approved *[Signature]* 10-29-85

Page 6 of

©Fisher Controls:

Rev

3.1.3 Stress Calculations

(a) STRS1: Point B₁ Normal Bending and Torsion Stress (psi)

M = (0.393)(DDISC)²(DELTP)(DLO) (9)

M = (0.393)(13.244)²(60.0)(0.906)

M = 3747.23

STRS1 = {(5.1)/(DSHFT)³} {M + {(M)² + (TB)²}^{0.5}} (10)

STRS1 = {(5.1)/(1.748)³} {3747.23 + {(3747.23)² + (2870.32)²}^{0.5}}

STRS1 = 8085.34

(b) STRS2: Point B₁ Bending and Torsion Shear Stress (psi)

STRS2 = {(5.1)/(DSHFT)³} {(M)² + (TB)²}^{0.5} (11)

STRS2 = {(5.1)/(1.748)³} {(3747.23)² + (2870.32)²}^{0.5}

STRS2 = 4507.21

(c) STRS3: Point B₂ Torsion and Direct Shear Stress (psi)

STRS3 = (5.1)(TB/(DSHFT)³) + (2/3)((DDISC)²(DELTP)/(DSHFT)²) (12)

STRS3 = (5.1)(2870.32/(1.748)³) + (2/3)((13.244)²(60.0)/(1.748)²)

STRS3 = 5037.02

(d) STRS4: Point C Torsion Load Shear Stress (psi)

STRS4 = (5.1){(TC)/((C1)(DSHFT)³)} (13)

STRS4 = (5.1){(2870.32)/((0.5)(1.748)³)} (13)

STRS4 = 5481.59

(e) STRS5: Point A Torsion Load Shear Stress (psi)

STRS5 = (5.1){(TA)/((C2)(DSHFT)³)} (14)

STRS5 = (5.1){(3708.85)/((0.75)(1.748)³)} (14)

STRS5 = 4721.98

No.	ES 199	A
By	<i>DCB</i>	10-29-85
Apv'd	<i>DCB</i>	10-29-85
Page	7	of



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

©Fisher Controls

Rev	
-----	--

(f) STRS6: Bushing Load Stress (psi)

$$STRS6 = (0.393)(DDISC)^2 (DELTP)/(DSHFT)^2 \quad (15)$$

$$STRS6 = (0.393)(13.244)^2 (60.0)/(1.748)^2$$

$$STRS6 = 1353.63$$


3.1.4 Calculation Comparison. A sample run of the Rotary Valve Shaft Stress Analysis Program was run 10/23/85 using the same input conditions that were used in this analysis. See Exhibit 1 for a copy of the Verification Example 1 program output. The following table shows the difference between the manually calculated values and the computer generated values, for the case of ANG = 0.0°.

(a) Valve Torque

Variable	Manual	Computer	% Difference
TQV	3,708.85	3708.85	0.0

(b) Stress Calculations

Variable	Manual	Computer	% Difference
STRS1	8,085.34	8,084.23	0.0
STRS2	4,507.21	4,506.11	0.0
STRS3	5,037.02	5,039.85	0.0
STRS4	5,481.59	5,480.26	0.0
STRS5	4,721.98	4,723.86	0.0
STRS6	1,353.63	1,353.63	0.0



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

By *DCS* 10-29-85
 Appvd *[Signature]* 10-29-85
 Page 8 of

©Fisher Controls

Rev

3.2 Verification Example 2. Verification Example 2 is used for verification of the program for conditions present when the valve disc is not seated (dynamic torque is present in the torque equations and the seating torque is not). This example also shows applications when the cam forces due to an offset disc (DM) and inertial forces due to fast stroking times (TQI) are not present. The conditions of disc offset and fast stroking times may or may not be present in particular applications. Because of a difference in seal arrangements and service conditions for different valves with specified service factors, TQS and TQI are data inputs and are calculated prior to running the program. Verification Example 2 is a special 14" Type 9280 with Adjustable T-Ring. The seat material is EPDM. The 17-4PH Class 4 shaft is pinned (C1 = 0.5) at the cast disc and keyed (C2 = 0.75) to the drive lever. The bushing material is bronze/graphite (Bushing Type 2). Gas flow direction is toward the hub. Process temperature is 320°F. The stroking time is greater than 0.5 seconds.

3.2.1 Data Input. The following table presents the input variables and the values used for Verification Example 2.

Variable	Value	Description
ANG	30.0	Angle opening, deg.
DDISC	13.244	Valve disc diameter, in.
DELTP	50.0	Pressure drop, psi
DLO	0.906	Disc hub to bushing distance, in.
TQS	0.0	Seating torque (0° only), in-lbf
TQI	0.0	Inertial torque, in-lbf
DM	0.0	Amount of disc offset, in.
DTF	49.5	Dynamic torque factor, dimensionless
DPIN	50.0	Inlet pressure, psi
DELTPF	0.25	Effective pressure drop factor, dimensionless
C1	0.5	Disc/shaft connection factor, dimensionless
C2	0.75	Drive/shaft connection factor, dimensionless
BSHTYP	2	Bushing type identification code
DSHFT	1.748	Shaft diameter, in.


 VERIFICATION OF
 ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

3.2.2 Torque Calculations

(a) TQF: Valve Bushing Friction Torque (in-lbf)

$$TQF = (DMU)(0.393)(DDISC)^2(DELTP)(DSHFT) \quad (16)$$

$$TQF = (0.2)(0.393)(13.244)^2(50.0)(1.748)$$

$$TQF = 1204.96$$

(b) TQP: Packing Torque (in-lbf)

$$TQP = 100(DSHFT)^{1.5} \quad (17)$$

$$TQP = 100(1.748)^{1.5}$$

$$TQP = 231.11$$

(c) TQC: Cam Torque (in-lbf)

$$TQC = (0.785)(DDISC)^2(DELTP)(DM) \quad (18)$$

$$TQC = (0.785)(13.244)^2(60.0)(0.0)$$

$$TQC = 0.0$$

(d) TQD: Dynamic Torque (in-lbf)

$$DELTP E = (DELTPF)(DPIN + 14.7)$$

$$DELTP E = (0.25)(50.0 + 14.7)$$

$$DELTP E = 16.18$$

$$TQD = DTF\{\text{smaller value of DELTP and DELTP E}\} \quad (19)$$

$$TQD = 49.5\{\text{smaller value of 50.0 and 16.18}\}$$

$$TQD = 800.66$$

(e) TQV: Valve Torque at Drive End of Shaft (in-lbf)

$$TQV = TQF + TQP + TQS + TQI + TQC + TQD \quad (26)$$

$$TQV = 1204.96 + 231.11 + 0.0 + 0.0 + 0.0 + 800.66$$

$$TQV = 2236.73$$

Fisher Controls

Engineering Standard

No. ES 199 A

FISHERVERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAMBy *DCB* 10-29-85Apvd *DCB* 10-29-85

Page 10 of

©Fisher Controls

Rev

(f) TA: Shaft Torque at Point A (in-lbf)

$$TA = TQV \quad (21)$$

$$TA = 2236.73$$

(g) TB: Shaft Torque at Point B (in-lbf)

$$TB = TQV - TQP/2 - TQF/2 \quad (22)$$

$$TB = 2236.73 - 231.11/2 - 1204.96/2$$

$$TB = 1518.70$$

(h) TC: Shaft Torque at Point C (in-lbf)

$$TC = TQV - TQP/2 - TQF/2 \quad (23)$$

$$TC = 2236.73 - 231.11/2 - 1204.96/2$$

$$TC = 1518.70$$

3.2.3 Stress Calculations

(a) STRS1: Point B₁ Normal and Torsion Stress (psi)

$$M = (0.393)(DDISC)^2 (DELTP)(DLO) \quad (24)$$

$$M = (0.393)(13.244)^2 (50.0)(0.906)$$

$$M = 3122.70$$

$$STRS1 = \{(5.1)/(DSHFT)^3\} \{M + \{(M)^2 + (TB)^2\}^{0.5}\} \quad (25)$$

$$STRS1 = \{(5.1)/(1.748)^3\} \{3122.70 + \{(3122.70)^2 + (1518.70)^2\}^{0.5}\}$$

$$STRS1 = 6297.51$$

(b) STRS2: Point B₁ Bending and Torsion Shear Stress (psi)

$$STRS2 = \{(5.1)/(DSHFT)^3\} \{(M)^2 + (TB)^2\}^{0.5} \quad (26)$$

$$STRS2 = \{(5.1)/(1.748)^3\} \{(3122.70)^2 + (1518.70)^2\}^{0.5}$$

$$STRS2 = 3315.72$$

VERIFICATION OF
 ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM
By *DC* 10-29-85Apvd *RL* 10-29-85

Page 11 of

FISHER

©Fisher Controls

Rev

(c) STRS3: Point B₂ Torsion and Direct Shear Stress (psi)

$$\text{STRS3} = (5.1)(\text{TB}/(\text{DSHFT})^3) + (2/3)((\text{DDISC})^2(\text{DELTP})/(\text{DSHFT})^2) \quad (27)$$

$$\text{STRS3} = (5.1)(1518.70/(1.748)^3) + (2/3)((13.244)^2(50.0)/(1.748)^2)$$

$$\text{STRS3} = 3363.69$$

(d) STRS4: Point C Torsion Load Shear Stress (psi)

$$\text{STRS4} = (5.1)\{(\text{TC})/((\text{C1})(\text{DSHFT})^3)\} \quad (28)$$

$$\text{STRS4} = (5.1)\{(1518.70)/((0.5)(1.748)^3)\}$$

$$\text{STRS4} = 2900.33$$

(e) STRS5: Point A Torsion Load Shear Stress (psi)

$$\text{STRS5} = (5.1)\{(\text{TA})/((\text{C2})(\text{DSHFT})^3)\} \quad (29)$$

$$\text{STRS5} = (5.1)\{(2236.73)/((0.75)(1.748)^3)\}$$

$$\text{STRS5} = 2847.73$$

(f) STRS6: Bearing Load Stress (psi)

$$\text{STRS6} = (0.393)(\text{DDISC})^2(\text{DELTP})/(\text{DSHFT})^2 \quad (30)$$

$$\text{STRS6} = (0.393)(13.244)^2(50.0)/(1.748)^2$$

$$\text{STRS6} = 1128.02$$

3.2.4 Calculation Comparison. A sample run of the Rotary Valve Shaft Stress Analysis was run 10/23/85 using the same input conditions that were used in this analysis. See Exhibit 2 for a copy of the Example 2 program output. The following table shows the difference between the manually calculated values and the computer generated values, for the case of ANG = 30.0°.



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

©Fisher Controls

Rev


(a) Valve Torque

Variable	Manual	Computer	% Difference
TQV	2,236.73	2,236.73	0.0

(b) Stress Calculations

Variable	Manual	Computer	% Difference
STRS1	6,297.51	6,296.82	0.0
STRS2	3,315.72	3,315.05	0.0
STRS3	3,363.69	3,366.05	0.0
STRS4	2,900.33	2,898.55	0.0
STRS5	2,847.73	2,848.86	0.0
STRS6	1,128.02	1,128.02	0.0

3.3 Verification. The Calculation Comparison in Sections 3.1.4 and 3.2.4 indicates that there is no difference between the computer generated values and the manually calculated values. These examples verify the accuracy of the Rotary Valve Shaft Stress Analysis.



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

By *DES* 10-29-85
 App'd *MD* 10-29-85
 Page 13 of

©Fisher Controls

Rev

EXHIBIT 1
Verification Example 1

ACTUATOR TORQUE CALCULATIONS REV. B

REF. NO. EXAMPLE 1
 VALVE TYPE Y280
 SHAFT MAT. SA-564 P1075 RC31-39
 DISC-SHAFT CON. PINNED
 FLOW DIR. TOWARD HUB
 DATE OCTOBER 23, 1985

TEMP. 328 DEG F
 VALVE SIZE 14 INCH
 BUSH. MAT. BRONZE/GRAPHITE
 DRIVE-SHAFT CON. KEYED
 BY DAVE STANZE

INPUT DATA

ANG	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
ODISC	13.244	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DELTP	60.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DLO	0.906	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TS	1805.890	0.000	0.000	0.005	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TI	60.670	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DM	0.020	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DIF	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DPTN	60.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DELTPF	60.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
STSH	98.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SBUSH	85.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
C1	0.500	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
C2	0.750	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
BSHTYP	2	0	0	0	0	0	0	0	0	0	0
DSHFT	1.748	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

GENERATED VARIABLES

ST	51450.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SS	25725.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SB	8500.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

OUTPUT

ACT. TORQ	3708.8462	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS1	8084.2344	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS2	4506.1054	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS3	5039.8516	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS4	5480.2578	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS5	4723.8594	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS6	1353.6267	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

Fisher Controls

Engineering Standard

No.	ES 199	A
By	<i>RSB</i>	10-29-85
Apvd	<i>[Signature]</i>	10-29-85
Page	14	of



VERIFICATION OF
ROTARY VALVE SHAFT STRESS ANALYSIS PROGRAM

©Fisher Controls

Rev	
-----	--

EXHIBIT 2
Verification Example 2

ACTUATOR TORQUE CALCULATIONS REV. 2

REF. NO. EXAMPLE 2
VALVE TYPE 9280
SHAFT MAT. SA-566 H1075 RC31-39
DISC-SHAFT CON. PINNED
FLOW DIR. TOWARD MCB
DATE OCTOBER 23, 1985

TEMP. 320 DEG F
VALVE SIZE 1 1/2 INCH
BUSH. MAT. BRONZE/GRAPHITE
DRIVE-SHAFT CON. KEYED
BY DAVE STANZE

INPUT DATA

AWG	30.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DISC	13.244	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DELTP	50.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DL0	0.906	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
TS	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
T1	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DM	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DIF	49.500	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
OPIN	50.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
DLTPF	0.250	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
STSH	98.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
SMUSH	85.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
C1	0.500	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
C2	0.750	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000
BSHTYP	2	0	0	0	0	0	0	0	0	0	0
DSHFT	1.748	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000	0.000

GENERATED VARIABLES

ST	51450.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SS	25725.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
SM	8500.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00

OUTPUT

ACT.TORQ	2236.7266	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS1	6296.8242	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS2	3315.0520	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS3	3366.0481	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS4	2898.5540	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS5	2848.8613	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000
STRS6	1128.0229	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000	0.0000

ATTACHMENT 11

FQP-11AB-7

ANSYS Program Q.A. Statement

(Swanson Analysis Systems, Inc.)
(letter dated 8-27-85 (M. J. Wheeler) to Fisher Controls (D. Stanze))

Swanson Analysis Systems, Inc.

Johnson Road, P.O. Box 65 Houston, PA 15342-0065

TWX 510-690-8655
PHONE (412) 746-3304



August 27, 1985

Mr. Dave Stanze
Senior Engineer
Fischer Controls
P. O. Box 190
Marshalltown, IA 50158

Dear Mr. Stanze:

Swanson Analysis has had an independent Quality Assurance department since 1983. The primary responsibility of this department has been to define and implement an independent verification process for all ANSYS versions. A Quality Assurance Manual and Technical Procedures Manual have been issued to clearly define everyone's responsibilities. All applicable employees have been trained in quality related areas.

Sincerely yours,
SWANSON ANALYSIS SYSTEMS, INC.

Mike Wheeler

Michael J. Wheeler, Manager
Quality Assurance

ktc

ATTACHMENT 12

FQP-11AB-7

ES 121, Rev. D

Control and Maintenance Procedures
for FCS Engineering Analytical Computer Programs and Data Bases

No.	ES 121	D
By	JBM	11-27-78
Apvd	dih	11-28-78
Page	1	of



©Fisher Controls 1978, 1985

Rev JCD 10-30-8

Title:

CONTROL AND MAINTENANCE PROCEDURES FOR FCS ENGINEERING ANALYTICAL COMPUTER PROGRAMS AND DATA BASES

Page Number	Revision Level	Page Number	Revision Level	Page Number	Revision Level	Page Number	Revision Level
1	D						
2	B						
3	B						
4	B						
5	C						
6	B						
7	B						
8	B						
9	B						
10	B						
11	B						
12	B						
13	B						
14	deleted B						
15	deleted C						
16	deleted A						

This page is the cover sheet of all documents containing 3 or more pages of specifications. The table above shows the revision level of each page of this document. A revision of this


page will be made when any page of this document is revised. When referring to this document specify the revision level of this page.

Fisher Controls

Engineering Standard

No.	ES 121	B
By	JBM	11-27-78
Apvd	dih	11-28-78
Page	2	of

CONTROL AND MAINTENANCE PROCEDURES FOR FCS ENGINEERING ANALYTICAL COMPUTER PROGRAMS AND DATA BASES



©Fisher Controls

Rev	JCD	10-30-8
-----	-----	---------

TABLE OF CONTENTS

1. SCOPE 3

2. REQUIREMENTS AND RESPONSIBILITIES FOR DOCUMENTATION OF COMPUTER PROGRAMS AND DATABASES. 3

3. INSTALLING AND REVISING COMPUTER PROGRAMS AND DATABASES 4

 3.1 Program Controller 4

 3.2 Program Documentation File. 4

 3.3 Fisher Controls Computer System 4

 3.4 St. Louis Monsanto/MIS Computer System 5

4. FORMAT REQUIREMENTS FOR COMPUTER PROGRAM FILES 5

 4.1 Section 1: Standards and Specifications Cover Sheet . . . 6

 4.2 Section 2: Table of Contents. 6

 4.3 Section 3: Abstract 6

 4.4 Section 4: Job Control Language (JCL) 7

 4.5 Section 5: Source Code Listing. 7

 4.6 Section 6: Description of Program Logic 7

 4.7 Section 7: Verification Documentation 7

 4.8 Section 8: Input Data 8

 4.9 Section 9: Output Data/Example 8

 4.10 Section 10: Installation Report 9

 4.11 Appendix A: Current Benchmark Problem/Installation Log Record 9

 4.12 Appendix B: Documentation File Change Records. 9

 4.13 Appendix C: Project Records. 9

5. FORMAT REQUIREMENTS FOR DATABASE DOCUMENTATION FILE 10

 5.1 Section 1: Abstract 10

 5.2 Section 2: Listing 10

 5.3 Section 3: Format 10

 5.4 Section 4: Installation Report. 10

 5.5 Appendix A: Documentation File Change Records. 11

 5.6 Appendix B: Project Records 11

6. RESPONSIBILITY SUMMARY. 11

 6.1 General 11

 6.2 Program Author 11

 6.3 Program Controller 12

7. REFERENCES. 12

EXHIBIT 1: Installation Report Form 13

No.	ES 121	E
By	JBM	11-27-78
Apvd	d/h	11-28-78
Page	3	of



CONTROL AND MAINTENANCE PROCEDURES FOR FCS ENGINEERING ANALYTICAL COMPUTER PROGRAMS AND DATA BASES

©Fisher Controls

Rev	JCD	10-30-8
-----	-----	---------

1. SCOPE

1.1 This engineering standard provides a procedure for documenting, revising, and maintaining FCS Engineering analytical computer programs and databases. Outlined in this standard are the procedures to follow in establishing a program or database with the necessary documentation file. In addition, applicable guidelines recommended by the following standards are incorporated:

ANSI/ASME NQA-1-1983. "Quality Assurance Program Requirements for Nuclear Facilities".

ANSI N413-1974. "Guidelines for the Documentation of Digital Computer Programs"

ANSI/ANS 10.2-1982. "Recommended Programming Practices to Facilitate the Portability of Scientific Computer Programs"

ANSI/ANS 10.5-1979. "Guidelines for Considering User Needs in Computer Program Development"

1.2 A secondary objective of this engineering standard is to present the format to be used for the Fisher Computer/database documentation file so that all of the necessary information will be provided in a logical and consistent manner.

1.3 Finally, an Installation Report form is described for documenting installation of programs and databases in either the Fisher Controls (Marshalltown) computer system or in the Monsanto Management Information System (MIS) using the St. Louis Monsanto Terminal Station (MTS). This report provides a check between what is documented and what resides in the computers.

2. REQUIREMENTS AND RESPONSIBILITIES FOR DOCUMENTATION OF COMPUTER PROGRAMS AND DATABASES

2.1 Any FCS Engineering analytical computer program (with associated database) used in the design of Fisher products in general applications will require documentation under a project file number (XXJAXX series). Any FCS Engineering computer program used to qualify equipment to Fisher customer specifications will also require similar documentation and project file number assignment.

2.2 It will be the responsibility of the Program Author to determine when the program/database qualifies for project file number assignment and documentation control and maintenance per this Engineering Standard. In general, if the computer program or database is to be released for use by anyone other than the Program Author, then the requirements of this standard must be met.

Fisher Controls

Engineering Standard

No.	ES 121	B
By	JBM	11-27-78
Apvd	djh	11-28-78
Page	4 of	
Rev	JCD	10-30-81

CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES



©Fisher Controls

2.3 If this standard is to be followed, it is the Program Author's responsibility to contact the Engineering Qualification and Analysis Group for assignment of a Program Controller who will initiate program/database installation and documentation procedures. At that time, a general description of the program/database content and its intended or expected application should be provided to the Program Controller by the Program Author. (See Section 6 of this standard for a summary of the responsibilities of the Program Author and Program Controller, respectively.)

3. INSTALLING AND REVISING COMPUTER PROGRAMS AND DATABASES

3.1 Program Controller. Installation of programs and databases will be the responsibility of an individual (henceforth referred to as the "Program Controller") designated by the Manager, Engineering Qualification and Analysis. A draft of the program/database should be submitted to the Program Controller for program/database installation on the selected computer system. The Program Controller will fill out the installation report form (See Exhibit 1), keeping a copy for insertion in the program/database file.

3.2 Program Documentation File. In all cases, the Program Controller must provide and/or assemble the XXJAXX Documentation File for the program or database. The use of the program or database may be denied the author or any other user until the documentation file is assembled and the project file number assignment is completed. The XXJAXX Documentation File will then be transferred to the Fisher Information Center for custody. In addition, the Manager, Engineering Qualification and Analysis Group (or designee) will maintain a current index file of the approved programs and databases with their associated project file numbers; this index will be circulated periodically in the FCS Engineering Department.

3.3 Fisher Controls Computer System

3.3.1 Installation procedures for Fisher-documented FCS Engineering programs will be dependent upon the host system being used. Examples of FCS Engineering programs subject to these documentation procedures are: ANSYS (VAX-based) or TK1SOLVER (PC-based). Note that purchased or leased programs are included, as well as Fisher-originated programs.

3.3.2 Purchased or leased programs will be installed following the installation procedures recommended by the program vendor. System ownership will be assigned to the installed program with "read-only" privileges for users, to avoid inadvertant erasure. A backup copy of the program will be maintained on separate media.

Fisher Controls

Engineering Standard

No. ES 121 C

CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES

By JBM 11-27-76

Apvd dih 11-28-76

Page 5 of



©Fisher Controls

Rev JCD 10-30-8

3.3.3 The following will be used when installing Fisher-originated programs. As above, system ownership will be assigned to the installed program with "read-only" privileges, and a backup copy will be maintained on separate media. In addition to the executable image of the installed program, an ASCII text file of the program will be maintained in the Installation User ID (UID) file. Also included in the Installation UID file will be any data sets used in execution of the program and any user-written sub-routines external to the program. An on-line "help" file will also be provided, outlining the purpose of the program and the steps necessary to use the program.

3.4 St. Louis Monsanto/MIS Computer System

3.4.1 The Program Controller will place the source code on the "USERID"¹ called "FSHLIB", unless special restrictions or other arrangements are made as noted on the Installation Report. The source code will then be copied to microfiche (or paper if the listing is less than about 50 pages) and will be included in the project file. This source code will be compiled and link-edited and placed on the same database ("FSHLIB") under the same name. In all cases, one hard copy backup will be maintained by the Program Controller. ("FSHLIB" is a restricted access data set that is password-protected, permitting read-only availability to users.) A copy of the program or database will also be made for the tape librarian, and this library copy is automatically backed up by St. Louis Monsanto MIS.

3.4.2 Examples of St. Louis Monsanto MIS programs subject to these documentation procedures are: SEISMIC3, SEISMIC4.

4. FORMAT REQUIREMENTS FOR COMPUTER PROGRAM FILES

This section describes the format for the FCS Engineering XXJAXX Computer Program Documentation File. A consistent format is necessary both for proper control and maintenance and also for ease in referencing and accessing the information by the user. The format for the documentation file is comprised of the following sections:

- (a) Section 1: Standards and Specifications Cover Sheet.
- (b) Section 2: Table of Contents.
- (c) Section 3: Abstract.
- (d) Section 4: Job Control Language (JCL), if applicable.
- (e) Section 5: Source Code Listing (on paper, microfiche or magnetic tape, diskette) or Source Code Location.
- (f) Section 6: Description of Program Logic/Content or Program Documentation Reference.
- (g) Section 7: Verification Documentation.
- (h) Section 8: Input Data
- (i) Section 9: Output Data/Example
- (j) Section 10: Installation Report
- (k) Appendix A: Current Benchmark Problem/Installation Log Record
- (l) Appendix B: Documentation File Change Records
- (m) Appendix C: Project Records

¹ "USERID" refers to a data set available through St. Louis MIS.

FISHERCONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES

By JBM 11-27-78

Apvd d/h 11-28-78

Page 6 of

©Fisher Controls

Rev JCB 10-30-8

If a program is written for Fisher through a subcontracted vendor or if an established, commercially-available program is used by Fisher Controls, vendor documentation is needed; in these cases, the above format can be altered to incorporate a program user's manual. Sections 1,2,3,4,5,7,10 along with the program user's manual may be used to satisfy requirements as long as the Program Controller finds the complete package acceptable. Section 10 of the program documentation should be filled out by the Program Controller using the special form in Exhibit 1; it is the Program Controller's responsibility to incorporate this report in the program documentation file.

4.1 Section 1: Standards and Specifications Cover Sheet

The purpose of the cover sheet(s) is to indicate the revision level of the project documentation file, and the corresponding revision level of the constituent pages or documents. Each sheet or document in the bound file should be listed, except for the Appendices. (In the case of Appendices, only the Appendix title page need be listed.) If an already page-numbered document is included (such as ES 117, ES 136, etc.), only the document and its overall revision level need be listed. Whenever a revision or change is made in the project documentation file, the appropriate changes in page or document revision levels should be entered on the cover sheet, and the revision level of the project file should be advanced and designated on the cover sheet; change record sheets must be completed (including checking and signatures) and should be filed in Appendix B of the program documentation file (see Section 4.12).

4.2 Section 2: Table of Contents

The Table of Contents should immediately follow the cover sheet, identifying the major constituents of the file and the corresponding page or section number.

4.3 Section 3: Abstract

4.3.1 The function of the computer program abstract is to give a summary of the program regarding its capabilities, purpose, and intended application or use. The following topics should be included in the abstract:

- (a) Program identification. Give the program name and current revision.
- (b) Describe the program function or purpose and define the type of problems to be solved.
- (c) Restrictions. Mention any limitations due to the program algorithms or computing facilities.
- (d) Programming language. Indicate the language or languages used.
- (e) Author. Give the name and address of the Program Author.

The abstract should be as brief as possible and to the point. A sentence or two addressing each topic should be adequate.

No.	ES 121	E
By	JBM	11-27-70
Apvd	djh	11-28-70
Page	7	of
Rev	JCS	10-30-80



CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES

©Fisher Controls

4.4 Section 4: Job Control Language (JCL)

The Program Controller shall provide listing of all the JCL requirements for the program, if applicable. Any data sets used should be referenced (with project file numbers if applicable). Explanations should be included to clarify the JCL usage for the user. (It is recognized that JCL is not used with many computer systems such as VAX.)

4.5 Section 5: Source Code Listing

The Source Code Listing means the list of program instructions in the selected program language (such as FORTRAN). The source listing is normally maintained on the program user ID disc. A source code backup must be maintained. The preferred method is magnetic tape with the tape location identified on the computer Program/Database Installation Report (Appendix A of ES121). Alternate methods are hard copy paper or microfiche. The Program Author will advise the Program Controller of the Source Code Listing backup mode and its location. Paper or microfiche copies will be included in the XXJAXX Program Documentation File by the Program Controller, and the magnetic tape location will be noted as applicable.

4.6 Section 6: Description of Program Logic

4.6.1 The Program Author shall provide a description of program logic demonstrating how the general problem solution method is carried out within the program. This section may contain a detailed flowchart or detailed prose specification or a self-contained Engineering Standard such as ES 117, which should reference the appropriate Program Documentation File Number (XXJAXX).

4.6.2 The Program Logic Section documentation should include the detailed mathematical method of solution. All of the mathematical techniques, equations, and algorithms used for solutions should be listed in sequence, with all equations numbered. Any auxiliary programs or external data files required for program utilization should also be listed. Related reference material should also be listed as appropriate. The Program Controller will include the Program Logic Description in the XXJAXX Program Documentation File.

4.7 Section 7: Verification Documentation

4.7.1 The Program Author is responsible for providing program verification documentation to the Program Controller for inclusion in the XXJAXX Program Documentation File. This should consist of validation information and examples to give credibility to the computer program. All sources for the mathematical models and derivations used in the program should be referenced, with assumptions and limitations clearly noted. Justification for the validity of all equations, algorithms, models, etc. used should be clearly presented. Equations should be numbered and tied to the contents of the source code and the output

No.	ES 121	B
By	JBM	11-27-76
Apvd	djh	11-28-76
Page	8 of	

CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES



©Fisher Controls

Rev	JCB	10-30-85
-----	-----	----------

format. For all computer programs (except leased programs), benchmark problems should be provided for program verification, comparing results from the new program to accepted hand calculations, test results, or previously-verified computer programs. Benchmark problem sets should be run initially as well as before and after any program revisions. If the verification data is lengthy and complex, this should be presented in an Engineering Standard (for example: ES 136) for ready reference, in lieu of unassembled separate pages or sections; this Engineering Standard should reference the appropriate Program Documentation File Number (XXJAXX). The Engineering Qualification and analysis Group will assist in the verification process upon request, and will provide the independent review and check which is necessary to satisfy the requirements of Section 4, Supplement 3S-1 of ANSI/ASME NQA-1-1983.

4.7.2 The Program Controller is responsible for maintaining a continuing quality assurance (QA) check on program integrity. To accomplish this, the same benchmark problems sets used in the verification documentation noted above should be re-run at intervals of not more than one year following the last revision. In the case of leased programs, a new program input tape copy may be obtained and installed yearly in lieu of re-doing benchmark problems. The current benchmark problem output or installation log (for leased programs) should be dated and filed in Appendix A of the XXJAXX Program Documentation File; any previous problem output or installation log may be discarded after verifying that there has been no change (see Section 4.11 below).

4.8 Section 8: Input Data

A list of the input data necessary for the user to supply to the program should be furnished by the Program Author. Normally, program inputs are made in response to program prompts. However, if special input procedures or pre-input calculations are required, these should be identified. The Program Controller will incorporate the input data information provided into the XXJAXX Program Documentation File.

4.9 Section 9: Output Data/Example

4.9.1 In this section, the Program Author should include a discussion of the program output, relating input variables to the output format options and to appropriate equations in the logic and verification sections; a sample problem output should be provided. A benchmark problem or a well-defined example should be chosen as an illustration. The sample output should be re-run after each program change.

4.9.2 The output section should also include information about typical or expected computer running time and costs, so that a user can estimate job costs and execution time for particular problems.

No.	ES 121	B
By	JBM	11-27-76
Apvd	d/h	11-28-76
Page	9	of
Rev	JCS	10-30-



CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES

©Fisher Controls

4.10 Section 10: Installation Report

The installation report form is illustrated in Exhibit 1 of this Engineering Standard. All necessary information regarding the accessing and usage of the program is documented in this report. It is the responsibility of the Program Controller to fill out this report, submit it to the Program Author for review and include it in the XXJAXX Program Documentation File.

4.11 Appendix A: Current Benchmark Problem/Installation Log Record

This is the repository for the current program quality documentation (Benchmark Problems or Installation Log) as described in Paragraph 4.7.2 of this Engineering Standard. Superseded problems and installation logs should be discarded. This appendix may be filed as a separate book, to facilitate documentation changes.

4.12 Appendix B: Documentation File Change Records

This is the repository for the change record sheets associated with the XXJAXX Program Documentation File. When a controlled page is revised (as shown on the Standards and Specifications Cover Sheet), the old version should be marked showing the changes, and the Major Revision stamp should be applied. The reason for the change should be noted, and then the marked page should be routed for review by the checker and approver. The Program Controller or designee should check all documentation revisions, and the Manager, Engineering Qualification and Analysis should approve documentation changes, initialing the appropriate blocks on the Major Revision stamp.

These approvals constitute authority for making the documentation change and for insuring that the changes have been made as marked. All these change record sheets should be retained and filed in Appendix B, in order, so that they may be readily found. The only exception is for controlled documents such as Engineering Standards, which may be included as an integral part of the documentation files. Revision documentation provisions for these are already established, and revision records are maintained in the Fisher change record files. If an ES document included in the XXJAXX Program Documentation File has been revised, this should be noted in the Program Controller's annual review of the documentation file, and the appropriate ES revision should be noted on the documentation file Standards and Specifications Cover Sheet, as a file revision. All Program Documentation File change records should be retained in this Appendix permanently. This appendix may be filed as a separate book to facilitate documentation additions.

4.13 Appendix C: Project Records

This is the repository for the Project XXJAXX records such as the Initial Information sheet, Final Summary, Supplementary Information sheets, and project time charge and cost records, as applicable, together with any project notes or correspondence. This Appendix may be filed as a separate book to facilitate additions and changes.

No	ES 121	E
By	JBM	11-27-76
Apvd	djh	11-28-76
Page	10 of	
Rev	QED	10-30-81



CONTROL AND MAINTENANCE PROCEDURES FOR FCS ENGINEERING ANALYTICAL COMPUTER PROGRAMS AND DATA BASES

©Fisher Controls

5. FORMAT REQUIREMENTS FOR DATABASE DOCUMENTATION FILE

The content of the database documentation file will consist of the following sections:

- (a) Section 1: Standards and Specifications Cover Sheet
- (b) Section 2: Abstract
- (c) Section 3: Listing
- (d) Section 4: Format
- (e) Section 5: Installation Report
- (f) Appendix A: Documentation File Change Records
- (g) Appendix B: Project Records

Most databases are for specific purposes and not for general applications, so most users will actually be the authors. It will still be necessary to prepare an abstract and provide a listing of the database (microfiche, or magnetic tape) if not already included in a documented program. A XXJAXX series file number will be assigned to the Database Documentation File also.

5.1 Section 1: Abstract

The abstract should, first of all, give the purpose for creating the database. The names and project file numbers of computer programs accessing the database should be listed. Intended use or application of the database should be discussed, and the format of the data should be briefly mentioned.

5.2 Section 2: Listing

If the database is of small to moderate size (less than 500 records of 80 character length), then a hard copy (paper) listing should be included in the documentation file. Hard copy (paper) listing is not needed for large databases, but the name and location of the magnetic tape backup should be noted in the documentation file.

5.3 Section 3: Format

In all cases, the input format for the database computer file will be identified. This may be on an individual record basis or for a group of records having varying format requirements. All of this should be clearly outlined. Whenever dimensional units are required, they should be defined.

5.4 Section 4: Installation Report

The installation report is illustrated in Exhibit 1 of this Engineering Standard. The same requirements apply to the database as to the computer program (See Paragraph 4.10: Installation Report).

No.	ES 121	B
By	JBM	11-27-78
Apvd	djh	11-28-78
Page	11 of	
Rev	JCS	10-30-85

CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES



©Fisher Controls

5.5 Appendix A: Documentation File Change Records

This is the repository for Change Record Sheets associated with the XXJAXX Database Documentation File. The provisions of Paragraph 4.12 apply to the Database Documentation File also.

5.6 Appendix B: Project Records

This is the repository for the Project XXJAXX records as listed under Paragraph 4.13 above.

6. RESPONSIBILITY SUMMARY

6.1 General

As an aid in implementing the requirements of this standard, the following itemized summary of responsibilities is provided. In general the Program Author is responsible for program/database origination and verification, and the Program Controller is responsible for entering the program into the computer system with appropriate backup and for assembly and maintenance of the computer program file.

6.2 Program Author

- (a) Program/database origination and description.
- (b) Decide if ES 121 Control is to apply. (if not, no further action per ES 121). (Para. 2.2)
- (c) Contact Engineering Qualification and Analysis Group for Program Controller assignment. (Para. 2.3)
- (d) Provide program/database description and application summary. (Para. 2.3)
- (e) Provide Source Code listing information to the Program Controller, for the program file. (Para. 4.5)
- (f) Provide the Program Logic Description to the Program Controller, for the program file. (Para. 4.6)
- (g) Provide verification documentation to the Program Controller for inclusion in the program file. This should include benchmark problems which the Program Controller can periodically repeat for verifying program integrity. (Para. 4.7.1)
- (h) Provide the input data list and any special input data procedures or calculations for the input map documentation for inclusion in the file. (Para. 4.8)
- (i) Provide the output data/example to the Program Controller for inclusions in the file. Expected computer running time should also be provided so the Program Controller can provide an estimate of computer run cost. (Para. 4.9)
- (j) Review the Installation Report (Exhibit 1 to ES 121) for accuracy and completeness. (Para. 4.10)

No.	ES 121	B
By	JBM	11-27-76
Apvd	djh	11-28-76
Page	12 of	

CONTROL AND MAINTENANCE PROCEDURES
FOR FCS ENGINEERING ANALYTICAL
COMPUTER PROGRAMS AND DATA BASES



©Fisher Controls

Rev	JCA	10-30-81
-----	-----	----------

6.3 Program Controller

- (a) Obtain program/database description and application information from the Program Author. (Para. 2.3)
- (b) Take out XXJAXX Series Project/File number by issuing an initial information sheet. This project number will be used to charge time spent (by the Program Author, Program Controller, and others) in program/database documentation activities per ES 121 (initial file, revisions, reviews) as long as the program/database is in active use. (Para. 2.1)
- (c) Add program/database to the Engineering Qualification and Analysis Group index file. (Para. 3.2)
- (d) Prepare and/or assemble data for the XXJAXX Program Documentation File (Cover sheet, Table of Contents, Abstract, JCL requirements, Source Code listing Location, Logic and Verification data, Input list, Output data and examples, expected program/database computer run cost). (Section 4)
- (e) Install program/database and run initial benchmark problems or printout to confirm correct installation. (Para. 3.1, 4.7.2)
- (f) Fill out Installation Report (Form 3475B) illustrated in Exhibit 1 of ES 121. Submit to the Program Author for review and include it in the XXJAXX documentation file. (Para. 4.10)
- (g) Establish an annual program/database review schedule and furnish a copy to the Program Author and to the Manager, Engineering Qualification and Analysis Group. [The annual reviews will include re-runs of the benchmark problem sets to demonstrate program integrity (or installation of new program input tapes for leased programs). Also any changes in the documentation file (such as ES document revisions) will be incorporated as a XXJAXX documentation file revision] (Para. 4.7.2)
- (h) Transfer the assembled XXJAXX Documentation File to the Fisher Information Center for Custody. (Para. 3.2)
- (i) When a program/database becomes inactive or obsolete, fill out a final summary, and close the XXJAXX project.

7. REFERENCES

- 7.1 ANSI/ASME NQA-1-1983. Quality Assurance Program Requirements for Nuclear Facilities.
- 7.2 ANSI/ANS 10.2-1982. Recommended Programming Practices to Facilitate the Portability of Scientific Computer Programs.
- 7.3 ANSI/ANS 10.5-1979. Guidelines for considering User Needs in Computer Program Development.
- 7.4 ANSI N413-1974. Guidelines for the Documentation of Digital Computer Programs.

Fisher Controls

Engineering Standard

No. ES 121 B

CONTROL AND MAINTENANCE PROCEDURES FOR FCS ENGINEERING ANALYTICAL COMPUTER PROGRAMS AND DATA BASES

By JBM 11-27-78

Apvd dlh 11-28-78

Page 13 of



©Fisher Controls

Rev JCD 10-30-85

EXHIBIT 1 Installation Report Form

COMPUTER PROGRAM / DATA BASE INSTALLATION REPORT

Subject of Report: [] computer program [] data base

Project File No. [] [] J A [] []

Name : _____

Author(s) : _____

Origin : [] Fisher [] Monsanto [] other _____

Module Name : _____

Source Code Location [] microfiche [] paper [] mag tape [] diskette

Program Location (compiled version) : [] FSHLIB (ST. Louis system) [] VAX (Fisher Controls system) [] P. C. (Fisher Controls system) [] other _____

Comments : _____

Program Author Review : _____ Date : _____

Program Controller Approval : _____ Date : _____

ATTACHMENT 13

FQP-11AB-7

OPERABILITY QUALIFICATION DATA

- a. BPC letter (Log BV 10286) to Fisher Controls dated 3-5-85 with BPC "Operability Qualification of Purge and Vent Valves".
- b. BPC letter (Log BV 10318) to Fisher Controls dated 3-25-85 concerning operability documentation.
- c. Fisher Controls memo dated 4-15-85, Whitsell to Pothast, with review of Bettis' torque values presented in the BPC "Operability Qualification of Purge and Vent Valves".

Bechtel Power Corporation

Engineers — Constructors
12440 East Imperial Highway
Norwalk, California 90650



MAIL ADDRESS
P.O. BOX 60660 - TERMINAL ANNEX, LOS ANGELES, CALIFORNIA 90060
TELEPHONE (213) 807-2000

March 5, 1985

Mr. Doug Potnast
Fisher Controls, Inc.
Marshalltown, IOWA 50158

Subject: Georgia Power Company
Plant Vogtle - Units 1 and 2
Bechtel Job 9510-001
P.O. Nos. PAV-206 and PAV-34
Butterfly Valves
File: X5AC03
Log: BV 10286

- References:
- A. Meeting between Fisher Controls, Inc. and Bechtel Corporation on February 15, 1985 at Marshalltown, Iowa (MN-1623)
 - B. Bechtel Power Corporation letter to Fisher Controls, Inc., BV-10211, dated February 7, 1985

Dear Mr. Potnast:

Attached for your records is the final draft of the "Operability Qualification of Purge and Vent Valves" incorporating the information agreed upon in reference A. This satisfies the requirement for information previously requested in reference B.

If you have any questions, please contact us.

Very truly yours,

BECHTEL POWER CORPORATION

H. G. Gronroos
Project Engineer
Western Power Division

FWK/NCB/WHJ/mel

Attachment: A. "Operability Qualification of Purge and Vent Valves"

xc: O. Batum w/att.
V-RMS w/att.

Operability Qualification of
Purge and Vent Valves

Demonstration of operability of the containment purge and vent valves and the ability of these valves to close during a design basis accident is necessary to assure containment isolation. This demonstration of operability is required by NUREG-0737, "Clarification of TMI Action Plan Requirements," II.E.4.2 for containment purge and vent valves which are not sealed closed during operational conditions 1, 2, 3 and 4.

1. For each purge and vent valve covered in the scope of this review, the following documentation demonstrating compliance with the "Guidelines for Demonstration of Operability of Purge and Vent Valves" (Attachment 2) is to be submitted for staff review:

- A. Dynamic Torque Coefficient Test Reports

- (Butterfly valves only) - including a description of the test setup.

- Response

- Testing has been performed by the butterfly valve supplier to obtain dynamic torque coefficients. See attachment 2.

- B. Operability Demonstration or In-situ Test Reports
(when used)

- Response

- Not Applicable

- C. Stress Reports

- Response

- The stress analysis for these valves are provided as part of the attachments.

- D. Seismic Reports for Valve Assembly (valve and operator)
and associated parts.

- Response

- The seismic reports for the valve assemblies are provided as part of the attachments.

E. Sketch or description of each valve installation showing the following (Butterfly valves only):

1. direction of flow
2. disc closure direction
3. curved side of disc, upstream or downstream (asymmetric discs)
4. orientation and distance of elbows, tees, bends, etc. within 20 pipe diameters of valve
5. shaft orientation
6. distance between valves

Response

See Table 1.

F. Demonstration that the maximum combined torque developed by the valve is below the actuator rating.

Response

YOKE ARM (DEGREES)	REQUIRED ACTUATOR TORQUE (in-lb.)	BETTIS ACTUATOR SPRING TORQUE (in-lb.)
0	3714.05	18828
10	1834.61	16628
20	2057.18	15602
30	2244.81	14268
40	3182.96	14345
50	3946.42	14952
60	6197.98	16088
70	8157.09	18845
80	11807.46	23362
90	11807.46	29640

See Table 2 and 3

2. The applicant should respond to the "Specific Valve Type Questions" (Attachment 1) which relate to his valve.

Response

See attachment 1.

3. Analysis, if used, should be supported by tests which establish torque coefficients of the valve at various angles. As torque coefficients in butterfly valves are dependent on disc shape, aspect ratio, angle of closure flow direction and approach flow, these things should be accurately represented during tests. Specifically, piping installations (upstream and downstream of the valve) during the test should be representative of actual field installations. For example, non-symmetric approach flow from an elbow upstream of a valve can result in fluid dynamic torques of double the magnitude of those found for a valve with straight piping upstream and downstream.

Response

Although testing was not performed to establish torque coefficients at various valve angles, analytical techniques used by the valve supplier are based on model testing experience and scaling developed over many years. More information is presented in attachment 2.

4. In-situ tests, when performed on a representative valve, should be performed on a valve of each size/type which is determined to represent the worst case load. Worst case flow direction, for example, should be considered.

Response

Not applicable. In-situ tests are not performed.

5. For two valves in series where the second valve is a butterfly valve, the effect of non-symmetric flow from the first valve should be considered if the valves are within 15 pipe diameters of each other.

Response

The valves are located 22'-5" and 22'-9 9/16" from each other (HV-2626B to HV-2627B and HV-2628B to HV-2629B respectively) or approximately a distance of 19 pipe diameters, which is not within the 15 pipe diameters limitation.

6. If the applicant takes credit for closure time vs. the buildup of containment pressure, he must demonstrate that the method is conservative with respect to the actual valve closure rate. Actual valve closure rate is to be determined under both loaded and unloaded conditions (if valves close faster at all angles of opening under loaded conditions, no load closure time may be used as conservative) and periodic inspection under tech. spec. requirements should be performed to assure closure rate does not increase with time or use.

Response

No credit was taken for closure time vs. the buildup of containment pressure. See attachment 2.

TABLE 1

Valve Tag Number	HV-2626B	HV2627B	HV2628B	HV2629B
1. Direction of Flow	Inlet-butt weld end outlet-raised face	Inlet-raised face outlet-butt weld end	Inlet-raised face outlet-butt weld end	Inlet-butt weld end outlet-raised face
2. Disc closure Direction	Clockwise	Clockwise	Clockwise	Clockwise
3. Curved side of disc	Upstream	Downstream	Downstream	Upstream
4. Orientation and distance of elbows, tee, bend within 20 pipe diameter of valve.	Tee-19'5" upstream, horizontal line 90° elbow-11'-6-1/4" upstream horizontal line. Tee-6'-9-11/16" upstream, vertical line. 90° elbow-2'8-11/16 upstream, vertical line. Flow orifice-23'-6-5/8 upstream, vertical line. Flow orifice-1'-10-1/4" downstream, horizontal line.	Tee-3'-0" downstream horizontal line. 90° elbow-10'-10-3/4" downstream, horizontal line. Tee-15'-7-5/16" downstream, vertical line. 90° elbow-19'-8-5/16" downstream vertical line. Flow orifice-1'-1-5/8" upstream, vertical line. Flow orifice-24'-3-1/4" downstream, horizontal line.	Tee-18'-9-9/16 upstream, horizontal line. 90° elbow-11'-9-3/4" upstream, horizontal line. Tee-3'-9-3/4" upstream, vertical line. 90° elbow-1'-8-3/4" upstream, vertical line. Flow orifice-25'-4-9/16" upstream, horizontal line. Flow orifice-1'10-1/2" downstream, horizontal line. Flow orifice-1'-10-1/8" downstream, horizontal line.	Tee-4'-0" downstream, horizontal line. 90° elbow-10'11-13/16 downstream horizontal line. Tee-16'-11'-3/16 downstream vertical line. 90° elbow-21-0-3/16" downstream, vertical line. Flow orifice-2'-7" upstream, horizontal line. Flow orifice-24'-7-10/16" downstream, horizontal line.
90 5. Shaft orientation.	Vertical	Vertical	Vertical	Vertical
6. Distance between valves.	22'-5" (between - V-2626B & 2627B)	22'-9-9/16" (between HV-2628B & 2629B)		

TABLE

ACTUATOR TORQUE CALCULATIONS

REV. B

REF. NO. CASE 4
 VALVE TYPE 9280
 SHAFT MAT. SA-564 H1075 31-39
 DISC-SHAFT CON. PINNED
 FLOW DIR. TOWARD HUB
 DATE 02-11-85

TEMP. 320 DEG F
 VALVE SIZE 14 INCH
 BUSH. MAT. BRONZE/GRAPHITE
 DRIVE-SHAFT CON. KEYED

BY JON C. WHITESSELL

INPUT DATA

ANG	0.0	10.000	20.000	30.000	40.000	50.000	60.000	70.000	80.000	90.000
DDISC	13.244	13.244	13.244	13.244	13.244	13.244	13.244	13.244	13.244	13.244
DELTP	60.000	50.000	50.000	50.000	50.000	50.000	50.000	50.000	50.000	50.000
DLO	0.906	0.906	0.906	0.906	0.906	0.906	0.906	0.906	0.906	0.906
TS	2037.000	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
TI	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DM	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
DTF	0.0	15.400	32.000	50.000	108.000	194.000	368.000	742.000	1145.000	1145.000
DPIN	60.000	50.000	50.000	50.000	50.000	50.000	50.000	50.000	50.000	50.000
DELTPF	60.000	0.400	0.300	0.250	0.250	0.200	0.200	0.140	0.140	0.140
STSH	98.000	98.000	98.000	98.000	98.000	98.000	98.000	98.000	98.000	98.000
SBUSH	85.000	85.000	85.000	85.000	85.000	85.000	85.000	85.000	85.000	85.000
C1	0.500	0.500	0.500	0.500	0.500	0.500	0.500	0.500	0.500	0.500
C2	0.750	0.750	0.750	0.750	0.750	0.750	0.750	0.750	0.750	0.750
BSHTYP	2	2	2	2	2	2	2	2	2	2
DSHFT	1.748	1.748	1.748	1.748	1.748	1.748	1.748	1.748	1.748	1.748

GENERATED VARIABLES

ST	51450.00	51450.00	51450.00	51450.00	51450.00	51450.00	51450.00	51450.00	51450.00	51450.00
SS	25725.00	25725.00	25725.00	25725.00	25725.00	25725.00	25725.00	25725.00	25725.00	25725.00
SH	8500.00	8500.00	8500.00	8500.00	8500.00	8500.00	8500.00	8500.00	8500.00	8500.00

OUTPUT

ACT.TORQ	3714.0564	1834.6165	2057.1843	2244.8140	3182.9634	3946.4241	6197.9805	8157.0937	11807.4687	11807.4687
STRS1	8087.2656	6147.9375	6225.5703	6300.2148	6779.6562	7269.5391	9003.0859	10684.2070	13981.1289	13981.1289
STRS2	4509.1367	3166.1660	3243.7979	3318.4426	3797.8850	4287.7695	6021.3125	7702.4336	10999.3555	10999.3555
STRS3	5044.8281	2982.0837	3194.6082	3373.7705	4269.5820	4998.5898	7148.5391	9019.2461	12504.8906	12504.8906
STRS4	5490.2148	2130.3176	2555.5364	2914.0049	4706.3477	6164.9492	10466.5742	14209.4844	21183.5664	21183.5664
STRS5	4730.4961	2336.7039	2620.1831	2859.1621	4054.0593	5026.4570	7894.2109	10389.4844	15038.8750	15038.8750
STRS6	1353.6267	1128.0229	1128.0229	1128.0229	1128.0229	1128.0229	1128.0229	1128.0229	1128.0229	1128.0229

8810-AXGAC03-5151-2 303

TABLE 2



VARIABLE NAME	VARIABLE DESCRIPTION
	<u>INPUT DATA</u>
ANG	ANGLE IN DEGREE
DDISC	DISC DIAMETER (UNITS: IN)
DELTP	PRESSURE DROP IF ITYP = 1 (UNITS: PSI)
DSHFT	SHAFT DIAMETER IF ITYP = 2 (UNITS: IN)
DSHFT	SHAFT DIAMETER IF ITYP = 3 (UNITS: IN)
DLO	HUB TO BUSH DISTANCE (UNITS: IN) FROM DRAWING 
TS	SEATING TORQUE (UNITS: IN-LBS) (FOR 0 DEGREE ANGLE ONLY) REFER TO TEST REPORT #92.3-44 SIZING EQUATION FOR 9200 (NEW EQUATION)
TI	INERTIAL TORQUE (UNITS: IN-LBS) (FOR FAST STROKING SPEED ONLY, LESS THAN $\frac{1}{2}$ SEC)
DM	AMOUNT OF CAM (UNITS: IN) FROM DRAWING 
DTF	DYNAMIC TORQUE FACTOR FROM SALES HANDBOOK: CFG 40B-10, C VALUES FOR 9200 SERIES, FLOW AGAINST HUB USE 1.5 C
DPIN	INLET PRESSURE (UNITS: PSIG) FROM REQUISITION IF ITYP = 3 LEAVE IT BLANK
DELTPF	EFFECTIVE PRESSURE DROP FACTOR FROM SALES HANDBOOK: CFG 40B-10, TABLE 1 (DO NOT INCLUDE P_1 , ONLY COEFFICIENT)
STSH	SHAFT STRENGTH FACTOR Σ FROM SALES HANDBOOK: CPG 20D-10
SBUSH	BUSH. STRENGTH FACTOR Σ FROM SALES HANDBOOK: CFG 20D-10
C1	DISC TO SHAFT CONCENTRATION FACTOR FOR PIN = 0.5, KEY = 0.75
C2	DRIVE TO SHAFT CONCENTRATION FACTOR FOR PIN = 0.5, KEY = 0.75


TABLE 2

VARIABLE NAME	VARIABLE DESCRIPTION
BSHTYP	<p data-bbox="527 497 1089 561">BUSH.TYPE.NO. FROM SALES HANDBOOK: CFG 20D-10</p> <p data-bbox="527 597 1235 661">NOTE: 1. ALL ARE REAL NUMBERS EXCEPT BSHTYP (BSHTYP-INTEGER)</p> <p data-bbox="639 693 1300 757">2. REPEAT CARDS 2 THROUGH 3 FOR NUMBER OF SHAFT CALCULATIONS</p> <p data-bbox="639 789 1268 853">3. REPEAT CARDS 3A AND 3B FOR NUMBER OF ANGLES FOR EACH SHAFT CALCULATION .</p> <p data-bbox="786 2002 834 2034">(3)</p>

TABLE 3

T316 SR2

YOKE ARM ANGLE (degrees)	SPRING TORQUE (in lb)	PRESSURE TORQUE (50)psi	PRESSURE TORQUE (60)psi	PRESSURE TORQUE (70)psi	PRESSURE TORQUE (80)psi
0	18828	19187	26587	33986	41386
15	15602	12435	17949	23463	28977
30	14268	9444	14147	18851	23554
45	14394	8053	12542	17031	21521
60	16088	7532	12300	17069	21837
75	20224	7572	13256	18941	24625
90	29640	7778	15600	23422	31245



ATTACHMENT 1

SPECIFIC VALVE TYPE QUESTIONS
AND RESPONSES FOR VEGP PURGE VALVES

Operability Qualification
of Purge and Vent Valves

Specific Valve Type Questions

The following questions apply to specific valve types only and need to be answered only where applicable. If not applicable, state so.

A. Torque Due to Containment Backpressure Effect (TCB)

For those air operated valves located inside containment, is the operator design of a type that can be affected by the containment pressure rise (backpressure effect) i.e., where the containment pressure acts to reduce the operator torque capability due to TCB. Discuss the operator design with respect to the air vent and bleeds. Show how TCB was calculated (if applicable).

Response

- a. The valves are equipped with BETTIS NT316B-SR2-M3 spring-return actuators. The spring side of the cylinder actuator is vented to the local ambient conditions; if the pressure side is vented (through the solenoid) to the same local ambient conditions, no pressure differential will exist across the cylinder as a result of surrounding local pressure rise. The spring will still drive the actuator to the safety-mode (closed) position and maintain that position as long as the solenoid remains de-energized and as long as no subsequent re-opening signal is received.
- In the event of a delay in solenoid de-energization, a local ambient pressure rise will reduce the ΔP across the cylinder, which will initially partially close the valve. When the solenoid subsequently de-energizes and vents, the spring would complete the closure stroke.
- b. In the event the external ambient pressure is maintained at an elevated level for a prolonged period with the solenoid still energized, and providing the regulator is vented to the same ambient level with a sufficiently high supply, the regulator would eventually adjust the air supply to the cylinder actuator to re-establish the initial full-open position.
- c. Adequate spring-driven torque output is available from the actuator to control the valve from any open or closed position (regardless of external ambient pressure), providing the cylinder casing is vented (locally). The torque available is well within the capabilities of the NT316B-SR2-M3.

- B. Where air operated valve assemblies use accumulators as the fail safe feature, describe the accumulator air system configuration and its operation. Discuss active electrical components in the accumulator system, and the basis used to determine their qualification for the environmental conditions experienced. Is this system seismically designed? How is the allowable leakage from the accumulators determined and monitored?

Response - Not Applicable.

- C. For valve assemblies requiring a seal pressurization system (inflatable main seal), describe the air pressurization system configuration and operation including means used to determine their qualification for the environmental condition experienced. Is this system seismically designed?

Response - Not Applicable.

- D. Where electric motor operators are used to close the valve has the minimum available voltage to the electric operator under both normal or emergency modes been determined and specified to the operator manufacturer to assure the adequacy of the operator to stroke the valve at accident conditions with these lower limit voltages available? Does this reduce voltage operation result in any significant change in stroke timing? Describe the emergency mode power source used.

Response - Not Applicable.

- E. Where electric motor and air operator units are equipped with handwheels, does their design provide for automatic re-engagement of the motor operator following the handwheel mode of operation? If not, what steps are taken to preclude the possibility of the valve being left in the handwheel mode following some maintenance, test, etc. type operation?

Response - Not Applicable.

- F. For electric motor operated valves have the torques developed during operation been found to be less than the torque limiting settings?

Response - Not Applicable.

ATTACHMENT 2

VEGP DEMONSTRATION OF OPERABILITY

OF PURGE AND VENT VALVES

Guidelines for Demonstration
of Operability of Purge and
Vent Valves

Operability

In order to establish operability, it must be shown that the valve actuator's torque capability has sufficient margin to overcome or resist the torques and/or forces (i.e., fluid dynamic, bearing, seating, friction) that resist closure when stroking from the initial open position to full seated (bubble tight) in the time limit specified. This should be predicted on the pressure(s) established in the containment following a design basis LOCA. Considerations which should be addressed in assuring valve design adequacy include:

1. Valve closure rate versus time - i.e., constant rate or other.

Response

In the case of a cylinder, spring-return actuator (such as the BETTIS NT316B-SR2-M3, Push Down to Open), full travel is achieved at a cylinder pressure of approximately 60 psig. Cylinder pressurization up to 60 psig is done to provide the maximum torque capability (hold-open torque) at 90 travel. Therefore the spring will not start to move the valve shaft linkage until some cylinder pressure bleed-down through the solenoid occurs (when the solenoid is de-energized).

When calculations were done to determine the allowable P at open angles, the assumption was made that the peak containment pressure (50 psig) was present immediately at the onset of the LOCA accident condition. This is a conservative approach since the buildup from ambient to 50 psig has been specified to occur in 5 seconds. No time-history study was made, since maximum conditions were assumed at the onset.

The Type NT316B-SR2-M3 actuator cylinder pressurized volume has to be expelled through a 3/4" NPT connection (Cv=7.5) connected to a NP831674E solenoid, in order for closure action to occur. There is minimal restriction in the solenoid (Cv=5.5), so that the pressure line to the actuator is immediately vented when the normally closed solenoid is de-energized upon receipt of the closure (safety-mode) signal .

Production valve stroking times were demonstrated as required (for each valve assembly) prior to shipment. At this point, the best stroking time data could be obtained by timing the installed valve assemblies during a field stroking test, conducted at the plant site.

When stroking time calculations or testing is done, lag times due to cylinder overpressure venting are considered and included

when supplying stroking data, i.e. the closure/opening times are noted from the time the solenoid signal is received, not from the time the actuator starts to move.

2. Flow direction through valve; P across valve.

Response

Peak containment (LOCA) pressure (50 psig, @ 320°F) was used in determining the fluid conditions across the valve at all open angles of rotation (10° to 90°). P across the valve was considered equal to peak containment pressure (PSIG). Material properties were evaluated at peak containment temperatures. The effect of compressible flow in sizing Fisher butterfly valves is best explained by the following:

AIR VS WATER SERVICE

Whenever a Fisher butterfly valve is in a gas flow application, the effects due to compressible flow are taken into consideration while determining the dynamic torque effects for each individual valve selection. This consideration is built into our valve selection procedures and requires a conscious liquid or gas decision in calculating the effective pressure drop of which the dynamic torque is a function.

Fisher's philosophy concerning the effects of compressible flow on butterfly valves is presented in ISA Transactions, Vol. 8, No. 4 entitled, "Effect of Fluid Compressibility on Torque in Butterfly Valves", written by Floyd P. Harthun (Manager, Product Evaluation, Fisher Controls Co. (Attachment 4)).

3. Single valve closure (inside containment or outside containment valve) or simultaneous closure. Establish worst case.

Response

No credit is taken for reduced pressure due to valves in series. Vogtle valves are designed for the maximum in-containment pressure.

4. Containment back pressure effect on closing torque margins of air operated valve which vent pilot air inside containment.

Response

See response to Item A in attachment 1.

5. Adequacy of accumulator (when used) sizing and initial charge for valve closure requirements.

Response - Not Applicable.

6. For valve operators using torque limiting devices - are the settings of the devices compatible with the torques required to operate the valve during the design basis condition.

Response - Not Applicable.

7. The effect of the piping system (turns, branches) upstream and downstream of all valve installations.

Response

All Fisher sizing data is based on dynamic torque determination tests which were performed with uniform flow profiles and on valve discs with representative geometries. The effects of a non-uniform flow profile, due to piping elbows, "T"-connections, etc., upstream, are discussed below.

The concern over geometrical piping system effects is relevant, since Fisher typically sizes butterfly valves assuming a uniform flow profile. A non-uniform flow could produce a non-uniform flow as illustrated by Figure A of Attachment 3. (handwritten note)

a. Valve/Flow Orientation, Figure A

The plant layout is such that the valve is oriented to the flow as depicted in Fig. A (Attachment 3), the non-uniform fluid profile will not produce an additional torque on the valve disc since both "wings" of the disc (as split by the shaft) will be subjected to the same flow with respect to time.

8. The effect of butterfly valve disc and shaft orientation to the fluid mixture egressing from the containment.

Response

See Item No. 7 response above.

Demonstration

Demonstration of the various aspects of operability of purge and vent valves may be by analysis, bench testing, in-situ testing or a combination of these means.

Purge and vent valve structural elements (valve/actuator assembly) must be evaluated to have sufficient stress margins to withstand loads imposed while valve closes during a design basis accident. Torsional shear, shear, bending, tension and compression loads/stresses should be considered. Seismic loading should be addressed.

Once valve closure and structural integrity are assured by analysis, testing or a suitable combination, a determination of the sealing integrity after closure and long term exposure to the containment environment should be evaluated. Emphasis should be directed at the effect of radiation and of the containment spray chemical solutions on seal material. Other aspects such as the effect on sealing from outside ambient temperatures and debris should be considered.

The following considerations apply when testing is chosen as a means for demonstrating valve operability:

Bench Testing

- A. Bench testing can be used to demonstrate suitability of the in-service valve by reason of its traceability in design to a test valve. The following factors should be considered when qualifying valves through bench testing.
 1. Whether a valve was qualified by testing of an identical valve assembly or by extrapolation of data from a similarly designed valve.

Response

In determining allowable pressure drops across a particular butterfly valve at various angles of the disc, Fisher Controls uses classical "mechanics of materials" type equations to calculate stress levels at various worst-case locations in the valve assembly (specifically, various locations along the valve shaft). The approach to the analysis, the equations used, and the combination of the calculated stresses all make up a portion of Fisher's design philosophy for butterfly valves. This analysis approach addresses all of the different states of shear and stress which are applicable to the loading conditions defined.

Establishing the loads that actually exist makes up the remaining portion of our design philosophy for butterfly valves. These loads range from easily calculated loads, such as bending due to pressure differential across the disc, to loads such as packing and dynamic torques which

require a certain amount of testing combined with scaling in order to analyze all valve sizes. It is the factor of dynamic torque that produces different stresses at different disc rotations and disc geometries. Through testing and scaling, Fisher has produced dynamic torque factors for incremental disc rotations.

The model tests used to establish the dynamic torque values used in sizing were conducted using 4" and 6" test valves with various aspect ratios ranging from 2:1 to 14:1 (such as 3:1, 4:1, 5:1, 8:1, 11:1, and 14:1). The dimensionless aspect ratio (defined as the ratio of the disc diameter to the hub diameter) was judged to be a significant parameter for evaluation of dynamic torques at various opening angles. The tests were conducted using the Fluid Controls Institute (FCI) specifications for test arrangement and conduct, per FCI paper 58-2.

No published data is available describing the precise scaling procedure used in establishing the sizing tables. However, the general approach is described in some detail in ISA Transactions, Vol. 8, No. 4, "Effects of Fluid Compressibility on Torque in Butterfly Valves" (Attachment 4). All of the testing, scaling and analytical results referenced above have been compiled and tabulated for all available valve sizes, classes, and materials, making it relatively easy to determine the allowable pressure drops, torque requirements, and capacities for specific constructions.

2. Whether measures were taken to assure that piping upstream and downstream and valve orientation are simulated.

Response

No credit was taken for downstream back pressure on the design of these valves. All design constraints for upstream piping provided by the valve supplier are factored into the system design.

3. Whether the following load and environmental factors were considered
 - a. Simulation of LOCA
 - b. Seismic loading
 - c. Temperature soak
 - d. Radiation exposure
 - e. Chemical exposure
 - f. Debris

Response

Simulation of LOCA, seismic loading, temperature soak, radiation exposure, and chemical exposure are delineated in Fisher Qualification Report FQP-11A. Debris was not considered because debris screens have been provided upstream of the valves to prevent debris from interfering with valve closure. Seismic loading is supplemented by seismic analysis, resonant frequency search testing, and seismic static loading of a Vogtle production valve.

- B. Bench testing of installed valves to demonstrate the suitability of the specific valve to perform its required function during the postulated design basis accident is acceptable.
1. The factors listed in Items A.2 and A.3 should be considered when taking this approach.

Response - Not Applicable.

In-Situ Testing

In-situ testing of purge and vent valves may be performed to confirm the suitability of the valve under actual conditions. When performing such tests, the conditions (loading, environment) to which the valve(s) will be subjected during the test should simulate the design basis accident.

NOTE: Post test valve examination should be performed to establish structural integrity of the key valve/ actuator components.

Response - Not Applicable.

Attachment 3: Piping System Sketches, Figures A and B




FIGURE A

Attachment 4: ISA TRANSACTIONS, Vol. 8, No. 4,
"Effects of Fluid Compressibility
on Torque in Butterfly Valves"

REPRINTED FROM



ISA

A publication of
INSTRUMENT
SOCIETY
of
AMERICA

Volume 8, Number 4

1969

TRANSACTIONS

**Effect of Fluid Compressibility
on Torque in Butterfly Valves**

FLOYD P. HARTHUN

Compliments of Fisher Controls Company

Effect of Fluid Compressibility on Torque in Butterfly Valves*

FLOYD P. KARTHUN†

*Fisher Governor Company
Marshalltown, Iowa*

► A technique is presented by which the shaft torque resulting from fluid flow through butterfly valves can be determined with reasonable accuracy for both compressible and incompressible flow. First, the general torque relationship for incompressible flow is established. Then, an effective pressure differential is defined to extend this relationship to include the effect of fluid compressibility. The application of this technique showed very good agreement with experimental test results.

INTRODUCTION

THE APPLICATION of butterfly valves in various automatic control systems requires proper actuator sizing for efficient control. Thus, a thorough knowledge of the fluid reaction forces acting on the valve disc is required. Extensive experimental work⁽¹⁾ has been performed in the past to establish a relationship to determine these forces and thus determine the resultant shaft torque. The general form of this relationship has been established and confirmed. However, by using the classical fluid momentum approach, a similar relationship can be obtained in which the torque is shown to be directly proportional to the measured valve pressure differential for a given disc position. This relationship along with most of the previously published torque information is adequate for incompressible flow. Although the effect of fluid compressibility on torque has been recognized, no useful relationship has been developed. The primary objective of this investigation is to extend the established torque relationship to include the effect of fluid compressibility.

*Presented at the 1968 ISA Annual Conference; revised August, 1969.

†Research Engineer.

DEVELOPMENT OF GENERAL TORQUE RELATIONSHIP

The total shaft torque required to operate butterfly valves can be separated into two major components:

1. Dynamic torque—that portion of the total operating torque attributable to the fluid reaction force of the flowing medium acting on the valve disc.
2. Friction torque—that portion of the total operating torque attributable to friction in the packing and bushings.

Since each of these components is independent of the other, a separate evaluation of each component affords the best approach to this problem. This investigation is limited to an evaluation of the dynamic torque component. If the friction on the valve shaft is assumed to be independent of direction of rotation, it can be readily isolated. The torque required to rotate the valve disc is measured in a clockwise and a counterclockwise direction through full travel. Since friction always opposes motion the difference between these values will be twice the actual shaft friction.

The dynamic torque for butterfly valves is a function of the fluid reaction forces acting on the valve disc. It would be difficult to determine these forces by purely analytical techniques. Experimental determination of the pressures and velocity profiles in the immediate area of the disc would also be quite difficult. However, if a control volume is selected so the boundaries are points of known pressure and velocity, an analysis of these forces can be made from the change in fluid momentum through this control volume.

INCOMPRESSIBLE FLOW

An expression for dynamic torque is developed assuming incompressible flow. This torque is a function of the fluid reaction force, F , and a moment arm, D , which is a characteristic dimension of the valve disc.

$$T_D = f(F, D) \quad (1)$$

Using the fluid momentum approach, the force, F , is given by:

$$F = M\Delta V \quad (2)$$

where

- F = sum of external forces acting on fluid
- M = mass flow rate
- ΔV = fluid velocity change through the control volume

The mass flow rate, M , is given by

$$M = \rho AV \quad (3)$$

By using a proportionality constant, B_1 , the mass flow rate can also be defined as

$$M = B_1 A (\rho \Delta P)^{1/2} \quad (4)$$

Equations (3) and (4) are combined to obtain the following expression for fluid velocity:

$$V = B_1 (\Delta P / \rho)^{1/2} \quad (5)$$

The velocity change through the control volume, ΔV , in Equation (2) can be expressed in terms of the velocity at the valve disc by use of a proportionality constant, B_2

$$F = B_2 M V \quad (6)$$

By substituting the expressions for mass flow rate Equation (4) and fluid velocity Equation (5) into Equation (6) the force on the valve disc is

$$F = B_1^2 B_2 A \Delta P \quad (7)$$

For a given valve size, the flow area, A , for any angle of disc rotation, θ , can be written as

$$A = B_\theta \frac{\pi D^2}{4} \quad (8)$$

The force, F , acts upon a moment arm which is a function of the disc diameter, D . Now, the dynamic torque can be written as

$$T_D = B_3 F D \quad (9)$$

Combining Equations (7), (8), and (9)

$$T_D = \frac{B_1^2 B_2 B_3 B_\theta \pi D^3 \Delta P}{4} \quad (10)$$

or

$$T_D = K_1 D^3 \Delta P \quad (10-A)$$

where

$$K_1 = \frac{B_1^2 B_2 B_3 B_\theta \pi}{4} = \frac{T_D}{D^3 \Delta P} \quad (10-B)$$

Equation (10-B) is defined as the dimensionless torque coefficient which can be determined experimentally from tests conducted with incompressible flow.

COMPRESSIBLE FLOW

The dynamic torque for butterfly valves is proportional to the mass flow rate and velocity change through a selected control volume for both compressible and incompressible flow (i.e., $T_D \propto M\Delta V$). Therefore, the approach used to obtain an expression for this torque assuming incompressible flow can be extended to compressible flow by re-defining these two variables.

First, assume that the velocity at the valve disc, V_d , is proportional to the velocity change through the control volume. Then, the dynamic torque can be expressed as

$$T_D \propto M V_d \quad (11)$$

The velocity at the valve disc is given by

$$V_d = \frac{M}{\rho_d A} \quad (12)$$

By combining Equations (11) and (12) the dynamic torque is shown to vary directly as the square of the mass flow rate and inversely with the fluid density at the valve disc.

$$T_D \propto \frac{M^2}{\rho_d} \quad (13)$$

Determining the flow rate of a compressible fluid through a control valve by analytical techniques is quite difficult because of valve geometry. The major problem is to establish the pressure differential between the valve inlet and the vena contracta. However, by defining the physical system in which the valve is installed to conform with specifications given by the Fluid Controls Institute (FCI),⁽²⁾ empirical relationships developed specifically for determining flow rate for control valves can be considered. Several such empirical relationships have been developed; however, only one, the Universal Gas Sizing Equation,⁽³⁾ has been shown to accurately define the flow rate for any valve configuration. This equation is given by

$$Q = \sqrt{\frac{520}{GT}} P_1 C_1 C_2 C_v \sin \left[\frac{59.64}{C_1 C_2} \sqrt{\frac{\Delta P}{P_1}} \right]_{rad} \quad (14)$$

Equation (14) can be rewritten to obtain an equivalent expression for mass flow rate,

$$M = 1.06 \sqrt{\rho_1 P_1} C_1 C_2 C_v \sin \left[\frac{59.64}{C_1 C_2} \sqrt{\frac{\Delta P}{P_1}} \right]_{\text{rad}} \quad (15)$$

The sine function in Equations (14) and (15) is used to define the transition between incompressible flow occurring at low pressure ratios ($\Delta P/P_1$) and critical flow.

Let

$$\theta = \left[\frac{59.64}{C_1 C_2} \sqrt{\frac{\Delta P}{P_1}} \right]_{\text{rad}} \quad (16)$$

Rewriting Equation (15) in the following manner:

$$M = 1.06 \sqrt{\rho_1 P_1} C_1 C_2 C_v F \quad (17)$$

The factor, F , is bounded by the following:

$$F = \sin \theta \quad \text{for } \theta < \pi/2$$

$$F = 1.0 \quad \text{for } \theta \geq \pi/2 \quad (18)$$

By substituting Equation (17) for the mass flow rate in Equation (13), the dynamic torque for a given valve is given by

$$T_D \propto \frac{\rho_1 P_1 (C_1 C_2 \sin \theta)^2}{\rho_d} \quad (19)$$

The only parameter in Equation (10) that cannot be readily obtained is the density at the valve disc, ρ_d . Assuming that the change in the ratio of fluid density at the valve inlet to fluid density at the valve disc with increasing pressure ratio is small relative to the total change in mass flow rate, the torque expression can be simplified in the following manner:

$$T_D \propto P_1 (C_1 C_2 \sin \theta)^2 \quad (20)$$

Therefore, for compressible flow:

$$T_D = K_2 P_1 (C_1 C_2 \sin \theta)^2 \quad (21)$$

For small values of pressure ratio ($\Delta P/P_1$) Equation (21) reduces to the incompressible torque relationship given by Equation (10-A).

As $\Delta P/P_1 \rightarrow 0$

$$\sin \theta = \theta \text{ (radians)}$$

$$T_D = K_2 (59.64)^2 \Delta P \quad (22)$$

The expression in Equation (22) is equivalent to the expression in Equation (10-A):

$$K_2 (59.64)^2 \Delta P = K_1 D^3 \Delta P$$

$$K_2 = \frac{K_1 D^3}{(59.64)^2} \quad (23)$$

By substituting the expression in Equation (23) for the coefficient K_2 in Equation (21), a general expression for dynamic torque for compressible flow is obtained using the dimensionless torque coefficient established for

incompressible flow.

$$T_D = K_1 D^3 P_1 \left[\frac{C_1 C_2}{59.64} \right]^2 \sin^2 \theta \quad (24)$$

For convenience the form of Equation (24) is simplified,

$$T_D = K_1 D^3 \Delta P_e \quad (25)$$

where

$$\Delta P_e = P_1 \left[\frac{C_1 C_2}{59.64} \right]^2 \sin^2 \theta \quad (26)$$

Equation (26) is defined as the pressure differential contributing to the dynamic torque on butterfly valves with conditions of compressible flow.

EXPERIMENTAL RESULTS

The first step in the experimental evaluation was to establish the dimensionless torque coefficient, K_1 , as a function of valve disc rotation as defined by Equation (10-B). A test was conducted on a 4-in. valve under the following controlled conditions:

1. The valve was installed in a 4-in. test line with a minimum of 12 pipe diameters of straight pipe upstream.
2. The pressure taps were located according to FCI specifications and attached to the test line according to specifications in the *ASME Power and Test Code*.⁽⁴⁾
3. Water at ambient temperature was used as the flowing medium.
4. The inlet pressure and outlet pressure were held constant.
5. The test was conducted at a low pressure ratio ($\Delta P/P_1 = 0.088$) to ensure incompressible flow.




Figure 1. Dimensionless torque coefficient, 4-in. butterfly valve incompressible flow: $P_1 = 100$ psig, $P = 110$ psi.




Figure 2. Dynamic torque vs. angle of disc rotation, 4-in. butterfly valve, comparison of experimental results with calculated torque, incompressible flow: $P_1 = 160$ psig, $\Delta P = 5$ psi.

Torque measurements were made at selected increments of disc rotation (0-90°). A transducer, consisting of a steel bar with strain gages attached, was fixed to the valve shaft and used in conjunction with an oscillograph to measure and record the shaft torque. The data from this test were used to determine the dimensionless torque coefficient plotted as a function of disc rotation on Figure 1. The curves plotted on Figure 2 show excellent agree-




Figure 4. Dynamic torque vs. angle of disc rotation, 8-in. butterfly valve, comparison of experimental results with calculated torque, incompressible flow: $P_1 = 100$ psig, $\Delta P = 5$ psi.

ment between measured torque and the torque calculated using this coefficient.

The next step was to verify that the torque coefficient is indeed applicable to other valve sizes provided geometric similarity is reasonably well maintained. The results on Figures 3 and 4 again show very good agreement between measured torque and calculated torque for two 8-in. valves.




Figure 3. Dynamic torque vs. angle of disc rotation, 8-in. butterfly valve, comparison of experimental results with calculated torque, incompressible flow: $P_1 = 100$ psig, $\Delta P = 5$ psi.




Figure 5. Dynamic torque vs. valve pressure drop, 4-in. butterfly valve, 60° disc rotation, comparison of experimental results with calculated torque, compressible flow: $P_1 = 214.4$ psia, flowing medium = air.




Figure 6. Dynamic torque vs. angle of disc rotation, 4-in. butterfly valve, comparison of experimental results with calculated torque, compressible flow: $P_1 = 114.4$ psia, $\Delta P = 5$ psi ($\Delta P/P_1 = 0.0446$), flowing medium = air.

It should be noted that discs in the two 8-in. valves were of substantially different geometric shape. Using the ratio of disc diameter to hub diameter as an indicator, these ratios were 4.56:1 and 3.55:1 for the valves used to obtain the data for Figures 3 and 4, respectively. The difference in torque magnitude for these valves with a 5 psi pressure differential shown in Figures 3 and 4 is the result of this difference in geometry. The disc in the 8-in. valve used for the test in Figure 3 was geometrically




Figure 7. Dynamic torque vs. angle of disc rotation, 4-in. butterfly valve, comparison of experimental results with calculated torque, compressible flow: $P_1 = 64.4$ psia, $\Delta P = 10$ psi ($\Delta P/P_1 = 0.115$), flowing medium = air.




Figure 8. Dynamic torque vs. angle of disc rotation, 4-in. butterfly valve, comparison of test results with calculated torque, compressible flow: $P_1 = 64.4$ psia, $\Delta P = 30$ psi ($\Delta P/P_1 = 0.466$), (critical flow) flowing medium = air.

similar to the disc in the 4-in. test valve used to establish the torque coefficient, K_1 .

The extension of the dynamic torque relationship to include the effect of fluid compressibility is accomplished by defining an effective pressure differential as shown in Equation (25). The curves on Figure 5 show the transition from incompressible flow to critical flow with increasing pressure ratio for a 4-in. valve set at 60° disc rotation. Here again there is very good agreement between the torque calculated using Equation (24) and the experimental results. The incompressible torque curve is also shown on Figure 5 to emphasize the effect of fluid compressibility.

The curves on Figures 6 through 8 are presented to compare experimental results with torque calculated using Equation (24) for full 90° disc rotation. At low pressure ratios, the torque using air as the flowing medium is essentially equal to the torque for incompressible flow (Figure 6). As the pressure ratio is increased, the effect of fluid compressibility becomes more pronounced as shown in Figure 7. Once critical flow has been attained, no further increase in torque is realized by increasing the valve pressure differential as shown on Figure 8.

CONCLUSIONS

A technique is presented which can be used to determine the dynamic torque for butterfly valves with reasonable accuracy. The basic torque relationship developed for incompressible flow is extended to include the effect of fluid compressibility. The method presented is developed

using the Universal Gas Sizing Equation to define an effective pressure differential for the transition from incompressible flow to critical flow. Application of this method shows excellent agreement with experimental test results.

NOTATION

A = Flow area, in.²
 B_1, B_2 = Constants of proportionality
 $C_1 = C_2/C_3$
 C_2 = Correction factor for variation in specific heat ratio
 C_3 = Gas sizing coefficient
 C_4 = Flow coefficient
 C = Nominal valve diameter, in.
 F = Force, lb
 G = Specific gravity
 K_1 = Dimensionless torque coefficient
 M = Mass flow rate, lb/s
 P_1 = Inlet pressure, psia
 ΔP = Valve pressure differential, psi

ΔP_v = Pressure differential affecting dynamic torque
 Q_1 = Flow rate incompressible fluid, scfh
 Q_2 = Flow rate compressible fluid, scfh
 T = Absolute temperature, °R
 T_D = Dynamic torque, in. lb
 V = Fluid velocity, in./s
 ρ_1 = Fluid density at upstream pressure tap, lb/in.³
 ρ_2 = Fluid density at valve disc, lb/in.³

REFERENCES

1. Keller, J. C., and Salzmann, I. F. January 1936 "Aerodynamic Model Tests on Butterfly Valves" *Escher-Wyss News*, 9.
2. *Recommended Voluntary Standards for Measurement Procedure for Determining Control Valve Flow Capacity*, 1958. Fluid Controls Institute, Inc., paper FCI 58-2.
3. Buresh, J. F., and Schuder, C. B. October 1964 "The Development of a Universal Gas Sizing Equation for Control Valves" *ISA Trans.* 3:322-328.
4. *Flow Measurement: Instruments and Apparatus. Supplement to the ASME Power Test Codes*, ASME report IPTC 19.5, 4-1959.

Bechtel Power Corporation

Engineers — Constructors

12440 East Imperial Highway
Norwalk, California 90650

MAIL ADDRESS
P.O. BOX 60860 - TERMINAL ANNEX LOS ANGELES, CALIFORNIA 90060
TELEPHONE (213) 807-2000



March 25, 1985

Mr. Doug Pothast (Vendor)
Fisher Controls, Inc.
Marshalltown, Iowa 50158

Subject: Georgia Power Company
Plant Vogtle Units 1 and 2
Bechtel Job 9510
Butterfly Valves
P.O. Nos. PAV206 and PAV234
File: X5AC03
Log: BV 10318

Reference: Meeting between Fisher Controls, Inc. and
Bechtel Corp. on Feb. 15, 1985 at Marshalltown,
Iowa (MN-1623)

Dear Mr. Pothast:

Attached is a better quality copy of Bettis Actuator Torque
Data.

Please remove table 3, from the "Operability Qualification
of Purge and Vent Valves", and replace with the attached
better copy of Torque Data.

We are requesting Fisher to submit an original signed
document to support the figures interpolated by Bechtel.
Your prompt attention to this matter will be appreciated.

If you have any questions, please contact us.

Very truly yours,

BECHTEL POWER CORPORATION

A handwritten signature in dark ink, appearing to read "H. G. Gronroos". The signature is fluid and cursive, written over the typed name.

H. G. Gronroos
Project Engineer
Western Power Division


NCB/WHJ/cb

Attachments: Bettis Actuator Torque Data, Table 3.

xc: O. Batum, w/att.
VRMS, w/att.

T316 SR2

YOKE ARM ANGLE (degrees)	SPRING TORQUE (in lb)	PRESSURE TORQUE (50)psi	PRESSURE TORQUE (60)psi	PRESSURE TORQUE (70)psi	PRESSURE TORQUE (80)psi
0	18828	19187	26587	33986	41386
15	15602	12435	17949	23463	28977
30	14268	9444	14147	18851	23554
45	14394	8053	12542	17031	21521
60	16088	7532	12300	17069	21837
75	20224	7572	13256	18941	24625
90	29640	7778	15600	23422	31245



ATTACHMENT 6

Includes: Fisher (G. H. Bettes Qualification Test)
Report 37274

(BPC Log # X5AC03-5093-4)

INDEX SHEET

Log Number AX5AC03-5093

Document Number 37274

Document Title G.H. BETTIS QUAL. TEST REPORT

Original Number of Shts. 698

Date Rec'd 2-10-83

Sub. No. 1

Rev. No. Date Rec'd Sub. No.

BECHTEL SHEET NUMBER

(R) pages 41 thru 60, 63 thru 80, 83 thru 88, 91 thru 94	3	8-1-83	2
109 thru 110, 115 thru 118, 121 thru 158, 163 thru 203, 216 thru 223, 230, 231, 241, 242, 674 thru 677		8-1-83	2
(A) pages 689 thru 791		8-1-83	2
(A) PAGES: 772 THRU 822		8-1-83	2
(R) SHTS. 789 & 806		8-1-83	2
		2-21-84	3
		3-8-85	4

JOB NO. 9510

VOBTE ELECTRIC GENERATING PLANT

EQUIPMENT TAG NO. VARIOLS

STARTUP DESIGNATION NO. VARIOLS

ACTIVITY NO. N/A

SYSTEM NO. VARIOLS

CATEGORY NO. 46/AY

RETROFITTING REQUIRED YES NO

Bechtel Log No. 9510

AX5AC03-5093-4

IMPORTANT

Permission to proceed does not constitute acceptance or approval of design details, calculations, analyses, test methods or materials developed or selected by the supplier and does not relieve supplier from full compliance with contractual obligations.

MICROFILM QUALITY ACCEPTABLE

DISTRIBUTION TO: MECHANICAL, HVAC, NSS, BOP, CONTROL SYSTEMS, ELECTRICAL, WIRING, CONDUIT, HAZARDS, CIVIL/STRUCTURAL, NUCLEAR, STRESS/PLANNING, CODES AND STANDARDS, ARCHITECTURAL, STARTUP, CONSTRUCTION, NOT REQUIRED BY ENGR, CLIENT, EQUIP. QUALIFICATION, W & OS, WESTINGHOUSE

INFO: REVIEW

IDENTIFYING TITLE OF THIS DOCUMENT: G.H. BETTIS QUAL. TEST REPORT NO. 37274

DATE RECEIVED 3/8/85

SIGNED [Signature]

DATE 3/25/85

DOCUMENT STATUS

WORK MAY PROCEED

REVISE AND RESUBMIT WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES INDICATED

REVISE AND RESUBMIT WORK MAY NOT PROCEED

INFORMATION ONLY DISTRIBUTION REQUIRED YES

RESUBMIT - NOT ACCEPTABLE FOR MICROFILM WORK MAY PROCEED

PF-5986 (1951) 9-84

PROPRIETARY

This document is the property of Bechtel Inc. and is loaned to you. It is not to be reproduced, copied, or distributed outside your organization.

CONFIDENTIAL

REF
VIA

... by anyone else without

CONFIDENTIAL

The information presented in this report is the property of GH-Bettis Corporation. Reproduction in whole or in part is expressly forbidden without prior written authorization by GH-Bettis Corporation. Updating of copies of this report which were not furnished directly by GH-Bettis Corporation shall be the responsibility of the party providing those reports.

BOOK NUMBER 68

ISSUED TO MR LARRY Rathje

COMPANY Fisher Control Co.

DATE DECEMBER 4, 1982

PROJECT _____

CUSTOMER P.O. 181173

GH-BETTIS S.O. 82-904500

NUCLEAR QUALIFICATION TEST REPORTNUMBER 37274GH-BETTIS CORPORATIONHOUSTON, TEXAS

This qualification test program was started in mid-year 1977 and completed January 1980. A number of revisions and additions were made to the test program; typically to reflect the continuously changing requirements demanded by the Nuclear industry. These included additional wear aging and thermal aging as qualification requirements were upgraded.

All qualification testing was conducted at Southwest Research Institute, San Antonio, Texas and Wyle Laboratories, Huntsville, Alabama.

The final results of this nuclear qualification test program show that all "N-Series" actuators manufactured by GH-Bettis are qualified for use in Nuclear Power Plants and will equal or exceed the requirements of the following standards:

IEEE 323-1974, Standard for Qualifying Class 1E Equipment for Nuclear Power Generating Stations.

IEEE 344-1975, Guide for Seismic Qualification of Class I Electrical Equipment for Nuclear Power Generating Stations.

IEEE 382 (ANSI N278.2.1, Draft 3, Rev. 0, February, 1977) American National Standard for Qualification of Safety Related Valve Actuators.

Four (4) actuator models were chosen for type of testing.

- (1) N732C-SR80-12 to qualify all NHD series actuators
- (2) NT420B-SR1-12 to qualify all NT series actuators (except NT-5 and NT-8 series actuators, seismically)
- (3) NT520B-SR1-12 to qualify NT5 and NT8 series actuators, seismically
- (4) NCB-520-SR80-12 to qualify all NCB series actuators.

These four (4) models chosen to be the type tested units since they best represent all of the variable affecting environmental qualification as well as exhibiting the lowest natural frequencies within their series based on their respective mass, centers-of-gravity and size and also, to exhibit the highest stress levels during operation.

PROPPRIETARY

This document is property of Georgia Power Company and is not to be reproduced, copied, loaned, exhibited or used by anyone else without written permission from Georgia Power Company.

Page 2

It should be noted that the elastomer seal materials and lubricants used in all actuators in this report are generically identical. Justification showing relationship between type tested and generic model actuators is shown in Appendix A.

This qualification test report is presently made up of six (6) principle sections or volumes. It is anticipated that additional sections may be added when further testing is done to meet future qualification requirements yet to be established. A short summary of each volume is as follows:

VOLUME I, THERMAL AGING, DYNAMIC FUNCTIONAL DATA

The purpose of Thermal Aging was to show that the ethylene propylene seals used in all "N-Series" nuclear actuators were suitable for a qualified service life of five (5) years. The original test parameters were established as 200°F for 200 hours at 100 percent humidity. Subsequent thermal aging (Volume V) of a Model NCB520-SR80-12 was performed at 250°F for 294 hours at 100 percent humidity. By Arrhenius Equation with continuous temperature of 120°F and an activation energy of 0.8eV, this shows that the ethylene propylene seals have qualified life expectancy of 6.5 years. Since the seals of lubricants used in NHD and NT Series actuators are generically the same as used in the NCB models, they to are considered to be covered by this subsequent thermal aging test. Based on this, elastomer seals in all GH-Bettis "N-Series" actuator must be changed every 5 years to maintain qualified.

Dynamic Functional Data was also obtained, in the beginning as baseline-date, and after each phase of testing to determine what effects, if any, that the various tests had on the operating capabilities of the actuators. It should be noted that throughout the test program a number of test equipment and control failures occurred including torque transducers, solenoid valves and limit switches. None of these items are part of the actuators being qualified, but are pieces of equipment used to test and operate the actuators themselves during qualification testing. (ASCO solenoid valves and NAMCO limit switches supplied by GH-Bettis are nuclear pre-qualified by their respective manufacturers.) NHD and NT Series actuators continued to perform throughout the test program at acceptable levels of torque output and speeds of operation.

VOLUME II, WEAR AGING, RADIATION AGING

The NCB520-SR80-12 actuator was originally operated 5000 cycles without maintenance while the N732C-SR80-12 and NT420-SR1-12 actuators were operated 2005 cycles. An additional 3000 cycles were added to these same N732C-SR80-12 and NT420B-SR1-12 units (Volume VI). Based on this, all "N-Series" actuators (less seals and lubricants) are suitable for a design service life of 5000 cycles or 40 years, whichever occurs first.

Page 3

All actuators were irradiated for a minimum total dosage of 1.4×10^8 rads (air equivalent) after thermal aging and wear aging with no noticeable effects on operability.

VOLUME III, SEISMIC TESTING

Each of the type tested units were subjected to a resonant search, plant induced vibration simulation and random biaxial excitation. There were no signs of cracking or yielding in the actuators and they performed normally during and after the tests. The Model NT520B-SR1-12 was added to the program to verify that the larger NT series actuators were suitably qualified.

VOLUME IV, LOCA TESTING

The Models N732C-SR80-12, NT-420B-SR1-12 and NCB520-SR80-12 actuators were shipped from Southwest Research Institute to Wyle Laboratories for Design Basis Event (LOCA) Testing. The Model NT520-SR1-12 was not tested since the seals and lubricants are generically identical to those used in the Model NT420B-SR1-12 unit. The Model N732C-SR80-12 and NT420B-SR1-12 actuators successfully passed LOCA simulation with only a minor decrease in torque output (approx. 10%). This is judged to be expected and acceptable. The Model NCB520-SR80-12 actuator was removed from testing after 9 hours because of excessive piston seal leakage. Post-test examination showed the piston seal to be damaged. A subsequent test of a re-designed NCB520-SR80-12 was successfully performed at a later date (Volume V).

It should again be noted that there were several failures of torque transducers, solenoid valves and limit switches. None of these items are part of the actuator and their performance failure and replacement should not be construed as a failure of the actuators. ASCO solenoid valves and NAMCO limit switches are separately qualified for nuclear service by their respective manufacturers.

VOLUME V, THERMAL AGING, WEAR AGING, RADIATION AND LOCA SIMULATION MODEL NCB520-SR80-12

A redesigned Model NCB520-SR80-12 actuator was submitted to Wyle Laboratories for Thermal Aging, Wear Aging, Radiation and LOCA Simulation. A comparison of post-test torque outputs with initial base line data shows no decrease in performance. Seismic testing was not re-done since the design changes in the piston seal and piston seal groove would not materially affect the seismic response of the actuator. With new thermal aging parameters of 294 hours at 250°F and 100% humidity the seals in the NCB520-SR80-12 actuator are suitable for 5 year service life without maintenance (Appendix E, Arrhenius Law). Likewise, the seals in Model N732C-SR80-12 and NT420B-SR1-12 actuators are also suitable for 5 years service life since they are generically identical.

Page 4

VOLUME VI, 3000 ADDITIONAL WEAR AGE CYCLES - N732C-SR80-12 AND
NT420B-SR1-12

The original Model N732C-SR80-12 and NT420B-SR1-80 actuators previously wear aged, thermal aged, irradiated and seismically tested at Southwest Research Institute (Volumes I, II, III) and subjected to LOCA simulation at Wyle Laboratories (Volume IV) were returned to Wyle Laboratories for additional wear aging of 3000 cycles. No appreciable differences in torque output was noted at the end of testing. Based on this, GH-Bettis believes all NCB, NHD and NT-Series actuators are suitable for 40 years design life (except seals and lubricants) and/or 5000 cycles, whichever occurs first.

PROPPRIETARY

This document is property of Georgia Power Company and is not to be reproduced, copied, loaned, exhibited or used by anyone else without written permission from Georgia Power Company.

Appendix A

GENERIC QUALIFICATION

Generic qualification of GH-Bettis nuclear rated valve actuators is accomplished in the following manner.

Three generic parent test actuators; NCB520-SR80-12, N732C-SR80-12 and NT-420B-SR1-12; were submitted to all facets of nuclear qualification testing in accordance with the requirements of IEEE 382 (ANSI N278.2.1, Draft 3, Rev. 0, February 1977). Testing was conducted at Southwest Research Institute and Wyle Laboratories. An additional actuator, NT-520B-SR1-12, was tested to the seismic requirements of that document.

Actuator Model NCB520-SR80-12 serves as the generic parent of all NCB model actuators for all nuclear environments. They share the following design similarities.

1. Housings are of gray iron and are of a single design with only three basic sizes available; 1½", 2" and 2½". The generic parent contains the 2" housing.
2. The housing is an integral part of the pressurized section of this model.
3. A ductile iron piston of a single design is incorporated in NCB series actuators and is guided by the center bar.
4. Lateral loading imposed by the scotch yoke mechanism is supported by the center bar.
5. Ductile iron yokes are of one design and are available in three sizes; 1½", 2" and 2½".
6. Yoke pins are of a single design; guided by a roll pin.
7. NCB series actuators share the same unit assembly configuration (e.g. the entire unit is held together and supported by a single center bar).
8. NCB seals are of one design and are provided in compounds successfully qualified by testing.
9. Coatings and lubricants are the same for all NCB models and are identical with those of the tested unit.

Actuator model N-732C-SR80-12 is the generic parent test actuator of all nuclear rated Heavy Duty (HD) model actuators. They share the following design similarities.

1. Cast ductile iron housings and housing covers are of a single design and are available in two sizes; 2" and 3". The generic parent utilized the 3" housing.

2. Pressure and spring cylinders are threaded into cast adapters which are in turn bolted into the housing with ferry head cap screws.
3. A single piston rod is utilized which traverses the housing and is supported at both ends of the housing by a bronze bushing.
4. The piston rod absorbs all lateral loading imposed by the scotch yoke mechanism.
5. Cast ductile iron yokes are of one design and are available in two sizes; 2" and 3". The parent test actuator contained the 3" yoke.
6. Yoke pins are of one design and are guided by cast ridges in the housing and cover.
7. HD series actuators share a common unit assembly configuration.
8. U-cup piston seals and polypak rod seals of qualified ethylene propylene compounds are unique to the heavy duty design.
9. Coatings and lubricants are the same for all nuclear rated HD models and are the same as those used in the tested unit.

Actuator Model NT-420B-SR1-12 serves as the generic parent test actuator of all NT series models for all nuclear environments excepting the seismic environment. It serves as the seismic generic parent of all NT3-SR and NT4-SR models. Following are design similarities shared by these models.

1. Ductile iron housings and housing covers are of a single design and are available in four sizes; 3", 4", 5" and 8". The generic parent utilized the 4" housing.
2. Pressure cylinders are of three piece construction; two end caps and a cylinder. These parts are attached together and to the actuator housing by two tie bars.
3. NT3-SR and NT4-SR spring cylinders are attached to a brace plate utilizing two tie bars and four symmetrically located external brace rods. The brace plate is attached to the actuator housing by four cap screws.
4. Piston rods and spring push rods are separate pieces, attached by threaded connections at the yoke pin nut.
5. Lateral loading imposed by the scotch yoke mechanism is absorbed by the yoke pin and rollers which are guided and supported by tracks located in the housing and housing cover.

6. Ductile iron yokes are of one design and are available in four sizes; 3", 4", 5" and 8". The parent test actuator utilized the 4" size.
7. NT3-SR and NT4-SR model actuators share a common unit assembly configuration.
8. All seals (piston T-seal, pressure cylinder end cap seals, rod seals, etc.) are of the same design and are molded of qualified ethylene propylene compounds.
9. Coatings and lubricants are the same for all nuclear rated T-series actuators; the same as those used in the generic parent.

Actuator Model NT-520B-SR1-12 serves as the seismic generic parent of all NT5-SR and NT8-SR series actuators. These models share the same spring cylinder support design, as follows. The spring cylinder is attached to the brace plate by two tie bars and two external brace rods located above the spring cylinder. The brace plate is attached to the housing by six cap screws and two shear pins.

Seismic analyses are provided for nuclear rated actuators at the request of the customer. All generic parent test actuators are believed to be the models which are the least rigid.

ATTACHMENT 7

Includes:

Fisher Qualification Report FQP-11AB-5

(BPC Log # X5AC03-5161-2)

INDEX SHEET

ATTACHMENT No 7 . Doc. # 5

Log Number AX5AC03-5161

Document Number FQP-11AB-5

Document Title QUALIFICATION RPT. FQP-11AB-5

Original Number of Sheets 137

Date Rec'd 2-11-85 Sub. No. 1

- - REVISE
- △ - ADD
- - DELETE

Rev. No.

Date Rec'd

MICROFILM
QUALITY
ACCEPTABLE

Sub. No.

BECHTEL SHEET NUMBER

A) Smt 138

5-6-85

2

DISTRIBUTION TO: FOR: REVIEW	INFO.	VOGTLE ELECTRIC GENERATING PLANT	JOB NO. 9510
• MECHANICAL _____		EQUIPMENT TAG NO. <u>VARIOUS</u>	
HVAC _____			
NSSS _____			
BOP _____			
• CONTROL SYSTEMS _____			
• ELECTRICAL _____		STARTUP DESIGNATION NO. <u>VARIOUS</u>	
WIRING _____		ACTIVITY NO. <u>N/A</u>	
CONDUIT _____		SYSTEM NO. <u>VARIOUS</u>	
HAZARDS _____		CATEGORY NO. <u>48 & 49 EQ</u>	
• CIVIL/STRUCTURAL _____		RETROFITTING REQUIRED <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
• NUCLEAR _____		Bechtel Log No. <u>9510</u>	
• STRESS/PLANT DESIGN _____		<u>AX5AC03-5161-2</u>	
• CODES AND STANDARDS _____		IMPORTANT	
• ARCHITECTURAL _____		Permission to proceed does not constitute acceptance or approval of design details, calculations, analyses, test methods or materials developed or selected by the supplier and does not relieve supplier from full compliance with contractual obligations.	
• STARTUP _____			
• CONSTRUCTION _____			
• NOT REQ'D BY ENGRG _____			
• CLIENT _____			
• EQUIP. QUALIFICATION <input checked="" type="checkbox"/>			
• M & QS _____			
• WESTINGHOUSE _____			

IDENTIFYING TITLE OF THIS DOCUMENT:
QUALIFICATION REPORT
FQP-11AB-5

DATE RECEIVED 5-6-85 SIGNED _____

DOCUMENT STATUS

WORK MAY PROCEED ADT

REVISE AND RESUBMIT WORK MAY PROCEED SUBJECT TO INCORPORATION OF CHANGES INDICATED

REVISE AND RESUBMIT WORK MAY NOT PROCEED

INFORMATION ONLY DISTRIBUTION REQ'D YES

RESUBMIT - NOT ACCEPTABLE FOR MICROFILM WORK MAY PROCEED

DATE 5-23-85

PF-5986 (9510) 9-84

PROPRIETARY
 This document is the property of the Westinghouse Electric Corporation and is not to be reproduced, stored, or used by anyone without the written permission of the Westinghouse Electric Corporation.