



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

ALABAMA POWER COMPANY

DOCKET NO. 50-348

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 139
License No. NPF-2


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern Nuclear Operating Company, Inc. (Southern Nuclear), dated December 30, 1997, as supplemented by letter dated April 9, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-2 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 139 , are hereby incorporated in the license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 3, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 139

TO FACILITY OPERATING LICENSE NO. NPF-2

DOCKET NO. 50-348

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

Remove

3/4 8-9(a)
3/4 8-13

Insert

3/4 8-9(a)
3/4 8-13

ELECTRICAL POWER SYSTEMS

AUXILIARY BUILDING D.C. DISTRIBUTION - OPERATING

SURVEILLANCE REQUIREMENTS (Continued)

5. The battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for the design load profile described in the Final Safety Analysis Report, Section 8.3.2, by subjecting the battery to a service test.
- d. At least once per 60 months by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of the battery service test per 4.8.2.3.2.c.5.
- e. At least once per 18 months, performance discharge test of battery capacity shall be given to any battery that shows signs of degradation or has reached 17 years or 85% of the service life expected for the application, whichever comes first. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.

ELECTRICAL POWER SYSTEMS

SERVICE WATER BUILDING D.C. DISTRIBUTION - OPERATING

SURVEILLANCE REQUIREMENTS (Continued)

2. There is no visible excessive corrosion at either terminals or connectors, or the connection resistance of these items is less than or equal to 1500 microhms from post to post*, and
 3. The average electrolyte temperatures of ten of the connected cells deviate less than or equal to 5°F from each other**.
- c. At least once per 18 months by verifying that:
1. The cells, cell plates and battery racks show no visual indication of physical damage or abnormal deterioration,
 2. The cell-to-cell and terminal connections are clean, tight, and coated with anti-corrosion material,
 3. The resistance of each cell-to-cell and terminal connection is less than or equal to 1500 microhms from post to post*, and
 4. The battery charger will supply at least 3 amperes at greater than or equal to 125 volts for at least 4 hours.
 5. The battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for the design load profile described in the Final Safety Analysis Report, Section 8.3.2, by subjecting the battery to a service test.

* For any connection resistance determined to be greater than 1500 microhms from post to post, the battery may be considered operable provided that within 24 hours the connection resistance is restored to less than or equal to 1500 microhms from post to post.

** If a deviation greater than 5°F is determined, the battery may be considered operable provided that within 24 hours the temperature deviation is corrected.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

SOUTHERN NUCLEAR OPERATING COMPANY, INC.

ALABAMA POWER COMPANY

DOCKET NO. 50-364

JOSEPH M. FARLEY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 131
License No. NPF-8


1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Southern Nuclear Operating Company, Inc. (Southern Nuclear), dated December 30, 1997, as supplemented by letter dated April 9, 1998, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this license amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications, as indicated in the attachment to this license amendment; and paragraph 2.C.(2) of Facility Operating License No. NPF-8 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 131, are hereby incorporated in the license. Southern Nuclear shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: November 3, 1998

ATTACHMENT TO LICENSE AMENDMENT NO. 131

TO FACILITY OPERATING LICENSE NO. NPF-8

DOCKET NO. 50-364

Replace the following pages of the Appendix A Technical Specifications with the enclosed pages. The revised areas are indicated by marginal lines.

Remove

3/4 8-12(a)
3/4 8-16

Insert

3/4 8-12(a)
3/4 8-16

ELECTRICAL POWER SYSTEMS

AUXILIARY BUILDING D. C. DISTRIBUTION - OPERATING

SURVEILLANCE REQUIREMENTS (Continued)

5. The battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for the design load profile described in the Final Safety Analysis Report, Section 8.3.2, by subjecting the battery to a service test.
- d. At least once per 60 months by verifying that the battery capacity is at least 80% of the manufacturer's rating when subjected to a performance discharge test. Once per 60 month interval, this performance discharge test may be performed in lieu of battery service test per 4.8.2.3.2.c.5.
- e. At least once per 18 months, performance discharge test of battery capacity shall be given to any battery that shows signs of degradation or has reached 17 years or 85% of the service life expected for the application, whichever comes first. Degradation is indicated when the battery capacity drops more than 10% of rated capacity from its average on previous performance tests, or is below 90% of the manufacturer's rating.

ELECTRICAL POWER SYSTEMS

SERVICE WATER BUILDING D.C. DISTRIBUTION - OPERATING

SURVEILLANCE REQUIREMENTS (Continued)

2. There is no visible excessive corrosion at either terminals or connectors, or the connection resistance of these items is less than or equal to 1500 microhms from post to post*, and
 3. The average electrolyte temperatures of ten of the connected cells deviate less than or equal to 5°F from each other**.
- c. At least once per 18 months by verifying that:
1. The cells, cell plates and battery racks show no visual indication of physical damage or abnormal deterioration,
 2. The cell-to-cell and terminal connections are clean, tight, and coated with anti-corrosion material,
 3. The resistance of each cell-to-cell and terminal connection is less than or equal to 1500 microhms from post to post*, and
 4. The battery charger will supply at least 3 amperes at greater than or equal to 125 volts for at least 4 hours.
 5. The battery capacity is adequate to supply and maintain in OPERABLE status all of the actual emergency loads for the design load profile described in the Final Safety Analysis Report, Section 8.3.2, by subjecting the battery to a service test.

* For any connection resistance determined to be greater than 1500 microhms from post to post, the battery may be considered operable provided that within 24 hours the connection resistance is restored to less than or equal to 1500 microhms from post to post.

** If a deviation greater than 5°F is determined, the battery may be considered operable provided that within 24 hours the temperature deviation is corrected.