



Northeast Nuclear Energy

Rope Ferry B-1. (Route 156), Waterford, CT 06385

Millstone Nuclear Power Station  
Northeast Nuclear Energy Company  
P.O. Box 128  
Waterford, CT 06385-0128  
(860) 447-1791  
Fax (860) 444-4277

The Northeast Utilities System

OCT 30 1998

Docket No. 50-336  
B17412

Re: 10 CFR 50.73(a)(2)(ii)

U.S. Nuclear Regulatory Commission  
Document Control Desk  
Washington, DC 20555


Millstone Nuclear Power Station Unit No. 2  
Licensee Event Report 98-004-01  
Auxiliary Feedwater Pump Performance Degraded

This letter forwards Licensee Event Report (LER) 98-004-01, documenting a condition that was discovered at Millstone Nuclear Power Station, Unit No. 2, on March 16, 1998. This LER is being submitted pursuant to 10 CFR 50.73(a)(2)(ii). This LER supplement provides an update on the analyses and investigation results for this condition.

The Northeast Nuclear Energy Company's (NNECO) commitments made within this letter are included in Attachment 1.

Very truly yours,

NORTHEAST NUCLEAR ENERGY COMPANY

  
\_\_\_\_\_  
J. A. Price  
Director - Millstone Unit No. 2

cc: see page 2

9811100328 981030  
PDR ADOCK 05000336  
S PDR

IE 22

Attachments: 1. List of Regulatory Commitments  
2. LER 98-004-01

cc: H. J. Miller, Region I Administrator  
D. G. McDonald, Jr., NRC Senior Project Manager, Millstone Unit No. 2  
D. P. Beaulieu, Senior Resident Inspector, Millstone Unit No. 2  
E. V. Imbro, Director, Millstone ICAVP Inspections  
S. Dembek, NRC Project Manager, Millstone Unit No. 1

Docket No. 50-336  
B17412

Attachment 1  
Millstone Nuclear Power Station, Unit No. 2  
Commitments

October 1998

Attachment 1

Regulatory Commitment Enclosure  
List of Regulatory Commitments

The following table identifies those actions committed to by NNECO in this document.

<b>REGULATORY COMMITMENT</b>	<b>COMMITTED DATE OR OUTAGE</b>
B17412.01: The pump will be returned to operable status, which will include high flow testing, prior to entering Mode 3 from the current outage.	prior to entering Mode 3
B17412.02: The Inservice Test program will be revised prior to entering Mode 4 from the current outage, and auxiliary feedwater pump high flow testing will be performed on a periodic basis.	prior to entering Mode 4

Docket No. 50-336  
B17412

Attachment 2

Millstone Nuclear Power Station, Unit No. 2

LER 98-004-01

October 1998