

EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS - T_{in} GREATER THAN OR EQUAL TO 350°F

SURVEILLANCE REQUIREMENTS

4.5.2 Each ECCS subsystem shall be demonstrated OPERABLE:

- a. At least once per 24 hours by verifying that the following valves are in the indicated positions with power to the valve operators removed:

<u>Valve Number</u>	<u>Valve Function</u>	<u>Valve Position</u>
SI-V-3	Accumulator Isolation	Open*
SI-V-17	Accumulator Isolation	Open*
SI-V-32	Accumulator Isolation	Open*
SI-V-47	Accumulator Isolation	Open*
SI-V-114	SI Pump to Cold-Leg Isolation	Open
RH-V-14	RHR Pump to Cold-Leg Isolation	Open
RH-V-26	RHR Pump to Cold-Leg Isolation	Open
RH-V-32	RHR to Hot-Leg Isolation	Closed
RH-V-70	RHR to Hot-Leg Isolation	Closed
SI-V-77	SI to Hot-Leg Isolation	Closed
SI-V-102	SI to Hot-Leg Isolation	Closed

- b. At least once per 31 days by:

- 1) Verifying that the ECCS piping is full of water by venting the ~~ECCS pump casings (excluding the operating centrifugal charging pump) and accessible discharge piping high points,~~ and
- 2) Verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

- c. By a visual inspection which verifies that no loose debris (rags, trash, clothing, etc.) is present in the containment which could be transported to the containment sump and cause restriction of the pump suction during LOCA conditions. This visual inspection shall be performed:

- 1) For all accessible areas of the containment prior to establishing primary CONTAINMENT INTEGRITY, and
- 2) At least once daily of the areas affected within containment by containment entry and during the final entry when primary CONTAINMENT INTEGRITY is established.

*Pressurizer pressure above 1000 psig.

EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS (Continued)

When the RCS has a vent area equal to or greater than 18 square inches, one Safety Injection pump may be made OPERABLE when in MODE 5 or MODE 6 (below 200°F). When operating in this configuration, cold overpressure protection is provided by the mechanical vent opening, equal to or greater than 18 square inches, that is required to be present in the RCS boundary prior to making the SI pump OPERABLE. This required RCS vent area and the surveillance requirement to verify the presence of the RCS vent area provides assurance that a mass addition transient can be relieved and that adequate cold overpressure protection is provided.

INSERT (A)

The Surveillance Requirements provided to ensure OPERABILITY of each component ensures that at a minimum, the assumptions used in the safety analyses are met and that subsystem OPERABILITY is maintained. Surveillance Requirements for throttle valve position stops and flow balance testing provide assurance that proper ECCS flows will be maintained in the event of a LOCA. Maintenance of proper flow resistance and pressure drop in the piping system to each injection point is necessary to: (1) prevent total pump flow from exceeding runout conditions when the system is in its minimum resistance configuration, (2) provide the proper flow split between injection points in accordance with the assumptions used in the ECCS-LOCA analyses, and (3) provide an acceptable level of total ECCS flow to all injection points equal to or above that assumed in the ECCS-LOCA analyses.

3/4.5.4 REFUELING WATER STORAGE TANK

The OPERABILITY of the refueling water storage tank (RWST) as part of the ECCS ensures that a sufficient supply of borated water is available for injection by the ECCS in the event of a LOCA. The limits on RWST minimum volume and boron concentration ensure that: (1) sufficient water is available within containment to permit recirculation cooling flow to the core and (2) the reactor will remain subcritical in the cold condition following mixing of the RWST and the RCS water volumes with all control rods inserted except for the most reactive control assembly. These assumptions are consistent with the LOCA analyses.

The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

The limits on contained water volume and boron concentration of the RWST also ensure a pH value of between 8.5 and 11.0 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

INSERT

(A)

With the exception of the operating centrifugal charging pump, the ECCS pumps are normally in a standby, non-operating mode. As such, flow path piping has the potential to develop voids and pockets of entrained gases. Maintaining the piping from the ECCS pumps to the RCS full of water (by verifying at the accessible ECCS discharge piping high points and pump casings, excluding the operating centrifugal charging pump) ensures that the system will perform properly, injecting its full capacity into the RCS upon demand. This will also prevent water hammer, pump cavitation, and pumping of non-condensable gas (e.g., air, nitrogen, or hydrogen) into the reactor vessel following a safety injection (SI) signal or during shutdown cooling. The 31 day Frequency takes into consideration the gradual nature of gas accumulation in the ECCS piping and the procedural controls governing system operation.

SECTION III

Retype Of The Proposed Change

The attached retype reflects the currently issued version of the Technical Specifications. Pending Technical Specification changes or Technical Specification changes issued subsequent to this submittal are not reflected in the enclosed retype. The enclosed retype should be checked for continuity with Technical Specifications prior to issuance.

EMERGENCY CORE COOLING SYSTEMS

ECCS SUBSYSTEMS - T_{avg} GREATER THAN OR EQUAL TO 350°F

SURVEILLANCE REQUIREMENTS

4.5.2 Each ECCS subsystem shall be demonstrated OPERABLE:

- a. At least once per 24 hours by verifying that the following valves are in the indicated positions with power to the valve operators removed:

<u>Valve Number</u>	<u>Valve Function</u>	<u>Valve Position</u>
SI-V-3	Accumulator Isolation	Open*
SI-V-17	Accumulator Isolation	Open*
SI-V-32	Accumulator Isolation	Open*
SI-V-47	Accumulator Isolation	Open*
SI-V-114	SI Pump to Cold-Leg Isolation	Open
RH-V-14	RHR Pump to Cold-Leg Isolation	Open
RH-V-26	RHR Pump to Cold-Leg Isolation	Open
RH-V-32	RHR to Hot-Leg Isolation	Closed
RH-V-70	RHR to Hot-Leg Isolation	Closed
SI-V-77	SI to Hot-Leg Isolation	Closed
SI-V-102	SI to Hot-Leg Isolation	Closed

- b. At least once per 31 days by:

- 1) Verifying that the ECCS piping is full of water, and
- 2) Verifying that each valve (manual, power-operated, or automatic) in the flow path that is not locked, sealed, or otherwise secured in position, is in its correct position.

- c. By a visual inspection which verifies that no loose debris (rags, trash, clothing, etc.) is present in the containment which could be transported to the containment sump and cause restriction of the pump suction during LOCA conditions. This visual inspection shall be performed:

- 1) For all accessible areas of the containment prior to establishing primary CONTAINMENT INTEGRITY, and
- 2) At least once daily of the areas affected within containment by containment entry and during the final entry when primary CONTAINMENT INTEGRITY is established.

*Pressurizer pressure above 1000 psig.

EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS (Continued)

When the RCS has a vent area equal to or greater than 18 square inches, one Safety Injection pump may be made OPERABLE when in MODE 5 or MODE 6 (below 200°F). When operating in this configuration, cold overpressure protection is provided by the mechanical vent opening, equal to or greater than 18 square inches, that is required to be present in the RCS boundary prior to making the SI pump OPERABLE. This required RCS vent area and the surveillance requirement to verify the presence of the RCS vent area provides assurance that a mass addition transient can be relieved and that adequate cold overpressure protection is provided.

The Surveillance Requirements provided to ensure OPERABILITY of each component ensures that at a minimum, the assumptions used in the safety analyses are met and that subsystem OPERABILITY is maintained. With the exception of the operating centrifugal charging pump, the ECCS pumps are normally in a standby, non-operating mode. As such, flow path piping has the potential to develop voids and pockets of entrained gases. Maintaining the piping from the ECCS pumps to the RCS full of water (by verifying at the accessible ECCS discharge piping high points and pump casings, excluding the operating centrifugal charging pump) ensures that the system will perform properly, injecting its full capacity into the RCS upon demand. This will also prevent water hammer, pump cavitation, and pumping of non-condensable gas (e.g., air, nitrogen, or hydrogen) into the reactor vessel following a safety injection (SI) signal or during shutdown cooling. The 31 day Frequency takes into consideration the gradual nature of gas accumulation in the ECCS piping and the procedural controls governing system operation. Surveillance Requirements for throttle valve position stops and flow balance testing provide assurance that proper ECCS flows will be maintained in the event of a LOCA. Maintenance of proper flow resistance and pressure drop in the piping system to each injection point is necessary to: (1) prevent total pump flow from exceeding runout conditions when the system is in its minimum resistance configuration, (2) provide the proper flow split between injection points in accordance with the assumptions used in the ECCS-LOCA analyses, and (3) provide an acceptable level of total ECCS flow to all injection points equal to or above that assumed in the ECCS-LOCA analyses.

3/4.5.4 REFUELING WATER STORAGE TANK

The OPERABILITY of the refueling water storage tank (RWST) as part of the ECCS ensures that a sufficient supply of borated water is available for injection by the ECCS in the event of a LOCA. The limits on RWST minimum volume and boron concentration ensure that: (1) sufficient water is available within containment to permit recirculation cooling flow to the core and (2) the reactor will remain subcritical in the cold condition following mixing of the RWST and the RCS water volumes with all control rods inserted except for the most reactive control assembly. These assumptions are consistent with the LOCA analyses.

The contained water volume limit includes an allowance for water not usable because of tank discharge line location or other physical characteristics.

EMERGENCY CORE COOLING SYSTEMS

BASES

3/4.5.2 and 3/4.5.3 ECCS SUBSYSTEMS (Continued)

The limits on contained water volume and boron concentration of the RWST also ensure a pH value of between 8.5 and 11.0 for the solution recirculated within containment after a LOCA. This pH band minimizes the evolution of iodine and minimizes the effect of chloride and caustic stress corrosion on mechanical systems and components.

Section IV

Determination Of Significant Hazards For The Proposed Change

IV. DETERMINATION OF SIGNIFICANT HAZARDS FOR THE PROPOSED CHANGE

License Amendment Request (LAR) 98-17 proposes a change to the Seabrook Station Technical Specification (TS) Surveillance Requirement (SR) 4.5.2b.1 to remove the prescriptive requirements of using the venting process as the sole means to verify that the Emergency Core Cooling System (ECCS) piping is full of water. Removal of the prescriptive requirements will provide North Atlantic operational flexibility and will allow the use of alternative techniques to verify the ECCS piping is full of water. In addition, the Bases associated with TS 3/4.5.2 will be expanded to reflect the intent of the surveillance requirement.

The proposed change is similar to SR 3.5.2.3 and its associated Bases contained in NUREG-1431, "Standard Technical Specifications - Westinghouse Plants," Rev. 1, April 1995. In addition, the proposed change is based on License Amendments for Commonwealth Edison Company's Byron Station Units 1 & 2 and Braidwood Station Units 1 & 2, that were approved by the NRC Staff as License Amendments 79 and 71, on February 16, 1996.

In accordance with 10 CFR 50.92, North Atlantic has reviewed the attached proposed change and has concluded that it does not involve a significant hazards consideration (SHC). The basis for the conclusion that the proposed change does not involve a SHC is as follows:

1. The proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

The proposed change does not adversely affect accident initiators or precursors nor alter the design assumptions, conditions, configuration of the facility or the manner in which the plant is operated. The proposed change does not alter or prevent the ability of structures, systems and components (SSCs) to perform their intended function to mitigate the consequences of an initiating event within the acceptance limits assumed in the Updated Final Safety Analysis Report (UFSAR).

Removal of the prescriptive requirements will not subject the ECCS system to conditions adverse to nuclear safety. The proposed change does not affect the source term, containment isolation or radiological release assumptions used in evaluating the radiological consequences of an accident previously evaluated in the Seabrook Station UFSAR. The use of proven alternative techniques to verify that the ECCS piping is full of water will continue to ensure that the ECCS system is capable of performing its intended designed safety function. Therefore, the proposed change does not involve a significant increase in the probability or consequences of an accident previously evaluated.

2. Create the possibility of a new or different kind of accident from any accident previously evaluated.

The proposed change does not alter the design assumptions, conditions, configuration of the facility or the manner in which the plant is operated and maintained in a state of readiness. Existing system and component redundancy is not being changed by the proposed change. The proposed change has no adverse affect on component or system interactions. The use of proven alternative techniques to verify that the ECCS piping is full of water will continue to ensure that the ECCS system is capable of performing its intended designed safety function. Therefore, since

there are no changes to the design assumptions, conditions, configuration of the facility, or the manner in which the plant is operated and maintained in a state of readiness, the proposed change does not create the possibility of a new or different kind of accident from any previously analyzed.

3. Involve a significant reduction in a margin of safety.

The proposed change does not adversely affect equipment design or operation and there are no changes being made to the Technical Specification required safety limits or safety system settings that would adversely affect plant safety. The proposed change does not change the intent of the surveillance requirement of ensuring that the system will perform properly, injecting its full capacity into the RCS upon demand without subjecting the system to hydraulic transients, pump cavitation, and pumping of non-condensable gas (e.g., air, nitrogen, or hydrogen) into the reactor vessel following a safety injection (SI) signal or during shutdown cooling.

Thus, it is concluded that the ECCS will continue to be available upon demand to mitigate the consequences of an accident and, therefore, there is no significant reduction in a margin of safety.

Based on the above evaluation, North Atlantic concludes that the proposed change does not constitute a significant hazard.

Sections V & VI

**Proposed Schedule for License Amendment Issuance and Effectiveness
and
Environmental Impact Assessment**

V. PROPOSED SCHEDULE FOR LICENSE AMENDMENT ISSUANCE AND EFFECTIVENESS

North Atlantic requests NRC review of License Amendment Request 98-17 and issuance of a license amendment by February 26, 1999, having immediate effectiveness and implementation required within 60 days. North Atlantic requests this review and approval schedule to allow utilization of the alternate techniques to minimize personnel radiation exposure and the potential exposure to high pressure fluids, and to minimize the time that ECCS valves are open.

VI. ENVIRONMENTAL IMPACT ASSESSMENT

North Atlantic has reviewed the proposed license amendment against the criteria of 10CFR51.22 for environmental considerations. The proposed change does not involve a significant hazards consideration, nor increase the types and amounts of effluent that may be released offsite, nor significantly increase individual or cumulative occupational radiation exposures. Based on the foregoing, North Atlantic concludes that the proposed change meets the criteria delineated in 10CFR51.22(c)(9) for a categorical exclusion from the requirements for an Environmental Impact Statement.