

LIC-98-0140

Enclosure 2

Calculation FC05977

ABB-CE Evaluation of Containment Spray Pump Net Positive Suction Head
Accounting for Sump Subcooling

9811120105 981029
PDR ADOCK 05000285
P PDR

CALCULATION COVER SHEET

Calculation Preparation, Review and Approval Form PED-QP-3.1 Form Page No. 1 of 2 Calculation Cover Sheet * Short Term Calc: <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO		CALCULATION NUMBER o <u>FCØ 5977</u> QA Category: <input checked="" type="checkbox"/> CQE <input type="checkbox"/> LIMITED CQE <input type="checkbox"/> FIRE PROT. <input type="checkbox"/> NON CQE o FILE NO. _____ PED DEPARTMENT <u>DEN - Mech. 357</u>		Calc. Page No. <u>1</u> *TOTAL PAGES <u>128</u>		
CALCULATION TITLE <u>ABB-CE Evaluation of Containment Spray Pump Net Positive Suction Head Accounting for Sump Subcooling</u>		VENDOR CALC. NO. <u>D-MECH-CALC-021</u> <input type="checkbox"/> MR NO. _____ <input type="checkbox"/> ENGR. ANALYSIS _____ <input type="checkbox"/> DBD NO. _____ <input type="checkbox"/> ECN NO. _____ <input checked="" type="checkbox"/> OTHER <u>CIB 920473/02</u>				
* APPROVALS - SIGNATURE & DATE			*REV. NO. <u>∅</u>	SUPERSEDES *CALC. NO. <u>NA</u>	CONFIRMATION *REQUIRED (✓) <input type="checkbox"/> YES <input checked="" type="checkbox"/> NO	
PREPARER(S)/DATE(S)	REVIEWER(S)/DATE(S)	INDEPENDENT REVIEWER(S)/DATE(S)				
Rich Harsell 6/12/92	Robert Paakkonen, (see ABB-CE calc. sheet)					
* EXTERNAL ORGANIZATION DISTRIBUTION						
NAME & LOCATION	CCPY SENT (✓)	NAME & LOCATION			COPY SENT (✓)	

* SEE INSTRUCTIONS ON REVERSE SIDE

° COMPLETED BY DOCUMENT CONTROL

CALCULATION COVER SHEET

CALCULATION PREPARATION, REVIEW AND APPROVAL
FORM PED-QP-3.2 Form Page No. 1 of 1

CALCULATION NO.

FCΦ5977

PRODUCTION ENGINEERING DIVISION
CALCULATION REVISION SHEET

REV.
NO.

DESCRIPTION /REASON FOR CHANGE

0

Initial issue

Evaluation of Containment Spray Pump Net Positive Suction Head
Accounting for Sump Sub-Cooling

Prepared for Omaha Public Power District, Fort Calhoun Station

Calculation No. : O-MECH-CALC-021 Rev. 00

Safety Related : Yes X No

Total Pages : 21

Appendices : A6, B24, C53, D21

Microfiche : None

Prepared By: R. B. Harsell R. B. Harsell

Reviewed By: R. F. Paakkonen

VERIFICATION STATUS: COMPLETE

The Safety-Related design information contained in this document has been verified to be correct by means of Design Review using Checklist(s) 2 of QAM-101.

R. Paakkonen R. Harsell 6/12/92
Independent Reviewer: Name/Signature/Date

Approved By: F. P. Ferraraccio, Supervisor F. P. Ferraraccio 6-12-92

Purpose: To investigate available Net Positive Suction Head (NPSH) of Fort Calhoun Station Containment Spray Pumps accounting for containment sump liquid sub-cooling.

Method and Results of Review :

Independent design review. The results of the review were found to be acceptable and consistent with that of the calculation.

RECORD OF REVISION

Revision	Date	Author	Reviewer	Approval	Extent of Rev.
00	6/12/92	R. Harsell	R. Paakkonen	F. Ferraraccio	Original issue

Table of Contents

<u>Section</u>	<u>Page</u>
1.0 INTRODUCTION	4
2.0 SCOPE	4
3.0 REFERENCES	5
4.0 BASIC DATA AND ASSUMPTIONS	6
5.0 METHOD OF ANALYSIS	7
6.0 RESULTS AND CONCLUSIONS	8
7.0 BODY OF THE CALCULATION	8

List of Tables

1 Containment Spray System Main Model Runs	8
2 Pipeline Total K Factors	14
3 Headloss Equations for the Containment Spray Pumps	15
4 Available Net Positive Suction Head for the Containment Spray Pumps	16
5 Available Net Positive Suction Head for SI-3B and SI-3C Operating in Parallel	16
6 Composite Flow vs. Configuration	17

List of Figures

1 OPPD CSP NPSH - 2P2H Configuration	18
2 OPPD CSP NPSH - 3P2H Configuration	19
3 OPPD CSP NPSH - 2P1H Configuration	20
4 OPPD CSP NPSH - 1P1H Configuration	21

Appendices

A Piping Diagram	A1
B PIPE-FLO Output	B1
C NET-FLO Output for CSS Main Model Runs	C1
D Selected References	D1

1.0 INTRODUCTION

The purpose of this calculation is to document the evaluation of available NPSH (NPSH_a) of Fort Calhoun Station's Containment Spray Pumps. This calculation documents the investigative effort to identify additional NPSH_a using the model of Reference 3.2 and accounting for containment sump sub-cooling. The minimum sump sub-cooling available is given in Reference 3.14. This results in an additional, but conservative, amount of NPSH_a.

2.0 SCOPE

This calculation applies to the Omaha Public Power District's Fort Calhoun Station Containment Spray System.

3.0 REFERENCES

- FC 05777
- 3.1 CE Calculation O-MPS-CALC-004 Rev. 01, "The Development of a Hydraulic Computer Model of the Containment Spray System at Fort Calhoun Station using the "As-Built" Piping Isometrics and "FLO-SERIES" Hydraulic Analysis Computer Code", dated 5/12/92.
FC 05906
- 3.2 CE Calculation O-MECH-CALC-019 Rev. 01, " Evaluation of Containment Spray Pump Net Positive Suction Head", dated 4/27/92.
- 3.3 CE Letter O-MPS-91-120, "Containment Spray System Open Item Closure", dated 8/23/91.
- 3.4 CE Letter O-MPS-91-147, "Containment Spray System NPSH Investigation for DBD Open Item Number 42", dated 10/10/91.
- 3.5 FLO-SERIES Users Manual dated 1990.
- 3.6 Garay, Paul N., "Pump Application Desk Book", The Fairmont Press, Inc., 1990.
- 3.7 Safety Guide 1, "Net Positive Suction Head for Emergency Core Cooling and Containment Heat Removal System Pumps", dated 11/2/70.
- 3.8 MISC-MPS-CALC-015 Revision 0, Quality Assurance Software Verification and Validation Report, dated 7-12-91 for PIPE-FLO version 3.91a and NET-FLO version 3.92a.
- 3.9 Crane Manual, Technical Paper No. 410, Twenty-Fourth printing, 1988.
- 3.10 Ft. Calhoun Station Unit No. 1, Surveillance Test ST-N2-1, "Containment Spray Nozzles", performed May 1987
- 3.11 OPPD OSAR 85-33, "Electrical Equipment Qualification Environment Determination", dated 3/21/86. Copy attached to Reference 3.2.
- 3.12 Facsimile from P. Kasztejna (Ingersoll-Rand) to D. Blanchard (ABB) concerning Containment Spray Pumps, received 3/19/92. Copy attached in Appendix D.
- 3.13 CE Calculation O-MPS-CALC-011 Rev. 00, "Calculation of Spray Initiation Time", dated 10/24/91.
- 3.14 ABB Inter-Office Correspondence OPS-92-0653, "Evaluation of the Pressure Margin Present Between the Saturation Pressure of the Containment Sump Water and the Containment Pressure - Post LOCA", dated 5/29/92. Copy attached in Appendix D.
- 3.15 ASME Steam Tables, dated 1979.
- 3.16 Ingersoll-Rand Company pump curves N-182A, N-171A, AND N-178A. Copy attached in Appendix D.

4.0 BASIC DATA AND ASSUMPTIONS

4.1 Assumptions 4.1 and 4.3 - 4.8 of Reference 3.1 apply. Those assumptions are:

- 4.1.1 The SIRWT water temperature is 90°F.
- 4.1.2 Pump elevation is 973.25 ft.
- 4.1.3 Spray headers "A" and "B" are at 1111.5 ft.
- 4.1.4 The same ring elevations are used.
- 4.1.5 The following pump curve data from Reference 3.16 was used to model the pumps:

<u>Pump</u>	<u>Curve No.</u>
SI-3A	N-178 A
SI-3B	N-182 A
SI-3C	N-171 A

- 4.2 Reference 3.11 allows the use of 6.0 feet of level in the containment sump for NPSH_v determination. Its applicability was established in Reference 3.2.
- 4.3 The NPSH_v curve in each of this calculation's Figures is based on Reference 3.12. This curve is the most recent curve of NPSH_v and was, therefore, used in this calculation. Its applicability was established in Reference 3.2.
- 4.4 Properties of sump liquid are approximated as water and, as such, the properties of Reference 3.15 apply to the sump liquid.

5.0 METHOD OF ANALYSIS

This calculation is an expansion of Reference 3.2. References 3.1, 3.2, 3.3, and 3.4 have noted a possible condition resulting in inadequate NPSH for the Containment Spray Pumps (CSP) during the recirculation phase of safety injection. This calculation uses the model developed for Reference 3.2.

The objective of this calculation is to calculate the available NPSH and compare it against the required NPSH. To determine $NPSH_a$, various parameters were considered. The parameters of elevation difference, sump level, and CSP suction headloss were considered in Reference 3.2. This calculation, however, expands that calculation by accounting for sump sub-cooling. The sump sub-cooling arises due to the pressure in containment being greater than the vapor pressure of the sump liquid. The total $NPSH_t$ is plotted against $NPSH_r$ to determine the available NPSH margin.

This Section discusses the methodology in general terms, while Section 7 explains, in detail, the methods employed in this calculation.

5.1 MODEL DEVELOPMENT

The model used in this calculation was developed in Reference 3.2. This included using Reference 3.5. FLO-SERIES has been QA certified by Reference 3.8. The Code Certificates are included in Appendix D.

5.1.1 MODEL MODIFICATION

The model of Reference 3.2 was modified to use the manufacturer's pump curve data. A set of runs was performed using the modified model. These runs included the ring data of Reference 3.10. The ring data input to FLO-SERIES was taken from Reference 3.1. The K factors for rings A-F and H-L were taken from Reference 3.1, Appendix G while the K factor for ring G was taken from Appendix T of Reference 3.1. Appendix T accounts for the missing nozzle annotated in Reference 3.10. The Piping Project Report showing the respective rings and K factors is located in Appendix B.

5.2 NPSH_a DETERMINATION

To determine the available NPSH, Equation 1 on page 200 of Reference 3.6 was used.

$$NPSH_a = \frac{(P_1 - P_v) (2.31)}{\text{Specific Gravity}} \pm Z - H_{fs} \quad (1)$$

where

$NPSH_a$ = available NPSH

P_1 = containment pressure

P_v = vapor pressure of the water at the pumping temperature; in this case, sump temperature

2.31 = conversion factor from psi to feet of head

Z = elevation difference between sump bottom and centerline of pump

H_{fs} = suction headloss

5.3 TEST CASE CONDITIONS

Runs were based on allowable CSP/CS header configurations that were developed in Reference 3.13. The configuration runs are listed in Table 1.

TABLE 1
CONTAINMENT SPRAY SYSTEM MAIN MODEL RUNS

RUN	CONFIGURATION	CSS PUMP	DISCHARGE HEADER
1	3P2H	SI-3A SI-3B SI-3C	HDR A HDR B
2	2P2H	SI-3B SI-3C	HDR A HDR B
3	3P1H	SI-3A SI-3B SI-3C	HDR B
4	2P1H	SI-3A SI-3B	HDR B
5	2P1H	SI-3A SI-3C	HDR B
6	1P1H	SI-3A	HDR B

NOTE: The designation xPyH determines the number of pumps (P) and headers (H). Results of these runs are found in Appendix C.

6.0 RESULTS

This calculation shows that crediting only 25% of the available sump liquid sub-cooling NPSH and accounting for a 6 foot level in the sump yields positive NPSH margins. Tables 4 and 5 and the Figures show the NPSH_a versus NPSH_r for various pump flow data points. Table 6 and the Figures show the NPSH_a values for the flows determined by FLO-SERIES. The 3P1H configuration is not graphed.

Based on Table 6 and the Figures, OPPD CSPs have sufficient NPSH_a providing credit is taken for sump liquid sub-cooling.

7.0 BODY OF THE CALCULATION

7.1 MODEL DEVELOPMENT AND VERIFICATION

The explanation of model development is included in Reference 3.1. The base model for this calculation comes from Reference 3.2. The base model, OPPDCS, was copied onto a working disk as OPPDCS1 and run using one set of conditions established in Reference 3.2. The verification run was documented in accordance with FLO-SERIES control procedures; the verification sheet is included in Appendix D. Once the working model was verified, it was modified as described in Section 7.1.1.

7.1.1 MODEL MODIFICATION

The working model was modified in accordance with Reference 3.4 by replacing the test pump data with the manufacturer's pump data. The pump replacement was accomplished by setting up new networks in NET-FLO Network Design & Configuration. The respective nodes were called up and the proper pump "installed" into the corresponding pipe. The Component Table Report of Appendix B includes the three pumps used. Components C, D, and E were placed into pipelines 74, 75, and 76, respectively. Additionally, for the runs involving only one header, Header A was blocked by the use of "phantom" check valves and 5000 psi for the fixed grade pressure. This check valve/high pressure combination resulted in zero flow through Header A. In this way, the system was modified and run in the configurations according to Table 1.

7.2 AVAILABLE NPSH DETERMINATION

As discussed in Section 5.2, $NPSH_a$ was determined using Equation 1. In order to calculate $NPSH_a$ the terms P_1 , P_v , specific gravity, Z, and H_u are necessary. Reference 3.14 transmitted the data pertaining to the conditions in containment that would yield the least, i.e. most conservative, amount of sub-cooling available.

7.2.1 CONTAINMENT PRESSURE (P_1)

The values for containment pressure are located in various containment analysis calculations. The specific containment pressure relevant to this calculation is given in Reference 3.14 as 16.43 psia.

7.2.2 VAPOR PRESSURE AT SUMP TEMPERATURE (P_v)

The vapor pressure is the saturation pressure corresponding to the sump temperature. The sump temperature relevant to this calculation is given in Reference 3.14 as 100.3°F.

7.2.3 $P_1 - P_v$

Reference 3.14 transmitted the minimum delta P available. This delta P results due to sump sub-cooling and results in additional $NPSH_a$. This differential pressure is stated in Reference 3.14 as 15.47 psi.

7.2.4 SPECIFIC GRAVITY

The specific gravity, as applicable to this case, is defined as

$$SG = \frac{\rho_{\text{water at sump temperature}}}{\rho_{\text{water at } 60^{\circ}\text{F}}} \quad (2)$$

where ρ (density at sump temperature of 100.3°F per Reference 3.14) is 61.996 lbm/ft³ from Reference 3.15
 ρ (density at 60°F) is 62.371 lbm/ft³ from Reference 3.15

therefore,

$$SG = \frac{61.996}{62.371} = 0.994 \quad (3)$$

7.2.5 NPSH_{SUBCOOLING}

Sections 7.2.2 through 7.2.4 are used to calculate the additional NPSH available due to sump subcooling. The additional NPSH available is

$$NPSH_{\text{SUBCOOLING}} = \frac{15.47}{0.994} * 2.31 = 35.95 \text{ feet} \quad (4)$$

To maintain conservatism, only 25% , or 8.99 feet, of the NPSH_{SUBCOOLING} will be accounted for in this calculation.

7.2.6 ELEVATION DIFFERENCE (Z)

The centerline of the CSPs are at 973.25 ft (Assumption 4.1.2) and the bottom of the containment sump is at 994 ft per Reference 3.1. This Z equals 20.75 ft but does not account for any level in the containment sump. There will, however, be water in the sump which will result in additional level. Reference 3.11 revealed that the height of water in the sump would be approximately 6.0 ft. This does not account for RCS volume but does account for SIT volume. The resultant Z is 26.75 ft. This calculation shows NPSH_a values for both Z = 20.75 feet and Z = 26.75 feet.

$$X - 973.25 = 26.75$$

$$\underline{X = 1000 \text{ ft}}$$

$$X - 973.25 = 20.75$$

$$X = 994$$

7.2.7 SUCTION HEADLOSS (H_{hs})

To determine the suction headloss equations for each pump, data for the respective piping sections of Reference 3.1 was used to calculate a Total K factor. FLO-SERIES computes two K factors, K_{valve} and K_{flow} . PIPE-FLO calculates K_{valve} based on the valves and fittings "installed" into each pipe section. This K_{valve} is shown on the individual Pipeline Reports which are located in Appendix B. NET-FLO then computes K_{flow} using fL/D. The values for f, L (in feet), and D (in inches) are also shown on the Pipeline Reports in Appendix B. Equation 5 was used to calculate K_{total} . Table 2 compiles the data from the Pipeline Reports and computes a Total K for each pipe section. Equation 6, taken from Reference 3.9, calculates K in terms of different size pipes. Using Equation 6, an effective K for the suction side of the respective pump is calculated and is shown in Table 3.

$$K_{total} = K_{valve} + K_{flow} \quad (5)$$

$$K_{smaller\ pipe} = K_{larger\ pipe} \left(\frac{d_{small}}{d_{large}} \right)^4 \quad (6)$$

Once an effective K factor was determined, Equation 7, taken from page 3-4 of Reference 3.9, was used to calculate the headloss at different flows.

$$H_{fs} = \frac{0.00259 K_{total} Q^2}{d_{small}^4} \quad (7)$$

7.2.8 SUCTION HEADLOSS (H_{hs}) FOR PUMPS SI-3B and SI-3C OPERATING IN PARALLEL

Runs 1-3 result in pumps SI-3B and SI-3C operating in parallel. Therefore, the flow in the common pipelines (108, 110, and 112) is essentially doubled. To account for this additional headloss, the resistance for those pipelines has been quadrupled when the CS system is operating in one of the applicable configurations. Equations 10 and 12 represent the headloss equations and Table 3 displays the results in spreadsheet format.

7.2.9 AVAILABLE NPSH EQUATION

Using Sections 7.2.1 through 7.2.8, the resultant NPSH_a equations for each CSP are:

$$SI-3A \quad NPSH_a = 8.99 + Z - 2.084 \times 10^{-7} Q^2 \quad (8)$$

$$SI-3B \quad NPSH_a = 8.99 + Z - 2.657 \times 10^{-7} Q^2 \quad (9)$$

$$SI-3B \text{ (w/ SI-3C)} \quad NPSH_a = 8.99 + Z - 3.899 \times 10^{-7} Q^2 \quad (10)$$

$$SI-3C \quad NPSH_a = 8.99 + Z - 2.750 \times 10^{-7} Q^2 \quad (11)$$

$$SI-3C \text{ (w/ SI-3B)} \quad NPSH_a = 8.99 + Z - 3.991 \times 10^{-7} Q^2 \quad (12)$$

The effective K factors and headloss equations are included in Table 3. NPSH_a calculations for Equations 8 through 12 are in spreadsheet form in Tables 4 and 5.

7.3 FLO-SERIES INPUT AND OUTPUT

7.3.1 FLO-SERIES INPUT

The main CS System network was formed in References 3.1 and 3.2. The network was modified per Section 7.1 of this calculation. The input data consisted of containment sump pressure and pressure at the discharge of the containment spray nozzles. Since the nozzles are also in containment, the pressures are similar. The difference arises due to the 6 foot level in the sump, in accordance with Assumption 4.2. This results in an additional 2.6 psi of pressure at Nodes H69 and H70 using Equation 13.

$$P_{\text{additional}} = \frac{6 \text{ ft} * 62.12 \frac{\text{lbf}}{\text{ft}^3}}{144 \frac{\text{inch}^2}{\text{ft}^2}} \quad (13)$$

where 62.12 lbf/ft³ is the density at 90°F (Reference 3.15)
144 inch²/ft² converts ft² to inch²

The initial pressure input is not important in this application; the only rigid requirement is that the difference between sump and containment spray nozzle pressure be 2.6 psi to account for sump water level.

7.3.2 FLO-SERIES OUTPUT

The FLO-SERIES output is contained in Appendix C. The RUN 1 output contains a complete NET-FLO report. This includes a Network Summary Report, a Configured Complete Junction Node Report, and a Complete Pipeline Report. These allow the reviewer to verify the node connections and ensure the proper pump was used. For other runs, only the Network Summary Report and Complete Pipeline Report are submitted.

Table 6 lists the flows computed by FLO-SERIES and the NPSH_a for each run in a composite format.

Table 2
PIPELINE TOTAL K FACTORS

Total K's for CSP suction pipes. Data is taken from Pipeline Reports in Appendix B.					
PIPE #	K v&f	f	L (ft)	D (in)	Total K
2	0.236	0.012	7.25	19.25	0.290
5	0.618	0.013	18.65	12.39	0.853
6	1.662	0.013	26.39	12.39	1.994
7	1.405	0.013	14.85	12.39	1.592
67	0.448	0.013	9.50	12.00	0.572
68	0.000	0.013	5.50	12.00	0.072
69	0.259	0.013	10.43	12.00	0.395
107	0.228	0.011	7.20	23.25	0.269
108	0.368	0.012	5.42	23.25	0.402
109	3.022	0.011	140.40	23.25	3.819
110	3.100	0.011	89.72	23.25	3.609
111	0.475	0.011	55.86	23.25	0.792
112	0.388	0.011	47.56	23.25	0.658

Table 3

HEADLOSS EQUATIONS FOR THE CONTAINMENT SPRAY PUMP

Headloss Equations for CSP SI-3A during Recirculation

Total K factors are from Table 2

Pipe	Diameter	Total K	In terms of	New K
5	12.39	0.853	12.00	0.750
67	12.00	0.572	12.00	0.572
107	23.25	0.269	12.00	0.019
109	23.25	3.819	12.00	0.271
111	23.25	0.792	12.00	0.056
Effective K =				1.668

Suction Head Losses for CSP SI-3A

$$HL = 0.00259 K Q^2/d^4$$

$$HL = 2.084E-07 Q^2$$

Headloss Equations for CSP SI-3B during Recirculation

Total K factors are from Table 2

7	12.39	1.592	12.00	1.401
69	12.00	0.395	12.00	0.395
* 108	23.25	0.402	12.00	0.029
* 110	23.25	3.609	12.00	0.256
* 112	23.25	0.658	12.00	0.047
Effective K =				2.127
K' =				3.121

Suction Head Losses for CSP SI-3B

$$HL = 0.00259 K Q^2/d^4$$

Single Pump

$$HL = 2.657E-07 Q^2$$

Two Pump

$$3.899E-07 Q^2$$

Headloss Equations for CSP SI-3C during Recirculation

Total K factors are from Table 2

2	19.25	0.290	12.00	0.044
6	12.39	1.994	12.00	1.755
68	12.00	0.072	12.00	0.072
* 108	23.25	0.402	12.00	0.029
* 110	23.25	3.609	12.00	0.256
* 112	23.25	0.658	12.00	0.047
Effective K =				2.201
K' =				3.196

Suction Head Losses for CSP SI-3C

$$HL = 0.00259 K Q^2/d^4$$

Single Pump

$$HL = 2.750E-07 Q^2$$

Two Pump

$$3.991E-07 Q^2$$

* refers to those sections of suction pipe which are shared by pumps 3B and 3C. These values for "New K" are quadrupled to determine K' for input to the "H" equation for when CSPs 3B and 3C are operating.

PAGE 16 of 21

Table 4

Based on NPSHsc = 8.99 ft								
Z = 20.75 ft (no level in the sump)								
HL = headloss based on appropriate equation from Table 3								
NPSHa = NPSHsc + Z - HL =	8.99 + 20.75 - HL	2000	2200	2400	2600	2800	3000	3200
NPSHa SI-3A	28.906	28.731	28.539	28.331	28.106	27.864	27.606	
NPSHa SI-3B	28.677	28.454	28.209	27.943	27.656	27.348	27.019	
NPSHa SI-3C	28.640	28.409	28.156	27.881	27.584	27.265	26.924	
NPSHr	14.8	16.5	18.3	20.2	22.5	24.5	27.0	
Based on NPSHsc = 8.99 ft								
Z = 26.75 ft (6 foot level in the sump per Reference 3.11)								
HL = headloss based on appropriate equation from Table 3								
NPSHa = NPSHsc + Z - HL =	8.99 + 26.75 - HL	2000	2200	2400	2600	2800	3000	3200
NPSHa SI-3A	34.906	34.731	34.539	34.331	34.106	33.864	33.606	
NPSHa SI-3B	34.677	34.454	34.209	33.943	33.656	33.348	33.019	
NPSHa SI-3C	34.640	34.409	34.156	33.881	33.584	33.265	32.924	
NPSHr	14.8	16.5	18.3	20.2	22.5	24.5	27.0	
NPSHr is taken from Reference 3.12								

Table 5
AVAILABLE NET POSITIVE SUCTION HEAD FOR
SI-3B AND SI-3C OPERATING IN PARALLEL

Available Net Positive Suction Head for CSPs SI-3B & SI-3C								
Based on NPSHsc = 8.99 ft								
Z = 20.75 ft and Headloss based on appropriate equation from Table 3								
NPSHa = NPSHsc + Z - HL = 8.99 + 20.75 - HL								
	Flow	2000	2200	2400	2600	2800	3000	3200
NPSHa SI-3B		28.18	27.85	27.49	27.10	26.68	26.23	25.75
NPSHa SI-3C		28.14	27.81	27.44	27.04	26.61	26.15	25.65
NPSHr		14.8	16.5	18.3	20.2	22.5	24.5	27.0

Based on NPSHsc = 8.99 ft								
Z = 26.75 ft and Headloss based on appropriate equation from Table 3								
NPSHa = NPSHsc + Z - HL = 8.99 + 26.75 - HL								
	Flow	2000	2200	2400	2600	2800	3000	3200
NPSHa SI-3B		34.18	33.85	33.49	33.10	32.68	32.23	31.75
NPSHa SI-3C		34.14	33.81	33.44	33.04	32.61	32.15	31.65
NPSHr		14.8	16.5	18.3	20.2	22.5	24.5	27.0


Table 6

COMPOSITE FLOW vs. CONFIGURATION

NPSHa for CSP flows as computed by FLO-SERIES Using manufacturer's pump curve data of Reference 3.16 NPSHsc = 8.99 ft					
Pump	Configuration	Flow (gpm)	NPSHa (ft) (Z=0 ft)	NPSHa (ft) (Z=6.0 ft)	Suction Headloss (ft)
SI-3A	3P2H	2489	28.449	34.449	1.291
	3P1H	1535	29.249	35.249	0.491
	2P1H	2 21	28.803	34.803	0.937
	1P1H	31'J3	27.695	33.695	2.045
SI-3B	3P2H	2566	27.173	33.173	2.567
	2P2H	3132	25.916	31.916	3.824
	3P1H	1563	28.788	34.788	0.952
	2P1H	2192	28.463	34.463	1.277
SI-3C	3P2H	2549	27.147	33.147	2.593
	2P2H	3115	25.867	31.867	3.873
	3P1H	1530	28.806	34.806	0.934
	2P1H	2180	28.433	34.433	1.307


Note: Flows listed are the highest flows for the specific pump in the specific configuration.
The FLO-SERIES flow outputs are found in Appendix C.

Figure 1
OPPD CSP NPSH w/ SUMP SUB-COOLING
 2P2H Configuration




NPSH_a taken from SI-3C of Table 5
 Vertical lines represent pump flows
 in 2P2H configuration.

Figure 2
OPPD CSP NPSH w/ SUMP SUB-COOLING
3P2H Configuration




NPSH_a taken from SI-3C of Table 5
Vertical lines represent pump flows
in 3P2H configuration.

Figure 3
OPPD CSP NPSH w/ SUMP SUB-COOLING
2P1H Configuration



NPSH_a taken from SI-3C of Table 4
Vertical lines represent pump flows
in 2P1H configuration.

Figure 4
OPPD CSP NPSH w/ SUMP SUB-COOLING
1P1H Configuration



NPSH_a taken from SI-3C of Table 4
Vertical lines represent pump flow
of SI-3A.

FC 05977


O-MECH-CALC-021 Rev. 00


Page A \


**APPENDIX A
PIPING DIAGRAM**



A2


Piping Diagram











RECIRCULATION (MINI-FLOW) PIPELINE

**APPENDIX B
PIPE-FLO OUTPUT**

- | | |
|-----|-------------------------------|
| B2 | OPPDGS Piping Project Report |
| B11 | Component Table Report |
| B12 | Pump Suction Pipeline Reports |

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Harsell

PROJECT : OPPDCS

PIPES : 123

UPDATED: JUNE 8, 1992

OPPD CONTAINMENT SPRAY SYSTEM
CSP NPSH EVALUATION W/ SUMP SUBCOOLING
O-MECH-CALC-021DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec
----- PRESSURE MIN: 0.00 MAX: 5000.00 PSI

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
1 SIRWT EXIT	STEEL 20 in/SCH 20	74.45	WATER 90 deg-F		2.593
2 SIRWT HEADER	STEEL 20 in/SCH 20	7.25	WATER 90 deg-F		0.236
3 SIRWT EXIT	STEEL 20 in/SCH 20	35.75	WATER 90 deg-F		1.884
4 SIRWT HEADER	STEEL 24 in/SCH 20	4	WATER 90 deg-F		12.521
5 SI-3A SUCTION	SSTEEL 12 in/SCH 10S	18.65	WATER 90 deg-F		0.618
6 SI-3C SUCTION	SSTEEL 12 in/SCH 10S	26.39	WATER 90 deg-F		1.662
7 SI-3B SUCTION	SSTEEL 12 in/SCH 10S	14.85	WATER 90 deg-F		1.405
8 SI-3A DISCHARGE	SSTEEL 8 in/SCH 40S	100.60	WATER 90 deg-F		4.062
9 SI-3B DISCHARGE	SSTEEL 8 in/SCH 40S	20.20	WATER 90 deg-F		2.937
10 SI-3C DISCHARGE	SSTEEL 8 in/SCH 40S	22.56	WATER 90 deg-F		3.218
11 DSCHRG HDR	SSTEEL 12 in/SCH 40S	2.11	WATER 90 deg-F		0.259
12 DSCHRG HDR	SSTEEL 12 in/SCH 40S	0.66	WATER 90 deg-F		0.580

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Harsell

PROJECT : OPPDCS

PIPES : 123

UPDATED: JUNE 8, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
13 DSCHRG HDR	SSTEEL 12 in/SCH 40S	173.70	WATER 90 deg-F		1.863
14 A HX INLET	SSTEEL 12 in/SCH 40S	23.16	WATER 90 deg-F		2.399
15 B HX INLET	SSTEEL 12 in/SCH 40S	32.16	WATER 90 deg-F		4.766
16 A HX OUTLET	SSTEEL 12 in/SCH 40S	15.44	WATER 90 deg-F		0.981
17 B HX OUTLET	SSTEEL 12 in/SCH 40S	14.19	WATER 90 deg-F		0.792
18 HX CROSS CONECT	SSTEEL 12 in/SCH 40S	12.63	WATER 90 deg-F		1.500
19 HX CROSS CONECT	SSTEEL 12 in/SCH 40S	12.27	WATER 90 deg-F		1.500
20 SDC DISCHARGE	SSTEEL 12 in/SCH 40S	1	WATER 90 deg-F		0.259
21 A HEADER	SSTEEL 12 in/SCH 40S	62.21	WATER 90 deg-F		2.435
22 B HEADER	SSTEEL 12 in/SCH 40S	66.47	WATER 90 deg-F		2.621
23 A HEADER	SSTEEL 8 in/SCH 40S	3.94	WATER 90 deg-F		1.430
24 B HEADER	SSTEEL 8 in/SCH 40S	3.94	WATER 90 deg-F		1.627
25 A HEADER	SSTEEL 12 in/SCH 40S	48.53	WATER 90 deg-F		1.345
26 A HEADER	SSTEEL 12 in/SCH 10S	52.95	WATER 90 deg-F		2.251

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Marsell

PROJECT : OPPDCS

PIPES : 123

UPDATED: JUNE 9, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
27 A HEADER	SSTEEL 12 in/SCH 10S	2.33	WATER 90 deg-F		0.514
28 A HEADER	SSTEEL 8 in/SCH 10S	47.35	WATER 90 deg-F		1.295
29 A HEADER	SSTEEL 8 in/SCH 10S	52.33	WATER 90 deg-F		1.578
30 A HEADER	SSTEEL 12 in/SCH 10S	6.20	WATER 90 deg-F		0.257
31 A HEADER	SSTEEL 12 in/SCH 10S	2.05	WATER 90 deg-F		0.257
32 A HEADER	SSTEEL 12 in/SCH 10S	1	WATER 90 deg-F		0.257
33 PIPE-33	SSTEEL 12 in/SCH 10S	2.05	WATER 90 deg-F		
34 A HEADER	SSTEEL 12 in/SCH 10S	4.11	WATER 90 deg-F		0.257
35 A HEADER	SSTEEL 12 in/SCH 10S	4.11	WATER 90 deg-F		0.257
36 A HEADER	SSTEEL 12 in/SCH 10S	4.11	WATER 90 deg-F		0.257
37 B HEADER	SSTEEL 12 in/SCH 10S	53.38	WATER 90 deg-F		2.287
38 B HEADER	SSTEEL 12 in/SCH 10S	1	WATER 90 deg-F		0.257
39 B HEADER	SSTEEL 8 in/SCH 10S	55.32	WATER 90 deg-F		1.559
40 B HEADER	SSTEEL 8 in/SCH 10S	51.50	WATER 90 deg-F		2.088

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Harsell

PROJECT : OPPDCS
PIPES : 123

UPDATED: JUNE 8, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
41 B HEADER	SSTEEL 12 in/SCH 10S	4.12	WATER 90 deg-F		
42 B HEADER	SSTEEL 12 in/SCH 10S	1	WATER 90 deg-F		0.257
43 B HEADER	SSTEEL 12 in/SCH 10S	0.66	WATER 90 deg-F		2.913
44 B HEADER	SSTEEL 12 in/SCH 10S	3.75	WATER 90 deg-F		
45 B HEADER	SSTEEL 12. in/SCH 10S	4.11	WATER 90 deg-F		0.257
46 B HEADER	SSTEEL 12 in/SCH 10S	4.11	WATER 90 deg-F		0.257
47 B HEADER	SSTEEL 12 in/SCH 10S	4.11	WATER 90 deg-F		0.257
48 B HEADER	SSTEEL 12 in/SCH 10S	4.11	WATER 90 deg-F		0.257
49 RING A	SSTEEL 8 in/SCH 10S	9.18	WATER 90 deg-F		1.273
50 RING B	SSTEEL 8 in/SCH 10S	17.55	WATER 90 deg-F		1.280
51 RING C	SSTEEL 6 in/SCH 10S	25.48	WATER 90 deg-F		1.261
52 RING D	SSTEEL 6 in/SCH 10S	33.24	WATER 90 deg-F		1.272
53 RING E	SSTEEL 4 in/SCH 10S	36.63	WATER 90 deg-F		1.052
54 RING E2	SSTEEL 4 in/SCH 10S	0.33	WATER 90 deg-F		0.322

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Harsell

PROJECT : OPPDCS

PIPES : 123

UPDATED: JUNE 8, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
55 RING E3	SSTEEL 3 in/SCH 10S	11.50	WATER 90 deg-F		0.338
56 RING F	SSTEEL 4 in/SCH 10S	5.35	WATER 90 deg-F		1.593
57 RING G	SSTEEL 8 in/SCH 10S	4.98	WATER 90 deg-F		1.267
58 RING H	SSTEEL 8 in/SCH 10S	13.45	WATER 90 deg-F		1.046
59 RING I	SSTEEL 6 in/SCH 10S	21.56	WATER 90 deg-F		1.258
60 RING J	SSTEEL 6 in/SCH 10S	29.45	WATER 90 deg-F		1.269
61 RING K	SSTEEL 4 in/SCH 10S	32.80	WATER 90 deg-F		1.050
62 RING K2	SSTEEL 4 in/SCH 10S	0.33	WATER 90 deg-F		0.322
63 RING K3	SSTEEL 3 in/SCH 10S	12	WATER 90 deg-F		0.335
64 RING L	SSTEEL 4 in/SCH 10S	5.39	WATER 90 deg-F		1.587
65 SPRAY HDR A	SSTEEL 12 in/SCH 10S	0.33	WATER 90 deg-F		2.913
66 SPRAY HDR A	SSTEEL 12 in/SCH 10S	0.33	WATER 90 deg-F		2.913
67 SI-3A SUCTION	SSTEEL 12 in/SCH 40S	9.50	WATER 90 deg-F		0.448
68 SUCTION SI-3C	SSTEEL 12 in/SCH 40S	5.50	WATER 90 deg-F		

ABB Combustion Engineering
CLIENT : Omaha Public Power District

PIPING PROJECT REPORT JUNE 8, 1992
R. Harsell

PROJECT : OPPDCS
PIPES : 123

UPDATED: JUNE 8, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
69 SUCTION SI-3B	SSTEEL 12 in/SCH 40S	10.43	WATER 90 deg-F		0.259
70 DISCHARGE HDR	SSTEEL 12 in/SCH 40S	0.66	WATER 90 deg-F		0.580
71 DISCHARGE HDR	SSTEEL 12 in/SCH 40S	0.66	WATER 90 deg-F		0.580
72 DISCHARGE HDR	SSTEEL 12 in/SCH 40S	0.66	WATER 90 deg-F		0.580
73 HEADER B	SSTEEL 12 in/SCH 40S	39.52	WATER 90 deg-F		0.518
74 PUMP SI-3A	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		0.333
75 PUMP SI-3B	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		0.333
76 PUMP SI-3C	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		0.371
77 HX-A	SSTEEL 12 in/SCH 40S	1	WATER 90 deg-F		
78 HX-B	SSTEEL 12 in/SCH 40S	1	WATER 90 deg-F		
79 RING A	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		65.909
80 RING B	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		99.196
81 RING C	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		150.980
82 RING D	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		284.020

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Harsell

PROJECT : OPPDCS

PIPES : 123

UPDATED: JUNE 8, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
83 RING E	SSTEEL 3 in/SCH 10S	1	WATER 90 deg-F		463.420
84 RING F	SSTEEL 4 in/SCH 10S	1	WATER 90 deg-F		138.920
85 RING G	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		58.820
86 RING H	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		107.060
87 RING I	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		174.330
88 RING J	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		300.980
89 RING K	SSTEEL 3 in/SCH 10S	1	WATER 90 deg-F		116.210
90 RING L	SSTEEL 4 in/SCH 10S	1	WATER 90 deg-F		128.500
91 SIRWT	STEEL 20 in/SCH 20	0.25	WATER 90 deg-F		0.500
92 SIRWT	STEEL 20 in/SCH 20	0.25	WATER 90 deg-F		0.500
93 PIPE-93	SSTEEL .5 in/SCH 80S	9,000	WATER 90 deg-F	%	5400000
94 CS RECIRC	SSTEEL 2 in/SCH 40S	23.54	WATER 90 deg-F		91.894
95 CS RECIRC	SSTEEL 2 in/SCH 40S	18	WATER 90 deg-F		89.961
96 CS RECIRC	SSTEEL 2 in/SCH 40S	8.46	WATER 90 deg-F		89.021

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992
R. HarsellPROJECT : OPPDCS
PIPES : 123

UPDATED: JUNE 8, 1992

	IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	FLUID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
97	CS RECIRC	SSTEEL 3 in/SCH 40S	0.60	WATER 90 deg-F		
98	COMMON RECIRC	SSTEEL 3 in/SCH 40S	9.40	WATER 90 deg-F		0.505
99	COMMON RECIRC	SSTEEL 6 in/SCH 40S	0.66	WATER 90 deg-F		0.596
100	CS RECIRC	SSTEEL 6 in/SCH 40S	1	WATER 90 deg-F		
101	COMMON RECIRC	SSTEEL 6 in/SCH 40S	27.24	WATER 90 deg-F		0.894
102	COMMON RECIRC	SSTEEL 6 in/SCH 40S	5	WATER 90 deg-F		0.596
103	COMMON RECIRC	SSTEEL 6 in/SCH 40S	43.25	WATER 90 deg-F		2.235
104	COMMON RECIRC	SSTEEL 4 in/SCH 80S	6	WATER 90 deg-F		11.644
105	COMMON RECIRC	SSTEEL 6 in/SCH 10S	24.99	WATER 90 deg-F		2.158
106	COMMON RECIRC	SSTEEL 6 in/SCH 10S	21.01	WATER 90 deg-F		0.590
107	CS SUMP PIPE	STEEL 24 in/SCH 20	7.20	WATER 90 deg-F		0.228
108	CS SUMP PIPE	STEEL 20 in/SCH 20	5.42	WATER 90 deg-F		0.368
109	COMMON SUMP LIN	STEEL 24 in/SCH 20	140.40	WATER 90 deg-F		3.022
110	COMMON SUMP LIN	STEEL 24 in/SCH 20	89.72	WATER 90 deg-F		3.100

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPING PROJECT REPORT

JUNE 8, 1992

R. Harsell

PROJECT : OPPDCS

PIPES : 123

UPDATED: JUNE 8, 1992

IDENTIFIER	MATERIAL SIZE / SCH	LENGTH (ft)	ID NAME TEMP	DESIGN FLOW-RATE (gal/min)	TOTAL K
111 COMMON SUMP LIN	STEEL 24 in/SCH 20	55.86	WATER 90 deg-F		0.475
112 COMMON SUMP LIN	STEEL 24 in/SCH 20	47.56	WATER 90 deg-F		0.388
113 cs recirc 3b	SSTEEL 2 in/SCH 40S	0.66	WATER 90 deg-F		0.776
114 cs recirc 3c	SSTEEL 2 in/SCH 40S	0.66	WATER 90 deg-F		0.776
115 cs recirc 3a	SSTEEL 2 in/SCH 40S	0.66	WATER 90 deg-F		0.776
116 cs recirc	SSTEEL 2 in/SCH 40S	0.66	WATER 90 deg-F		0.560
117 common to sirwt	SSTEEL 6 in/SCH 10S	1	WATER 90 deg-F		1.000
118 SI-3C DISCHARGE	SSTEEL 8 in/SCH 40S	1	WATER 90 deg-F		
119 SI-3B DISCHARGE	SSTEEL 8 in/SCH 40S	1	WATER 90 deg-F		
120 SI-3A DISCHARGE	SSTEEL 8 in/SCH 40S	1	WATER 90 deg-F		
121 SUMP ENTRANCE	STEEL 24 in/SCH 20	0.25	WATER 90 deg-F		0.500
122 SUMP ENTRANCE	STEEL 24 in/SCH 20	0.25	WATER 90 deg-F		0.500
123 A1HEADER	SSTEEL 12 in/SCH 40S	25.28	WATER 90 deg-F		1.917

COMPONENT TABLE REPORT as of MAY 21, 1992

TABLE NAME: 6 COMPONENT ENTRIES

CSS COMPONENTS FOR OPPD CSP NPSH w/ SUBCOOLING

CODE	COMPONENT ID	POWER EQUATION
A	HX-A	HEAD LOSS = 1.54E-06 * Q ^ 2
	DATA POINTS: 0 gal/min vs. 0 ft of fluid	
	DATA POINTS: 1500 gal/min vs. 3.476 ft of fluid	
	DATA POINTS: 4000 gal/min vs. 24.72 ft of fluid	
B	FLOW VALVE	HEAD LOSS = 7.99E-07 * Q ^ 2
	DATA POINTS: 0 gal/min vs. 0 ft of fluid	
	DATA POINTS: 2000 gal/min vs. 3.194 ft of fluid	
	DATA POINTS: 4000 gal/min vs. 12.776 ft of fluid	
C	SI-3A	(pump) HEAD RISE = 500 - 1.01E-07 * Q ^ 2.642
	DATA POINTS: 0 gal/min vs. 500 ft of fluid	
	DATA POINTS: 2800 gal/min vs. 370 ft of fluid	
	DATA POINTS: 3200 gal/min vs. 315 ft of fluid	
D	SI-3B	(pump) HEAD RISE = 496 - 5.62E-08 * Q ^ 2.713
	DATA POINTS: 0 gal/min vs. 496 ft of fluid	
	DATA POINTS: 2800 gal/min vs. 370 ft of fluid	
	DATA POINTS: 3200 gal/min vs. 315 ft of fluid	
E	SI-3C	(pump) HEAD RISE = 494 - 4.14E-08 * Q ^ 2.749
	DATA POINTS: 0 gal/min vs. 494 ft of fluid	
	DATA POINTS: 2800 gal/min vs. 370 ft of fluid	
	DATA POINTS: 3200 gal/min vs. 315 ft of fluid	
F	flow meter	HEAD LOSS = 8.68E-07 * Q ^ 2
	DATA POINTS: 0 gal/min vs. 0 ft of fluid	
	DATA POINTS: 2000 gal/min vs. 3.46 ft of fluid	
	DATA POINTS: 4500 gal/min vs. 17.51 ft of fluid	

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SIRWT HEADER MAR 19, 1992
Petrasko/ Harsell

PROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 2 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 20 density: 62.108 lbs/ft³
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipois

NOMINAL SIZE: 20 in DESIGN FLOW RATE:
inside diameter: 19.25 in FLUID VELOCITY:
PIPE LENGTH: 7.25 ft HEAD LOSS:
ELEVATION IN: 981.00 ft PRESSURE IN:
OUT: 981.00 ft OUT:

----- VALVES AND FITTINGS -----
VALVE NO FFT - 0.012 K - VALUE
1 TEE-RUN 0.236
V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 0.236

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SI-3A SUCTION MAR 19, 1992
Petrasko/ HarsellPROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 5 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: SSTEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 10S density: 62.108 lbs/ft^3
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipoisNOMINAL SIZE: 12 in DESIGN FLOW RATE:
inside diameter: 12.39 in FLUID VELOCITY:
PIPE LENGTH: 18.65 ft HEAD LOSS:
ELEVATION IN: 980.00 ft PRESSURE IN:
OUT: 980.00 ft OUT:----- VALVES AND FITTINGS -----
VALVE NO FFT - 0.013 K - VALUE
1 2 * ELBOW-S 90 deg 0.515
2 GATE 0.103

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 0.618

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SI-3C SUCTION MAR 19, 1992
Petrasko/ Harsell

PROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 6 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: SSTEEL	FLUID: WATER at 90.0 deg-F
SCHEDULE: 10S	density: 62.108 lbs/ft ³
abs. roughness: 1.80E-03 in	viscosity: 0.7600 centipois

NOMINAL SIZE: 12 in	DESIGN FLOW RATE:
inside diameter: 12.39 in	FLUID VELOCITY:
PIPE LENGTH: 26.39 ft	HEAD LOSS:
ELEVATION IN: 981.00 ft	PRESSURE IN:
OUT: 978.00 ft	OUT:

----- VALVES AND FITTINGS -----		
VALVE NO	FFT - 0.013	K - VALUE
1	FIX-K VALUE	0.787
2	3 * ELBOW-S	0.772
3	GATE	0.103

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 1.662

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SI-3B SUCTION MAR 19, 1992
Petrasko/ HarsellPROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 7 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: SSTEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 10S density: 62.108 lbs/ft^3
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipoisNOMINAL SIZE: 12 in DESIGN FLOW RATE:
inside diameter: 12.39 in FLUID VELOCITY:
PIPE LENGTH: 14.85 ft HEAD LOSS:
ELEVATION IN: 981.00 ft PRESSURE IN:
OUT: 979.00 ft OUT:----- VALVES AND FITTINGS -----

VALVE NO	FFT -	K - VALUE
1	FIX-K VALUE	0.787
2	2 * ELBOW-S 90 deg	0.515
3	GATE	0.103

V&F HEAD LOSS = 0.000 ft V&F TOTAL K = 1.405

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SI-3A SUCTION MAR 19, 1992
Petrasko/ HarsellPROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 67 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: SSTEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 40S density: 62.108 lbs/ft^3
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipoisNOMINAL SIZE: 12 in DESIGN FLOW RATE:
inside diameter: 12.00 in FLUID VELOCITY:
PIPE LENGTH: 9.50 ft HEAD LOSS:
ELEVATION IN: 980.00 ft PRESSURE IN:
OUT: 973.00 ft OUT:----- VALVES AND FITTINGS -----

VALVE NO		FFT - 0.013	K - VALUE
1	ELBOW-S	45 deg	0.189
2	ELBOW-S	90 deg	0.259

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 0.448

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SUCTION SI-3C MAR 19, 1992
Petrasko/ Harsell

PROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 68 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: SSTEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 40S density: 62.108 lbs/ft³
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipois

NOMINAL SIZE: 12 in DESIGN FLOW RATE:
inside diameter: 12.00 in FLUID VELOCITY:
PIPE LENGTH: 5.50 ft HEAD LOSS:
ELEVATION IN: 978.00 ft PRESSURE IN:
OUT: 973.00 ft OUT:

----- VALVES AND FITTINGS -----
none

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : SUCTION SI-3B MAR 19, 1992
Petrasko/ Harsell

PROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 69 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: SSTEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 40S density: 62.108 lbs/ft³
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipois

NOMINAL SIZE: 12 in DESIGN FLOW RATE:
inside diameter: 12.00 in FLUID VELOCITY:
PIPE LENGTH: 10.43 ft HEAD LOSS:
ELEVATION IN: 979.00 ft PRESSURE IN:
OUT: 973.00 ft OUT:

----- VALVES AND FITTINGS -----

VALVE NO	FFT -	K - VALUE
1	0.013	0.259

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 0.259

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : CS SUMP PIPE

MAR 19, 1992
Petrasko/ Harsell

PROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 107 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

----- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 20 density: 62.108 lbs/ft³
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipois

NOMINAL SIZE: 24 in DESIGN FLOW RATE:
inside diameter: 23.25 in FLUID VELOCITY:
PIPE LENGTH: 7.20 ft HEAD LOSS:
ELEVATION IN: 980.00 ft PRESSURE IN:
OUT: 980.00 ft OUT:

----- VALVES AND FITTINGS -----

VALVE NO	FFT -	K - VALUE
1	0.011	0.228

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 0.228

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : CS SUMP PIPE

MAR 19, 1992

Petrasko/ Harsell

PROJECT : OPPDCS	DESIGN RULES:	VELOCITY MIN:	MAX: 1000.00 ft/sec
PIPE NO : 108	-----	PRESSURE MIN:0	MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL	FLUID: WATER at 90.0 deg-F
SCHEDULE: 20	density: 62.108 lbs/ft ³
abs. roughness: 1.80E-03 in	viscosity: 0.7600 centipois

NOMINAL SIZE: 20 in	DESIGN FLOW RATE:
inside diameter: 19.25 in	FLUID VELOCITY:
PIPE LENGTH: 5.42 ft	HEAD LOSS:
ELEVATION IN: 982.00 ft	PRESSURE IN:
OUT: 982.00 ft	OUT:

----- VALVES AND FITTINGS -----			
VALVE NO	FFT -	0.012	K - VALUE
1	TEE-RUN		0.236
2	REDUCER	seat: 23.25 , appr: 2.00	0.132

V&F HEAD LOSS -	0.000 ft	V&F TOTAL K -	0.368
-----------------	----------	---------------	-------

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : COMMON SUMP LIN MAR 19, 1992
Petrasko/ HarsellPROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 109 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 20 density: 62.108 lbs/ft^3
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipoisNOMINAL SIZE: 24 in DESIGN FLOW RATE:
inside diameter: 23.25 in FLUID VELOCITY:
PIPE LENGTH: 140.40 ft HEAD LOSS:
ELEVATION IN: 994.00 ft PRESSURE IN:
OUT: 982.00 ft OUT:

----- VALVES AND FITTINGS -----

VALVE NO		FFT - 0.011	K - VALUE
1	CK-SW-ANG		1.141
2	BUTTERFLY		0.285
3	2 * ELBOW-S	24 deg	0.276
4	2 * ELBOW-L	90 deg	0.320
5	EXIT		1.000

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 3.022

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : COMMON SUMP LIN MAR 19, 1992
Petrasko/ HarsellPROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 110 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 20 density: 62.108 lbs/ft³
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipoisNOMINAL SIZE: 24 in DESIGN FLOW RATE:
inside diameter: 23.25 in FLUID VELOCITY:
PIPE LENGTH: 89.72 ft HEAD LOSS:
ELEVATION IN: 994.00 ft PRESSURE IN:
OUT: 982.00 ft OUT:

VALVE AND FITTINGS		
VALVE NO	FFI	K - VALUE
1	CK-SW-ANG	1.141
2	BUTTERFLY	0.285
3	2 * ELBOW-L	0.195
4	3 * ELBOW-L	0.479
5	EXIT	1.000

V&F HEAD LOSS = 0.000 ft V&F TOTAL K = 3.100

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : COMMON SUMP LIN MAR 19, 1992
Petrasko/ HarsellPROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 111 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

---- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 20 density: 62.108 lbs/ft^3
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipoisNOMINAL SIZE: 24 in DESIGN FLOW RATE:
inside diameter: 23.25 in FLUID VELOCITY:
PIPE LENGTH: 55.86 ft HEAD LOSS:
ELEVATION IN: 982.00 ft PRESSURE IN:
OUT: 980.00 ft OUT:----- VALVES AND FITTINGS -----
VALVE NO FFT - 0.011 K - VALUE
1 ELBOW-L 20 deg 0.087
2 ELBOW-L 90 deg 0.160
3 TEE-RUN 0.228

V&F HEAD LOSS = 0.000 ft V&F TOTAL K = 0.475

ABB Combustion Engineering

CLIENT : Omaha Public Power District

PIPELINE REPORT : COMMON SUMP LIN MAR 19, 1992
Petrasko/ Harsell

PROJECT : OPPDCS DESIGN RULES: VELOCITY MIN: MAX: 1000.00 ft/sec
PIPE NO : 112 ----- PRESSURE MIN:0 MAX: 5000.00 PSI

----- PIPE CHARACTERISTICS ----- FLUID PROPERTIES -----

MATERIAL: STEEL FLUID: WATER at 90.0 deg-F
SCHEDULE: 20 density: 62.108 lbs/ft^3
abs. roughness: 1.80E-03 in viscosity: 0.7600 centipois

NOMINAL SIZE: 24 in DESIGN FLOW RATE:
inside diameter: 23.25 in FLUID VELOCITY:
PIPE LENGTH: 47.56 ft HEAD LOSS:
ELEVATION IN: 992.00 ft PRESSURE IN:
OUT: 992.00 ft OUT:

----- VALVES AND FITTINGS -----
VALVE NO FFT - 0.011 K - VALUE
1 ELBOW-L 90 deg 0.160
2 TEE-RUN 0.228

V&F HEAD LOSS - 0.000 ft V&F TOTAL K - 0.388

APPENDIX C
NET-FLO OUTPUT FOR CSS MAIN MODEL RUNS

C2	NET-FLO Output for Run 1
C19	NET-FLO Output for Run 2
C26	NET-FLO Output for Run 3
C33	NET-FLO Output for Run 4
C40	NET-FLO Output for Run 5
C47	NET-FLO Output for Run 6

ABB Combustion Engineering

CLIENT : Omaha Public Power District

NETWORK SUMMARY REPORTS

JUNE 8, 1992

R. Harsell

NETWORK NAME : OPPDCS1

DATA FOR PIPES: OPPDCS

UPDATED : JUNE 8, 1992

OPPD CSP NPSH W/ SUMP SUBCOOLING

O-MECH-CALC-021

3P2H:3A,3B,3C SUCTION FROM THE SUMP (6 ft)

0.01 % DEVIATION after 8 ITERATIONS

FIXED GRADE SUMMARY

NODE	NETWORK CONNECTION PIPELINE			FLOW-RATE (gal/min)		FIXED GRADE / PRESSURE SOURCE
R1	>>>	79	RING A	>>>	1,149.88	>>> 14.70 PSI
R2	>>>	80	RING B	>>>	926.30	>>> 14.70 PSI
R3	>>>	81	RING C	>>>	740.49	>>> 14.70 PSI
R4	>>>	82	RING D	>>>	537.40	>>> 14.70 PSI
R7	>>>	83	RING E	>>>	108.05	>>> 14.70 PSI
R8	>>>	84	RING F	>>>	336.13	>>> 14.70 PSI
R9	>>>	85	RING G	>>>	1,198.03	>>> 14.70 PSI
R10	>>>	86	RING H	>>>	875.66	>>> 14.70 PSI
R11	>>>	87	RING I	>>>	675.80	>>> 14.70 PSI
R12	>>>	88	RING J	>>>	510.55	>>> 14.70 PSI
R15	>>>	89	RING K	>>>	207.66	>>> 14.70 PSI
R16	>>>	90	RING L	>>>	338.13	>>> 14.70 PSI
H70	<<<	121	SUMP ENTRANCE	<<<	7,604.09	<<< 17.30 PSI

NET FLOWS IN: 0.01 gal/min

DEMAND SUMMARY

JUNCTION NODE	DEMAND (gal/min)	JUNCTION NODE	DEMAND (gal/min)
------------------	----------------------	------------------	----------------------

NET DEMAND IN: 0.00 gal/min

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

C1	0	989.00	1,032.58	18.80
----	---	--------	----------	-------

PIPES IN:	PIPES OUT:	1 SIRWT EXIT
-----------	------------	--------------

C10	0	974.00	1,433.68	198.26
-----	---	--------	----------	--------

PIPES IN: 74 PUMP SI-3A X 93XPIPE-93	PIPES OUT: 120 SI-3A DISCHARGE
---	--------------------------------

C11	0	979.50	1,408.62	185.08
-----	---	--------	----------	--------

PIPES IN: 8 SI-3A DISCHARGE	PIPES OUT: 70 DISCHARGE HDR X 93XPIPE-93
-----------------------------	---

C12	0	974.00	1,423.93	194.06
-----	---	--------	----------	--------

PIPES IN: 75 PUMP SI-3B	PIPES OUT: 119 SI-3B DISCHARGE
-------------------------	--------------------------------

C13	0	979.50	1,409.60	185.50
-----	---	--------	----------	--------

PIPES IN: 9 SI-3B DISCHARGE	PIPES OUT: 71 DISCHARGE HDR
-----------------------------	-----------------------------

C14	0	974.00	1,425.13	194.57
-----	---	--------	----------	--------

PIPES IN: 76 PUMP SI-3C	PIPES OUT: 118 SI-3C DISCHARGE
-------------------------	--------------------------------

C15	0	979.50	1,409.60	185.50
-----	---	--------	----------	--------

PIPES IN: 10 SI-3C DISCHARGE	PIPES OUT: 72 DISCHARGE HDR
------------------------------	-----------------------------

C16	0	979.50	1,408.16	184.88
-----	---	--------	----------	--------

PIPES IN: 11 DSCHRG HDR 70 DISCHARGE HDR	PIPES OUT: 13 DSCHRG HDR
---	--------------------------

COMPLETE JUNCTION NODE REPORT

JUNE 8, 1992

Page C 5

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEM. ND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
C17	0	979.50	1,409.12	185.30
	PIPS IN:	71 DISCHARGE HDR 72 DISCHARGE HDR	PIPS OUT:	11 DSCHRG HDR
C18	0	997.66	1,377.73	163.93
	PIPS IN:	13 DSCHRG HDR	PIPS OUT:	14 A HX INLET 15 B HX INLET
C19	0	993.75	1,372.84	163.50
	PIPS IN:	14 A HX INLET	PIPS OUT:	77 HX-A
C2	0	981.50	1,032.58	22.03
	PIPS IN:	1 SIRWT EXIT 2 SIRWT HEADER	PIPS OUT:	6 SI-3C SUCTION
C20	0	993.75	1,368.32	161.55
	PIPS IN:	15 B HX INLET	PIPS OUT:	78 HX-B
C21	0	995.75	1,350.53	153.02
	PIPS IN:	77 HX-A	PIPS OUT:	16 A HX OUTLET
C22	0	996.75	1,348.37	151.66
	PIPS IN:	16 A HX OUTLET	PIPS OUT:	18 HX CROSS CONECT 21 A HEADER
C23	0	995.75	1,345.92	151.03
	PIPS IN:	78 HX-B	PIPS OUT:	17 B HX OUTLET

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

C24	0	996.75	1,344.13	149.83
-----	---	--------	----------	--------

PIPES IN:	17 B HX OUTLET	PIPES OUT:	19 HX CROSS CONECT
			22 B HEADER

C25	0	990.50	1,348.37	154.35
-----	---	--------	----------	--------

PIPES IN:	18 HX CROSS CONECT	PIPES OUT:	X 20XSDC DISCHARGE
-----------	--------------------	------------	--------------------

C26	0	990.50	1,344.13	152.52
-----	---	--------	----------	--------

PIPES IN:	19 HX CROSS CONECT	PIPES OUT:
	X 20XSDC DISCHARGE	

C27	0	1,008.00	1,329.94	138.85
-----	---	----------	----------	--------

PIPES IN:	21 A HEADER	PIPES OUT:	23 A HEADER
-----------	-------------	------------	-------------

C28	0	1,009.00	1,325.18	136.37
-----	---	----------	----------	--------

PIPES IN:	22 B HEADER	PIPES OUT:	24 B HEADER
-----------	-------------	------------	-------------

C29	0	1,009.00	1,304.45	127.43
-----	---	----------	----------	--------

PIPES IN:	23 A HEADER	PIPES OUT:	25 A HEADER
-----------	-------------	------------	-------------

C3	0	981.50	1,032.62	22.05
----	---	--------	----------	-------

PIPES IN:	108 CS SUMP PIPE	PIPES OUT:	2 SIRWT HEADER
			7 SI-3B SUCTION

C30	0	1,032.00	1,300.81	115.94
-----	---	----------	----------	--------

PIPES IN:	25 A HEADER	PIPES OUT:	26 A HEADER
-----------	-------------	------------	-------------

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
C31	0	1,009.00	1,297.76	124.54
PIPES IN: 24 B HEADER		PIPES OUT: 73 HEADER B		
C32	0	1,036.70	1,295.82	111.76
PIPES IN: 73 HEADER B		PIPES OUT: 37 B HEADER		
C33	0	1,074.00	1,296.11	95.80
PIPES IN: 26 A HEADER		PIPES OUT: 27 A HEADER 29 A HEADER		
C34	0	1,074.00	1,295.88	95.70
PIPES IN: 27 A HEADER		PIPES OUT: 28 A HEADER		
C35	0	1,111.50	1,291.10	77.46
PIPES IN: 28 A HEADER		PIPES OUT: 30 A HEADER		
C36	0	1,111.50	1,291.16	77.49
PIPES IN: 29 A HEADER		PIPES OUT: 65 SPRAY HDR A 66 SPRAY HDR A		
C37	0	1,111.50	1,290.95	77.40
PIPES IN: 30 A HEADER		PIPES OUT: 31 A HEADER 49 RING A		
C38	0	1,111.50	1,290.93	77.39
PIPES IN: 31 A HEADER 65 SPRAY HDR A		PIPES OUT: 32 A HEADER		

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

C39	0	1,111.50	1,290.85	77.35
-----	---	----------	----------	-------

PIPES IN:	32 A HEADER 66 SPRAY HDR A	PIPES OUT:	33 PIPE-33
-----------	-------------------------------	------------	------------

C4	0	989.00	1,033.56	19.22
----	---	--------	----------	-------

PIPES IN:		PIPES OUT:	3 SIRWT EXIT
-----------	--	------------	--------------

C40	0	1,111.50	1,290.83	77.35
-----	---	----------	----------	-------

PIPES IN:	33 PIPE-33	PIPES OUT:	34 A HEADER 50 RING B
-----------	------------	------------	--------------------------

C41	0	1,111.50	1,290.73	77.30
-----	---	----------	----------	-------

PIPES IN:	34 A HEADER	PIPES OUT:	35 A HEADER 51 RING C
-----------	-------------	------------	--------------------------

C42	0	1,111.50	1,290.69	77.29
-----	---	----------	----------	-------

PIPES IN:	35 A HEADER	PIPES OUT:	36 A HEADER 52 RING D
-----------	-------------	------------	--------------------------

C43	0	1,111.50	1,290.68	77.28
-----	---	----------	----------	-------

PIPES IN:	36 A HEADER	PIPES OUT:	53 RING E
-----------	-------------	------------	-----------

C44	0	1,074.00	1,291.03	93.61
-----	---	----------	----------	-------

PIPES IN:	37 B HEADER	PIPES OUT:	38 B HEADER 40 B HEADER
-----------	-------------	------------	----------------------------

C45	0	1,074.00	1,290.93	93.56
-----	---	----------	----------	-------

PIPES IN:	38 B HEADER	PIPES OUT:	39 B HEADER
-----------	-------------	------------	-------------

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

C46	0	1,111.50	1,284.66	74.68
-----	---	----------	----------	-------

PIPES IN:	40 B HEADER	PIPES OUT:	41 B HEADER
-----------	-------------	------------	-------------

C47	0	1,111.50	1,284.64	74.68
-----	---	----------	----------	-------

PIPES IN:	41 B HEADER	PIPES OUT:	42 B HEADER
-----------	-------------	------------	-------------

C48	0	1,111.50	1,285.67	75.12
-----	---	----------	----------	-------

PIPES IN:	39 B HEADER	PIPES OUT:	43 B HEADER
-----------	-------------	------------	-------------

C49	0	1,111.50	1,284.45	74.59
-----	---	----------	----------	-------

PIPES IN:	44 B HEADER	PIPES OUT:	45 B HEADER 57 RING G
-----------	-------------	------------	--------------------------

C5	0	980.00	1,033.56	23.10
----	---	--------	----------	-------

PIPES IN:	3 SIRWT EXIT	PIPES OUT:	4 SIRWT HEADER
-----------	--------------	------------	----------------

C50	0	1,111.50	1,284.22	74.50
-----	---	----------	----------	-------

PIPES IN:	45 B HEADER	PIPES OUT:	46 B HEADER 58 RING H
-----------	-------------	------------	--------------------------

C51	0	1,111.50	1,284.11	74.45
-----	---	----------	----------	-------

PIPES IN:	46 B HEADER	PIPES OUT:	47 B HEADER 59 RING I
-----------	-------------	------------	--------------------------

C52	0	1,111.50	1,284.07	74.43
-----	---	----------	----------	-------

PIPES IN:	47 B HEADER	PIPES OUT:	48 B HEADER 60 RING J
-----------	-------------	------------	--------------------------

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

C53	0	1,111.50	1,284.06	74.43
-----	---	----------	----------	-------

PIPES IN: 48 B HEADER PIPES OUT: 61 RING K

C54	0	1,111.50	1,284.53	74.63
-----	---	----------	----------	-------

PIPES IN: 42 B HEADER
43 B HEADER PIPES OUT: 44 B HEADER

C6	0	980.00	1,033.56	23.10
----	---	--------	----------	-------

PIPES IN: 4 SIRWT HEADER
107 CS SUMP PIPE PIPES OUT: 5 SI-3A SUCTION

C60	0	975.00	1,423.84	193.59
-----	---	--------	----------	--------

PIPES IN: 119 SI-3B DISCHARGE PIPES OUT: 9 SI-3B DISCHARGE

C61	0	975.00	1,425.04	194.10
-----	---	--------	----------	--------

PIPES IN: 118 SI-3C DISCHARGE PIPES OUT: 10 SI-3C DISCHARGE

C62	0	975.00	1,433.59	197.79
-----	---	--------	----------	--------

PIPES IN: 120 SI-3A DISCHARGE PIPES OUT: 8 SI-3A DISCHARGE

C7	0	973.25	1,032.51	25.56
----	---	--------	----------	-------

PIPES IN: 67 SI-3A SUCTION PIPES OUT: 74 PUMP SI-3A

C8	0	973.25	1,031.07	24.94
----	---	--------	----------	-------

PIPES IN: 68 SUCTION SI-3C PIPES OUT: 76 PUMP SI-3C

C9	0	973.25	1,031.11	24.96
----	---	--------	----------	-------

PIPES IN: 69 SUCTION SI-3B PIPES OUT: 75 PUMP SI-3B

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

H3	0	982.00	1,033.63	22.27
----	---	--------	----------	-------

PIPES IN: 109 COMMON SUMP LIN PIPES OUT: 111 COMMON SUMP LIN

H70	0	994.00	1,033.85	17.19
-----	---	--------	----------	-------

PIPES IN: 121 SUMP ENTRANCE PIPES OUT: 109 COMMON SUMP LIN
110 COMMON SUMP LIN

N3	0	980.00	1,033.58	23.11
----	---	--------	----------	-------

PIPES IN: 111 COMMON SUMP LIN PIPES OUT: 107 CS SUMP PIPE

N42	0	---	1,032.99	---
-----	---	-----	----------	-----

PIPES IN: 110 COMMON SUMP LIN PIPES OUT: 112 COMMON SUMP LIN

N9	0	980.00	1,032.82	22.78
----	---	--------	----------	-------

PIPES IN: 112 COMMON SUMP LIN PIPES OUT: 108 CS SUMP PIPE

R1	0	1,117.50	1,289.90	74.36
----	---	----------	----------	-------

PIPES IN: 49 RING A PIPES OUT: 79 RING A

R10	0	1,119.30	1,283.66	70.89
-----	---	----------	----------	-------

PIPES IN: 58 RING H PIPES OUT: 86 RING H

R11	0	1,122.30	1,282.72	69.19
-----	---	----------	----------	-------

PIPES IN: 59 RING I PIPES OUT: 87 RING I

R12	0	1,124.60	1,283.16	68.39
-----	---	----------	----------	-------

PIPES IN: 60 RING J PIPES OUT: 88 RING J

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
R13	0	1,124.50	1,277.87	66.15
	PIPES IN: 61 RING K		PIPES OUT: 62 RING K2 64 RING L	
R14	0	1,124.50	1,277.76	66.10
	PIPES IN: 62 RING K2		PIPES OUT: 63 RING K3	
R15	0	1,127.50	1,276.61	64.31
	PIPES IN: 63 RING K3		PIPES OUT: 89 RING K	
R16	0	1,126.50	1,276.20	64.57
	PIPES IN: 64 RING L		PIPES OUT: 90 RING L	
R2	0	1,120.90	1,290.05	72.96
	PIPES IN: 50 RING B		PIPES OUT: 80 RING B	
R3	0	1,123.50	1,288.95	71.36
	PIPES IN: 51 RING C		PIPES OUT: 81 RING C	
R4	0	1,125.40	1,289.63	70.83
	PIPES IN: 52 RING D		PIPES OUT: 82 RING D	
R5	0	1,125.30	1,286.26	69.42
	PIPES IN: 53 RING E		PIPES OUT: 54 RING E2 56 RING F	
R6	0	1,128.00	1,286.23	68.25
	PIPES IN: 54 RING E2		PIPES OUT: 55 RING E3	

NODE COUNT: 81

DESIGN RULES: PRESSURE MIN: 0.00 MAX: 5000.00 PSI

JUNCTION NODE	DEMAND (gal/min)	ELEVATION (ft)	HYDRAULIC GRADE	PRESSURE (PSI)
------------------	----------------------	-------------------	--------------------	-------------------

R7	0	1,127.70	1,285.91	68.24
----	---	----------	----------	-------

PIPES IN: 55 RING E3 PIPES OUT: 83 RING E

R8	0	1,127.00	1,284.61	67.98
----	---	----------	----------	-------

PIPES IN: 56 RING F PIPES OUT: 84 RING F

R9	0	1,115.30	1,283.39	72.50
----	---	----------	----------	-------

PIPES IN: 57 RING G PIPES OUT: 85 RING G

S1	0	980.00	1,032.96	22.84
----	---	--------	----------	-------

PIPES IN: 5 SI-3A SUCTION PIPES OUT: 67 SI-3A SUCTION

S2	0	979.00	1,031.45	22.62
----	---	--------	----------	-------

PIPES IN: 7 SI-3B SUCTION PIPES OUT: 69 SUCTION SI-3B

S3	0	978.75	1,031.13	22.59
----	---	--------	----------	-------

PIPES IN: 6 SI-3C SUCTION PIPES OUT: 68 SUCTION SI-3C

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
1	SIRWT EXIT	C1	C2	0.00	0.00	0.00
2	SIRWT HEADER	C3 *	C2	0.04	2.81	2,549.27
3	SIRWT EXIT	C4	C5	0.00	0.00	0.00
4	SIRWT HEADER	C5	C6	0.00	0.00	0.00
5	SI-3A SUCTION	C6	S1	0.60	6.62	2,489.21
6	SI-3C SUCTION	C2	S3	1.45	6.78	2,549.27
7	SI-3B SUCTION	C3	S2	1.17	6.83	2,565.61
8	SI-3A DISCHARGE	C62	C11	24.97	15.96	2,489.21
9	SI-3B DISCHARGE	C60	C13	14.24	16.45	2,565.61
10	SI-3C DISCHARGE	C61	C15	15.44	16.34	2,549.27
11	DSCHRG HDR	C17	C16	0.94	14.51	5,114.88
13	DSCHRG HDR	C16	C18	30.43	21.57	7,604.09
14	A HX INLET	C18	C19	4.91	10.77	3,798.25
15	B HX INLET	C18	C20	9.44	10.79	3,805.84
16	A HX OUTLET	C21	C22	2.16	10.77	3,798.25
17	B HX OUTLET	C23	C24	1.79	10.79	3,805.84
18	HX CROSS CONECT	C22	C25	0.00	0.00	0.00
19	HX CROSS CONECT	C24	C26	0.00	0.00	0.00
20	SDC DISCHARGE	C25	C26	*** CLOSED ***		
21	A HEADER --- WITH COMPONENT F - flow meter	C22	C27	18.43	10.77	3,798.25
22	B HEADER --- WITH COMPONENT F - flow meter	C24	C28	18.95	10.79	3,805.84

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
23	A HEADER	C27	C29	25.49	24.35	3,798.25
	--- WITH COMPONENT B - FLOW VALVE					
24	B HEADER	C28	C31	27.42	24.40	3,805.84
	--- WITH COMPONENT B - FLOW VALVE					
25	A HEADER	C29	C30	3.64	10.77	3,798.25
26	A HEADER	C30	C33	4.70	10.10	3,798.25
27	A HEADER	C33	C34	0.23	5.21	1,957.71
28	A HEADER	C34	C35	4.78	11.52	1,957.71
29	A HEADER	C33	C36	4.94	10.84	1,840.55
30	A HEADER	C35	C37	0.15	5.21	1,957.71
31	A HEADER	C37	C38	0.02	2.15	807.83
32	A HEADER	C38	C39	0.08	4.41	1,658.60
33	PIPE-33	C39	C40	0.02	7.05	2,648.37
34	A HEADER	C40	C41	0.10	4.58	1,722.08
35	A HEADER	C41	C42	0.03	2.61	981.59
36	A HEADER	C42	C43	0.01	1.18	444.19
37	B HEADER	C32	C44	4.79	10.12	3,805.84
38	B HEADER	C44	C45	0.11	5.01	1,883.00
39	B HEADER	C45	C48	5.26	11.09	1,883.00
40	B HEADER	C44	C46	6.37	11.32	1,922.84
41	B HEADER	C46	C47	0.02	5.12	1,922.84
42	B HEADER	C47	C54	0.11	5.12	1,922.84
43	B HEADER	C48	C54	1.14	5.01	1,883.00

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	PIPELINE ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
44	B HEADER	C54	C49	0.08	10.12	3,805.84
45	B HEADER	C49	C50	0.23	6.94	2,607.81
46	B HEADER	C50	C51	0.10	4.61	1,732.14
47	B HEADER	C51	C52	0.04	2.81	1,056.34
48	B HEADER	C52	C53	0.01	1.45	545.79
49	RING A	C37	R1	1.05	6.77	1,149.88
50	RING B	C40	R2	0.78	5.45	926.30
51	RING C	C41	R3	1.78	7.48	740.49
52	RING D	C42	R4	1.06	5.43	537.40
53	RING E	C43	R5	4.42	10.00	444.19
54	RING E2	R5	R6	0.03	2.43	108.05
55	RING E3	R6	R7	0.32	4.15	108.05
56	RING F	R5	R8	1.65	7.56	336.13
57	RING G	C49	R9	1.06	7.05	1,198.03
58	RING H	C50	R10	0.56	5.16	875.66
59	RING I	C51	R11	1.39	6.83	675.80
60	RING J	C52	R12	0.91	5.16	510.55
61	RING K	C53	R13	6.19	12.28	545.79
62	RING K2	R13	R14	0.12	4.67	207.66
63	RING K3	R14	R15	1.15	7.98	207.66
64	RING L	R13	R16	1.67	7.61	338.13
65	SPRAY HDR A	C36	C38	0.23	2.26	850.77

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
66	SPRAY HDR A	C36	C39	0.31	2.63	989.77
67	SI-3A SUCTION	S1	C7	0.45	7.06	2,489.21
68	SUCTION SI-3C	S3	C8	0.06	7.23	2,549.27
69	SUCTION SI-3B	S2	C9	0.34	7.28	2,565.61
70	DISCHARGE HDR	C11	C16	0.46	7.06	2,489.21
71	DISCHARGE HDR	C13	C17	0.48	7.28	2,565.61
72	DISCHARGE HDR	C15	C17	0.48	7.23	2,549.27
73	HEADER B	C31	C32	1.94	10.79	3,805.84
74	PUMP SI-3A --- WITH COMPONENT C - SI-3A	C7	C10	(401.17)	25.16	2,489.21
75	PUMP SI-3B --- WITH COMPONENT D - SI-3B	C9	C12	(392.82)	25.93	2,565.61
76	PUMP SI-3C --- WITH COMPONENT E - SI-3C	C8	C14	(394.06)	25.76	2,549.27
77	HX-A --- WITH COMPONENT A - HX-A	C19	C21	22.31	10.77	3,798.25
78	HX-B --- WITH COMPONENT A - HX-A	C20	C23	22.40	10.79	3,805.84
79	RING A --- WITH CHECK VALVE	R1	FG	138.32	11.62	1,149.88
80	RING B --- WITH CHECK VALVE	R2	FG	135.07	9.36	926.30
81	RING C --- WITH CHECK VALVE	R3	FG	131.37	7.48	740.49
82	RING D --- WITH CHECK VALVE	R4	FG	130.15	5.43	537.40
83	RING E --- WITH CHECK VALVE	R7	FG	124.13	4.15	108.05

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
84	RING F --- WITH CHECK VALVE	R8	FG	123.53	7.56	336.13
85	RING G	R9	FG	134.01	12.11	1,198.03
86	RING H	R10	FG	130.28	8.85	875.66
87	RING I	R11	FG	126.34	6.83	675.80
88	RING J	R12	FG	124.48	5.16	510.55
89	RING K	R15	FG	115.03	7.98	207.66
90	RING L	R16	FG	115.62	7.61	338.13
93	PIPE-93	C11	C10	*** CLOSED ***		
107	CS SUMP PIPE	N3	C6	0.02	1.88	2,489.21
108	CS SUMP PIPE	N9	C3	0.20	5.64	5,114.88
109	COMMON SUMP LIN	H70	H3	0.22	1.88	2,489.21
110	COMMON SUMP LIN	H70	N42	0.86	3.86	5,114.88
111	COMMON SUMP LIN	H3	N3	0.05	1.88	2,489.21
112	COMMON SUMP LIN	N42	N9	0.17	3.86	5,114.88
118	SI-3C DISCHARGE	C14	C61	0.09	16.34	2,549.27
119	SI-3B DISCHARGE	C12	C60	0.09	16.45	2,565.61
120	SI-3A DISCHARGE	C10	C62	0.09	15.96	2,489.21
121	SUMP ENTRANCE	FG	H70	0.26	5.74	7,604.69

ABB Combustion Engineering

CLIENT : Omaha Public Power District

NETWORK SUMMARY REPORTS

JUNE 8, 1992

R. Harsell

NETWORK NAME : OPPDCS1

DATA FOR PIPES: OPPDCS

UPDATED : JUNE 8, 1992

OPPD CSP NPSH W/ SUMP SUBCOOLING

O-MECH-CALC-021

2P2H: 3B & 3C SUCTION FROM THE SUMP (6 ft)

0.00 % DEVIATION after 9 ITERATIONS

FIXED GRADE SUMMARY

NETWORK CONNECTION NODE PIPELINE				FLOW-RATE (gal/min)	FIXED GRADE / PRESSURE SOURCE	
R1	>>>	79	RING A	>>>	951.05	>>> 14.70 PSI
R2	>>>	80	RING B	>>>	761.70	>>> 14.70 PSI
R3	>>>	81	RING C	>>>	606.04	>>> 14.70 PSI
R4	>>>	82	RING D	>>>	438.26	>>> 14.70 PSI
R7	>>>	83	RING E	>>>	87.71	>>> 14.70 PSI
R8	>>>	84	RING F	>>>	273.24	>>> 14.70 PSI
R9	>>>	85	RING G	>>>	994.00	>>> 14.70 PSI
R10	>>>	86	RING H	>>>	721.50	>>> 14.70 PSI
R11	>>>	87	RING I	>>>	553.71	>>> 14.70 PSI
R12	>>>	88	RING J	>>>	416.44	>>> 14.70 PSI
R15	>>>	89	RING K	>>>	168.32	>>> 14.70 PSI
R16	>>>	90	RING L	>>>	274.69	>>> 14.70 PSI
H70	<<<	121	SUMP ENTRANCE	<<<	6,246.65	<<< 17.30 PSI

NET FLOWS OUT: 0.01 gal/min

DEMAND SUMMARY

JUNCTION NODE	DEMAND (gal/min)	JUNCTION NODE	DEMAND (gal/min)
------------------	----------------------	------------------	----------------------

NET DEMAND IN: 0.00 gal/min

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
1	SIRWT EXIT	C1	C2	0.00	0.00	0.00
2	SIRWT HEADER	C3	* C2	0.05	3.43	3,115.12
3	SIRWT EXIT	C4	C5	0.00	0.00	0.00
4	SIRWT HEADER	C5	C6	0.00	0.00	0.00
5	SI-3A SUCTION	C6	S1	0.00	0.00	0.00
6	SI-3C SUCTION	C2	S3	2.16	8.29	3,115.12
7	SI-3B SUCTION	C3	S2	1.73	8.33	3,131.52
8	SI-3A DISCHARGE	C62	C11	0.00	0.00	0.00
9	SI-3B DISCHARGE	C60	C13	21.19	20.08	3,131.52
10	SI-3C DISCHARGE	C61	C15	23.04	19.97	3,115.12
11	DSCHRG HDR	C17	C16	1.40	17.72	6,246.65
13	DSCHRG HDR	C16	C18	20.62	17.72	6,246.65
14	A HX INLET	C18	C19	3.31	8.84	3,117.99
15	B HX INLET	C18	C20	6.38	8.87	3,128.66
16	A HX OUTLET	C21	C22	1.46	8.84	3,117.99
17	B HX OUTLET	C23	C24	1.21	8.87	3,128.66
18	HX CROSS CONECT	C22	C25	0.00	0.00	0.00
19	HX CROSS CONECT	C24	C26	0.00	0.00	0.00
20	SDC DISCHARGE	C25	C26	*** CLOSED ***		
21	A HEADER --- WITH COMPONENT F - flow meter	C22	C27	12.43	8.84	3,117.99
22	B HEADER --- WITH COMPONENT F - flow meter	C24	C28	12.82	8.87	3,128.66

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY			MIN:	0.00	MAX: 1000.00 ft/sec	
PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
23	A HEADER	C27	C29	17.18	19.99	3,117.99
	--- WITH COMPONENT B - FLOW VALVE					
24	B HEADER	C28	C31	18.53	20.06	3,128.66
	--- WITH COMPONENT B - FLOW VALVE					
25	A HEADER	C29	C30	2.47	8.84	3,117.99
26	A HEADER	C30	C33	3.18	8.29	3,117.99
27	A HEADER	C33	C34	0.16	4.28	1,607.11
28	A HEADER	C34	C35	3.24	9.46	1,607.11
29	A HEADER	C33	C36	3.35	8.89	1,510.88
30	A HEADER	C35	C37	0.10	4.28	1,607.11
31	A HEADER	C37	C38	0.01	1.75	656.05
32	A HEADER	C38	C39	0.05	3.60	1,354.93
33	PIPE-33	C39	C40	0.01	5.76	2,166.94
34	A HEADER	C40	C41	0.07	3.74	1,405.24
35	A HEALER	C41	C42	0.02	2.13	799.20
36	A HEADER	C42	C43	0.00	0.96	360.94
37	B HEADER	C32	C44	3.24	8.32	3,128.66
38	B HEADER	C44	C45	0.07	4.12	1,547.90
39	B HEADER	C45	C48	3.57	9.11	1,547.90
40	B HEADER	C44	C46	4.32	9.31	1,580.76
41	B HEADER	C46	C47	0.02	4.21	1,580.76
42	B HEADER	C47	C54	0.07	4.21	1,580.76
43	B HEADER	C48	C54	0.77	4.12	1,547.90

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

Pipeline No	ID	From Node	To Node	Head-Loss (Gain)	Velocity (ft/sec)	Flow-Rate (gal/min)
44	B HEADER	C54	C49	0.06	8.32	3,128.66
45	B HEADER	C49	C50	0.16	5.68	2,134.66
46	B HEADER	C50	C51	0.07	3.76	1,413.16
47	B HEADER	C51	C52	0.03	2.29	859.45
48	B HEADER	C52	C53	0.01	1.18	443.01
49	RING A	C37	R1	0.72	5.60	951.05
50	RING B	C40	R2	0.53	4.48	761.70
51	RING C	C41	R3	1.20	6.12	606.04
52	RING D	C42	R4	0.71	4.43	438.26
53	RING E	C43	R5	2.95	8.12	360.94
54	RING E2	R5	R6	0.02	1.97	87.71
55	RING E3	R6	R7	0.21	3.37	87.71
56	RING F	R5	R8	1.10	6.15	273.24
57	RING G	C49	R9	0.73	5.85	994.00
58	RING H	C50	R10	0.38	4.25	721.50
59	RING I	C51	R11	0.94	5.60	553.71
60	RING J	C52	R12	0.61	4.21	416.44
61	RING K	C53	R13	4.11	9.97	443.01
62	RING K2	R13	R14	0.03	3.79	168.32
63	RING K3	R14	R15	0.77	6.47	168.32
64	RING L	R13	R16	1.10	6.18	274.69
65	SPRAY HDR A	C36	C38	0.16	1.86	698.88

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

Pipeline No	ID	From Node	To Node	Head-Loss (Gain)	Velocity (ft/sec)	Flow-Rate (gal/min)
66	SPRAY HDR A	C36	C39	0.21	2.16	812.00
67	SI-3A SUCTION	S1	C7	0.00	0.00	0.00
68	SUCTION SI-3C	S3	C8	0.09	8.83	3,115.12
69	SUCTION SI-3B	S2	C9	0.50	8.88	3,131.52
70	DISCHARGE HDR	C11	C16	0.00	0.00	0.00
71	DISCHARGE HDR	C13	C17	0.72	8.88	3,131.52
72	DISCHARGE HDR	C15	C17	0.71	8.83	3,115.12
73	HEADER B	C31	C32	1.32	8.87	3,128.66
74	PUMP SI-3A --- WITH COMPONENT C	C7	C10	*** CLOSED ***		
75	PUMP SI-3B --- WITH COMPONENT D - SI-3B	C9	C12	(319.68)	31.65	3,131.52
76	PUMP SI-3C --- WITH COMPONENT E - SI-3C	C8	C14	(321.59)	31.48	3,115.12
77	HX-A --- WITH COMPONENT A - HX-A	C19	C21	15.04	8.84	3,117.99
78	HX-B --- WITH COMPONENT A - HX-A	C20	C23	15.14	8.87	3,128.66
79	RING A --- WITH CHECK VALVE	R1	FG	94.62	9.61	951.05
80	RING B --- WITH CHECK VALVE	R2	FG	91.33	7.70	761.70
81	RING C --- WITH CHECK VALVE	R3	FG	87.99	6.12	606.04
82	RING D --- WITH CHECK VALVE	R4	FG	86.56	4.43	438.26
83	RING E --- WITH CHECK VALVE	R7	FG	81.79	3.37	87.71

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	PIPELINE ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
84	RING F --- WITH CHECK VALVE	R8	FG	81.62	6.15	273.24
85	RING G	R9	FG	92.25	10.05	994.00
86	RING H	R10	FG	88.44	7.29	721.50
87	RING I	R11	FG	84.81	5.60	553.71
88	RING J	R12	FG	82.82	4.21	416.44
89	RING K	R15	FG	75.57	6.47	168.32
90	RING L	R16	FG	76.31	6.18	274.69
93	PIPE-93	C11	C10	*** CLOSED ***		
107	CS SUMP PIPE	N3	C6	0.00	0.00	0.00
108	CS SUMP PIPE	N9	C3	0.30	6.88	6,246.65
109	COMMON SUMP LIN	H70	H3	0.00	0.00	0.00
110	COMMON SUMP LIN	H70	N42	1.28	4.72	6,246.65
111	COMMON SUMP LIN	H3	N3	0.00	0.00	0.00
112	COMMON SUMP LIN	N42	N9	0.24	4.72	6,246.65
118	SI-3C DISCHARGE	C14	C61	0.14	19.97	3,115.12
119	SI-3B DISCHARGE	C12	C60	0.14	20.08	3,131.52
120	SI-3A DISCHARGE	C10	C62	0.00	0.00	0.00
121	SUMP ENTRANCE	FG	H70	0.17	4.72	6,246.65

ABB Combustion Engineering

CLIENT : Omaha Public Power District

NETWORK SUMMARY REPORTS

JUNE 8, 1992
R. HarsellNETWORK NAME : OPPDCS1
UPDATED : JUNE 8, 1992

DATA FOR PIPES: OPPDCS

OPPD CSP NPSH W/ SUMP SUBCOOLING
O-MECH-CALC-021

3P1H:3A,3B,3C HDR B SUCTION FROM THE SUMP (6 ft)

0.01 % DEVIATION after 14 ITERATIONS

FIXED GRADE SUMMARY

NETWORK CONNECTION		PIPELINE		FLOW-RATE (gal/min)	FIXED GRADE / PRESSURE SOURCE	
NODE						
R1	>>>	79	RING A	>>>	0.00	>>> 5,000.00 PSI
R2	>>>	80	RING B	>>>	0.00	>>> 5,000.00 PSI
R3	>>>	81	RING C	>>>	0.00	>>> 5,000.00 PSI
R4	>>>	82	RING D	>>>	0.00	>>> 5,000.00 PSI
R7	>>>	83	RING E	>>>	0.00	>>> 5,000.00 PSI
R8	>>>	84	RING F	>>>	0.00	>>> 5,000.00 PSI
R9	>>>	85	RING G	>>>	1,447.60	>>> 14.70 PSI
R10	>>>	86	RING H	>>>	1,063.15	>>> 14.70 PSI
R11	>>>	87	RING I	>>>	823.60	>>> 14.70 PSI
R12	>>>	88	RING J	>>>	624.07	>>> 14.70 PSI
R15	>>>	89	RING K	>>>	254.88	>>> 14.70 PSI
R16	>>>	90	RING L	>>>	414.41	>>> 14.70 PSI
H70	<<<	121	SUMP ENTRANCE	<<<	4,627.72	<<< 17.30 PSI

NET FLOWS IN: 0.01 gal/min

FC 05977

O-MECH-CALC-021 Rev. 00

Page C 27

DEMAND SUMMARY

JUNCTION NODE	DEMAND (gal/min)	JUNCTION NODE	DEMAND (gal/min)
------------------	----------------------	------------------	----------------------

NET DEMAND IN: 0.00 gal/min

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

Pipeline No	ID	From Node	To Node	Head-Loss (Gain)	Velocity (ft/sec)	Flow-Rate (gal/min)
1	SIRWT EXIT	C1	C2	0.00	0.00	0.00
2	SIRWT HEADER	C3 *	C2	0.01	1.69	1,530.20
3	SIRWT EXIT	C4	C5	0.00	0.00	0.00
4	SIRWT HEADER	C5	C6	0.00	0.00	0.00
5	SI-3A SUCTION	C6	S1	0.23	4.08	1,534.64
6	SI-3C SUCTION	C2	S3	0.53	4.07	1,530.20
7	SI-3B SUCTION	C3	S2	0.43	4.16	1,562.89
8	SI-3A DISCHARGE	C62	C11	9.58	9.84	1,534.64
9	SI-3B DISCHARGE	C60	C13	5.30	10.02	1,562.89
10	SI-3C DISCHARGE	C61	C15	5.58	9.81	1,530.20
11	DSCHRG HDR	C17	C16	0.35	8.77	3,093.08
13	DSCHRG HDR	C16	C18	11.40	13.12	4,627.72
14	A HX INLET	C18	C19	0.00	0.00	0.00
15	B HX INLET	C18	C20	13.94	13.12	4,627.72
16	A HX OUTLET	C21	C22	0.00	0.00	0.00
17	B HX OUTLET	C23	C24	2.64	13.12	4,627.72
18	HX CROSS CONECT	C22	C25	0.00	0.00	0.00
19	HX CROSS CONECT	C24	C26	0.00	0.00	0.00
20	SDC DISCHARGE	C25	C26	*** CLOSED ***		
21	A HEADER	C22	C27	0.00	0.00	0.00
	--- WITH COMPONENT F - flow meter			*** MODEL OUT OF RANGE ***		
22	B HEADER	C24	C28	27.99	13.12	4,627.72
	--- WITH COMPONENT F - flow meter			*** MODEL OUT OF RANGE ***		

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
23	A HEADER	C27	C29	0.00	0.00	0.00
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
24	B HEADER	C28	C31	40.53	29.67	4,627.72
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
25	A HEADER	C29	C30	0.00	0.00	0.00
26	A HEADER	C30	C33	0.00	0.00	0.00
27	A HEADER	C33	C34	0.00	0.00	0.89
28	A HEADER	C34	C35	0.00	0.01	0.89
29	A HEADER	C36 *	C33	0.00	0.01	0.89
30	A HEADER	C35	C37	0.00	0.00	0.89
31	A HEADER	C37	C38	0.00	0.00	0.89
32	A HEADER	C38	C39	0.00	0.00	0.44
33	PIPE-33	C39	C40	0.00	0.00	0.00
34	A HEADER	C40	C41	0.00	0.00	0.00
35	A HEADER	C41	C42	0.00	0.00	0.00
36	A HEADER	C42	C43	0.00	0.00	0.00
37	B HEADER	C32	C44	7.06	12.31	4,627.72
38	B HEADER	C44	C45	0.16	6.09	2,289.70
39	B HEADER	C45	C48	7.74	13.48	2,289.70
40	B HEADER	C44	C46	9.38	13.76	2,338.02
41	B HEADER	C46	C47	0.03	6.22	2,338.02
42	B HEADER	C47	C54	0.16	6.22	2,338.02
43	B HEADER	C48	C54	1.68	6.09	2,289.70

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY AVG: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
44	B HEADER	C54	C49	0.12	12.31	4,627.72
45	B HEADER	C49	C50	0.35	8.46	3,180.12
46	B HEADER	C50	C51	0.16	5.63	2,116.96
47	B HEADER	C51	C52	0.06	3.44	1,293.36
48	B HEADER	C52	C53	0.02	1.78	669.29
49	RING A	C37	R1	0.00	0.00	0.00
50	RING B	C40	R2	0.00	0.00	0.00
51	RING C	C41	R3	0.00	0.00	0.00
52	RING D	C42	R4	0.00	0.00	0.00
53	RING E	C43	R5	0.00	0.00	0.00
54	RING E2	R5	R6	0.00	0.00	0.00
55	RING E3	R6	R7	0.00	0.00	0.00
56	RING F	R5	R8	0.00	0.00	0.00
57	RING G	C49	R9	1.55	8.52	1,447.50
58	RING H	C50	R10	0.82	6.26	1,063.15
59	RING I	C51	R11	2.06	8.32	823.60
60	RING J	C52	R12	1.35	6.31	624.07
61	RING K	C53	R13	9.25	15.06	669.29
62	RING K2	R13	R14	0.17	5.74	254.88
63	RING K3	R14	R15	1.72	9.79	254.88
64	RING L	R13	R16	2.50	9.33	414.41
65	SPRAY HDR A	C38 *	C36	0.00	0.00	0.45

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
66	SPRAY HDR A	C39 *	C36	0.00	0.00	0.44
67	SI-3A SUCTION	S1	C7	0.17	4.35	1,534.64
68	SUCTION SI-3C	S3	C8	0.02	4.34	1,530.20
69	SUCTION SI-3B	S2	C9	0.13	4.43	1,562.89
70	DISCHARGE HDR	C11	C16	0.17	4.35	1,534.64
71	DISCHARGE HDR	C13	C17	0.18	4.43	1,562.89
72	DISCHARGE HDR	C15	C17	0.17	4.34	1,530.20
73	HEADER B	C31	C32	2.85	13.12	4,627.72
74	PUMP SI-3A	C7	C10	(472.10)	15.51	1,534.64
	--- WITH COMPONENT C - SI-3A					
75	PUMP SI-3B	C9	C12	(468.68)	15.79	1,562.89
	--- WITH COMPONENT D - SI-3B					
76	PUMP SI-3C	C8	C14	(468.96)	15.46	1,530.20
	--- WITH COMPONENT E - SI-3C					
77	HX-A	C19	C21	0.00	0.00	0.00
	--- WITH COMPONENT A - HX-A *** MODEL OUT OF RANGE ***					
78	HX-B	C20	C23	33.13	13.12	4,627.72
	--- WITH COMPONENT A - HX-A *** MODEL OUT OF RANGE ***					
79	RING A	R1	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE *** CLOSED BY REVERSE FLOW ***					
80	RING B	R2	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE *** CLOSED BY REVERSE FLOW ***					
81	RING C	R3	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE *** CLOSED BY REVERSE FLOW ***					
82	RING D	R4	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE *** CLOSED BY REVERSE FLOW ***					
83	RING E	R7	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE *** CLOSED BY REVERSE FLOW ***					

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
84	RING F	R8	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	***	CLOSED BY REVERSE FLOW ***			
85	RING G	R9	FG	195.65	14.63	1,447.60
86	RING H	R10	FG	192.04	10.74	1,063.15
87	RING I	R11	FG	187.64	8.32	823.60
88	RING J	R12	FG	185.99	6.31	624.07
89	RING K	R15	FG	173.29	9.79	254.88
90	RING L	R16	FG	173.67	9.33	414.41
93	PIPE-93	C11	C10	*** CLOSED ***		
107	CS SUMP PIPE	N3	C6	0.01	1.16	1,534.64
108	CS SUMP PIPE	N9	C3	0.07	3.41	3,093.08
109	COMMON SUMP LIN	H70	H3	0.09	1.16	1,534.64
110	COMMON SUMP LIN	H70	N42	0.32	2.34	3,093.08
111	COMMON SUMP LIN	H3	N3	0.02	1.16	1,534.64
112	COMMON SUMP LIN	N42	N9	0.06	2.34	3,093.08
118	SI-3C DISCHARGE	C14	C61	0.03	9.81	1,530.20
119	SI-3B DISCHARGE	C12	C60	0.04	10.02	1,562.89
120	SI-3A DISCHARGE	C10	C62	0.03	9.84	1,534.64
121	SUMP ENTRANCE	FG	H70	0.10	3.50	4,627.72

ABB Combustion Engineering

CLIENT : Omaha Public Power District

NETWORK SUMMARY REPORTS

JUNE 8, 1992

R. Harsell

NETWORK NAME : OPPDCS1

DATA FOR PIPES: OPPDCS

UPDATED : JUNE 8, 1992

OPPD CSP NPSH W/ SUMP SUBCOOLING

O-MECH-CALC-021

2P1H:3A & 3B HDR B SUCTION FROM THE SUMP (6 ft)

0.01 % DEVIATION after 14 ITERATIONS

FIXED GRADE SUMMARY

NETWORK CONNECTION NODE	PIPELINE			FLOW-RATE (gal/min)		FIXED GRADE / PRESSURE SOURCE
R1	>>>	79	RING A	>>>	0.00	>>> 5,000.00 PSI
R2	>>>	80	RING B	>>>	0.00	>>> 5,000.00 PSI
R3	>>>	81	RING C	>>>	0.00	>>> 5,000.00 PSI
R4	>>>	82	RING D	>>>	0.00	>>> 5,000.00 PSI
R7	>>>	83	RING E	>>>	0.00	>>> 5,000.00 PSI
R8	>>>	84	RING F	>>>	0.00	>>> 5,000.00 PSI
R9	>>>	85	RING G	>>>	1,349.79	>>> 14.70 PSI
R10	>>>	86	RING H	>>>	989.77	>>> 14.70 PSI
R11	>>>	87	RING I	>>>	765.82	>>> 14.70 PSI
R12	>>>	88	RING J	>>>	579.73	>>> 14.70 PSI
R15	>>>	89	RING K	>>>	236.46	>>> 14.70 PSI
R16	>>>	90	RING L	>>>	384.63	>>> 14.70 PSI
H70	<<<	121	SUMP ENTRANCE	<<<	4,306.21	<<< 17.30 PSI

NET FLOWS IN: 0.01 gal/min

DEMAND SUMMARY

JUNCTION NODE	DEMAND (gal/min)	JUNCTION NODE	DEMAND (gal/min)
------------------	----------------------	------------------	----------------------

NET DEMAND IN: 0.00 gal/min

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	PIPELINE ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
1	SIRWT EXIT	C1	C2	0.00	0.00	0.00
2	SIRWT HEADER	C2	C3	0.00	0.00	0.00
3	SIRWT EXIT	C4	C5	0.00	0.00	0.00
4	SIRWT HEADER	C5	C6	0.00	0.00	0.00
5	SI-3A SUCTION	C6	S1	0.43	5.63	2,114.64
6	SI-3C SUCTION	C2	S3	0.00	0.00	0.00
7	SI-3B SUCTION	C3	S2	0.85	5.83	2,191.57
8	SI-3A DISCHARGE	C62	C11	18.07	13.56	2,114.64
9	SI-3B DISCHARGE	C60	C13	10.40	14.05	2,191.57
10	SI-3C DISCHARGE	C61	C15	0.00	0.00	0.00
11	DSCHRG HDR	C17	C16	0.17	6.22	2,191.57
13	DSCHRG HDR	C16	C18	9.89	12.21	4,306.21
14	A HX INLET	C18	C19	0.00	0.00	0.00
15	B HX INLET	C18	C20	12.08	12.21	4,306.21
16	A HX OUTLET	C21	C22	0.00	0.00	0.00
17	B HX OUTLET	C23	C24	2.29	12.21	4,306.21
18	HX CROSS CONECT	C22	C25	0.00	0.00	0.00
19	HX CROSS CONECT	C24	C26	0.00	0.00	0.00
20	SDC DISCHARGE	C25	C26	*** CLOSED ***		
21	A HEADER	C22	C27	0.00	0.00	0.00
	--- WITH COMPONENT F - flow meter			*** MODEL OUT OF RANGE ***		
22	B HEADER	C24	C28	24.24	12.21	4,306.21
	--- WITH COMPONENT F - flow meter					

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
23	A HEADER	C27	C29	0.00	0.00	0.00
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
24	B HEADER	C28	C31	35.10	27.61	4,306.21
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
25	A HEADER	C29	C30	0.00	0.00	0.00
26	A HEADER	C30	C33	0.00	0.00	0.00
27	A HEADER	C33	C34	0.00	0.00	0.90
28	A HEADER	C34	C35	0.00	0.01	0.90
29	A HEADER	C36 *	C33	0.00	0.01	0.90
30	A HEADER	C35	C37	0.00	0.00	0.90
31	A HEADER	C37	C38	0.00	0.00	0.90
32	A HEADER	C38	C39	0.00	0.00	0.45
33	PIPE-33	C39	C40	0.00	0.00	0.00
34	A HEADER	C40	C41	0.00	0.00	0.00
35	A HEADER	C41	C42	0.00	0.00	0.00
36	A HEADER	C42	C43	0.00	0.00	0.00
37	B HEADER	C32	C44	6.12	11.46	4,306.21
38	B HEADER	C44	C45	0.14	5.67	2,130.60
39	B HEADER	C45	C48	6.71	12.54	2,130.60
40	B HEADER	C44	C46	8.13	12.81	2,175.61
41	B HEADER	C46	C47	0.03	5.79	2,175.61
42	B HEADER	C47	C54	0.14	5.79	2,175.61
43	B HEADER	C48	C54	1.46	5.67	2,130.60

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
44	B HEADER	C54	C49	0.10	11.46	4,306.21
45	B HEADER	C49	C50	0.30	7.87	2,956.42
46	B HEADER	C50	C51	0.13	5.23	1,966.64
47	B HEADER	C51	C52	0.05	3.19	1,200.83
48	B HEADER	C52	C53	0.01	1.65	621.09
49	RING A	C37	R1	0.00	0.00	0.00
50	RING B	C40	R2	0.00	0.00	0.00
51	RING C	C41	R3	0.00	0.00	0.00
52	RING D	C42	R4	0.00	0.00	0.00
53	RING E	C43	R5	0.00	0.00	0.00
54	RING E2	R5	R6	0.00	0.00	0.00
55	RING E3	R6	R7	0.00	0.00	0.00
56	RING F	R5	R8	0.00	0.00	0.00
57	RING G	C49	R9	1.35	7.95	1,349.79
58	RING H	C50	R10	0.71	5.83	989.77
59	RING I	C51	R11	1.79	7.74	765.82
60	RING J	C52	R12	1.17	5.86	579.73
61	RING K	C53	R13	7.98	13.98	621.09
62	RING K2	R13	R14	0.15	5.32	236.46
63	RING K3	R14	R15	1.48	9.09	236.46
64	RING L	R13	R16	2.16	8.66	384.63
65	SPRAY HDR A	C38 *	C36	0.00	0.00	0.45

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	PIPELINE ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
66	SPRAY HDR A	C39 *	C36	0.00	0.00	0.45
67	SI-3A SUCTION	S1	C7	0.33	6.00	2,114.64
68	SUCTION SI-3C	S3	C8	0.00	0.00	0.00
69	SUCTION SI-3B	S2	C9	0.25	6.22	2,191.57
70	DISCHARGE HDR	C11	C16	0.33	6.00	2,114.64
71	DISCHARGE HDR	C13	C17	0.35	6.22	2,191.57
72	DISCHARGE HDR	C15	C17	0.00	0.00	0.00
73	HEADER B	C31	C32	2.47	12.21	4,306.21
74	PUMP SI-3A	C7	C10	(435.51)	21.37	2,114.64
	--- WITH COMPONENT C - SI-3A					
75	PUMP SI-3B	C9	C12	(428.41)	22.15	2,191.57
	--- WITH COMPONENT D - SI-3B					
76	PUMP SI-3C	C14	C8	*** CLOSED ***		
	--- WITH COMPONENT E -					
77	HX-A	C19	C21	0.00	0.00	0.00
	--- WITH COMPONENT A - HX-A	*** MODEL OUT OF RANGE ***				
78	HX-B	C20	C23	28.68	12.21	4,306.21
	--- WITH COMPONENT A - HX-A	*** MODEL OUT OF RANGE ***				
79	RING A	R1	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	*** CLOSED BY REVERSE FLOW ***				
80	RING B	R2	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	*** CLOSED BY REVERSE FLOW ***				
81	RING C	R3	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	*** CLOSED BY REVERSE FLOW ***				
82	RING D	R4	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	*** CLOSED BY REVERSE FLOW ***				
83	RING E	R7	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	*** CLOSED BY REVERSE FLOW ***				

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
84	RING F	R8	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	***	CLOSED BY REVERSE FLOW ***			
85	RING G	R9	FG	170.10	13.64	1,349.79
86	RING H	R10	FG	166.44	10.00	989.77
87	RING I	R11	FG	162.23	7.74	765.82
88	RING J	R12	FG	160.50	5.86	579.73
89	RING K	R15	FG	149.14	9.09	236.46
90	RING L	R16	FG	149.62	8.66	384.63
93	PIPE-93	C11	C10	*** CLOSED ***		
107	CS SUMP PIPE	N3	C6	0.01	1.60	2,114.64
108	CS SUMP PIPE	N9	C3	0.04	2.42	2,191.57
109	COMMON SUMP LIN	H70	H3	0.16	1.60	2,114.64
110	COMMON SUMP LIN	H70	N42	0.16	1.66	2,191.57
111	COMMON SUMP LIN	H3	N3	0.04	1.60	2,114.64
112	COMMON SUMP LIN	N42	N9	0.03	1.66	2,191.57
118	SI-3C DISCHARGE	C14	C61	0.00	0.00	0.00
119	SI-3B DISCHARGE	C12	C60	0.07	14.05	2,191.57
120	SI-3A DISCHARGE	C10	C62	0.06	13.56	2,114.64
121	SUMP ENTRANCE	FG	H70	0.08	3.25	4,306.21

ABB Combustion Engineering

CLIENT : Omaha Public Power District

NETWORK SUMMARY REPORTS

JUNE 8, 1992

R. Harsell

NETWORK NAME : OPPDCS1

DATA FOR PIPES: OPPDCS

UPDATED : JUNE 8, 1992

OPPD CSP NPSH W/ SUMP SUBCOOLING

O-MECH-CALC-021

2P1H:3A & 3C HDR B SUCTION FROM THE SUMP (6 ft)

0.01 % DEVIATION after 14 ITERATIONS

FIXED GRADE SUMMARY

NODE		NETWORK CONNECTION PIPELINE			FLOW-RATE (gal/min)		FIXED GRADE / PRESSURE SOURCE
R1	>>>	79	RING A	>>>	0.00	>>>	5,000.00 PSI
R2	>>>	80	RING B	>>>	0.00	>>>	5,000.00 PSI
R3	>>>	81	RING C	>>>	0.00	>>>	5,000.00 PSI
R4	>>>	82	RING D	>>>	0.00	>>>	5,000.00 PSI
R7	>>>	83	RING E	>>>	0.00	>>>	5,000.00 PSI
R8	>>>	84	RING F	>>>	0.00	>>>	5,000.00 PSI
R9	>>>	85	RING G	>>>	1,348.31	>>>	14.70 PSI
R10	>>>	86	RING H	>>>	988.66	>>>	14.70 PSI
R11	>>>	87	RING I	>>>	764.94	>>>	14.70 PSI
R12	>>>	88	RING J	>>>	579.06	>>>	14.70 PSI
R15	>>>	89	RING K	>>>	236.18	>>>	14.70 PSI
R16	>>>	90	RING L	>>>	384.18	>>>	14.70 PSI
H70	<<<	121	SUMP ENTRANCE	<<<	4,301.34	<<<	17.30 PSI

NET FLOWS IN: 0.01 gal/min

FC 05977

O-MECH-CALC-021 Rev. 00

Page C 41

DEMAND SUMMARY

JUNCTION NODE	DEMAND (gal/min)	JUNCTION NODE	DEMAND (gal/min)
------------------	----------------------	------------------	----------------------

NET DEMAND IN: 0.00 gal/min

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
1	SIRWT EXIT	C1	C2	0.00	0.00	0.00
2	SIRWT HEADER	C3 *	C2	0.03	2.40	2,179.91
3	SIRWT EXIT	C4	C5	0.00	0.00	0.00
4	SIRWT HEADER	C5	C6	0.00	0.00	0.00
5	SI-3A SUCTION	C6	S1	0.44	5.64	2,121.43
6	SI-3C SUCTION	C2	S3	1.06	5.80	2,179.91
7	SI-3B SUCTION	C3	S2	0.00	0.00	0.00
8	SI-3A DISCHARGE	C62	C11	18 18	13.60	2,121.43
9	SI-3B DISCHARGE	C60	C13	0.00	0.00	0.00
10	SI-3C DISCHARGE	C61	C15	11.30	13.98	2,179.91
11	DSCHRG HDR	C17	C16	0.17	6.18	2,179.91
13	DSCHRG HDR	C16	C18	9.87	12.20	4,301.34
14	A HX INLET	C18	C19	0.00	0.00	0.00
15	B HX INLET	C18	C20	12.05	12.20	4,301.34
16	A HX OUTLET	C21	C22	0.00	0.00	0.00
17	B HX OUTLET	C23	C24	2.29	12.20	4,301.34
18	HX CROSS CONECT	C22	C25	0.00	0.00	0.00
19	HX CROSS CONECT	C24	C26	0.00	0.00	0.00
20	SDC DISCHARGE	C25	C26	*** CLOSED ***		
21	A HEADER	C22	C27	0.00	0.00	0.00
	--- WITH COMPONENT F - flow meter			*** MODEL OUT OF RANGE ***		
22	B HEADER	C24	C28	24.19	12.20	4,301.34
	--- WITH COMPONENT F - flow meter					

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
23	A HEADER	C27	C29	0.00	0.00	0.00
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
24	B HEADER	C28	C31	35.02	27.58	4,301.34
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
25	A HEADER	C29	C30	0.00	0.00	0.00
26	A HEADER	C30	C33	0.00	0.00	0.00
27	A HEADER	C33	C34	0.00	0.00	0.90
28	A HEADER	C34	C35	0.00	0.01	0.90
29	A HEADER	C36 *	C33	0.00	0.01	0.90
30	A HEADER	C35	C37	0.00	0.00	0.90
31	A HEADER	C37	C38	0.00	0.00	0.90
32	A HEADER	C38	C39	0.00	0.00	0.45
33	PIPE-33	C39	C40	0.00	0.00	0.00
34	A HEADER	C40	C41	0.00	0.00	0.00
35	A HEADER	C41	C42	0.00	0.00	0.00
36	A HEADER	C42	C43	0.00	0.00	0.00
37	B HEADER	C32	C44	6.11	11.44	4,301.34
38	B HEADER	C44	C45	0.13	5.66	2,128.19
39	B HEADER	C45	C48	6.70	12.53	2,128.19
40	B HEADER	C44	C46	8.12	12.79	2,173.15
41	B HEADER	C46	C47	0.03	5.78	2,173.15
42	B HEADER	C47	C54	0.14	5.78	2,173.15
43	B HEADER	C48	C54	1.46	5.66	2,128.19

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

Pipeline No	ID	From Node	To Node	Head-Loss (Gain)	Velocity (ft/sec)	Flow-Rate (gal/min)
44	B HEADER	C54	C49	0.10	11.44	4,301.34
45	B HEADER	C49	C50	0.30	7.86	2,953.03
46	B HEADER	C50	C51	0.13	5.23	1,964.37
47	B HEADER	C51	C52	0.05	3.19	1,199.42
48	B HEADER	C52	C53	0.01	1.65	620.36
49	RING A	C37	R1	0.00	0.00	0.00
50	RING B	C40	R2	0.00	0.00	0.00
51	RING C	C41	R3	0.00	0.00	0.00
52	RING D	C42	R4	0.00	0.00	0.00
53	RING E	C43	R5	0.00	0.00	0.00
54	RING E2	R5	R6	0.00	0.00	0.00
55	RING E3	R6	R7	0.00	0.00	0.00
56	RING F	R5	R8	0.00	0.00	0.00
57	RING G	C49	R9	1.35	7.94	1,348.31
58	RING H	C50	R10	0.71	5.82	988.66
59	RING I	C51	R11	1.78	7.73	764.94
60	RING J	C52	R12	1.17	5.85	579.06
61	RING K	C53	R13	7.96	13.96	620.36
62	RING K2	R13	R14	0.15	5.31	236.18
63	RING K3	R14	R15	1.48	9.08	236.18
64	RING L	R13	R16	2.15	8.65	384.18
65	SPRAY HDR A	C38 *	C36	0.00	0.00	0.45

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
66	SPRAY HDR A	C39 *	C36	0.00	0.00	0.45
67	SI-3A SUCTION	S1	C7	0.33	6.02	2,121.43
68	SUCTION SI-3C	S3	C8	0.05	6.18	2,179.91
69	SUCTION SI-3B	S2	C9	0.00	0.00	0.00
70	DISCHARGE HDR	C11	C16	0.33	6.02	2,121.43
71	DISCHARGE HDR	C13	C17	0.00	0.00	0.00
72	DISCHARGE HDR	C15	C17	0.35	6.18	2,179.91
73	HEADER B	C31	C32	2.46	12.20	4,301.34
74	PUMP SI-3A	C7	C10	(434.97)	21.44	2,121.43
	--- WITH COMPONENT C - SI-3A					
75	PUMP SI-3B	C9	C12	*** CLOSED ***		
	--- WITH COMPONENT D -					
76	PUMP SI-3C	C8	C14	(428.68)	22.03	2,179.91
	--- WITH COMPONENT E - SI-3C					
77	HX-A	C19	C21	0.00	0.00	0.00
	--- WITH COMPONENT A - HX-A			*** MODEL OUT OF RANGE ***		
78	HX-B	C20	C23	28.62	12.20	4,301.34
	--- WITH COMPONENT A - HX-A			*** MODEL OUT OF RANGE ***		
79	RING A	R1	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE			*** CLOSED BY REVERSE FLOW ***		
80	RING B	R2	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE			*** CLOSED BY REVERSE FLOW ***		
81	RING C	R3	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE			*** CLOSED BY REVERSE FLOW ***		
82	RING D	R4	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE			*** CLOSED BY REVERSE FLOW ***		
83	RING E	R7	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE			*** CLOSED BY REVERSE FLOW ***		

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

Pipeline No	ID	From Node	To Node	Head-Loss (Gain)	Velocity (ft/sec)	Flow-Rate (gal/min)
84	RING F	R8	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	***	CLOSED BY REVERSE FLOW ***			
85	RING G	R9	FG	169.73	13.63	1,348.31
86	RING H	R10	FG	166.07	9.99	988.66
87	RING I	R11	FG	161.86	7.73	764.94
88	RING J	R12	FG	160.13	5.85	579.06
89	RING K	R15	FG	148.79	9.08	236.18
90	RING L	R16	FG	149.26	8.65	384.18
93	PIPE-93	C11	C10	*** CLOSED ***		
107	CS SUMP PIPE	N3	C6	0.01	1.60	2,121.43
108	CS SUMP PIPE	N9	C3	0.04	2.40	2,179.91
109	COMMON SUMP LIN	H70	H3	0.16	1.60	2,121.43
110	COMMON SUMP LIN	H70	N42	0.16	1.65	2,179.91
111	COMMON SUMP LIN	H3	N3	0.04	1.60	2,121.43
112	COMMON SUMP LIN	N42	N9	0.03	1.65	2,179.91
118	SI-3C DISCHARGE	C14	C61	0.07	13.98	2,179.91
119	SI-3B DISCHARGE	C12	C60	0.00	0.00	0.00
120	SI-3A DISCHARGE	C10	C62	0.06	13.60	2,121.43
121	SUMP ENTRANCE	FG	H70	0.08	3.25	4,301.34

ABB Combustion Engineering

CLIENT : Omaha Public Power District

NETWORK SUMMARY REPORTS

JUNE 8, 1992

R. Harsell

NETWORK NAME : OPPDCS1

DATA FOR PIPES: OPPDCS

UPDATED : JUNE 8, 1992

OPPD CSP NPSH W/ SUMP SUBCOOLING

O-MECH-CALC-021

1P1H: 3A HDR B SUCTION FROM THE SUMP (6 ft)

0.01 % DEVIATION after 15 ITERATIONS

FIXED GRADE SUMMARY

NETWORK CONNECTION NODE		PIPELINE			FLOW-RATE (gal/min)	FIXED GRADE / PRESSURE SOURCE	
R1	>>>	79	RING A	>>>	0.00	>>>	5,000.00 PSI
R2	>>>	80	RING B	>>>	0.00	>>>	5,000.00 PSI
R3	>>>	81	RING C	>>>	0.00	>>>	5,000.00 PSI
R4	>>>	82	RING D	>>>	0.00	>>>	5,000.00 PSI
R7	>>>	83	RING E	>>>	0.00	>>>	5,000.00 PSI
R8	>>>	84	RING F	>>>	0.00	>>>	5,000.00 PSI
R9	>>>	85	RING G	>>>	995.19	>>>	14.70 PSI
R10	>>>	86	RING H	>>>	722.41	>>>	14.70 PSI
R11	>>>	87	RING I	>>>	554.44	>>>	14.70 PSI
R12	>>>	88	RING J	>>>	416.99	>>>	14.70 PSI
R15	>>>	89	RING K	>>>	168.56	>>>	14.70 PSI
R16	>>>	90	RING L	>>>	275.07	>>>	14.70 PSI
H70	<<<	121	SUMP ENTRANCE	<<<	3,132.66	<<<	17.30 PSI

NET FLOWS IN: 0.00 gal/min

DEMAND SUMMARY

JUNCTION NODE	DEMAND (gal/min)	JUNCTION NODE	DEMAND (gal/min)
------------------	----------------------	------------------	----------------------

NET DEMAND IN: 0.00 gal/min

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
1	SIRWT EXIT	C1	C2	0.00	0.00	0.00
2	SIRWT HEADER	C2	C3	0.00	0.00	0.00
3	SIRWT EXIT	C4	C5	0.00	0.00	0.00
4	SIRWT HEADER	C5	C6	0.00	0.00	0.00
5	SI-3A SUCTION	C6	S1	0.94	8.33	3,132.66
6	SI-3C SUCTION	C2	S3	0.00	0.00	0.00
7	SI-3B SUCTION	C3	S2	0.00	0.00	0.00
8	SI-3A DISCHARGE	C62	C11	39.41	20.09	3,132.66
9	SI-3B DISCHARGE	C60	C13	0.00	0.00	0.00
10	SI-3C DISCHARGE	C61	C15	0.00	0.00	0.00
11	DSCHRG HDR	C17	C16	0.00	0.00	0.00
13	DSCHRG HDR	C16	C18	5.29	8.88	3,132.66
14	A HX INLET	C18	C19	0.00	0.00	0.00
15	B HX INLET	C18	C20	6.40	8.88	3,132.66
16	A HX OUTLET	C21	C22	0.00	0.00	0.00
17	B HX OUTLET	C23	C24	1.22	8.88	3,132.66
18	HX CROSS CONECT	C22	C25	0.00	0.00	0.00
19	HX CROSS CONECT	C24	C26	0.00	0.00	0.00
20	SDC DISCHARGE	C25	C26	*** CLOSED ***		
21	A HEADER	C22	C27	0.00	0.00	0.00
	--- WITH COMPONENT F - flow meter			*** MODEL OUT OF RANGE ***		
22	B HEADER	C24	C28	12.85	8.88	3,132.66
	--- WITH COMPONENT F - flow meter					

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
23	A HEADER	C27	C29	0.00	0.00	0.00
	--- WITH COMPONENT B - FLOW VALVE			*** MODEL OUT OF RANGE ***		
24	B HEADER	C28	C31	18.58	20.09	3,132.66
	--- WITH COMPONENT B - FLOW VALVE					
25	A HEADER	C29	C30	0.00	0.00	0.00
26	A HEADER	C30	C33	0.00	0.00	0.00
27	A HEADER	C33	C34	0.00	0.00	0.66
28	A HEADER	C34	C35	0.00	0.00	0.66
29	A HEADER	C36 *	C33	0.00	0.00	0.66
30	A HEADER	C35	C37	0.00	0.00	0.66
31	A HEADER	C37	C38	0.00	0.00	0.66
32	A HEADER	C38	C39	0.00	0.00	0.33
33	PIPE-33	C39	C40	0.00	0.00	0.00
34	A HEADER	C40	C41	0.00	0.00	0.00
35	A HEADER	C41	C42	0.00	0.00	0.00
36	A HEADER	C42	C43	0.00	0.00	0.00
37	B HEADER	C32	C44	3.25	8.33	3,132.66
38	B HEADER	C44	C45	0.07	4.12	1,549.88
39	B HEADER	C45	C48	3.58	9.12	1,549.88
40	B HEADER	C44	C46	4.33	9.32	1,582.78
41	B HEADER	C46	C47	0.02	4.21	1,582.78
42	B HEADER	C47	C54	0.07	4.21	1,582.78
43	B HEADER	C48	C54	0.77	4.12	1,549.88

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	PIPELINE ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
44	B HEADER	C54	C49	0.06	8.33	3,132.66
45	B HEADER	C49	C50	0.16	5.69	2,137.47
46	B HEADER	C50	C51	0.07	3.76	1,415.06
47	B HEADER	C51	C52	0.03	2.29	860.62
48	B HEADER	C52	C53	0.01	1.18	443.63
49	RING A	C37	R1	0.00	0.00	0.00
50	RING B	C40	R2	0.00	0.00	0.00
51	RING C	C41	R3	0.00	0.00	0.00
52	RING D	C42	R4	0.00	0.00	0.00
53	RING E	C43	R5	0.00	0.00	0.00
54	RING E2	R5	R6	0.00	0.00	0.00
55	RING E3	R6	R7	0.00	0.00	0.00
56	RING F	R5	R8	0.00	0.00	0.00
57	RING G	C49	R9	0.74	5.86	995.19
58	RING H	C50	R10	0.38	4.25	722.41
59	RING I	C51	R11	0.94	5.60	554.44
60	RING J	C52	R12	0.61	4.21	416.99
61	RING K	C53	R13	4.12	9.98	443.63
62	RING K2	R13	R14	0.08	3.79	168.56
63	RING K3	R14	R15	0.77	6.48	168.56
64	RING L	R13	R16	1.11	6.19	275.07
65	SPRAY HDR A	C38 *	C36	0.00	0.00	0.33

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

Pipeline No	ID	From Node	To Node	Head-Loss (Gain)	Velocity (ft/sec)	Flow-Rate (gal/min)
66	SPRAY HDR A	C39 *	C36	0.00	0.00	0.33
67	SI-3A SUCTION	S1	C7	0.71	8.88	3,132.66
68	SUCTION SI-3C	S3	C8	0.00	0.00	0.00
69	SUCTION SI-3B	S2	C9	0.00	0.00	0.00
70	DISCHARGE HDR	C11	C16	0.72	8.88	3,132.66
71	DISCHARGE HDR	C13	C17	0.00	0.00	0.00
72	DISCHARGE HDR	C15	C17	0.00	0.00	0.00
73	HEADER B	C31	C32	1.32	8.88	3,132.66
74	PUMP SI-3A --- WITH COMPONENT C - SI-3A	C7	C10	(319.4)	31.66	3,132.66
75	PUMP SI-3B --- WITH COMPONENT D -	C9	C12	*** CLOSED ***		
76	PUMP SI-3C --- WITH COMPONENT E -	C14	C8	*** CLOSED ***		
77	HX-A --- WITH COMPONENT A - HX-A	C19	C21	0.00	0.00	0.00
				*** MODEL OUT OF RANGE ***		
78	HX-B --- WITH COMPONENT A - HX-A	C20	C23	15.18	8.88	3,132.66
79	RING A --- WITH CHECK VALVE	R1	FG	0.00	0.00	0.00
				*** CLOSED BY REVERSE FLOW ***		
80	RING B --- WITH CHECK VALVE	R2	FG	0.00	0.00	0.00
				*** CLOSED BY REVERSE FLOW ***		
81	RING C --- WITH CHECK VALVE	R3	FG	0.00	0.00	0.00
				*** CLOSED BY REVERSE FLOW ***		
82	RING D --- WITH CHECK VALVE	R4	FG	0.00	0.00	0.00
				*** CLOSED BY REVERSE FLOW ***		
83	RING E --- WITH CHECK VALVE	R7	FG	0.00	0.00	0.00
				*** CLOSED BY REVERSE FLOW ***		

COMPLETE PIPELINE REPORT

JUNE 8, 1992

PIPELINE COUNT: 100

DESIGN RULES: VELOCITY MIN: 0.00 MAX: 1000.00 ft/sec

PIPELINE NO	ID	FROM NODE	TO NODE	HEAD-LOSS (GAIN)	VELOCITY (ft/sec)	FLOW-RATE (gal/min)
84	RING F	R8	FG	0.00	0.00	0.00
	--- WITH CHECK VALVE	***	CLOSED BY REVERSE FLOW ***			
85	RING G	R9	FG	92.47	10.06	995.19
86	RING H	R10	FG	88.67	7.30	722.41
87	RING I	R11	FG	85.03	5.60	554.44
88	RING J	R12	FG	83.04	4.21	416.99
89	RING K	R15	FG	75.78	6.48	168.56
90	RING L	R16	FG	76.52	6.19	275.07
93	PIPE-93	C11	C10	*** CLOSED ***		
107	CS SUMP PIPE	N3	C6	0.02	2.37	3,132.66
108	CS SUMP PIPE	N9	C3	0.00	0.00	0.00
109	COMMON SUMP LIN	H70	H3	0.35	2.37	3,132.66
110	COMMON SUMP LIN	H70	N42	0.00	0.00	0.00
111	COMMON SUMP LIN	H3	N3	0.08	2.37	3,132.66
112	COMMON SUMP LIN	N42	N9	0.00	0.00	0.00
118	SI-3C DISCHARGE	C14	C61	0.00	0.00	0.00
119	SI-3B DISCHARGE	C12	C60	0.00	0.00	0.00
120	SI-3A DISCHARGE	C10	C62	0.14	20.09	3,132.66
121	SUMP ENTRANCE	FG	H70	0.04	2.37	3,132.66

APPENDIX D
SELECTED REFERENCES

- | | |
|-----|------------------------------|
| D2 | Reference 3.12 |
| D5 | Reference 3.14 |
| D16 | Reference 3.16 |
| D19 | FLO-SERIES Code Certificates |
| D21 | Model Verification Checklist |

INGERSOLL-RANDEPD ENGINEERING
942 MEMORIAL PARKWAY
PHILLIPSBURG, NEW JERSEYDATE: 19 MARCH 92TO: Doug BlanchardCOMPANY, LOCATION ABB. Comb. EngrTELECOPIER NUMBER 203-285-4044FROM PAUL J. KASZTEJNA

TELEPHONE (908) 859-8353

NUMBER OF PAGES BEING SENT
(INCLUDING COVER)Re: 6UCL ppsS/N 0669-60, 61, 62Containment Spray Pumps

With regard to page 3 of your 12 MR92 fax to
Kurt Schumann I have the following comments.

D) I would project operating points of
2950 gpm basis 24' NPSHA and
2450 gpm basis 19' NPSHA

This is basis your figure 1 and actual test
data that we have on this pump design. We
have actual tests indicating 25' NPSHR @ 3000 gpm

c) Any type of orifice or control valve is

LOCATION: FOURTH FLOOR BENTLEY BUILDING

AUTOMATIC ANSWER NUMBER (908) 859-7322(@ 245' actual)

Page 2

D. Blanchard.

possible to alter the system curve to reduce the potential of runout flow. An orifice within the pump would also achieve similar results by a steeper head/capacity curve causing less runout flow.

ALTERNATE

- B) No ~~workable~~ impeller designs are available that would produce better runout NPSH characteristics. We would have to study casing and impeller design to determine exactly what would be required. Right now looks like no easy solutions.

- A) "In place" NPSH testing; I feel would be of questionable value. We would always have doubts if done accurately and question the results. We would have to accurately measure suction and discharge pressure as well as flow. This requires pipe taps in both suction and discharge and accessibility to pipe for an ultra-sonic flow meter. NPSH tests are not easily done.


c2

Phil Nagayash
Kurt Schumann

Figure 1
OPPD CSP NPSH

2P2H Configuration
 ↳ 2 Pumps > worst
 2 slender configuration

IR NPSHS Survey
 dated 3/19/92





Inter-Office Correspondence

To: R. Harsell
F. P. Ferraraccio

From: M. Petraske
OPS-92-0653
May 29, 1992

xc: M. J. Gancarz
R. C. Whipple
J. J. Herbst
M. D. Michonski
QRC (2) - Permanent

- References:
- 1) ABB CE Calculation No. 002-AS91-C-001 Rev. 00,
"OPPD Maximum Safeguards Hot Leg LOCA
Containment Analysis", Dated 9-5-91.
 - 2) ABB CE Calculation No. 002-NT90-C-012 Rev. 00.
"Evaluation of LOCA Long Term Containment
Response for Fort Calhoun Station", Dated 11-
26-90.
 - 3) Omaha Public Power District Fort Calhoun
Station Updated Final Safety Analysis Report,
R2, Dated 7-91.

- Enclosure:
- 1) Graphs and Data Tables Developed from CONTRANS
Case #AVQC, Case #OSNVBV97, and Case #AGTL.

Subject: EVALUATION OF THE PRESSURE MARGIN PRESENT BETWEEN THE
SATURATION PRESSURE OF THE CONTAINMENT SUMP WATER AND THE
CONTAINMENT PRESSURE - POST LOCA.

This memo is in response to your request to transmit the results of a review of Omaha Public Power District's Fort Calhoun Station containment transient analysis. This review was conducted to support the containment spray pump Net Positive Suction Head available (NPSHa) investigation.

The containment analysis runs are from the NRC approved code CONTRANS. This code simulates the pressure and temperature response in the containment following a design basis event. The output of this analysis code includes the containment pressure, sump water temperature, and various other containment parameters as a function of time during an event.

It is from this data, specifically the sump water temperature, that the saturation pressure of the sump water can be determined. The CONTRANS analysis runs chosen from References (1) and (2) are either the analysis of record, Case #AVQC (Reference 3), or provide a scenario where the sump temperature would be maximized and the containment pressure minimized, Case #AGTL and Case #OSNVBV97 (Reference 1 and 2).

Case #AVQC utilizes 1 spray header with spray water at 105°F and updated Shutdown Cooling Heat Exchanger data. Case #AGTL is the same as Case #AVQC except it has a revised decay heat input, a spray flow of 2510 GPM and 2 spray headers. Case #OSNVBV97 is a best estimate maximum safeguards case. It should be noted that all these cases are LOCA cases. The Main Steam Line Break cases of record in Reference (3) were not reviewed since the transient calculations are terminated prior to the time of the receipt of the Recirculation Actuation Signal (RAS). Since the MSLB case does not have any data post RAS it is impossible to predict the pressure response in containment. Note also that the cases reviewed were run to a maximum of 100,000 seconds, predictions of sub-cooling beyond that time were not possible.

The curves and tables developed in Enclosure (1) use the data taken directly from the CONTRANS case output and the ASME Steam Tables. The containment pressure is a direct output of the code while the saturation pressure of the sump water was developed using the temperature given by CONTRANS, and the corresponding saturation pressure from the ASME Steam Tables. This provided data for the containment pressure and the sump water saturation pressure. These two sets of data were then plotted and the minimum pressure differential determined.

The minimum differential pressure is being sought because it minimizes the amount of Net Positive Suction Pressure available to the containment spray pump during an event. This result is the goal of the evaluation this document is supporting.

In evaluating the curves and data tables in Enclosure (1) it can be seen that the minimum pressure differential between the containment sump saturation pressure and the total containment pressure, after the initiation of Recirculation Actuation Signal, is 15.47 psi. In each of the cases RAS is not achieved until after 1400 seconds into the transient. Therefore, any pressure differentials before this time are not considered in this evaluation. This occurs during the maximum safe guards case, Case #OSNVBV97, with all safety injection pumps running and two spray headers, with fan coolers. The minimum pressure differential occurs with the total containment pressure of 16.43 psia at 99650 seconds, and sump water at 100.3°F.

It should be noted that Case #OSNVBV97 never has sump water in excess of 212°F. In the three cases investigated, the sump temperature was maintained below 212°F except in Case #AVQC, between 18520 and 79520 seconds. In that case the sump water does reach the saturation point of water, at 14.7 psia, and 212°F, but the containment pressure in this range is maintained above 38.26 psia.


This provides a margin of over-pressure, from the containment pressure to the saturation pressure of the sump water, of 23 psi. This information is provided simply to illustrate that the water does exceed the saturation temperature at 14.7 psia, but there is sufficient over-pressure on the water to maintain it in a sub-cooled state.

At all times in the three analyses there are large margins of containment pressure in excess of the saturation pressure of the sump water. Therefore the minimum differential pressure, 15.47, is achieved in Case #OSNVBV97, at 99650 seconds.

The enclosed data has been Quality Assured in accordance with the QAPM guidelines. Should you have any questions, please do not hesitate to contact myself at x5485, or Mike Gancarz at x4600.

QA Status: Verified
The safety related design information contained in this document has been reviewed and satisfies (where applicable) the items contained on checklist(s) <u>9</u> , <u>—</u> , and <u>—</u> of the Quality Assurance Procedures Manual. This review is so certified.
Independent Reviewer <u>Z. D. Michon</u>
Date <u>6-1-92</u>
Document Rev. No. <u>-0-</u>

OPPD LOCA CONTAINMENT PRESSURE vs TIME
Case # OSNVBV97



FC 05977
O-MECH-CALC-021 Rev. 00
Page D-7
OPS-92-0653
Enclosure (1)
page 1 of 8


OPS-92-0653
Enclosure (1)
page 2 of 8

OPPD LOCA CONTAINMENT P/T vs TIME				
Case # OSNVBV97				
TIME, SEC	WATER, F	CONTAINMENT PRESS, PSIA	SUMP SAT. PRESS, PSIA	DELTA, P
0.0	90.0	14.70	0.69	14.01
0.2	90.5	16.78	0.71	16.07
0.4	93.4	19.23	0.78	18.45
1.3	111.8	28.03	1.34	26.69
2.8	135.1	38.00	2.54	35.46
3.8	148.0	43.49	3.54	39.95
4.8	159.9	48.54	4.73	43.81
5.8	169.9	53.02	5.98	47.04
7.8	183.9	59.86	8.18	51.68
8.8	188.0	62.10	8.95	53.15
10.8	192.7	64.69	9.89	54.8
12.8	194.3	66.07	10.23	55.84
18.8	194.0	65.85	10.17	55.68
20.8	193.7	65.72	10.10	55.62
28.8	192.6	65.28	9.87	55.41
38.8	191.1	64.91	9.56	55.35
68.8	190.5	62.74	9.44	53.3
88.8	192.0	60.87	9.75	51.12
98.8	192.6	60.03	9.87	50.16
112.8	193.1	58.77	9.97	48.8
122.8	193.2	57.92	9.99	47.93
132.8	193.4	57.11	10.04	47.07
152.8	193.6	55.60	10.08	45.52
172.8	193.5	54.20	10.06	44.14
192.8	193.3	52.91	10.02	42.89
210.8	193.0	51.81	9.95	41.86
248.8	192.1	49.42	9.75	39.67
288.8	190.8	46.89	9.50	37.39
308.8	190.0	45.71	9.34	36.37
338.8	188.6	43.93	9.06	34.87
368.8	187.1	42.20	8.77	33.43
388.8	186.1	41.13	8.58	32.55
428.8	184.0	38.95	8.20	30.75
448.8	183.0	37.92	8.02	29.9
468.8	181.9	37.03	7.83	29.2
488.8	180.9	35.99	7.66	28.33
530.0	178.7	34.13	7.29	26.84
730.0	169.2	27.56	5.88	21.68
830.0	165.0	25.17	5.34	19.83
930.0	161.0	23.40	4.85	18.55
1030.0	157.4	22.10	4.45	17.65
1180.0	152.5	20.77	3.95	16.82
1380.0	146.7	18.97	3.42	15.55
1530.0	145.4	18.99	3.29	15.7
1730.0	144.7	19.04	3.25	15.79
1930.0	144.1	18.97	3.21	15.76
2390.0	142.5	18.72	3.08	15.64
2840.0	140.9	18.50	2.96	15.54
3890.0	137.0	18.15	2.67	15.48

OPS-92-0653
 Enclosure (1)
 page 3 of 8

OPPD LOCA CONTAINMENT P/T vs TIME				
Case # OSNVBV97				
TIME, SEC	WATER, F	CONTAINMENT PRESS, PSIA	SUMP SAT. PRESS, PSIA	DELTA, P
4640.0	134.3	17.97	2.49	15.48
5240.0	132.3	17.85	2.36	15.49
6290.0	129.0	17.68	2.16	15.52
7640.0	125.3	17.51	1.96	15.55
8240.0	123.8	17.44	1.88	15.56
9290.0	121.5	17.34	1.76	15.58
10850.0	118.5	17.22	1.62	15.6
12650.0	115.7	17.12	1.50	15.62
13650.0	114.4	17.07	1.45	15.62
18650.0	109.9	16.91	1.27	15.64
21650.0	108.2	16.84	1.21	15.63
25650.0	106.6	16.78	1.15	15.63
29650.0	105.6	16.73	1.12	15.61
39650.0	103.9	16.64	1.06	15.58
49650.0	102.8	16.58	1.03	15.55
59650.0	102.0	16.54	1.00	15.54
69650.0	101.5	16.50	0.99	15.51
79650.0	101.0	16.47	0.98	15.49
89650.0	100.6	16.45	0.96	15.49
99650.0	100.3	16.43	0.96	15.47
100000.0	100.2	16.43	0.95	15.48

OPPD LOCA CONTAINMENT PRESSURE vs TIME
Case # AVQC



FC 05977
O-MECH-CALC-021 Rev. 00
page D 11

OPS-92-0653
Enclosure (1)
page 4 of 8

OPS-92-0653
Enclosure (1)
page 5 of 8

OPPD LOCA CONTAINMENT P/T vs TIME				
Case # AVQC				
TIME, SEC	WATER, F	CONTAINMENT PRESS, PSIA	SUMP SAT. PRESS, PSIA	DELTA, P
0.0	120.0	17.70	1.69	16.01
0.2	119.9	19.39	1.69	17.70
0.4	121.4	21.79	1.76	20.03
1.3	134.5	30.66	2.50	28.16
2.8	153.2	40.80	4.02	36.78
3.8	164.0	46.42	5.21	41.21
4.8	174.1	51.61	6.58	45.03
5.8	182.7	56.23	7.97	48.26
7.8	194.9	63.35	10.36	52.99
8.8	198.5	65.74	11.17	54.57
10.8	202.6	68.60	12.16	56.44
12.8	203.9	70.17	12.49	57.68
18.8	204.1	70.35	12.54	57.81
20.8	204.1	70.34	12.54	57.80
28.8	204.0	70.37	12.51	57.86
38.8	203.8	70.52	12.46	58.06
68.8	202.5	71.19	12.14	59.05
88.8	201.4	71.82	11.86	59.96
98.8	200.8	72.13	11.72	60.41
112.8	199.9	72.49	11.50	60.99
122.8	199.3	72.77	11.36	61.41
132.8	198.6	73.07	11.20	61.87
152.8	197.3	73.71	10.90	62.81
172.8	197.4	74.06	10.92	63.14
192.8	198.1	74.25	11.08	63.17
210.8	198.7	74.43	11.22	63.21
248.8	199.4	74.35	11.38	62.97
288.8	199.9	74.18	11.50	62.68
308.8	200.0	73.94	11.53	62.41
338.8	200.2	73.60	11.57	62.03
368.8	200.2	73.08	11.57	61.51
388.8	200.1	72.72	11.55	61.17
428.8	199.9	72.03	11.50	60.53
448.8	199.9	71.68	11.50	60.18
468.8	199.7	71.33	11.45	59.88
488.8	199.6	71.00	11.43	59.57
530.0	199.3	70.34	11.36	58.98
730.0	197.9	67.17	11.03	56.14
830.0	197.1	65.70	10.85	54.85
930.0	196.3	64.33	10.67	53.66
1030.0	195.3	62.50	10.45	52.05
1180.0	193.9	59.87	10.15	49.72
1380.0	191.9	56.74	9.72	47.02
1530.0	190.4	54.69	9.41	45.28
1730.0	188.4	52.31	9.02	43.29
1930.0	186.3	50.30	8.62	41.68
2360.0	182.2	46.87	7.89	38.98
2860.0	178.0	43.92	7.18	36.74
3860.0	183.0	43.60	8.02	35.58

FO 05977

O-MECH-CALC-021 Rev. 00


Page D 13

OPS-92-0653
 Enclosure (1)
 page 6 of 8

OPPD LC CA CONTAINMENT P/T vs TIME				
Case # AVQC				
TIME, SEC	WATER, F	CONTAINMENT PRESS, PSIA	SUMP SAT. PRESS, PSIA	DELTA, P
4260.0	184.9	43.48	8.37	35.11
5260.0	189.5	43.15	9.24	33.91
6260.0	193.4	42.89	10.04	32.85
7260.0	196.8	42.69	10.78	31.91
8260.0	199.4	42.52	11.38	31.14
9260.0	202.3	42.37	12.08	30.29
10320.0	204.6	42.23	12.66	29.57
12320.0	208.3	42.11	13.65	28.46
13520.0	210.0	42.08	14.12	27.96
18520.0	215.3	42.04	15.68	26.36
21520.0	217.2	42.00	16.27	25.73
25520.0	218.9	41.91	16.82	25.09
29520.0	219.8	41.75	17.12	24.63
39520.0	220.2	41.14	17.25	23.89
49520.0	219.1	40.39	16.89	23.50
59520.0	217.4	39.64	16.34	23.30
69520.0	215.5	38.92	15.75	23.17
79520.0	213.7	38.26	15.19	23.07
89520.0	211.9	37.66	14.66	23.00
99520.0	210.2	37.12	14.18	22.94
100000.0	210.1	37.09	14.15	22.94

OPPD LOCA CONTAINMENT PRESSURE vs TIME

Case # AGTL



OPS-92-0653
Enclosure (1)
page 8 of 8

OPPD LOCA CONTAINMENT P/T vs TIME					
Case # AGTL	TIME, SEC	WATER, F	CONTAINMENT PRESS, PSIA	SUMP SAT. PRESS, PSIA	DELTA, P
	0.00	120.0	17.70	1.69	16.01
	0.17	119.9	19.39	1.69	17.702
	0.37	121.4	21.79	1.76	20.03
	1.30	134.5	30.66	2.10	28.16
	2.80	153.2	40.80	4.02	36.78
	3.80	164.0	46.42	5.22	41.2
	4.80	174.1	51.61	6.58	45.03
	5.80	182.7	56.23	7.97	48.26
	7.80	194.9	63.35	10.36	52.99
	8.80	198.5	65.74	11.17	54.57
	10.80	202.6	68.60	12.16	56.44
	12.80	203.9	70.17	12.48	57.69
	18.80	204.1	70.35	12.54	57.81
	20.80	204.1	70.34	12.54	57.8
	28.80	204.0	70.37	12.51	57.86
	38.80	203.8	70.52	12.46	58.06
	68.80	202.5	71.19	12.13	59.06
	88.80	201.4	71.82	11.86	59.96
	98.80	200.8	72.13	11.71	60.42
	112.80	199.9	72.49	11.50	60.99
	122.80	199.3	72.77	11.36	61.41
	132.80	198.6	73.07	11.19	61.88
	152.80	197.3	73.70	10.89	62.81
	172.80	196.2	74.34	10.65	63.69
	192.80	197.4	74.41	10.92	63.49
	210.80	198.4	74.51	11.15	63.36
	248.80	199.8	74.23	11.48	62.75
	288.80	200.9	73.87	11.74	62.13
	308.80	201.3	73.54	11.84	61.7
	338.80	201.7	73.06	11.94	61.12
	368.80	202.0	72.42	12.01	60.41
	388.80	202.1	71.98	12.03	59.95
	428.80	202.2	71.13	12.06	59.07
	448.80	202.3	70.70	12.06	58.62
	468.80	202.3	70.27	12.08	58.19
	488.80	202.3	69.86	12.08	57.78
	530.00	202.2	69.05	12.06	56.99
	730.00	201.3	65.22	11.84	53.38
	830.00	200.6	63.46	11.67	51.79
	930.00	199.9	61.83	11.50	50.33
	1030.00	199.0	59.82	11.29	48.53
	1180.00	197.5	56.71	10.94	45.77
	1380.00	195.2	53.14	10.43	42.71
	1530.00	193.4	50.88	10.04	40.84
	1730.00	190.9	48.31	9.52	38.79
	1930.00	188.4	46.14	9.02	37.12
	2360.00	183.6	42.44	8.13	34.31
	2860.00	181.2	40.29	7.71	32.58
	3860.00	185.9	40.09	8.55	31.54
	4260.00	187.6	39.94	8.87	31.07
	5000.00	190.5	39.69	9.44	30.25

CURVE NO. N-18 A
DATE 1-14-72

CURVES ARE APPROXIMATE. PUMP GUARANTEED FOR ONE SET OF CONDITIONS CAPACITY, HEAD AND EFFICIENCY GUARANTEES ARE BASED ON BROWNSTEIN AND WHEN HANDLING CLEAR, COLD, FRESH WATER AT A TEMPERATURE OF NOT OVER 60° F. AND NOT OVER 15 FOOT SUCTION LIFT.

C.E.I. CONTRACT NUMBER 23866
C.E.I. PURCHASE ORDER 9900164

C.E.I. CUSTOMER IMPELLER PATT. NO. 6JC3A

DIA. IN.

OMAHA INDUS. POWER DISTRICT DIFFUSOR PATT. NO.

FIRE CALLDOWN STATION UNIT I

USE CONVENTIONAL SPRAY PUMPS

B.H.P.

EST. PERFORMANCE
AT .005 INCREASED CLEARANCE

CAPACITY	HEAD	EFF.	BHP
90	1200	470	60
	1500	400	68
	1700	452	72
80	2000	438	77
	2400	405	80

7.0

6.0

PER CENT EFFICIENCY

5.0

4.0

3.0

2.0

1.0

HEAD

NPSH

GALLONS PER MINUTE

THIS WILL CERTIFY THAT THIS CURVE IS
BASED ON ACTUAL TEST PERFORMANCE.

A. Brklich

A. BRKICH

FEB. 11, 1970

CHARACTERISTIC CURVE

NO. 6 TYPE UCL PUMP
360R. P. M.

PUMP NO. 360R52 ORDER NO. 001-322

INGERSOLL-RAND COMPANY

CAMERON PUMP DIVISION

DATE 1-14-72

CURVE N-182


FC 05977
O-MECH-CALC-021 Rev. 80
Page D-14

CURVES ARE APPROXIMATE. PUMP GUARANTEED FOR ONE SET OF CONDITIONS CAPACITY, HEAD AND EFFICIENCY GUARANTEES ARE BASED ON SHORTEST AND WHEN HANDLING CLEAR, COLD, FRESH WATER AT A TEMPERATURE OF NOT OVER 65° F. AND NOT OVER 15 FOOT SUCTION LIFT.

CEI CONTRACT NUMBER 23866
CEI PURCHASE ORDER 9900104

CEI CUSTOMER: OMAHA PUBLIC POWER DIA. 11
DISTRICT DIFFUSOR PATT. NO.

FORT CALHOUN STATION UNIT 1
USE: CONTAINMENT SPRAY PUMPS



COMPUTER CODE CERTIFICATE

The following code, as noted by its name, version number and executable file identification, is approved for design use.

Code Name:

PIPE-FLO

Version Number:

3.91a

Executable File Identification:

PIPEFLO

Computer(s):

IBM PC COMPATABLES

List any limitations on use, special hardware considerations, etc.

Verification and Validation Report Number:

MISC-MPS-CALC-015

Program Manager:

MARK PETRASKE

Date:

7/12/91

COMPUTER CODE CERTIFICATE

The following code, as noted by its name, version number and executable file identification, is approved for design use.

Code Name: NET-FLO

Version Number: 3.92a

Executable File Identification: * NETFLO

Computer(s): IBM PC COMPATABLE

List any limitations on use, special hardware considerations, etc.

Verification and Validation Report Number: MISC-NPS-CALC-015

Program Manager: MARK PETRASKE WMA/DPY

Date: 7/12/91

CHECKLIST FOR FLO-SERIES VERIFYING RUNS

Preparer	Reviewer	Task
✓	RFP	Original Database Model <u>Offgas</u>
✓	RFP	Taken from Calc <u>O-MECH-CALC-019</u> to 01
✓	RFP	Trial run of original database reproduces results of calc run.
✓	RFP	Original database copied to <u>OFFGAS3</u> file
✓	RFP	New file trial run reproduces results of calc run.
✓	RFP	List of modifications to new file: want mfg pumpa to Test pump of vme-019. new model used in CALC O-MECH-CALC-021 per OPI use API w/ JUMP function JUNCTION
In ✓ CALC-019	RFP	Piping project on file
✓	RFP	Network summary report on file
✓	RFP	Complete junction node report on file
✓	RFP	Complete pipeline report on file
✓	RFP	Piping diagram on file (<u>In CALC-019</u> <u>+CALC-021</u>)
✓	RFP	COMPTBL.SYS on file
✓	—	USRVALV.SYS on file
✓	RFP	Any other comments: FLO-SERIES PRINTOUTS ON FILE w/ O-MECH-CALC-021 per LST

Preparer: M. A.Reviewer: R. Rapp 6-10-92