



South Texas Project Electric Generating Station P.O. Box 289 Wadsworth, Texas 77483

October 29, 1998
NOC-AE-000345
File No.: G02
10CFR50
STI#30752257

Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

South Texas Project
Unit 2
Docket No. STN 50-499
Special Report on Steam Generator Inservice Inspection Results

In accordance with Technical Specifications 4.4.5.5a. and 6.9.2, South Texas Project submits the following information on the number of tubes plugged in Unit 2 steam generators:

Steam Generator	Tubes Plugged During 2RE06	Cumulative Total
2A	19	165
2B	7	193
2C	17	187
2D	9	189
Total Unit 2		734

If there are any questions regarding this report, please contact Mr. S. M. Head at (512) 972-7136 or myself at (512) 972-7162.

S. E. Thomas
for S. E. Thomas
Manager
Design Engineering Department

Jew

SET/nl

120009

9811120156 981029
PDR ADOCK 05000499
G PDR

c:

Ellis W. Merschoff
Regional Administrator, Region IV
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

Thomas W. Alexion
Project Manager, Mail Code 13H3
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Cornelius F. O'Keefe
Sr. Resident Inspector
c/o U. S. Nuclear Regulatory Commission
P. O. Box 910
Bay City, TX 77404-0910

J. R. Newman, Esquire
Morgan, Lewis & Bockius
1800 M. Street, N.W.
Washington, DC 20036-5869

M. T. Hardt/W. C. Gunst
City Public Service
P. O. Box 1771
San Antonio, TX 78296

A. Ramirez/C. M. Canady
City of Austin
Electric Utility Department
721 Barton Springs Road
Austin, TX 78704

Jon C. Wood
Matthews & Branscomb
One Alamo Center
106 S. St. Mary's Street, Suite 700
San Antonio, TX 78205-3692

Institute of Nuclear Power
Operations - Records Center
700 Galleria Parkway
Atlanta, GA 30339-5957

Richard A. Ratliff
Bureau of Radiation Control
Texas Department of Health
1100 West 49th Street
Austin, TX 78756-3189

D. G. Tees/R. L. Balcom
Houston Lighting & Power Co.
P. O. Box 1700
Houston, TX 77251

Central Power and Light Company
ATTN: G. E. Vaughn/C. A. Johnson
P. O. Box 289, Mail Code: N5012
Wadsworth, TX 77483

U. S. Nuclear Regulatory Commission
Attention: Document Control Desk
Washington, D.C. 20555-0001